

Mr. G. R. Horn
Sr. Vice President of Energy Supply
Nebraska Public Power District
1414 15th Street
Columbus, NE 68601

May 9, 1997

SUBJECT: COOPER NUCLEAR STATION - AMENDMENT NO. 176 TO FACILITY
OPERATING LICENSE NO. DPR-46 (TAC NO. M98516)

Dear Mr. Horn:

The Commission has issued the enclosed Amendment No. 176 to Facility Operating License No. DPR-46 for the Cooper Nuclear Station (CNS). The amendment consists of changes to the Technical Specifications (TS) in response to your application dated May 2, 1997, as superseded by your letter dated May 5, 1997.

The amendment relocates the surveillance requirements of TS 4.4.A.2.a regarding the setpoint for the Standby Liquid Control (SLC) system relief valves to the Updated Safety Analysis Report (USAR) and the Augmented Testing Program, which is part of the Inservice Testing Program. Also, TS Bases Section 3.4.A is revised to delete the related discussion of SLC relief valve testing.

As described in Section 4.0 of the enclosed safety evaluation, in accordance with 10 CFR 50.91(a)(5), the staff has determined that an emergency exists in that failure of the Commission to act in a timely way would result in the prevention of the resumption of operation of the CNS.

A copy of our related Safety Evaluation is also enclosed. The Notice of Issuance and final determination of no significant hazards consideration and opportunity for a hearing will be included in the Commission's biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:
James R. Hall, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosures: 1. Amendment No. 176 to License No. DPR-46
2. Safety Evaluation

NRC FILE CENTER COPY

cc w/encls: See next page

DISTRIBUTION:

Docket File	PUBLIC	PD4-1 r/f	J. Kilcrease, RIV f/r
C. Hawes	ACRS	OGC (15B18)	E. Adensam (EGA1)
G. Hill (2)	C. Grimes	J. Roe	
J. Hall	T. Gwynn, RIV	L. Hurley, RIV	

Document Name: C0098516.AMD

OFC	PM/PD4-1	LA/PD4-1	BC/TSIB 47-511	D/PD4-1	OGC
NAME	JHall <i>JH</i>	CHawes <i>CMH</i>	CGrimes <i>CG</i>	WBeckner <i>WB</i>	<i>CHOLLER</i>
DATE	5/7/97	5/7/97	5/9/97	5/9/97	5/8/97
COPY	YES/NO	YES/NO	YES/NO	YES/NO	YES/NO

9705150037 970509
PDR ADDCK 05000298
PDR

140044

OFFICIAL RECORD COPY

*111
DFO1*

[Handwritten signature]



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

May 9, 1997

Mr. G. R. Horn
Sr. Vice President of Energy Supply
Nebraska Public Power District
1414 15th Street
Columbus, NE 68601

SUBJECT: COOPER NUCLEAR STATION - AMENDMENT NO. 176 TO FACILITY
OPERATING LICENSE NO. DPR-46 (TAC NO. M98516)

Dear Mr. Horn:

The Commission has issued the enclosed Amendment No. 176 to Facility Operating License No. DPR-46 for the Cooper Nuclear Station (CNS). The amendment consists of changes to the Technical Specifications (TS) in response to your application dated May 2, 1997, as superseded by your letter dated May 5, 1997.

The amendment relocates the surveillance requirements of TS 4.4.A.2.a regarding the setpoint for the Standby Liquid Control (SLC) system relief valves to the Updated Safety Analysis Report (USAR) and the Augmented Testing Program, which is part of the Inservice Testing Program. Also, TS Bases Section 3.4.A is revised to delete the related discussion of SLC relief valve testing.

As described in Section 4.0 of the enclosed safety evaluation, in accordance with 10 CFR 50.91(a)(5), the staff has determined that an emergency exists in that failure of the Commission to act in a timely way would result in the prevention of the resumption of operation of the CNS.

A copy of our related Safety Evaluation is also enclosed. The Notice of Issuance and final determination of no significant hazards consideration and opportunity for a hearing will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script that reads "James R. Hall".

James R. Hall, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosures: 1. Amendment No. 176 to
License No. DPR-46
2. Safety Evaluation

cc w/encls: See next page

Mr. G. R. Horn
Nebraska Public Power Company

Cooper Nuclear Station

cc:

Mr. John R McPhail, General Counsel
Nebraska Public Power District
P. O. Box 499
Columbus, NE 68602-0499

Lincoln Electric System
ATTN: Mr. Ron Stoddard
11th & O Streets
Lincoln, NE 68508

Nebraska Public Power District
ATTN: Mr. P. D. Graham
Vice President of Nuclear Energy
P. O. Box 98
Brownville, NE 68321

Midwest Power
ATTN: Richard J. Singer, Manager-Nuclear
907 Walnut Street
P. O. Box 657
Des Moines, IA 50303

Randolph Wood, Director
Nebraska Department of Environmental
Control
P. O. Box 98922
Lincoln, NE 68509-8922

Nebraska Public Power District
ATTN: Mr. B. L. Houston, Nuclear
Licensing & Safety Manager
P. O. Box 98
Brownville, NE 68321

Mr. Larry Bohlken, Chairman
Nemaha County Board of Commissioners
Nemaha County Courthouse
1824 N Street
Auburn, NE 68305

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 218
Brownville, NE 68321

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Ms. Cheryl Rogers, LLRW Program Manager
Division of Radiological Health
Nebraska Department of Health
301 Centennial Mall, South
P. O. Box 95007
Lincoln, NE 68509-5007

Mr. Ronald A. Kucera, Department Director
of Intergovernmental Cooperation
Department of Natural Resources
P.O. Box 176
Jefferson City, MO 65102



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

NEBRASKA PUBLIC POWER DISTRICT

DOCKET NO. 50-298

COOPER NUCLEAR STATION

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 176
License No. DPR-46

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Nebraska Public Power District (the licensee) dated May 5, 1997, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9705150042 970509
PDR ADOCK 05000298
P PDR


2. Accordingly, the license is amended to approve the relocation of certain Technical Specification requirements to licensee-controlled documents, as described in Licensee's application dated May 5, 1997, and reviewed in the Staff's safety evaluation report dated May 9, 1997. This license is also hereby amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. DPR-46 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 176, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



William D. Beckner, Project Director
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: May 9, 1997

ATTACHMENT TO LICENSE AMENDMENT NO. 176

FACILITY OPERATING LICENSE NO. DPR-46

DOCKET NO. 50-298

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

REMOVE PAGES

107
110

INSERT PAGES

107
110

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

3.4 STANDBY LIQUID CONTROL SYSTEM

Applicability:

Applies to the operating status of the Standby Liquid Control (SLC) System.

Objective:

To assure the OPERABILITY of a system with the capability to SHUTDOWN the reactor and maintain the SHUTDOWN condition without the use of control rods.

Specification:

- A. Normal System Operation
 - 1. During periods when fuel is in the reactor and prior to startup from a Cold Condition, the Standby Liquid Control System shall be operable, except as specified in 3.4.B below. This system need not be operable when the reactor is in the Cold Condition and all control rods are fully inserted and Specification 3.3.A is met.

4.4 STANDBY LIQUID CONTROL SYSTEM

Applicability:

Applies to the surveillance requirements of the Standby Liquid Control (SLC) System.

Objective:

To verify the OPERABILITY of the SLC System.

Specification:

- A. Normal System Operation
 - The OPERABILITY of the SLC System shall be shown by the performance of the following tests:
 - 1. At least once each 3 months each subsystem shall be tested for OPERABILITY by recirculating demineralized water to the test tank and verifying each pump develops a flow rate ≥ 38.2 gpm at a discharge pressure ≥ 1300 psig.
 - 2. At least once during each OPERATING CYCLE:
 - a. Manually initiate the system, except explosive valves, and pump boron solution from the SLC Storage Tank through the recirculation path. Verify each pump develops a flow rate ≥ 38.2 gpm at a discharge pressure ≥ 1300 psig. After pumping boron solution the system will be flushed with demineralized water.

3.4 BASES

STANDBY LIQUID CONTROL SYSTEM

- A. The Standby Liquid Control (SLC) System consists of two, distinct subsystems, each containing one positive displacement pump and independent suction from the SLC storage tank, and discharge to a common injection header through parallel explosive valves. The purpose of the SLC System is to provide the capability of bringing the reactor from RATED POWER to a cold, xenon-free SHUTDOWN CONDITION assuming that none of the withdrawn control rods can be inserted. To meet this objective, the system is designed to inject a quantity of boron that produces a concentration of 660 ppm of boron in the reactor pressure vessel in less than 125 minutes. The 660 ppm concentration in the reactor pressure vessel is required to bring the reactor from RATED POWER to a 3.0 percent Δk subcritical condition, considering the hot to cold reactivity difference, xenon poisoning, etc. The time requirement for inserting the boron solution was selected to override the rate of reactivity insertion caused by cooldown of the reactor following the xenon poison peak.

The conditions under which the SLC System must provide shutdown capability are identified in Limiting Conditions for Operation. If no more than one OPERABLE control rod is withdrawn, the basic shutdown reactivity requirement for the core is satisfied and the SLC System is not required. Thus, the basic reactivity requirement for the core is the primary determinant of when the SLC System is required.

- B. Only one of the two SLC subsystems is needed for operating the system. One inoperable subsystem does not immediately threaten shutdown capability, and reactor operation can continue while the inoperable subsystem is being repaired. The seven day completion time is based on the availability of an OPERABLE subsystem capable of performing the intended SLC system function and the low probability of a Design Basis Accident (DBA) or severe transient occurring concurrent with the failure of the Control Rod Drive (CRD) system to shut down the plant.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 176 TO FACILITY OPERATING LICENSE NO. DPR-46

NEBRASKA PUBLIC POWER DISTRICT

COOPER NUCLEAR STATION

DOCKET NO. 50-298

1.0 INTRODUCTION

By letter dated May 2, 1997, as superseded by letter dated May 5, 1997, the Nebraska Public Power District (NPPD, the licensee) submitted a request for changes to the Technical Specifications (TSs) for the Cooper Nuclear Station (CNS). The requested changes would relocate the surveillance requirements of TS 4.4.A.2.a regarding the setpoint for the Standby Liquid Control (SLC) system relief valves to the Updated Safety Analysis Report (USAR) and the Augmented Testing Program, which is part of the Inservice Testing (IST) Program. Also, TS Bases Section 3.4.A would be revised to delete the related discussion of SLC relief valve testing. On March 27, 1997, the licensee submitted an amendment request to convert the CNS TS to the Improved Standard Technical Specifications format of NUREG-1433, Revision 1, "Standard Technical Specifications for General Electric Plants, BWR/4." That request also included the relocation of the SLC relief valve setpoint requirements to the USAR and IST program.

2.0 BACKGROUND

The CNS USAR states, "The safety objective of the standby liquid control (SLC) system is to provide a backup method, independent of the control rods, to maintain the reactor subcritical as the nuclear system cools." The system is designed to allow a control room operator to manually initiate one or both SLC pumps to inject a sufficient quantity of boron neutron absorber solution into the reactor vessel, to shut down the reactor at a steady rate and maintain subcriticality, within the capacity of the shutdown cooling systems. Relief valves are provided on each pump discharge leg to prevent overpressurization.

The CNS TSs currently specify a minimum and a maximum SLC relief valve opening pressure setpoint and a minimum reset pressure setpoint. The maximum opening pressure setpoint is based on system overpressure protection requirements. The minimum operating pressure and reset pressure setpoints for the SLC are established to preclude recirculation flow through the relief valves. Such recirculation would divert a portion of the borated solution back to the pump suction, thereby reducing the rate of boron injection into the reactor vessel.

Prior to 1983, the CNS TS limits for the SLC relief valves were from 1400 psig to 1680 psig; the valves were set at a nominal value of 1460 psig. In 1983, the relief valve setpoint was raised to a nominal setpoint of 1540 psig, which was selected so that it was in the middle of the allowable range of 1400 to 1680 psig.

In April of 1986, General Electric (GE) performed a calculation as a part of an assessment in response to 10 CFR 50.62, the Commission's rule regarding Anticipated Transients Without Scram (ATWS). That calculation determined the discharge pressure for simultaneous operation of both SLC pumps to be approximately 1380 psig. Consequently, GE recommended the addition of a margin of 70 psi to the calculated pressure to allow for $\pm 3\%$ relief valve setpoint drift, and for pressure fluctuations characteristic of positive displacement pumps. Based on this analytical result, GE recommended raising the SLC relief valve minimum setpoint in the TSs from 1400 to 1450 psig, to provide sufficient margin to preclude intermittent opening of the relief valves, which could result in diverting a portion of the injected boron solution away from the reactor vessel.

In a letter dated April 8, 1987, NPPD notified the Nuclear Regulatory Commission (NRC) of proposed changes to the SLC system to meet the requirements of the ATWS rule (10 CFR 50.62). In that letter, NPPD indicated that the SLC pump discharge pressure would increase to 1378.5 psig during dual-pump operation; therefore, the licensee committed to raise the SLC system relief valve lower setpoint pressure to provide approximately 70 psi setpoint margin to minimize the potential for relief valve leakage and the corresponding decrease in the boron injection rate to the vessel.

On December 23, 1987, the NRC safety evaluation (SE) relating to the ATWS rule for CNS concluded that the proposed changes to the SLC system, including the dual-pump operating configuration, were acceptable to meet the requirements of the rule. The staff's SE also indicated that NPPD should submit a TS change request as soon as possible to revise the TS lower limit for the relief valve setpoint. On April 29, 1988, the licensee applied for a license amendment which proposed to raise the SLC relief valve TS minimum setpoint to 1450 psig (nominal). In May of 1988, a SLC pump injection test was performed, which noted higher pump discharge pressures (approximately 1419 psig) than those previously calculated (approximately 1380 psig).

On July 5, 1988, the NRC issued License Amendment No. 123, which approved raising the minimum TS pressure setpoint for the SLC relief valves from 1400 to 1450 psig. The NRC's safety evaluation stated that the purpose of the minimum pressure setpoint was to preclude recirculation flow through the relief valves. Although the actual pump testing in May 1988 revealed a higher discharge pressure of 1419 psig; on September 29, 1988, GE reevaluated the previous calculation and stated that there was still sufficient relief valve pressure margin at the system design flow rate of 106 gpm (both pumps operating) to assure full flow rate to the reactor vessel. The GE report also stated that while the SLC system test results were higher than predicted, there was no evidence that the SLC system would not meet the ATWS rule

requirements as intended. In reaching this conclusion, GE recognized that CNS normally set the SLC relief valves at a nominal setpoint of 1540 psig and considered that the minimum TS setpoint limit of 1450 psig was still valid; because the remaining 31 psi margin would still account for pump ripple effects, and there was no need to include the 3% allowance for setpoint drift at 1450 psig because CNS did not set the SLC relief valves at that pressure.

In November of 1996, the NRC identified this as a potential reduction in the margin of safety, and consequently, a potential unreviewed safety question (USQ), as defined in 10 CFR 50.59. The staff's approval of Amendment No. 123 was based on the licensee maintaining a 70 psi margin between the calculated system pressure of 1380 psig during an ATWS event and the minimum Technical Specification pressure setting for the relief valves of 1450 psig. However, the testing data and revised calculation performed in May 1988 indicated that a difference of only 31 psi would exist, as the test data indicated a peak system pressure of 1419 psig would be reached. Although the ATWS requirements were being met, as the licensee had been administratively controlling the actual relief valve setpoint at 1540 psig, the NRC still viewed this issue as a reduction in the margin of safety (a reduction from 70 psi to 31 psi) and a potential USQ. The existing CNS TS would allow the SLC relief valve setpoint to be set at the lower limit of 1450 psig, where the valves (and the system) would still be considered operable. However, at this point, the combined effects of 3% setpoint drift and pump ripple, when added to the revised peak calculated system pressure of 1419 psig, could have exceeded the relief valve setpoint and caused the valves to open. This scenario could have reduced the rate of boron injection into the reactor vessel below the rate assumed by the staff in its safety evaluations related to the ATWS rule and Amendment No. 123.

3.0 EVALUATION

The specific changes proposed in the licensee's May 5, 1997, letter are as follows:

Section 4.4.A.2.a

This paragraph delineating the operability requirements for the SLC relief valves has been removed from the TS, based on the fact that the control of the relief valve setpoint has been relocated to the Augmented Testing Program, which is a part of the Inservice Testing Program. In addition, the nominal setpoint of 1540 psig \pm 1% and the basis for that setpoint are now described in the USAR.

Section 3.4.A Bases

The paragraph describing the significance of the SLC relief valve setpoint limits has been deleted, since the SLC relief valve setpoint requirements have been relocated from the TSs to the USAR and the IST program.

The licensee provided the following discussion in support of the requested amendment:

(1) The original calculated nominal SLC system pressure of 1380 psig, which was used in establishing the Technical Specifications SLC relief valve minimum opening pressure of 1450 psig by adding 70 psi margin, has been recalculated to be 1419 psig based on test data; this increase in nominal SLC system pressure from 1380 psig to 1419 psig has brought into question the adequacy of the Technical Specification minimum pressure for the SLC relief valves.

(2) The SLC relief valves are set and administratively controlled at a nominal setpoint of 1540 psig \pm 1% per the IST Augmented Testing Program, which is much higher than the Technical Specification minimum opening pressure of 1450 psig and therefore, yields a margin of 121 psi above the recalculated SLC system pressure of 1419 psig. This margin of 121 psi is greater and more conservative than the 70 psi margin which the current Technical Specification minimum opening pressure is based on.

(3) The relocation of the SLC relief valve setpoint control from the Technical Specifications has also been proposed in the CNS Improved Technical Specification (ITS) submittal dated March 27, 1997. It is based on the adequacy of the administrative control established on the changes to SLC testing and relief valve setpoint requirements in the IST program.

(4) The SLC relief valve nominal setpoint of 1540 \pm 1% and its associated bases have been included in the USAR, a copy of which is being enclosed with this proposed change request. It confirms that any changes to the SLC relief valve nominal setpoint would fall under the purview of 10 CFR 50.59 regulation.

With the proposed relocation of TS 4.4.A.2.a, the licensee will continue to maintain the control of the SLC relief valve nominal setpoint at 1540 psig \pm 1% under the current IST Augmented Testing Program. When a setpoint drift of \pm 3% is applied to the relief valve nominal setpoint, under the worst case conditions, the actual setpoint could go as low as 1478 psig or as high as 1602 psig; therefore, the nominal setpoint will be controlled within stricter limits than currently allowed by TS (1450 to 1680 psig). The maximum expected SLC system pressure for two-pump operation is 1433 psig, which is based on an estimated 14 psig for pump ripple effects added to the calculated system pressure of 1419 psig. Consequently, under the worst case setpoint drift condition, control of the SLC relief valve nominal setpoint at 1540 psig \pm 1% would still result in maintaining significant margin to ensure that the relief valves will not lift and cause recirculation flow if the SLC system is called upon during the operating interval between setpoint verification tests. The 70 psi margin relied upon by the staff in its safety evaluation related to License Amendment No. 123 to account for setpoint drift and pump ripple effects will be preserved by the proposed controls, and an additional margin of approximately 45 psi will be available (1478 - 1433 psig, after accounting

for said effects) to preclude relief valve lifting. Furthermore, with the inclusion of the SLC relief valve setpoint at 1540 psig \pm 1% in the USAR, the licensee is required to evaluate any future changes to the setpoint in accordance with 10 CFR 50.59.

Section 50.36 of Title 10 of the Code of Federal Regulations established the regulatory requirements related to the content of technical specifications. The rule requires that technical specifications include items in specific categories, including safety limits, limiting conditions for operation, and surveillance requirements; however, the rule does not specify the particular requirements to be included in a plant's TS. The NRC developed criteria to determine which of the design conditions and associated surveillances needed to be located in the TS. These criteria were incorporated into 10 CFR 50.36(c)(2)(ii), which states that:

"A technical specification limiting condition for operation of a nuclear reactor must be established for each item meeting one or more of the following criteria:

(A) *Criterion 1.* Installed instrumentation that is used to detect, and indicate in the control room, a significant abnormal degradation of the reactor coolant pressure boundary.

(B) *Criterion 2.* A process variable, design feature, or operating restriction that is an initial condition of a design basis accident or transient analysis that either assumes the failure of or presents a challenge to the integrity of a fission product barrier.

(C) *Criterion 3.* A structure, system or component that is part of the primary success path and which functions or actuates to mitigate a design basis accident or transient that either assumes the failure of or presents a challenge to the integrity of a fission product barrier.

(D) *Criterion 4.* A structure, system or component which operating experience or probabilistic risk assessment has shown to be significant to public health and safety.

The Commission acknowledged, in the "Final Policy Statement on Technical Specifications Improvements for Nuclear Power Reactors," (58 FR 39132), that its implementation may result in the relocation of existing technical specification requirements to licensee controlled documents and programs. However, in issuing the revisions to 10 CFR 50.36 (60 FR 36953), the Commission also indicated that the standby liquid control system was one of the systems to be included in TS under Criterion 4.

The staff has determined that the licensee's proposed change to relocate the requirements for the SLC relief valve setpoint does not eliminate the requirements for the licensee to ensure that the SLC system is capable of performing its safety function. Although the SLC relief valve setpoint is

relocated from the TSs to the USAR and the IST program, the licensee must continue to evaluate any changes to this setpoint in accordance with 10 CFR 50.59. Should the licensee's determination conclude that an unreviewed safety question is involved, due to either (1) an increase in the probability or consequences of accidents or malfunctions of equipment important to safety, (2) the creation of a possibility for an accident or malfunction of a different type than any evaluated previously, or (3) a reduction in the margin of safety, NRC approval and a license amendment would be required prior to implementation of the change. NRC inspection and enforcement programs also enable the staff to monitor facility changes and licensee adherence to USAR commitments and to take any remedial action that may be appropriate.

The staff's review concluded that 10 CFR 50.36 does not require the SLC relief valve setpoint to be retained in TSs. Requirements related to the operability, applicability, and surveillance requirements, including performance of testing to ensure operability of the SLC system are retained due to the system's importance in mitigating the consequences of an accident. However, the staff has determined that the inclusion of the relief valve setpoint is an operational detail related to the licensee's safety analyses, which are adequately controlled by the requirements of 10 CFR 50.59. The staff has concluded, therefore, that relocation of the SLC relief valve setpoint is acceptable because (1) its inclusion in TSs is not specifically required by 10 CFR 50.36 or other regulations, (2) the setpoint has been relocated to the Updated Safety Analysis Report and IST program, is adequately controlled by 10 CFR 50.59 and 10 CFR 50.55a, and its inclusion in the TS is not required to avert an immediate threat to the public health and safety, and (3) changes that are deemed to involve an unreviewed safety question, will require prior NRC approval in accordance with 10 CFR 50.59(c).

4.0 EMERGENCY CIRCUMSTANCES

In its May 5, 1997, application, the licensee requested that this amendment be treated as an emergency amendment. In accordance with 10 CFR 50.91(a)(5), the licensee provided the following information regarding why this emergency situation occurred and how it could not have been avoided.

The licensee states that the request for an emergency license amendment has resulted from the fact that the NRC notified the licensee on May 1, 1997, of the SLC relief valve setpoint concern as a CNS startup issue. Although an NRC inspection in November of 1996 first raised the issue as a potential reduction in the margin of safety and a potential unreviewed safety question, the licensee disagreed. Several subsequent discussions between the staff and the licensee still failed to result in agreement and the licensee continues to maintain that its actions have been conservative and that the issue does not involve an USQ. On May 1, 1997, the NRC staff verbally informed the licensee that the existing TS regarding the lower limit for the SLC relief valve setpoint was inadequate to ensure the proper function of the system under all postulated conditions, and that the TS needed to be revised prior to the resumption of plant operation.

The staff concludes that an emergency condition exists in that failure to act in a timely way would result in prevention of resumption of operation of the Cooper Nuclear Station. In addition, the staff has assessed the licensee's reasons for failing to file an application sufficiently in advance to preclude an emergency, and concluded that the licensee has acted expeditiously, by virtue of its March 27, 1997, request to convert the CNS TS to the Improved Standard Technical Specifications. Due to the period of time required for the staff to review the extensive TS conversion application, the licensee promptly proposed this amendment to remedy the immediate situation. Thus, the staff concludes that the licensee has not abused the emergency provisions by failing to make timely application for the amendment. Thus, conditions needed to satisfy 10 CFR 50.91(a)(5) exist, and the amendment is being processed on an emergency basis.

5.0 FINAL NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION

The Commission's regulations in 10 CFR 50.92(c) state that the Commission may make a final determination that a license amendment involves no significant hazards consideration if operation of the facility in accordance with the amendment would not: (1) Involve a significant increase in the probability or consequences of an accident previously evaluated; or, (2) Create the possibility of a new or different kind of accident from any previously evaluated; or, (3) Involve a significant reduction in a margin of safety.

The following evaluation by the licensee demonstrates that the proposed amendment does not involve a significant hazards consideration:

(1) The proposed amendment does not involve a significant increase in the probability or consequences of an accident previously evaluated. Standby Liquid Control (SLC) system is designed to meet two functions: a) bring the Reactor to a cold shutdown condition without use of control rods, and b) meet the requirements of the ATWS Rule per 10 CFR 50.62. Neither of these functions are impacted by the relocation of the SLC relief valve setpoint control from the Technical Specifications to the IST Augmented Testing Program and to the USAR. Furthermore, the removal does not alter any input parameters or precursors for any accident analyses described in the USAR. The function of the SLC relief valves during an ATWS event is to remain closed during two-pump SLC operation, thereby preventing recirculation flow. Also, the relief valve testing requirements per the IST Augmented Testing Program preserves the requirements to test the valves. Consequently, the ability of the relief valves to perform their credited function is not challenged by this proposed change. Therefore, relocation of the SLC relief valve setpoint control from the CNS Technical Specifications does not involve a significant increase in the probability or consequences of an accident previously evaluated.

(2) The proposed change will not create the possibility of a new or different kind of accident than evaluated in the USAR. The proposed change does not result in any physical change to CNS Structures, Systems,

or Component, nor does it change the fit, form, or function of any equipment/component taken credit for in the accident analyses described in the USAR. Therefore, the relocation of the SLC relief valve setpoint control from the Technical Specifications does not create the possibility of a new or different kind of accident.

(3) The proposed relocation of SLC relief valve testing from the CNS Technical Specifications to the IST Augmented Testing Program and to the USAR will not reduce the margin of safety. The SLC relief valve setpoint are being tested at the same frequency under the IST Augmented Testing Program. Under this program, the valves are set at a nominal setpoint of 1540 psig \pm 1%. Since the maximum nominal SLC system pressure based on test data is determined to be 1419 psig, a margin of 121 psi is available between this calculated pressure and the relief valve nominal setpoint. This 121 psi margin allows for pump ripple and setpoint drift as opposed to only 70 psi which in the past has been added as a margin to obtain the current Technical Specification minimum limit of 1450 psig from the original calculated maximum SLC system pressure of 1380 psig to account for the same reasons. Although the SLC calculated maximum system pressure has increased from 1380 psig to 1419 psig based on test data by setting the SLC relief valve at a nominal setpoint of 1540 psig \pm 1%, an increase in the margin will be achieved since consistent methodology has been applied in both cases.

Based on the above, the staff has made a final determination that the amendment involves no significant hazards consideration.

6.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Nebraska State official was notified of the proposed issuance of the amendment. The State official had no comments.

7.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has made a final no significant hazards finding with respect to this amendment. Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

8.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: James R. Hall

Date: May 9, 1997