

DISTRIBUTION

Docket File

July 25, 1988

NRC PDR
Local PDR
PD21 r/f
S. Varga (14E4)
G. Lainas
E. Adensam
P. Anderson
L. Kintner
OGC
E. Jordan (MNBB 3302)
B. Grimes (9A2)
ACRS (10)
GPA/PA

Docket No. 50-416

Mr. Oliver D. Kingsley, Jr.
Vice President, Nuclear Operations
System Energy Resources, Inc.
P. O. Box 23054
Jackson, Mississippi 39205

Dear Mr. Kingsley:

SUBJECT: ONSITE DIESEL GENERATOR TEST SCHEDULE - GRAND GULF NUCLEAR
STATION, UNIT 1 (TAC NO. 67823)

Enclosed is a copy of an Environmental Assessment and Finding of No Significant Impact relative to the Grand Gulf Nuclear Station, Unit 1, for your information. This assessment relates to your request dated April 8, 1988, as supplemented June 21 1988, which proposed a Technical Specifications (TS) amendment which would change TS Table 4.8.1.1.2-1 concerning the diesel generator test schedule. These changes were proposed in response to the NRC's Generic Letter 84-15.

This assessment has been forwarded to the Office of the Federal Register for publication.

Sincerely,

151 Annie L. Kintner

Lester L. Kintner, Senior Project Manager
Project Directorate II-1
Division of Reactor Projects I/II

Enclosure:
Environmental Assessment

cc w/enclosure:
See next page

DF01
11

8808010205 880725
PDR ADOCK 05000416
P PDC

OFC	:LA:PD21:DRPR:PM:PD21:DRPR:D:PD21:DRPR:	:	:	:	:
NAME	:Anderson : LKintner:ch: EAdensam	:	:	:	:
DATE	: 7/22/88 : 7/24/88 : 7/25/88	:	:	:	:

OFFICIAL RECORD COPY

Mr. Oliver D. Kingsley, Jr.
System Energy Resources, Inc.

Grand Gulf Nuclear Station (GGNS)

cc:

Mr. Ted H. Cloninger
Vice President, Nuclear Engineering
and Support
System Energy Resources, Inc.
Post Office Box 23054
Jackson, Mississippi 39205

Mr. C. R. Hutchinson
GGNS General Manager
System Energy Resources, Inc.
Post Office Box 756
Port Gibson, Mississippi 39150

Robert B. McGehee, Esquire
Wise, Carter, Child, Steen and Caraway
P.O. Box 651
Jackson, Mississippi 39205

The Honorable William J. Guste, Jr.
Attorney General
Department of Justice
State of Louisiana
Baton Rouge, Louisiana 70804

Nicholas S. Reynolds, Esquire
Bishop, Liberman, Cook, Purcell
and Reynolds
1400 L Street, N.W.
Washington, D. C. 20005-3502

Office of the Governor
State of Mississippi
Jackson, Mississippi 39201

Mr. Ralph T. Lally
Manager of Quality Assurance
Middle South Utilities System
Services, Inc.
639 Loyola Avenue, 3rd Floor
New Orleans, Louisiana 70113

Attorney General
Gartin Building
Jackson, Mississippi 39205

Mr. John G. Cesare
Director, Nuclear Licensing
System Energy Resources, Inc.
P.O. Box 23054
Jackson, Mississippi 39205

Mr. Jack McMillan, Director
Division of Solid Waste Management
Mississippi Department of Natural
Resources
Post Office Box 10385
Jackson, Mississippi 39209

Mr. C. B. Hogg, Project Manager
Bechtel Power Corporation
P. O. Box 2166
Houston, Texas 77252-2166

Alton B. Cobb, M.D.
State Health Officer
State Board of Health
P.O. Box 1700
Jackson, Mississippi 39205

Mr. Ross C. Butcher
Senior Resident Inspector
U. S. Nuclear Regulatory Commission
Route 2, Box 399
Port Gibson, Mississippi 39150

President
Claiborne County Board of Supervisors
Port Gibson, Mississippi 39150

Mr. James E. Cross
GGNS Site Director
Systems Energy Resources, Inc.
P.O. Box 756
Port Gibson, Mississippi 39150

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street
Suite 2900
Atlanta, Georgia 30323

UNITED STATES NUCLEAR REGULATORY COMMISSION
MISSISSIPPI POWER & LIGHT COMPANY
SYSTEM ENERGY RESOURCES INC.
SOUTH MISSISSIPPI ELECTRIC POWER ASSOCIATION
DOCKET NO. 50-416
ENVIRONMENTAL ASSESSMENT AND FINDING OF
NO SIGNIFICANT IMPACT

The U. S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-29 issued to Mississippi Power & Light Company, System Energy Resources, Inc., and South Mississippi Electric Power Associates, (the licensees), for operation of the Grand Gulf Nuclear Station (GGNS), Unit 1, located in Claiborne County, Mississippi.

ENVIRONMENTAL ASSESSMENT

Identification of Proposed Action:

The proposed amendment would change the onsite diesel generator test schedule in the Technical Specifications (TS) by changing the criterion for more frequent testing.

The proposed action is in accordance with the licensee's application for amendment dated April 8, 1988, as supplemented by letter dated June 21, 1988.

The Need for the Proposed Action:

The proposed change to the TS is required in order to reduce the wear of diesel generators due to the frequent testing required by the present TS.

8808010208 880725
PDR ADOCK 05000416
P PDC

Environmental Impacts of the Proposed Action:

The Commission has completed its evaluation of the proposed change to TS and has concluded that the proposed amendment would not adversely affect plant safety. Therefore, the proposed amendment does not significantly increase the probability or consequences of any accident. The Commission also concludes that the amendment involves no significant increase in the amounts and no significant change in the types of any effluents that may be released offsite and that there should be no significant increase in individual or cumulative occupational radiation exposure. Accordingly, the Commission concludes that this proposed action would result in no significant radiological environmental impact.

With regard to potential non-radiological impacts, the proposed change to the TS involves requirements with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. It does not affect non-radiological plant effluents and has no other environmental impact. Therefore, the Commission concludes that there are no significant non-radiological environmental impacts associated with the proposed amendment.

Alternative to the Proposed Action:

Since the Commission concluded that there are no significant environmental effects that would result from the proposed action, any alternatives with equal or greater environmental impacts need not be evaluated.

The principal alternative would be to deny the requested amendment. This would not reduce environmental impacts of plant operation and would result in reduced operational flexibility.

Alternative Use of Resources:

This action does not involve the use of any resources not previously considered in the Final Environmental Statement related to the operation of Grand Gulf Nuclear Station Units 1 and 2, dated September 1981.

Agencies and Persons Consulted:

The NRC staff reviewed the licensee's request and did not consult other agencies or persons.

FINDING OF NO SIGNIFICANT IMPACT

The Commission has determined not to prepare an environmental impact statement for the proposed license amendment.

Based upon the foregoing environmental assessment, we conclude that the proposed action will not have a significant effect on the quality of the human environment.

For further details with respect to this action, see the application for amendment dated April 8, 1988, as supplemented June 21, 1988, which are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the Hinds Junior College, McLendon Library, Raymond, Mississippi 39154.

Dated at Rockville, Maryland, this 25th day of July 1988.

FOR THE NUCLEAR REGULATORY COMMISSION

151
Elinor G. Adensam, Director
Project Directorate II-1
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

OFC	:LA:PD21:DRPR:PM:PD21:DRPR:	OGC	:D:PD21:DRPR:	:	:	:
NAME	:PAnderson	:LKintner:clh	::EAdensam	:	:	:
DATE	:06/12/88	:07/12/88	:06/1/88	:06/20/88	:	:

OFFICIAL RECORD COPY 7/14