

Docket No. 50-416

March 4, 1992

Mr. William T. Cottle  
Vice President, Operations GGNS  
Entergy Operations, Inc.  
Post Office Box 756  
Port Gibson, Mississippi 39150

Dear Mr. Cottle:

SUBJECT: CORRECTION TO AMENDMENT NO. 89 TO FACILITY OPERATING LICENSE  
NPF-29 - GRAND GULF NUCLEAR STATION, UNIT 1 (TAC NO. M80701)

On February 20, 1992, the Commission issued Amendment No. 89 to Facility Operating License No. NPF-29 to Grand Gulf Nuclear Station, Unit 1. The amendment authorized a one-time extension of the required test interval for overall integrated leak rate tests (Type A tests) as specified in coupling the third Type A test to the plant shutdown for the 10-year Inservice Inspection outage.

Correction is being made to incorporate corrected Technical Specification (TS) overleaf page B 3/4 6-2 to TS B 3/4 6-1. The overleaf page inadvertently omitted changes made with Amendment No. 84. Please accept our apologies for any inconvenience this may have caused you.

Sincerely,  
ORIGINAL SIGNED BY

Paul W. O'Connor, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III/IV/V  
Office of Nuclear Reactor Regulation

Enclosure:  
TS pages B 3/4 6-1  
and B 3/4 6-2

cc w/enclosure:  
See next page

DISTRIBUTION

|                |                   |                  |                    |
|----------------|-------------------|------------------|--------------------|
| Docket File    | NRC/Local PDR     | PD4-1 Reading    | P. Noonan          |
| M. Virgilio    | OPA(2G5)          | J. Larkins       | PD4-1 Plant File   |
| P. O'Connor(2) | OGC               | D. Hagan(3206)   | T.Gody,Jr.(13E21)  |
| G. Hill(4)     | Wanda Jones(7103) | C. Grimes(11E22) | D. Pickett (13H15) |
| ACRS(10)       | OC/LFMB(MS4503)   | D. Verrelli      | R. Hall (13E21)    |

|      |                             |                             |                            |
|------|-----------------------------|-----------------------------|----------------------------|
| OFC  | LA:PD4-1 <i>[Signature]</i> | PM:PD4-1 <i>[Signature]</i> | D:PD4-1 <i>[Signature]</i> |
| NAME | PNoonan                     | PO'Connor                   | J.Larkins                  |
| DATE | 3/3/92                      | 3/3/92                      | 3/4/92                     |

OFFICIAL RECORD COPY Document Name: GG80701.ltr

9203090205 920304  
PDR ADDOCK 05000416  
P PDR

RECEIVED 1992



UNITED STATES  
NUCLEAR REGULATORY COMM  
WASHINGTON, D. C. 20555

March 4, 1992

Docket No. 50-416

Mr. William T. Cottle  
Vice President, Operations GGNS  
Entergy Operations, Inc.  
Post Office Box 756  
Port Gibson, Mississippi 39150

Dear Mr. Cottle:

SUBJECT: CORRECTION TO AMENDMENT NO. 89 TO FACIL  
NPF-29 - GRAND GULF NUCLEAR STATION, UN

On February 20, 1992, the Commission issued Amendn  
Operating License No. NPF-29 to Grand Gulf Nuclear  
amendment authorized a one-time extension of the r  
overall integrated leak rate tests (Type A tests)  
third Type A test to the plant shutdown for the 10  
outage.

Correction is being made to incorporate corrected  
overleaf page B 3/4 6-2 to TS B 3/4 6-1. The over  
omitted changes made with Amendment No. 84. Pleas  
any inconvenience this may have caused you.

Sincerely,

A handwritten signature in cursive script, reading "Paul W.", is positioned above the typed name.

Paul W. O'Connor  
Project Director  
Division of Re  
Office of Nuc

Enclosure:  
TS pages B 3/4 6-1  
and B 3/4 6-2

cc w/enclosure:  
See next page

Mr. W. T. Cottle  
Grand Gulf Nuclear Station

Entergy Operations, Inc.

cc:

Mr. Raubin L. Randels  
Project Engineer, Manager  
Bechtel Power, Corp.  
P. O. Box 2166  
Houston, Texas 77252-2166

Mr. C. R. Hutchinson  
GGNS General Manager  
Entergy Operations, Inc.  
P. O. Box 756  
Port Gibson, Mississippi 39150

Robert B. McGehee, Esquire  
Wise, Carter, Child & Caraway  
P. O. Box 651  
Jackson, Mississippi 39205

The Honorable William J. Guste, Jr.  
Attorney General  
Department of Justice  
State of Louisiana  
P. O. Box 94005  
Baton Rouge, Louisiana 70804-9005

Nicholas S. Reynolds, Esquire  
Winston & Strawn  
1400 L Street, N.W. - 12th Floor  
Washington, D.C. 20005-3502

Alton B. Cobb, M.D.  
State Health Officer  
State Board of Health  
P. O. Box 1700  
Jackson, Mississippi 39205

Mr. Jack McMillan, Director  
Division of Solid Waste Management  
Mississippi Department of Natural  
Resources  
P. O. Box 10385  
Jackson, Mississippi 39209

Office of the Governor  
State of Mississippi  
Jackson, Mississippi 39201

President,  
Claiborne County Board of Supervisors  
Port Gibson, Mississippi 39150

Mike Morre, Attorney General  
Frank Spencer, Asst. Attorney General  
State of Mississippi  
Post Office Box 22947  
Jackson, Mississippi 39225

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta St., Suite 2900  
Atlanta, Georgia 30323

Mr. John P. McGaha  
Vice President, Operations Support  
Entergy Operations, Inc.  
P.O. Box 31995  
Jackson, Mississippi 39286-1995

Mr. Michael J. Meisner  
Director, Nuclear Licensing  
Entergy Operations, Inc.  
P. O. Box 756  
Port Gibson, Mississippi 39150

Mr. Donald C. Hintz, Executive Vice  
President & Chief Operating Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, Mississippi 39286-1995

Mr. C. B. Hogg, Project Manager  
Bechtel Power Corporation  
P. O. Box 2166  
Houston, Texas 77252-2166

Mr. Johnny Mathis  
Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Route 2, Box 399  
Port Gibson, Mississippi 39150

## 3/4.6 CONTAINMENT SYSTEMS

### BASES

#### 3/4.6.1 PRIMARY CONTAINMENT

##### 3/4.6.1.1 PRIMARY CONTAINMENT INTEGRITY

PRIMARY CONTAINMENT INTEGRITY ensures that the release of radioactive materials from the containment atmosphere will be restricted to those leakage paths and associated leak rates assumed in the accident analyses. This restriction, in conjunction with the leakage rate limitation, will limit the site boundary radiation doses to within the limits of 10 CFR Part 100 during accident conditions.

##### 3/4.6.1.2 CONTAINMENT LEAKAGE

The limitations on containment leakage rates ensure that the total containment leakage volume will not exceed the value assumed in the accident analyses at the peak accident pressure of 11.5 psig, P. As an added conservatism, the measured overall integrated leakage rate is further limited to less than or equal to 0.75 L during performance of the periodic tests to account for possible degradation of the containment leakage barriers between leakage tests.

Operating experience with the main steam line isolation valves has indicated that degradation has occasionally occurred in the leak tightness of the valves; therefore the special requirement for testing these valves.

The surveillance testing for measuring leakage rates is consistent with the requirements of Appendix J to 10 CFR 50 with the exception of exemptions granted for testing the airlocks after each opening, and uncoupling the third Type A test of each 10-year service period from the last outage of that period.

##### 3/4.6.1.3 CONTAINMENT AIR LOCKS

The limitations on closure and leak rate for the containment air locks are required to meet the restrictions on PRIMARY CONTAINMENT INTEGRITY and the containment leakage rate given in Specifications 3.6.1.1 and 3.6.1.2. The specification makes allowances for the fact that there may be long periods of time when the air locks will be in a closed and secured position during reactor operation. Only one closed door in each air lock is required to maintain the integrity of the containment. Verification that each air lock door inflatable seal system is OPERABLE by the performance of a local leak-detection test for a period of less than 48 hours is permissible if it can be demonstrated that the leakage rate can be accurately determined for this shorter period. (This is in accordance with Sections 6.4 and 7.6 of ANSI N45.4-1972.)

##### 3/4.6.1.4 MSIV LEAKAGE CONTROL SYSTEM

Calculated doses resulting from the maximum leakage allowance for the main steamline isolation valves in the postulated LOCA situations would be a small fraction of the 10 CFR 100 guidelines, provided the main steam line system from the isolation valves up to and including the turbine condenser remains intact. Operating experience has indicated that degradation has occasionally occurred in the leak tightness of the MSIV's such that the specified leakage requirements have not always been maintained continuously. The requirement for the leakage control system will reduce the untreated leakage from the MSIVs when isolation of the primary system and containment is required.