

Docket No. 50-416

February 25, 1992

Mr. William T. Cottle  
Vice President, Operations GGNS  
Energy Operations, Inc.  
Post Office Box 756  
Port Gibson, Mississippi 39150

Dear Mr. Cottle:

SUBJECT: ISSUANCE OF AMENDMENT NO. 91 TO FACILITY OPERATING LICENSE  
NO. NPF-29 - GRAND GULF NUCLEAR STATION, UNIT 1, REGARDING  
(TAC NO. M81916)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 91 to Facility Operating License No. NPF-29 for the Grand Gulf Nuclear Station, Unit 1. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated October 18, 1991.

The amendment deletes a TS requirement to perform a daily surveillance verifying the measured recirculation system drive flow to be less than or equal to the established drive flow for a given flow control valve position.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,  
ORIGINAL SIGNED BY

Paul W. O'Connor, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV&V  
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 91 to NPF-29
- 2. Safety Evaluation

cc w/enclosures:

See next page

DISTRIBUTION

Docket File	NRC/LPDRs	PD4-1 r/f	PNoonan	MVirgilio	OPA
JLarkins	PD4-1 p/f	PO'Connor(2)	OGC	DHagan	TGody, Jr.
GHill(4)	Wanda Jones	CGrimes	DPickett	ACRS (10)	OC/LFMB
DVerrelli					

OFC: PD4-1/LA	PD4-1/PM	OGC	PD4-1/D
NAME: PNoonan	PO'Connor/vmw		JLarkins
DATE: 2/15/92	2/15/92	2/15/92	2/25/92

*JLarkins*  
1/1



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

February 25, 1992

Docket No. 50-416

Mr. William T. Cottle  
Vice President, Operations GGNS  
Entergy Operations, Inc.  
Post Office Box 756  
Port Gibson, Mississippi 39150

Dear Mr. Cottle:

SUBJECT: ISSUANCE OF AMENDMENT NO. 91 TO FACILITY OPERATING LICENSE  
NO. NPF-29 - GRAND GULF NUCLEAR STATION, UNIT 1, REGARDING  
(TAC NO. M81916)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 91 to Facility Operating License No. NPF-29 for the Grand Gulf Nuclear Station, Unit 1. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated October 18, 1991.

The amendment deletes a TS requirement to perform a daily surveillance verifying the measured recirculation system drive flow to be less than or equal to the established drive flow for a given flow control valve position.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

A handwritten signature in black ink that reads "Paul W. O'Connor".

Paul W. O'Connor, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV&V  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 91 to NPF-29
2. Safety Evaluation

cc w/enclosures:  
See next page

Mr. W. T. Cottle  
Entergy Operations, Inc.

Grand Gulf Nuclear Station

cc:

Mr. Raubin L. Randels  
Project Engineer, Manager  
Bechtel Power, Corp.  
P. O. Box 2166  
Houston, Texas 77252-2166

Mr. C. R. Hutchinson  
GGNS General Manager  
Entergy Operations, Inc.  
P. O. Box 756  
Port Gibson, Mississippi 39150

Robert B. McGehee, Esquire  
Wise, Carter, Child & Caraway  
P. O. Box 651  
Jackson, Mississippi 39205

The Honorable William J. Guste, Jr.  
Attorney General  
Department of Justice  
State of Louisiana  
P. O. Box 94005  
Baton Rouge, Louisiana 70804-9005

Nicholas S. Reynolds, Esquire  
Winston & Strawn  
1400 L Street, N.W. - 12th Floor  
Washington, D.C. 20005-3502

Alton B. Cobb, M.D.  
State Health Officer  
State Board of Health  
P. O. Box 1700  
Jackson, Mississippi 39205

Mr. Jack McMillan, Director  
Division of Solid Waste Management  
Mississippi Department of Natural  
Resources  
P. O. Box 10385  
Jackson, Mississippi 39209

Office of the Governor  
State of Mississippi  
Jackson, Mississippi 39201

President,  
Claiborne County Board of Supervisors  
Port Gibson, Mississippi 39150

Mike Morre, Attorney General  
Frank Spencer, Asst. Attorney General  
State of Mississippi  
Post Office Box 22947  
Jackson, Mississippi 39225

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta St., Suite 2900  
Atlanta, Georgia 30323

Mr. John P. McGaha  
Vice President, Operations Support  
Entergy Operations, Inc.  
P.O. Box 31995  
Jackson, Mississippi 39286-1995

Mr. Michael J. Meisner  
Director, Nuclear Licensing  
Entergy Operations, Inc.  
P. O. Box 756  
Port Gibson, Mississippi 39150

Mr. Donald C. Hintz, Executive Vice  
President & Chief Operating Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, Mississippi 39286-1995

Mr. C. B. Hogg, Project Manager  
Bechtel Power Corporation  
P. O. Box 2166  
Houston, Texas 77252-2166

Mr. Johnny Mathis  
Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Route 2, Box 399  
Port Gibson, Mississippi 39150



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

ENERGY OPERATIONS, INC.

SYSTEM ENERGY RESOURCES, INC.

SOUTH MISSISSIPPI ELECTRIC POWER ASSOCIATION

MISSISSIPPI POWER AND LIGHT COMPANY

DOCKET NO. 50-416

GRAND GULF NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 91  
License No. NPF-29

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Entergy Operations, Inc. (the licensee) dated October 18, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 2.C.(2) of Facility Operating License No. NPF-29 is hereby amended to read as follows:

- (2) Technical Specifications

- The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 91, are hereby incorporated into this license. Entergy Operations, Inc. shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John T. Larkins, Director  
Project Directorate IV-1  
Division of Reactor Projects III/IV&V  
Office of Nuclear Reactor Regulation

Attachment: Changes to the  
Technical Specifications

Date of Issuance: February 25, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 91

FACILITY OPERATING LICENSE NO. NPF-29

DOCKET NO. 50-416

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change.

REMOVE PAGES

3/4 3-7

3/4 3-8

INSERT PAGES

3/4 3-7

3/4 3-8

TABLE 4.3.1.1-1

REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION (a)</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
1. Intermediate Range Monitors:				
a. Neutron Flux - High	S/U,S, <sup>(b)</sup> S	S/U, W W	R R	2 3, 4, 5
b. Inoperative	NA	W	NA	2, 3, 4, 5
2. Average Power Range Monitor: <sup>(f)</sup>				
a. Neutron Flux - High, Setdown	S/U,S, <sup>(b)</sup> S	S/U, W W	SA SA	2 3, 5
b. Flow Biased Simulated Thermal Power - High	S	Q	W <sup>(d)(e)</sup> , SA, R <sup>(i)</sup>	1
c. Neutron Flux - High	S	Q	W <sup>(d)</sup> , SA	1
d. Inoperative	NA	Q	NA	1, 2, 3, 5
3. Reactor Vessel Steam Dome Pressure - High	S	Q	R <sup>(g)</sup>	1, 2 <sup>(j)</sup>
4. Reactor Vessel Water Level - Low, Level 3	S	Q	R <sup>(g)</sup>	1, 2
5. Reactor Vessel Water Level - High, Level 8	S	Q	R <sup>(g)</sup>	1
6. Main Steam Line Isolation Valve - Closure	NA	Q	R	1
7. Main Steam Line Radiation - High	S	Q	R	1, 2 <sup>(j)</sup>
8. Drywell Pressure - High	S	Q	R <sup>(g)</sup>	1, 2 <sup>(k)</sup>

TABLE 4.3.1.1-1 (Continued)  
REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
9. Scram Discharge Volume Water Level - High				
a. Transmitter/Trip Unit	S	Q	R <sup>(g)</sup>	1, 2, 5 <sup>(1)</sup>
b. Float Switch	NA	Q	R	1, 2, 5 <sup>(1)</sup>
10. Turbine Stop Valve - Closure	S	Q	R <sup>(g)</sup>	1
11. Turbine Control Valve Fast Closure Valve Trip System Oil Pressure - Low	S	Q	R <sup>(g)</sup>	1
12. Reactor Mode Switch Shutdown Position	NA	R	NA	1, 2, 3, 4, 5
13. Manual Scram	NA	W	NA	1, 2, 3, 4, 5

(a) Neutron detectors may be excluded from CHANNEL CALIBRATION.

(b) The IRM and SRM channels shall be determined to overlap for at least 1/2 decade during each startup after entering OPERATIONAL CONDITION 2 and the IRM and APRM channels shall be determined to overlap for at least 1/2 decade during each controlled shutdown, if not performed within the previous 7 days.

(c) [DELETED]

(d) This calibration shall consist of the adjustment of the APRM channel to conform to the power values



TABLE 4.3.1.1-1 (Continued)  
REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
9. Scram Discharge Volume Water Level - High				
a. Transmitter/Trip Unit	S	Q	R <sup>(g)</sup>	1, 2, 5 <sup>(1)</sup>
b. Float Switch	NA	Q	R	1, 2, 5 <sup>(1)</sup>
10. Turbine Stop Valve - Closure	S	Q	R <sup>(g)</sup>	1
11. Turbine Control Valve Fast Closure Valve Trip System Oil Pressure - Low	S	Q	R <sup>(g)</sup>	1
12. Reactor Mode Switch Shutdown Position	NA	R	NA	1, 2, 3, 4, 5
13. Manual Scram	NA	W	NA	1, 2, 3, 4, 5

(a) Neutron detectors may be excluded from CHANNEL CALIBRATION.

(b) The IRM and SRM channels shall be determined to overlap for at least 1/2 decade during each startup after entering OPERATIONAL CONDITION 2 and the IRM and APRM channels shall be determined to overlap for at least 1/2 decade during each controlled shutdown, if not performed within the previous 7 days.

(c) [DELETED]

(d) This calibration shall consist of the adjustment of the APRM channel to conform to the power values



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 91 TO FACILITY OPERATING LICENSE NO. NPF-29

ENERGY OPERATIONS, INC., ET AL.

GRAND GULF NUCLEAR STATION, UNIT 1

DOCKET NO. 50-416

1.0 INTRODUCTION

By letter dated October 18, 1991, the licensee (Entergy Operations, Inc.), submitted a request for changes to the Grand Gulf Nuclear Station (GGNS) Unit 1, Technical Specifications (TS). The requested changes would delete a TS requirement to perform a daily surveillance verifying the measured recirculation system drive flow to be less than or equal to the established drive flow for a given flow control valve position.

2.0 EVALUATION

The proposed change to the GGNS TS would delete the requirement to perform Note (h) daily for the Average Power Range Monitor - Flow Biased Simulated Thermal Power (APRM-FBSTP)-High scram function identified as item 2.b in Table 4.3.1.1.1. The loss of feedwater heater (LFWH) analysis is central to the issues surrounding the requested change to the simulated thermal power (STP) trip surveillance requirement because historically it is the only safety analysis for which STP trip credit has been taken. The analysis methodology for this event changed significantly during Cycle 1. As originally licensed for Cycle 1, the LFWH analysis credited the STP trip to minimize the calculated severity of the transient. An improved analytic methodology, first employed during the Maximum Extended Operating Domain (MEOD) analysis during Cycle 1 and then repeated for each reload, assumes no STP trip. The LFWH analysis provided by Grand Gulf for MEOD and each cycle reload allow reactor power to reach a new, higher steady state level and demonstrate acceptable critical power ratio (CPR) results. This approach is equivalent to considering the complete failure of the STP (and any other) trip. The GGNS reload safety analysis, therefore, does not take credit for the APRM-FBSTP scram function in ensuring that the safety limit of minimum critical power ratio (MCPR) is not exceeded. Also, it further demonstrates that any increase in the simulated thermal power scram setpoint is well analyzed for the LFWH event (i.e., no scram is assumed).

The GGNS has identified the deletion of this surveillance as a TS change beneficial to safety through reduction of operator burden. While the proposed change, in and of itself, may not provide a major reduction in operator burden, the licensee believe that the cumulative effect of this and similar changes planned for the future will be a positive safety improvement.

Based on the above evaluation of this TS change request, the staff finds that it is acceptable.

After evaluating the TS change request to delete the surveillance requirement for the flow based STP trip instrumentation, the removal of this surveillance is considered acceptable. The justification for this modification to the TS is based on the fact that the STP trip signal is no longer credited by the licensee in any of its safety analysis.

### 3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Mississippi State official was notified of the proposed issuance of the amendment. The State official had no comments.

### 4.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes in surveillance requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (56 FR 57696). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

### 5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: M. Razzaque  
P. W. O'Connor

Date: February 25, 1992