

December 18, 1991

Mr. William T. Cottle  
Vice President, Operations GGNS  
Entergy Operations, Inc.  
Post Office Box 756  
Port Gibson, Mississippi 39150

Dear Mr. Cottle:

SUBJECT: ISSUANCE OF AMENDMENT NO. 85 TO FACILITY OPERATING LICENSE  
NO. NPF-29 - GRAND GULF NUCLEAR STATION, UNIT 1, REGARDING  
(TAC NO. M81324)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 85 to Facility Operating License No. NPF-29 for the Grand Gulf Nuclear Station, Unit 1. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated August 15, 1991.

The amendment will remove requirements for the Balance of Plant Load Shedding feature of the Load Shed and Sequencing System contained in TS Tables 3.3.3-1, 3.3.3-2, and 4.3.3-1.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY

Paul W. O'Connor, Sr. Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III, IV, and V  
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 85 to NPF-29
- 2. Safety Evaluation

cc w/enclosures:

See next page

DISTRIBUTION

Docket File	NRC/Local PDR	PD4-1 Reading	P. Noonan
M. Virgilio	GPA/PA(MS2G5)	J. Larkins	PD4-1 Plant File
P. O'Connor(2)	OGC(MS15B18)	D. Hagan(MS3206)	RTwigg
G. Hill(4)	Wanda Jones(MS7103)	C. Grimes(MS11E22)	
ACRS(10)(MSP315)	ARM/LFMB(MS4503)	D. Verrelli	

*Re for*

*CP*

OFC	: PD4-1/LA	: PD4-1/PE	: PD4-1/PM	: SELB	: OGC	: PD4-1/D
NAME	: PNoonan	: RTwigg:pk	: PO'Connor	: FRosa	: J.Hill	: J.Larkins
DATE	: 11/20/91	: 11/20/91	: 11/20/91	: 12/4/91	: 12/11/91	: 12/18/91

OFFICIAL RECORD COPY  
Document Name: GG AMEND/81324

9201030227 911218  
PDR ADDCK 05000416  
P PDR

OFFICIAL RECORD COPY *DFO*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

December 18, 1991

Docket No. 50-416

Mr. William T. Cottle  
Vice President, Operations GGNS  
Entergy Operations, Inc.  
Post Office Box 756  
Port Gibson, Mississippi 39150

Dear Mr. Cottle:

SUBJECT: ISSUANCE OF AMENDMENT NO. 85 TO FACILITY OPERATING LICENSE  
NO. NPF-29 - GRAND GULF NUCLEAR STATION, UNIT 1, REGARDING  
(TAC NO. M81324)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 85 to Facility Operating License No. NPF-29 for the Grand Gulf Nuclear Station, Unit 1. This amendment consists of changes to the Technical Specifications (TS) in response to your application dated August 15, 1991.

The amendment will remove requirements for the Balance of Plant Load Shedding feature of the Load Shed and Sequencing System contained in TS Tables 3.3.3-1, 3.3.3-2, and 4.3.3-1.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script that reads "Paul W. O'Connor".

Paul W. O'Connor, Sr. Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III, IV, and V  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 85 to NPF-29
2. Safety Evaluation

cc w/enclosures:  
See next page

Mr. W. T. Cottle  
Entergy Operations, Inc.

Grand Gulf Nuclear Station

cc:

Mr. Raubin L. Randels  
Project Engineer, Manager  
Bechtel Power, Corp.  
P. O. Box 2166  
Houston, Texas 77252-2166

Mr. C. R. Hutchinson  
GGNS General Manager  
Entergy Operations, Inc.  
P. O. Box 756  
Port Gibson, Mississippi 39150

Robert B. McGehee, Esquire  
Wise, Carter, Child & Caraway  
P. O. Box 651  
Jackson, Mississippi 39205

The Honorable William J. Guste, Jr.  
Attorney General  
Department of Justice  
State of Louisiana  
P. O. Box 94005  
Baton Rouge, Louisiana 70804-9005

Nicholas S. Reynolds, Esquire  
Winston & Strawn  
1400 L Street, N.W. - 12th Floor  
Washington, D.C. 20005-3502

Alton B. Cobb, M.D.  
State Health Officer  
State Board of Health  
P. O. Box 1700  
Jackson, Mississippi 39205

Mr. Jack McMillan, Director  
Division of Solid Waste Management  
Mississippi Department of Natural  
Resources  
P. O. Box 10385  
Jackson, Mississippi 39209

Office of the Governor  
State of Mississippi  
Jackson, Mississippi 39201

President,  
Claiborne County Board of Supervisors  
Port Gibson, Mississippi 39150

Mike Morre, Attorney General  
Frank Spencer, Asst. Attorney General  
State of Mississippi  
Post Office Box 22947  
Jackson, Mississippi 39225

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta St., Suite 2900  
Atlanta, Georgia 30323

Mr. John P. McGaha  
Vice President, Operations Support  
Entergy Operations, Inc.  
P.O. Box 31995  
Jackson, Mississippi 39286-1995

Mr. Michael J. Meisner  
Director, Nuclear Licensing  
Entergy Operations, Inc.  
P. O. Box 756  
Port Gibson, Mississippi 39150

Mr. Donald C. Hintz, Executive Vice  
President & Chief Operating Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, Mississippi 39286-1995

Mr. C. B. Hogg, Project Manager  
Bechtel Power Corporation  
P. O. Box 2166  
Houston, Texas 77252-2166

Mr. Johnny Mathis  
Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Route 2, Box 399  
Port Gibson, Mississippi 39150



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

ENTERGY OPERATIONS, INC.

SYSTEM ENERGY RESOURCES, INC.

SOUTH MISSISSIPPI ELECTRIC POWER ASSOCIATION

MISSISSIPPI POWER AND LIGHT COMPANY

DOCKET NO. 50-416

GRAND GULF NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 85  
License No. NPF-29

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Entergy Operations, Inc. (the licensee) dated August 15, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 2.C.(2) of Facility Operating License No. NPF-29 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 85, are hereby incorporated into this license. Entergy Operations, Inc. shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John T. Larkins, Director  
Project Directorate IV-1  
Division of Reactor Projects III, IV, and V  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: December 18, 1991

ATTACHMENT TO LICENSE AMENDMENT NO. 85

FACILITY OPERATING LICENSE NO. NPF-29

DOCKET NO. 50-416

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE PAGES

3/4 3-32

3/4 3-29

3/4 3-35a

INSERT PAGES

3/4 3-32

3/4 3-29

3/4 3-35a

TABLE 3.3.3-1 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION

TRIP FUNCTION	MINIMUM OPERABLE CHANNELS PER TRIP FUNCTION (a)	APPLICABLE OPERATIONAL CONDITIONS	ACTION
<b>C. DIVISION 3 TRIP SYSTEM</b>			
1. HPCS SYSTEM			
a. Reactor Vessel Water Level - Low, Low, Level 2	4 <sup>(b)</sup>	1, 2, 3, 4*, 5*	33
b. Drywell Pressure - High##	4 <sup>(b)</sup>	1, 2, 3	33
c. Reactor Vessel Water Level-High, Level 8	2 <sup>(c)</sup>	1, 2, 3, 4*, 5*	31
d. Condensate Storage Tank Level-Low	2 <sup>(d)</sup>	1, 2, 3, 4*, 5*	34
e. Suppression Pool Water Level-High	2 <sup>(d)</sup>	1, 2, 3, 4*, 5*	34
f. Manual Initiation##	1	1, 2, 3, 4*, 5*	32
<b>D. LOSS OF POWER</b>			
1. Division 1 and 2			
a. 4.16 kV Bus Undervoltage (Loss of Voltage)	4	1, 2, 3, 4**, 5**	30
b. Deleted			
c. 4.16 kV Bus Undervoltage (Degraded Voltage)	4	1, 2, 3, 4**, 5**	30
2. Division 3			
a. 4.16 kV Bus Undervoltage (Loss of Voltage)	4	1, 2, 3, 4**, 5**	30
b. 4.16 kV Bus Undervoltage (Degraded Voltage)	4	1, 2, 3, 4**, 5**	30

(a) A channel may be placed in an inoperable status for up to 2 hours during periods of required surveillance without placing the trip system in the tripped condition provided at least one other OPERABLE channel in the same trip system is monitoring that parameter.  
 (b) Also actuates the associated division diesel generator.  
 (c) Provides signal to close HPCS pump discharge valve only.  
 (d) Provides signal to HPCS pump suction valves only.  
 \* Applicable when the system is required to be OPERABLE per Specification 3.5.2 or 3.5.3.  
 \*\* Required when applicable ESF equipment is required to be OPERABLE.  
 # Not required to be OPERABLE when reactor steam dome pressure is less than or equal to 135 psig.  
 ## The injection function of Drywell Pressure - High and Manual Initiation are not required to be OPERABLE with indicated reactor vessel water level on the wide range instrument greater than Level 8 setpoint coincident with the reactor pressure less than 600 psig.

TABLE 3.3.3-1 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION

ACTION

- ACTION 30 - With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip Function requirement:
- a. With one channel inoperable, place the inoperable channel in the tripped condition within one hour or declare the associated system(s) inoperable.
  - b. With more than one channel inoperable, declare the associated system(s) inoperable.
- ACTION 31 - With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip Function requirement, declare the associated ADS trip system or ECCS inoperable.
- ACTION 32 - With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip Function requirement, restore the inoperable channel to OPERABLE status within 8 hours or declare the associated ADS trip system or ECCS inoperable.
- ACTION 33 - With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip Function requirement, place the inoperable channel(s) in the tripped condition within one hour or declare the HPCS system inoperable.
- ACTION 34 - With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip Function requirement, place at least one inoperable channel in the tripped condition within one hour or declare the HPCS system inoperable.
- ACTION 35 - With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip Function requirement, place the inoperable channel(s) in the tripped condition within one hour or declare the associated system(s) inoperable.



TABLE 3.3.3-2 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
D. <u>LOSS OF POWER</u>		
1. <u>Division 1 and 2</u>		
a. 4.16 kV Bus Undervoltage (Loss of Voltage)	1. 4.16 kV Basis 2912 volts	2912 +0, -291 volts
	2. 120 volt Basis 83.2 volts	83.2 +0, -8.3 volts
	3. Time Delay 0.5 seconds	0.5 +0.5, -0.1 seconds
b. Deleted		
c. 4.16 kV Bus Undervoltage (Degraded Voltage)	1. 4.16 kV Basis 3744 volts	3744 +93.6, -0 volts
	2. 120 volt Basis 107 volts	107 +2.7, -0 volts
	3. Time Delay 9.0 seconds	9.0 ± 0.5 seconds
2. <u>Division 3</u>		
a. 4.16 kV Bus Undervoltage (Loss of Voltage)	1. 4.16 kV Basis 3045 volts	3045 ± 61 volts
	2. 120 volt Basis 87 volts	87 ± 1.7 volts
	3. Time Delay 2.3 seconds	2.3 + 0.2, -0.3 seconds

\*See Bases Figure B 3/4 3-1.

TABLE 3.3.3-2 (Continued)

EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
D. <u>LOSS OF POWER (Continued)</u>		
2. <u>Division 3 (Continued)</u>		
b. 4.16 kV Bus Undervoltage (Degraded Voltage)	1. 4.16 kV Basis 3661 volts	3661 ± 102.5 volts
	2. 120 volt Basis 104.6 volts	104.6 ± 2.93 volts
	3. Time Delay 5 minutes/No LOCA 4 seconds/LOCA	5 minutes ± 30 seconds (4.0 ± 0.4 seconds)

TABLE 4.3.3.1-1 (Continued)  
 EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
<b>B. DIVISION 2 TRIP SYSTEM (Continued)</b>				
<b>2. AUTOMATIC DEPRESSURIZATION SYSTEM</b>				
<b>TRIP SYSTEM "B" #</b>				
a. Reactor Vessel Water Level - Low Low Low, Level 1	S	M	R(a)	1, 2, 3
b. Drywell Pressure-High	S	M	R(a)	1, 2, 3
c. ADS Initiation Timer	NA	M	Q	1, 2, 3
d. Reactor Vessel Water Level - Low, Level 3	S	M	R(a)	1, 2, 3
e. LPCI Pump B and C Discharge Pressure-High	S	M	R(a)	1, 2, 3
f. Manual Initiation	NA	R(b)	NA	1, 2, 3
g. ADS Bypass Timer (High Drywell Pressure)	NA	M	Q	1, 2, 3
h. Manual Inhibit	NA	R	NA	1, 2, 3
<b>C. DIVISION 3 TRIP SYSTEM</b>				
<b>1. HPCS SYSTEM</b>				
a. Reactor Vessel Water Level - Low Low, Level 2	S	M	R(a)	1, 2, 3, 4*, 5*
b. Drywell Pressure-High##	S	M	R(a)	1, 2, 3
c. Reactor Vessel Water Level-High, Level 8	S	M	R(a)	1, 2, 3, 4*, 5*
d. Condensate Storage Tank Level - Low	S	M	R(a)	1, 2, 3, 4*, 5*
e. Suppression Pool Water Level - High	S	M	R(a)	1, 2, 3, 4*, 5*
f. Manual Initiation##	NA	R(b)	NA	1, 2, 3, 4*, 5*

TABLE 4.3.3.1-1 (Continued)  
EMERGENCY CORE COOLING SYSTEM ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
D. <u>LOSS OF POWER</u>				
1. <u>Division 1 and 2</u>				
a. 4.16 kV Bus Undervoltage (Loss of Voltage)	NA	M(e)	R	1, 2, 3, 4**, 5**
b. Deleted				
c. 4.16 kV Bus Undervoltage (Degraded Voltage)	NA	M(e)	R	1, 2, 3, 4**, 5**
2. <u>Division 3</u>				
a. 4.16 kV Bus Undervoltage (Loss of Voltage)	NA	NA	R	1, 2, 3, 4**, 5**
b. 4.16 kV Bus Undervoltage (Degraded Voltage)	NA	NA	R	1, 2, 3, 4**, 5**



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 85 TO FACILITY OPERATING LICENSE NO. NPF-29

ENTERGY OPERATIONS, INC., ET AL.

GRAND GULF NUCLEAR STATION, UNIT 1

DOCKET NO. 50-416

1.0 INTRODUCTION

By letter dated August 15, 1991, the licensee, Entergy Operations, Inc., submitted a request for changes to the Grand Gulf Nuclear Station Unit 1, Technical Specifications (TS). The requested changes would remove requirements for the Balance of Plant (BOP) Load Shedding feature of the Load Shed and Sequencing System.

2.0 EVALUATION

The Class IE electrical distribution system at Grand Gulf Unit 1 has three means of voltage protection. The primary means detects complete loss of voltage and sheds loads when voltage remains degraded below 70% for 0.5 seconds or longer. The secondary means detects a sustained degraded voltage condition and sheds loads when voltage remains below 90% for 9 seconds or longer. These schemes are entirely within the bounds of the Class IE electrical system to ensure proper maintenance of the voltage condition on the safety buses under all design conditions. The Balance of Plant (BOP) Load Shedding feature is a third level of voltage protection whose successful operation is not a prerequisite for any safety function and is not credited in the system voltage calculations for Unit 1.

The BOP Load Shedding capability was designed to offer a possible improvement in the offsite voltage profile for the Class IE electrical buses under degraded voltage conditions with a loss of coolant accident (LOCA) signal present. As originally planned, Grand Gulf was to be a two unit facility. Under certain conditions, both units would share one transformer for their BOP loads. In this situation with both units at full power, it was expected that a LOCA on one unit would result in a degraded voltage profile for the BOP loads. To reduce the possibility of voltage degradation to 70% and to restore the voltage profile to greater than 90% within 9 seconds, the BOP Load Shedding feature was installed. If the feature were successful, a LOCA on one plant under these conditions would not result in loss of BOP loads at both units.

On September 16, 1990, and again on July 28, 1991, surveillance of the BOP Load Shedding circuitry resulted in non-valid shedding of the BOP loads causing reactor trips (via turbine trips) and subsequent challenges to safety systems. Due to the cancellation of Unit 2, the potential for the extreme system operating condition of degraded grid voltage during full-power operation of both units and the possibility of a LOCA at one unit resulting in loss of BOP load shedding at another unit no longer exists. Given the potential for challenges to safety systems and that the BOP Load Shedding function is not required for any safety function, the staff concludes that removal of the requirements for the BOP Load Shedding feature of the Load Shed and Sequencing System contained in the Technical Specifications does not involve a significant safety concern and will result in a net benefit to safety.

### 3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Mississippi State official was notified of the proposed issuance of the amendment. The State official had no comments.

### 4.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (56 FR 47237). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

### 5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: R. Twigg

Date: December 18, 1991