

May 5, 1993

Docket No. 50-416

Mr. C. Randy Hutchinson  
Vice President, Operations GGNS  
Entergy Operations, Inc.  
Post Office Box 756  
Port Gibson, Mississippi 39150

Dear Mr. Hutchinson:

SUBJECT: CORRECTION TO AMENDMENT NOS. 102 AND 104 TO FACILITY OPERATING  
LICENSE NO. NPF-29 - GRAND GULF NUCLEAR STATION, UNIT 1 (TAC  
NOS. M84500 AND M84323)

On December 3 and 23, 1992, the Commission issued Amendment Nos. 102 and 104 respectively to Facility Operating License No. NPF-29 for the Grand Gulf Nuclear Station, Unit 1. Amendment No. 102 removed the Technical Specification (TS) tables that include lists of components referenced in individual specifications, modified the requirements to remove all references to these tables, and modified the TS to state requirements in general terms that include the components listed in the tables removed from the TS in accordance with guidance received in Generic Letter (GL) 91-08. Amendment No. 104 modified the TS regarding the licensee's inservice inspection program to include a statement of compliance with the NRC staff's position on schedule, methods, personnel, and sample expansion given in GL 88-01 and revised leakage monitoring requirements.

TS pages 3/4 4-9, 3/4 4-10, and 3/4 6-3 contained several typographical errors and format errors. Correction is being made to these pages to fix these errors. The corresponding overleaf page to TS page 3/4 6-3 is also included to maintain document completeness. Please accept our apology for any inconvenience these errors may have caused you.

Sincerely,

ORIGINAL SIGNED BY:  
Paul W. O'Connor, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III/IV/V  
Office of Nuclear Reactor Regulation

9305140073 930505  
PDR ADOCK 05000416  
P PDR

Enclosures:  
Corrected TS pages

cc w/enclosures:  
See next page

DISTRIBUTION:

Docket File	NRC & LPDRs	PD4-1 r/f	P. Noonan
M. Virgilio	OPA(2G5)	J. Pellet	T. Gody, Jr. (13E21)
P. O'Connor (2)	OGC (15B18)	D. Hagan (3206)	D. Pickett (13H15)
G. Hill (2)	C. Grimes (11E22)	ACRS(10)	Wanda Jones (7103)
OC/LFMB (4503)	J. Roe (13A2)	D. Verrelli, RII	R. Hall (13E21)

OFC	LA:PD4-1 <i>pm</i>	PM:PD4-1 <i>pm</i>	D:PD4-1
NAME	PNoonan:pk	PO'Connor	JPellet <i>JP</i>
DATE	5/5/93	5/5/93	5/5/93
COPY	YES/NO	YES/NO	YES/NO

OFFICIAL RECORD COPY Document Name: GGAMDCOR.LTR

100187

CP-1

DF01



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

May 5, 1993

Docket No. 50-416

Mr. C. Randy Hutchinson  
Vice President, Operations GGNS  
Entergy Operations, Inc.  
Post Office Box 756  
Port Gibson, Mississippi 39150

Dear Mr. Hutchinson:

SUBJECT: CORRECTION TO AMENDMENT NOS. 102 AND 104 TO FACILITY OPERATING  
LICENSE NO. NPF-29 - GRAND GULF NUCLEAR STATION, UNIT 1 (TAC  
NOS. M84500 AND M84323)

On December 3 and 23, 1992, the Commission issued Amendment Nos. 102 and 104 respectively to Facility Operating License No. NPF-29 for the Grand Gulf Nuclear Station, Unit 1. Amendment No. 102 removed the Technical Specification (TS) tables that include lists of components referenced in individual specifications, modified the requirements to remove all references to these tables, and modified the TS to state requirements in general terms that include the components listed in the tables removed from the TS in accordance with guidance received in Generic Letter (GL) 91-08. Amendment No. 104 modified the TS regarding the licensee's inservice inspection program to include a statement of compliance with the NRC staff's position on schedule, methods, personnel, and sample expansion given in GL 88-01 and revised leakage monitoring requirements.

TS pages 3/4 4-9, 3/4 4-10, and 3/4 6-3 contained several typographical errors and format errors. Correction is being made to these pages to fix these errors. The corresponding overleaf page to TS page 3/4 6-3 is also included to maintain document completeness. Please accept our apology for any inconvenience these errors may have caused you.

Sincerely,

A handwritten signature in cursive script, reading "Paul W. O'Connor", is written above the typed name.

Paul W. O'Connor, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III/IV/V  
Office of Nuclear Reactor Regulation

Enclosures:  
Corrected TS pages

cc w/enclosures:  
See next page

Mr. C. Randy Hutchinson  
Entergy Operations, Inc.

Grand Gulf Nuclear Station

cc:

Mr. H. W. Keiser, President  
and Chief Executive Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, Mississippi 39286-1995

Robert B. McGehee, Esquire  
Wise, Carter, Child & Caraway  
P. O. Box 651  
Jackson, Mississippi 39205

Nicholas S. Reynolds, Esquire  
Winston & Strawn  
1400 L Street, N.W. - 12th Floor  
Washington, D.C. 20005-3502

Mr. Sam Mabry, Director  
Division of Solid Waste Management  
Mississippi Department of Natural  
Resources  
P. O. Box 10385  
Jackson, Mississippi 39209

President,  
Claiborne County Board of Supervisors  
Port Gibson, Mississippi 39150

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta St., Suite 2900  
Atlanta, Georgia 30323

Mr. Michael J. Meisner  
Director, Nuclear Licensing  
Entergy Operations, Inc.  
P. O. Box 756  
Port Gibson, Mississippi 39150

Mr. K. G. Hess  
Bechtel Power Corporation  
P. O. Box 2166  
Houston, Texas 77252-2166

Mr. Rudolph H. Bernhard  
Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Route 2, Box 399  
Port Gibson, Mississippi 39150

GGNS General Manager  
Entergy Operations, Inc.  
P. O. Box 756  
Port Gibson, Mississippi 39150

The Honorable William J. Guste, Jr.  
Attorney General  
Department of Justice  
State of Louisiana  
P. O. Box 94005  
Baton Rouge, Louisiana 70804-9005

Alton B. Cobb, M.D.  
State Health Officer  
State Board of Health  
P. O. Box 1700  
Jackson, Mississippi 39205

Office of the Governor  
State of Mississippi  
Jackson, Mississippi 39201

Mike Morre, Attorney General  
Frank Spencer, Asst. Attorney General  
State of Mississippi  
Post Office Box 22947  
Jackson, Mississippi 39225

Mr. John P. McGaha  
Vice President, Operations Support  
Entergy Operations, Inc.  
P.O. Box 31995  
Jackson, Mississippi 39286-1995

Mr. S. S. Chan  
Project Engineer  
Bechtel Power, Corporation  
P.O. Box 2166  
Houston, Texas 77252-2166

## REACTOR COOLANT SYSTEM

### OPERATIONAL LEAKAGE

#### LIMITING CONDITION FOR OPERATION

---

3.4.3.2 Reactor coolant system leakage shall be limited to:

- a. No PRESSURE BOUNDARY LEAKAGE.
- b. 5 gpm UNIDENTIFIED LEAKAGE.
- c. 30 gpm total leakage.
- d. 1 gpm leakage at a reactor coolant system pressure of  $1050 \pm 10$  psig from any reactor coolant system pressure isolation valve specified in Table 3.4.3.2-1.
- e. 2 gpm increase in UNIDENTIFIED LEAKAGE within any 24-hour period or less (applicable in OPERATIONAL CONDITION 1 only).

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2 and 3.

#### ACTION:

- a. With any PRESSURE BOUNDARY LEAKAGE, be in at least HOT SHUTDOWN within 12 hours and in COLD SHUTDOWN within the next 24 hours.
- b. With any reactor coolant system leakage greater than the limits in b and/or c, above, reduce the leakage rate to within the limits within 4 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- c. With any reactor coolant system pressure isolation valve leakage greater than the above limit, isolate the high pressure portion of the affected system from the low pressure portion within 4 hours by use of at least two closed manual or deactivated automatic valves, or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- d. With one or more high/low pressure interface valve pressure monitors and/or interlocks inoperable, restore the inoperable monitor(s) and/or interlock(s) to OPERABLE status within 30 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- e. With any reactor coolant system UNIDENTIFIED LEAKAGE increase greater than 2 gpm within any 24-hour period or less, identify the source of leakage increase as not service sensitive Type 304 or 316 austenitic stainless steel within 4 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

## REACTOR COOLANT SYSTEM

### SURVEILLANCE REQUIREMENTS

---

4.4.3.2.1 The reactor coolant system leakage shall be demonstrated to be within each of the above limits by:

- a. Monitoring the drywell atmospheric particulate and gaseous radioactivity at least once per 12 hours,
- b. Monitoring the drywell floor and equipment drain sump level and flow rate at least once per 12 hours,
- c. Monitoring the drywell air coolers condensate flow rate at least once per 12 hours, and
- d. Monitoring the reactor vessel head flange leak detection system at least once per 24 hours.

4.4.3.2.2 Each reactor coolant system pressure isolation valve specified in Table 3.4.3.2-1 shall be demonstrated OPERABLE by leak testing pursuant to Specification 4.0.5 and verifying the leakage of each valve to be within the specified limit:

- a. At least once per 18 months, and
- b. Prior to returning the valve to service following maintenance, repair or replacement work on the valve which could affect its leakage rate.

The provisions of Specification 4.0.4 are not applicable for entry into OPERATIONAL CONDITION 3.

4.4.3.2.3 The high/low pressure interface valves leakage pressure monitors shall be demonstrated OPERABLE with alarm and interlock setpoints per Table 3.4.3.2-2 and Table 3.4.3.2-3 by performance of a:

- a. CHANNEL FUNCTIONAL TEST at least once per 31 days, and
- b. CHANNEL CALIBRATION at least once per 18 months.

## CONTAINMENT SYSTEMS

### LIMITING CONDITION FOR OPERATION (Continued)

#### ACTION (Continued)

- b. The combined leakage rate for all penetrations and all valves<sup>#</sup> subject to Type B and C tests to less than or equal to  $0.60 L_a$ , and
- c. The leakage rate to less than 100 scf per hour for all four main steam lines through the isolation valves, and
- d. The combined leakage rate for all containment isolation valves in hydrostatically tested lines which penetrate the primary containment to less than or equal to 1 gpm times the total number of such valves,

prior to increasing reactor coolant system temperature above 200°F.

#### SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR 50 using the methods and provisions of ANSI N45.4 - 1972:

- a. Three Type A Overall Integrated Containment Leakage Rate tests shall be conducted at  $40 \pm 10$  month intervals\* during shutdown at  $P_a$ , 11.5 psig, during each 10-year service period.
- b. If any periodic Type A test fails to meet  $0.75 L_a$ , the test schedule for subsequent Type A tests shall be reviewed and approved by the Commission. If two consecutive Type A tests fail to meet  $0.75 L_a$ , a Type A test shall be performed at least every 18 months until two consecutive Type A tests meet  $0.75 L_a$ , at which time the above test schedule may be resumed.
- c. The accuracy of each Type A test shall be verified by a supplemental test which:
  - 1. Confirms the accuracy of the test by verifying that the containment leakage rate,  $L'_v$ , calculated in accordance with ANSI N-45.4-1972, Appendix C, is within 25 percent of the containment leakage rate,  $L_v$ , measured prior to the introduction of the superimposed leak.
  - 2. Has duration sufficient to establish accurately the change in leakage rate between the Type A test and the supplemental test.
  - 3. Requires the quantity of gas injected into the containment or bled from the containment during the supplemental test to be between  $0.75 L_a$  and  $1.25 L_a$ .

---

<sup>#</sup>Except for those that are hydrostatically leak tested.

\*The third Type A test within the first 10-year service period shall be conducted prior to startup following the sixth refueling outage. This is an exemption from 10 CFR Part 50, Appendix J Requirements.