Docket No. 50-416

April 13, 1992

Mr. William T. Cottle Vice President, Operations GGNS Entergy Operations, Inc. Post Office Box 756 Port Gibson, Mississippi 39150

Dear Mr. Cottle:

SUBJECT: ISSUANCE OF AMENDMENT NO. 95 TO FACILITY OPERATING LICENSE NO. NPF-29 - GRAND GULF NUCLEAR STATION, UNIT 1 (TAC NO. M76779)

The Nuclear Regulatory Commission has issued the enclosed Amendment No.95 to Facility Operating License No. NPF-29 for the Grand Gulf Nuclear Station, Unit 1. This amendment revises the Technical Specifications (TS) in response to your application dated May 4, 1990.

The amendment changes the indicated location of temperature elements that initiate the Reactor Water Cleanup System (RWCU) from the "RWCU Valve Nest Room" to the "RWCU Hx Room Valve Nest Area".

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly <u>Federal</u> <u>Register</u> notice.

Sincerely, ORIGINAL SIGNED BY: Paul W. O'Connor, Senior Project Manager Project Directorate IV-1 Division of Reactor Projects - III/IV/V Office of Nuclear Reactor Regulation

Enclosures: 1. Amendment No. 95 to NPF-29 2. Safety Evaluation

cc w/enclosures: See next page

9204210212 920413 PDR ADOCK 05000416

DISTRIBUTION

| Docket File | NRC/Local PDR |
|----------------|---------------------|
| M. Virgilio | OPA(MS2G5) |
| P. O'Connor(2) | D. Hagan(MS3206) |
| ACRS(10) | Wanda Jones (MS7103 |
| D. Verrelli | ARM/LFMB(MS4503) |
| | |

PD4-1 Reading J. Larkins G. Hill(4)) C. Grimes(MS11E22) R. Hall (MS13E21)

P. Noonan PD4-1 Plant File T. Gody, Jr.(MS13E21) D. Pickett (MS13H15) OGC(MS15B18)

| OFC | LA:PD4-1 | PM:PD4-1 | OGE GG | D:PD4-1 |
|------|-----------|-------------|-----------|----------|
| NAME | PNoonan T | PO'Connor | RBichnann | JLarkins |
| DATE | 3/17/92 | 3 / 11 / 92 | 3 1/9/92 | 4 17 192 |

OFFICIAL RECORD COPY Document Name: GG76779.AMD





UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

April 13, 1992

Docket No. 50-416

Mr. William T. Cottle Vice President, Operations GGNS Entergy Operations, Inc. Post Office Box 756 Port Gibson, Mississippi 39150

Dear Mr. Cottle:

SUBJECT: ISSUANCE OF AMENDMENT NO. 95 TO FACILITY OPERATING LICENSE NO. NPF-29 - GRAND GULF NUCLEAR STATION, UNIT 1 (TAC NO. M76779)

The Nuclear Regulatory Commission has issued the enclosed Amendment No.95 to Facility Operating License No. NPF-29 for the Grand Gulf Nuclear Station, Unit 1. This amendment revises the Technical Specifications (TS) in response to your application dated May 4, 1990.

The amendment changes the indicated location of temperature elements that initiate the Reactor Water Cleanup System (RWCU) from the "RWCU Valve Nest Room" to the "RWCU Hx Room Valve Nest Area".

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly <u>Federal Register</u> notice.

Sincerely,

Paul W. O'Connor, Senior Project Manager Project Directorate IV-1 Division of Reactor Projects - III/IV/V Office of Nuclear Reactor Regulation

Enclosures:

Amendment No. 95 to NPF-29
 Safety Evaluation

cc w/enclosures: See next page Mr. W. T. Cottle Grand Gulf Nuclear Station

cc:

Mr. Raubin L. Randels Project Engineer, Manager Bechtel Power, Corp. P. O. Box 2166 Houston, Texas 77252-2166

Robert B. McGehee, Esquire Wise, Carter, Child & Caraway P. O. Box 651 Jackson, Mississippi 39205

Nicholas S. Reynolds, Esquire Winston & Strawn 1400 L Street, N.W. - 12th Floor Washington, D.C. 20005-3502

Mr. Jack McMillan, Director
Division of Solid Waste Management
Mississippi Department of Natural
Resources
P. O. Box 10385
Jackson, Mississippi 39209

President, Claiborne County Board of Supervisors Port Gibson, Mississippi 39150

Regional Administrator, Region II U.S. Nuclear Regulatory Commission 101 Marietta St., Suite 2900 Atlanta, Georgia 30323

Mr. Michael J. Meisner Director, Nuclear Licensing Entergy Operations, Inc. P. O. Box 756 Port Gibson, Mississippi 39150

Mr. D. L. Brannen, Vice President Bechtel Power Corporation P. O. Box 2166 Houston, Texas 77252-2166

Mr. Johnny Mathis Senior Resident Inspector U.S. Nuclear Regulatory Commission Route 2, Box 399 Port Gibson, Mississippi 39150 Entergy Operations, Inc.

Mr. C. R. Hutchinson GGNS General Manager Entergy Operations, Inc. P. O. Box 756 Port Gibson, Mississippi 39150

The Honorable William J. Guste,Jr. Attorney General Department of Justice State of Louisiana P. O. Box 94005 Baton Rouge, Louisiana 70804-9005

Alton B. Cobb, M.D. State Health Officer State Board of Health P. O. Box 1700 Jackson, Mississippi 39205

Office of the Governor State of Mississippi Jackson, Mississippi 39201

Mike Morre, Attorney General Frank Spencer, Asst. Attorney General State of Mississippi Post Office Box 22947 Jackson, Mississippi 39225

Mr. John P. McGaha Vice President, Operations Support Entergy Operations, Inc. P.O. Box 31995 Jackson, Mississippi 39286-1995

Mr. Donald C. Hintz, Executive Vice President & Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286-1995



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

ENTERGY OPERATIONS, INC.

SYSTEM ENERGY RESOURCES, INC.

SOUTH MISSISSIPPI ELECTRIC POWER ASSOCIATION

MISSISSIPPI POWER AND LIGHT COMPANY

DOCKET NO. 50-416

GRAND GULF NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 95 License No. NPF-29

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Entergy Operations, Inc. (the licensee) dated May 4, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 2.C.(2) of Facility Operating License No. NPF-29 is hereby amended to read as follows:
 - (2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 95, are hereby incorporated into this license. Entergy Operations, Inc. shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

John T. Larkins, Director Project Directorate IV-1 Division of Reactor Projects - III/IV/V Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: April 13, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 95

FACILITY OPERATING LICENSE NO. NPF-29

DOCKET NO. 50-416

Replace the following page of the Appendix A Technical Specification with the attached page. The revised page is identified by amendment number and contains vertical lines indicating the area of change.

REMOVE PAGE

INSERT PAGE

3/4 3-17

3/4 3-17

TABLE 3.3.2-2 (Continued)

. •

•

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

| TRI | P FUN | CTION | TRIP SETPOINT | ALLOWABLE VALUE | | | |
|-----|------------|---|---|------------------------------------|--|--|--|
| 2. | MAI | MAIN STEAM LINE ISOLATION (Continued) | | | | | |
| | g. | Main Steam Line Tunnel ∆ Temp High | <pre>< 101°F**</pre> | < 104°F** | | | |
| | h. | Manual Initiation | NA | NA | | | |
| 3. | <u>SEC</u> | SECONDARY CONTAINMENT ISOLATION | | | | | |
| | a. | Reactor Vessel Water Level - Low Low, Level 2 | ≥ -41.6 inches* | > -43.8 inches | | | |
| | b. | Drywell Pressure - High | ≤ 1.23 psig | - < 1.43 psig | | | |
| | C. | Fuel Handling Area Ventilation Exhaust Radition - High High | <pre>< 3.6 mR/hr**</pre> | < 4.0 mR/hr** | | | |
| | d. | Fuel Handling Area Pool Sweep Exhaust Radiation - High High | < 30 mR/hr** | - < 35 mR/hr** | | | |
| | e. | Manual Initiation | NA | NA | | | |
| 4. | REA | REACTOR WATER CLEANUP SYSTEM ISOLATION | | | | | |
| | a. | ∆ Flow - High | <u><</u> 79 gpm | < 89** gpm | | | |
| | b. | ∆ Flow Timer | 45 seconds | < 57 seconds | | | |
| | c. | Equipment Area Temperature - High 1. RWCU Hx Room 2. RWCU Pump Rooms 3. RWCU Hx Room Valve Nest Area | <pre>< 120°F < 170°F < 135°F</pre> | - < 126°F < 176°F < 141°F | | | |
| | d. | Equipment Area ∆ Temp High 1. RWCU Hx Room 2. RWCU Pump Rooms 3. RWCU Hx Room Valve Nest Area | - < 65°F < 115°F < 70°F | < 66°F < 118°F < 73°F | | | |
| | e. | Reactor Vessel Water Level - Low Low, Level 2 | <pre>> -41.6 inches*</pre> | - ≥ -43.8 inches | | | |

3/4 3-17

Amendment No. 95



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 95 TO FACILITY OPERATING LICENSE NO. NPF-29

ENTERGY OPERATIONS, INC., ET AL.

GRAND GULF NUCLEAR STATION, UNIT 1

DOCKET NO. 50-416

1.0 INTRODUCTION

By letter dated May 4, 1990, Entergy Operations, Inc., the licensee for Grand Gulf Nuclear Station, Unit 1, proposed to amend Technical Specification (TS) Table 3/4.3.2-2 to clarify the location of the area temperature and delta temperature isolation actuation instrumentation for the Reactor Water Cleanup (RWCU) system. In particular, the TS is being revised to indicate the location of the temperature isolation instrumentation from "RWCU Valve Nest Room" to "RWCU Hx Valve Nest Area" in Table 3.3.2.2 Sections 4.C.3 and 4.D.3.

In a letter dated January 16, 1990, the licensee committed to the above change in response to a Quality Deficiency Report (QDR) 239-89 dated July 18, 1989, which identified discrepancies between the pipe break assumptions and the actual plant instrumentation used to detect and isolate RWCU pipe breaks. In particular, the QDR identified that (1) the RWCU line break analysis relied on an isolation function time consistent with temperature instrument design (isolation time 60 seconds) for breaks detectable only by the flow instrumentation (isolation time 100 seconds) in those portions of the RWCU piping containing cold water (i.e., less than 120°F), and that (2) the RWCU Valve Nest Room did not contain area temperature and area delta temperature as listed in Table 3.3.2-2.

In its submittal, the licensee has provided the results of a new break analysis for those portions of the RWCU system which are dependent on the delta flow instrumentation to justify the change.

2.0 EVALUATION

204210221 92041

PDR

ADOCK 05000416

The licensee indicated that TS requirements for the RWCU isolation instrumentation described in TS Table 3.3.2-2 Section 4 addresses leak detection instrumentation serving both "hot" process and "cold" process piping and components. The requirements on the RWCU "hot" process piping and components are both delta flow instrumentation and temperature (equipment area and equipment area delta) instrumentation. The requirement on the RWCU "cold" (i.e., less than 120°F) process piping and components is delta flow instrumentation, only. The high area temperature and high area delta temperature isolation instrumentation for these areas are generally not effective for detection of leaks and were deleted from the TS in 1984 as part of TS Amendment No. 13 to prevent spurious operations. The licensee has indicated that in response to the QDR, the pipe break design analyses for those postulated "cold" RWCU break locations which are dependent on only the delta flow instrumentation for detection and automatic isolation were revised for isolation function time from 60 seconds consistent with temperature instrumentation to 100 seconds, consistent with delta flow instrumentation. The larger time delay associated with delta flow trip logic was not accounted for in the existing analysis. The new line break analysis was performed for the following areas:

- a. RWCU pipe chase inside the containment
- b. RWCU Valve Nest Room
- c. RWCU Holding Pump Room
- d. RWCU filter/demineralizer rooms A and B.

The licensee stated that from the results of the new RWCU line break analysis for the identified areas, the new isolation function time based on only the delta flow trip was determined to be acceptable since the higher resulting blowdown parameters are still well within existing design limits. This is based on more accurate assessment of the increased blowdown parameters affecting systems, structures, and components needed to mitigate the postulated RWCU line breaks and perform the required safe shutdown functions. This assessment included the dependent consequences such as room pressurization transients, environmental qualification profiles, etc. for not only the RWCU areas immediately affected but also for the adjoining areas up to and including the containment structure. The impact of flooding was found to be negligible. The offsite doses were also found to be much less than those already evaluated for the main steam line break outside containment event. The reactor vessel water level response to the postulated RWCU piping failures was evaluated as a mild event in comparison to the more limiting pipe breaks.

The licensee indicated that the new RWCU line break analysis does not affect any of the associated TS instrument operability requirements or setpoint values nor are any new TS requirements being imposed for the delta flow or "hot pipe" temperature instruments. The evaluation has shown that the line break detection and isolation functions for piping failures in the "RWCU Valve Nest Room" which contain only cold piping are adequately performed by the delta flow instrumentation and are consistent with other "cold" RWCU process component areas. Therefore, additional TS requirements for temperature monitoring the "RWCU Valve Nest Room" are not required. The temperature elements specified in the TS as being in the "RWCU Valve Nest Room" are actually installed in the "RWCU Hx Room Valve Nest Area". This discrepancy does not affect the analysis performed for the "RWCU Hx Room" and that the temperature setpoints listed in TS are appropriate for the as-built configuration.

The staff has reviewed the licensee submittal as discussed above and finds the proposed TS change acceptable since reliance on the high delta flow instrumentation for detecting and isolating RWCU piping failures in the "cold" RWCU equipment rooms is supported by new analysis and meet all design functions. The proposed change does not affect plant safety as the new parameter values remain enveloped by the existing design.

Based on the above evaluation, the staff concludes that the licensee proposed change to TS Table 3.3.2-2 Sections 4.C.3 and 4.D.3 to revise the location of the RWCU area temperature and delta temperature isolation instrumentation from "RWCU Valve Nest Room" to "RWCU Hx Valve Nest Area" and the isolation function time based on the delta flow instrumentation for isolation are acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Mississippi State official was notified of the proposed issuance of the amendment. The State official had no comment.

4.0 <u>ENVIRONMENTAL CONSIDERATION</u>

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluent that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (56 FR 47236). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: R. Goel

Date: April 13, 1992