

Docket No. 50-416

March 10, 1992

Mr. William T. Cottle
Vice President, Operations GGNS
Entergy Operations, Inc.
Post Office Box 756
Port Gibson, Mississippi 39150

Dear Mr. Cottle:

SUBJECT: CORRECTION TO AMENDMENT NO. 91 TO FACILITY OPERATING LICENSE
NPF-29 - GRAND GULF NUCLEAR STATION, UNIT 1 (TAC NO. M81916)

On February 25, 1992, the Commission issued Amendment No. 91 to Facility Operating License No. NPF-29 to Grand Gulf Nuclear Station, Unit 1. The amendment deleted a Technical Specification (TS) requirement to perform a daily surveillance verifying the measured recirculation system drive flow to be less than or equal to the established drive flow for a given flow control valve position.

Correction is being made to delete footnote "h" only from TS page 3/4 3-8. The corresponding overleaf page is also provided to maintain document completeness. Please accept our apologies for any inconvenience this may have caused you.

Sincerely,

ORIGINAL SIGNED BY

Paul W. O'Connor, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
TS pages 3/4 3-8

cc w/enclosure:
See next page

DISTRIBUTION

Docket File	NRC/Local PDR	PD4-1 Reading	P. Noonan
M. Virgilio	OPA(MS2G5)	J. Larkins	PD4-1 Plant File
P. O'Connor(2)	OGC	D. Hagan(MS3206)	T. Gody, Jr.(MS13E21)
G. Hill(4)	Wanda Jones	C. Grimes(MS11E22)	D. Pickett (MS13H15)
ACRS(10)	OC/LFMB(MS4503)	D. Verrelli	R. Hall (MS13E21)

OFC	LA:PD4-1 <i>John</i>	PM:PD4-1 <i>Paul</i>	D:PD4-1
NAME	PNoonan	PO'Connor	JLarkins
DATE	3/9/92	3/9/92	3/9/92

OFFICIAL RECORD COPY Document Name:

9203130153 920310
PDR ADOCK 05000416
P PDR

DO NOT WRITE IN THESE SPACES
DO NOT WRITE IN THESE SPACES

DF01



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 10, 1992

Docket No. 50-416

Mr. William T. Cottle
Vice President, Operations GGNS
Entergy Operations, Inc.
Post Office Box 756
Port Gibson, Mississippi 39150

Dear Mr. Cottle:

SUBJECT: CORRECTION TO AMENDMENT NO. 91 TO FACILITY OPERATING LICENSE
NPF-29 - GRAND GULF NUCLEAR STATION, UNIT 1 (TAC NO. M81916)

On February 25, 1992, the Commission issued Amendment No. 91 to Facility Operating License No. NPF-29 to Grand Gulf Nuclear Station, Unit 1. The amendment deleted a Technical Specification (TS) requirement to perform a daily surveillance verifying the measured recirculation system drive flow to be less than or equal to the established drive flow for a given flow control valve position.

Correction is being made to delete footnote "h" only from TS page 3/4 3-8. The corresponding overleaf page is also provided to maintain document completeness. Please accept our apologies for any inconvenience this may have caused you.

Sincerely,

A handwritten signature in cursive script that reads "Paul W. O'Connor".

Paul W. O'Connor, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
TS pages 3/4 3-8

cc w/enclosure:
See next page

Mr. W. T. Cottle
Grand Gulf Nuclear Station

Entergy Operations, Inc.

cc:

Mr. Raubin L. Randels
Project Engineer, Manager
Bechtel Power, Corp.
P. O. Box 2166
Houston, Texas 77252-2166

Mr. C. R. Hutchinson
GGNS General Manager
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, Mississippi 39150

Robert B. McGehee, Esquire
Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, Mississippi 39205

The Honorable William J. Guste, Jr.
Attorney General
Department of Justice
State of Louisiana
P. O. Box 94005
Baton Rouge, Louisiana 70804-9005

Nicholas S. Reynolds, Esquire
Winston & Strawn
1400 L Street, N.W. - 12th Floor
Washington, D.C. 20005-3502

Alton B. Cobb, M.D.
State Health Officer
State Board of Health
P. O. Box 1700
Jackson, Mississippi 39205

Mr. Jack McMillan, Director
Division of Solid Waste Management
Mississippi Department of Natural
Resources
P. O. Box 10385
Jackson, Mississippi 39209

Office of the Governor
State of Mississippi
Jackson, Mississippi 39201

President,
Claiborne County Board of Supervisors
Port Gibson, Mississippi 39150

Mike Morre, Attorney General
Frank Spencer, Asst. Attorney General
State of Mississippi
Post Office Box 22947
Jackson, Mississippi 39225

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., Suite 2900
Atlanta, Georgia 30323

Mr. John P. McGaha
Vice President, Operations Support
Entergy Operations, Inc.
P.O. Box 31995
Jackson, Mississippi 39286-1995

Mr. Michael J. Meisner
Director, Nuclear Licensing
Entergy Operations, Inc.
P. O. Box 756
Port Gibson, Mississippi 39150

Mr. Donald C. Hintz, Executive Vice
President & Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286-1995

Mr. C. B. Hogg, Project Manager
Bechtel Power Corporation
P. O. Box 2166
Houston, Texas 77252-2166

Mr. Johnny Mathis
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Route 2, Box 399
Port Gibson, Mississippi 39150

TABLE 4.3.1.1-1

REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION^(a)</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
1. Intermediate Range Monitors:				
a. Neutron Flux - High	S/U,S, ^(b) S	S/U, W W	R R	2 3, 4, 5
b. Inoperative	NA	W	NA	2, 3, 4, 5
2. Average Power Range Monitor: ^(f)				
a. Neutron Flux - High, Setdown	S/U,S, ^(b) S	S/U, W W	SA SA	2 3, 5
b. Flow Biased Simulated Thermal Power - High	S	Q	W ^{(d)(e)} , SA, R ⁽ⁱ⁾	1
c. Neutron Flux - High	S	Q	W ^(d) , SA	1
d. Inoperative	NA	Q	NA	1, 2, 3, 5
3. Reactor Vessel Steam Dome Pressure - High	S	Q	R ^(g)	1, 2 ^(j)
4. Reactor Vessel Water Level - Low, Level 3	S	Q	R ^(g)	1, 2
5. Reactor Vessel Water Level - High, Level 8	S	Q	R ^(g)	1
6. Main Steam Line Isolation Valve - Closure	NA	Q	R	1
7. Main Steam Line Radiation - High	S	Q	R	1, 2 ^(j)
8. Drywell Pressure - High	S	Q	R ^(g)	1, 2 ^(k)

TABLE 4.3.1.1-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
9. Scram Discharge Volume Water Level - High				
a. Transmitter/Trip Unit	S	Q	R(g)	1, 2, 5 ⁽¹⁾
b. Float Switch	NA	Q	R	1, 2, 5 ⁽¹⁾
10. Turbine Stop Valve - Closure	S	Q	R(g)	1
11. Turbine Control Valve Fast Closure Valve Trip System Oil Pressure - Low	S	Q	R(g)	1
12. Reactor Mode Switch Shutdown Position	NA	R	NA	1, 2, 3, 4, 5
13. Manual Scram	NA	W	NA	1, 2, 3, 4, 5

- (a) Neutron detectors may be excluded from CHANNEL CALIBRATION.
- (b) The IRM and SRM channels shall be determined to overlap for at least 1/2 decade during each startup after entering OPERATIONAL CONDITION 2 and the IRM and APRM channels shall be determined to overlap for at least 1/2 decade during each controlled shutdown, if not performed within the previous 7 days.
- (c) [DELETED]
- (d) This calibration shall consist of the adjustment of the APRM channel to conform to the power values calculated by a heat balance during OPERATIONAL CONDITION 1 when THERMAL POWER > 25% of RATED THERMAL POWER. Adjust the APRM channel if the absolute difference is greater than 2% of RATED THERMAL POWER.
- (e) This calibration shall consist of the adjustment of the APRM flow biased channel to conform to a calibrated flow signal.
- (f) The LPRMs shall be calibrated at least once per 1000 MWD/T using the TIP system.
- (g) Calibrate trip unit at least once per 92 days.
- (h) Deleted.
- (i) This calibration shall consist of verifying the 6 ± 1 second simulated thermal power time constant.
- (j) Not applicable when the reactor pressure vessel head is unbolted or removed per Specification 3.10.1.
- (k) Not applicable when DRYWELL INTEGRITY is not required.
- (l) Applicable with any control rod withdrawn. Not applicable to control rods removed per Specification 3.9.10.1 or 3.9.10.2.

GRAND GULF-UNIT 1

3/4 3-8

Amendment No. 67, 91