

873-9 ✓



COMMONWEALTH OF KENTUCKY
DEPARTMENT OF HEALTH
620 SOUTH THIRD STREET
LOUISVILLE 2, KENTUCKY

RUSSELL E. TEAGUE, M.D., M.P.H.
COMMISSIONER OF HEALTH

June 22, 1959

Mr. Harold L. Price, Director
Division of Licensing and Regulation
U. S. Atomic Energy Commission
Washington 25, D. C.

Dear Mr. Price:

I am in receipt of your notice of proposed rule making as published in the Federal Register on May 23, 1959. I have noted the contents with interest and would like, therefore, to make the following comment:

It is noted in paragraph "C", that it was expressly desirable to avoid locating a power or test reactor within several miles upwind from centers of population. In like manner, if a site is considered on a stream then, if at all possible, the power or test reactor should be located on the downstream side of centers of population so as to avoid any possible hazard to the water supply intake of such centers of population.

This is my suggestion at this time.

Sincerely yours,

Russell E. Teague
Russell E. Teague, M.D.
Commissioner of Health

copy to OGC + PDR 6/25/59 - 722

RET/bh

*A1114
P450 Comment*