

Docket No. 50-368

Mr. William Cavanaugh, III  
 Vice President, Generation  
 and Construction  
 Arkansas Power & Light Company  
 P. O. Box 551  
 Little Rock, Arkansas 72203

Distribution:

Docket  
 NRC PDR  
 Local PDR  
 ORB#3 Reading  
 NRR Reading  
 H. R. Denton  
 E. G. Case  
 R. Hartfield, MPA  
 G. Bennington, MPA  
 D. Eisenhut  
 R. Purple  
 T. Novak  
 R. Tedesco  
 G. Lainas  
 J. Murray

J. Roe  
 PMKreutzer (3)  
 M. Williams  
 OELD  
 OI&E (3)  
 B. Jones (4)  
 ACRS (16)  
 OPA (Clare Miles) *cel*  
 NSIC  
 TERA  
 Secretariat (SECY)  
 R. Diggs  
 J. Heltemes, AEOD  
 Project Manager  
 RAClark

Dear Mr. Cavanaugh:

SUBJECT: ORDER FOR MODIFICATION OF LICENSE CONCERNING ENVIRONMENTAL  
 QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

Ref. (a) Commission Memorandum and Order of May 23, 1980 (80-CLI-21)  
 Ref. (b) Inspection and Enforcement Bulletin Supplement No. 2 to  
 IEB-79-01B, September 30, 1980.

This letter transmits an Order for Modification of License which changes  
 the Technical Specifications for Arkansas Nuclear One - Unit 2. This  
 change is a result of Ref. (a) which required the staff to codify the  
 documentation requirements for the qualification of safety-related  
 electrical equipment. A copy of the Order is being filed with the Office  
 of the Federal Register for publication.

The deadline of November 1, 1980 for submittal of the qualification infor-  
 mation is not changed by this Order. Some additional information regarding  
 the file is contained in Ref. (b). Questions regarding this Order should  
 be directed through your Project Manager.

Sincerely,

Original Signed By

Robert A. Clark, Chief  
 Operating Reactors Branch #3  
 Division of Licensing

Enclosure:  
 Order

cc w/enclosure: See Next Page

RECEIVED DISTRIBUTION SERVICES UNIT  
 NOV 10 AM 10 00  
 US NRC DISTRIBUTION SERVICES BRANCH

8011110327

*60*

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL	ORB#3:DL	D:DL
SURNAME	PMKreutzer/JL	PM <i>[Signature]</i>	RAClark	M Williams	D Eisenhut
DATE	10/24/80	10/24/80	10/24/80	10/24/80	10/24/80



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

Docket 50-368

October 24, 1980

Docket No. 50-368

Mr. William Cavanaugh, III  
Vice President, Generation  
and Construction  
Arkansas Power & Light Company  
P. O. Box 551  
Little Rock, Arkansas 72203

Dear Mr. Cavanaugh:

SUBJECT: ORDER FOR MODIFICATION OF LICENSE CONCERNING ENVIRONMENTAL  
QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

Ref. (a) Commission Memorandum and Order of May 23, 1980 (80-CLI-21)  
Ref. (b) Inspection and Enforcement Bulletin Supplement No. 2 to  
IEB-79-01B, September 30, 1980.

This letter transmits an Order for Modification of License which changes the Technical Specifications for Arkansas Nuclear One - Unit 2. This change is a result of Ref. (a) which required the staff to codify the documentation requirements for the qualification of safety-related electrical equipment. A copy of the Order is being filed with the Office of the Federal Register for publication.

The deadline of November 1, 1980 for submittal of the qualification information is not changed by this Order. Some additional information regarding the file is contained in Ref. (b). Questions regarding this Order should be directed through your Project Manager.

Sincerely, \*

A handwritten signature in black ink, appearing to read "Robert A. Clark".

Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing

Enclosure:  
Order

cc w/enclosure: See Next Page

October 24, 1980

cc:

Mr. David C. Trimble  
Manager, Licensing  
Arkansas Power & Light Company  
P. O. Box 551  
Little Rock, Arkansas 72203

Mr. James P. O'Hanlon  
General Manager  
Arkansas Nuclear One  
P. O. Box 608  
Russellville, Arkansas 72801

Mr. William Johnson  
U. S. Nuclear Regulatory Commission  
P. O. Box 2090  
Russellville, Arkansas 72801

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
Suite 420, 7735 Old Georgetown Road  
Bethesda, Maryland 20014

Nick Reynolds  
c/o DeBevoise & Liberman  
1200 Seventeenth St. N.W.  
Washington, D.C. 20036

Arkansas Polytechnic College  
Russellville, Arkansas 72801

Honorable Ermil Grant  
Acting County Judge of Pope County  
Pope County Courthouse  
Russellville, Arkansas 72801

Mr. Paul F. Levy, Director  
Arkansas Department of Energy  
3000 Kavanaugh  
Little Rock, Arkansas 72205

Mr. Charles B. Brinkman  
Manager - Washington Nuclear  
Operations  
C-E Power Systems  
4853 Cordell Avenue, Suite A-1  
Bethesda, Maryland 20014

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection Agency  
Region VI Office  
ATTN: EIS COORDINATOR  
1201 Elm Street  
First International Building  
Dallas, Texas 75270

Director, Bureau of Environmental  
Health Services  
4815 West Markham Street  
Little Rock, Arkansas 72201

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of    )  
  )  
ARKANSAS POWER AND LIGHT COMPANY                    )  
(Arkansas Nuclear One - Unit 2)                        )  
  )  
  )

Docket No. 50-368

ORDER FOR MODIFICATION OF LICENSE

I.

Arkansas Power and Light Company (licensee) is the holder of License No. NPF-6, which authorizes the operation of the Arkansas Nuclear One - Unit 2 nuclear power plant at steady state reactor power levels not in excess of 2815 megawatts thermal (rated power). The facility consists of a Pressurized Water Reactor located at the licensee's site in Pope County, Arkansas.

II.

On November 4, 1977, the Union of Concerned Scientists (UCS) filed with the Commission a "Petition for Emergency and Remedial Relief." The petition sought action in two areas: fire protection for electrical cables, and environmental qualification of electrical components. By Memorandum and Order dated April 13, 1978 (7 NRC 400), the Commission denied certain aspects of the petition and, with respect to other aspects, ordered the NRC staff to take several related actions. UCS filed a Petition for Reconsideration on May 2, 1978. By Memorandum and Order, dated May 23, 1980, the Commission reaffirmed its April 13, 1978 decision regarding the possible shutdown of operating reactors. However, the Commission's May 23, 1980 decision directed licensees and the NRC staff to undertake certain actions.

With respect to environmental qualification of safety-related electrical equipment, the Commission determined that the provisions of the two staff documents - the Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines) and NUREG-0588, "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," December 1979 (copies attached) "form the requirements which licensees and applicants must meet in order to satisfy those aspects of 10 CFR Part 50, Appendix A General Design Criterion (GDC-4), which relate to environmental qualifications of safety-related electrical equipment." The Commission directed, for replacement parts in operating plants, "unless there are sound reasons to the contrary, the 1974 standard in NUREG-0588 will apply." The Commission also directed the staff to complete its review of the information sought from licensees by Bulletin 79-01B<sup>1</sup> and to complete its review of environmental qualification of safety-related electrical equipment in all operating plants, including the publication of Safety Evaluation Reports, by February 1, 1981. The Commission imposed a deadline that, "by no later than June 30, 1982 all safety-related electrical equipment in all operating plants shall be qualified to the DOR Guidelines or NUREG-0588."

---

<sup>1</sup> Bulletin 79-01B was not sent to licensees for plants under review as part of the staff's Systematic Evaluation Program. The information sought by Bulletin 79-01B was requested from these licensees by a series of letters and meetings during the months of February and March, 1980.

The Commission requested the staff to, "keep the Commission and the public apprised of any further findings of incomplete environmental qualification of safety-related electrical equipment, along with corrective actions taken or planned," and requested the staff to provide bi-monthly progress reports to the Commission.

The Commission further directed that, "In order to leave no room for doubt on this issue, the staff is to prepare additional Technical Specifications for all operating plants which codify the documentation requirement paragraph of the Guidelines (paragraph 8.0)." The staff was directed to add these documentation requirements to each license after they were approved by the Commission.

The Commission also pointed out that the various deadlines imposed in its Order, "do not excuse a licensee from the obligation to modify or replace inadequate equipment promptly."

### III.

The Commission has approved the Technical Specification provisions set forth in Section IV below which specify documentation requirements and which specifically impose on the licensee the requirement of the Commission's May 23, 1980 Memorandum and Order that by no later than June 30, 1982 all safety-related electrical equipment shall be qualified to the DOR Guidelines or NUREG-0588.

The information developed during the Commission review of the UCS Petition emphasizes the importance of prompt completion of the upgrading of

environmental qualification of safety-related electrical equipment to conform to the DOR Guidelines or NUREG-0588 and of adequate documentation of equipment qualifications. The deadlines set forth in the Commission's Memorandum and Order dated May 23, 1980, assure that such upgrading will be accomplished promptly. In order to assure prompt completion of necessary qualification work or replacement of unqualified components, if necessary, in conformance with the requirements of the Commission's Memorandum and Order dated May 23, 1980, and to provide complete and adequate documentation as promptly as possible, such upgrading and documentation work must commence immediately. Therefore, I have concluded that the public health, safety and interest require this Order for Modification of License to be effective immediately.

IV.

Accordingly, pursuant to the Atomic Energy Act of 1954, as amended, and the Commission's Rules and Regulations in 10 CFR Parts 2 and 50, IT IS ORDERED THAT EFFECTIVE IMMEDIATELY Facility Operating License No. NPF-6 is hereby amended to add the following provisions to the Appendix A Technical Specifications.

- (a) "By no later than June 30, 1982, all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588, "Interim Staff Position on Environmental

Qualification of Safety-Related Electrical Equipment," December 1979. Copies of these documents are attached to Order for Modification of License No. NPF-6 dated October 24, 1980.

- (b) "By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified."

To effectuate the foregoing, appropriate pages for incorporation into the Technical Specifications are attached to this Order.

V.

The licensee or any person whose interest may be affected by this Order may request a hearing within 20 days of the date of publication of this Order in the Federal Register. Any request for a hearing will not stay the effective date of this Order. Any request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555. A copy of the request should also be sent to the Executive Legal Director, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, and to Nick Reynolds, Esq., DeBevoise & Liberman, 1200 Seventeenth Street, N. W., Washington, D. C. 20036, attorney for the licensee.




If a hearing is held concerning this Order, the issues to be considered at the hearing shall be:

- a. whether the licensee should be required to have the environmental qualification records referred to in Section IV, above, available at a central location by no later than December 1, 1980; and
- b. whether all safety-related electrical equipment should be qualified as required in Section IV, above, by no later than June 30, 1982.

Operation of the facility on terms consistent with this Order is not stayed by the pendency of any proceedings on the Order.

FOR THE NUCLEAR REGULATORY COMMISSION

  
\_\_\_\_\_  
Darrell G. Fisenhut, Director  
Division of Licensing  
Office of Nuclear Reactor Regulation

Effective Date: October 24, 1980  
Bethesda, Maryland

Attachments:

1. Technical Specification Pages
2. Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors
3. NUREG-0588, Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment.

## ADMINISTRATIVE CONTROLS

### 6.10 RECORD RETENTION

In addition to the applicable record retention requirements of Title 10, Code of Federal Regulations, the following records shall be retained for at least the minimum period indicated.

6.10.1 The following records shall be retained for at least five years:

- a. Records and logs of unit operation covering time interval at each power level.
- b. Records and logs of principal maintenance activities, inspections, repair and replacement of principal items of equipment related to nuclear safety.
- c. ALL REPORTABLE OCCURRENCES submitted to the Commission.
- d. Records of surveillance activities, inspections and calibrations required by these Technical Specifications.
- e. Records of changes made to the procedures required by Specification 6.8.1.
- f. Records of radioactive shipments.
- g. Records of sealed source and fission detector leak tests and results.
- h. Records of annual physical inventory of all sealed source material of record.

6.10.2 The following records shall be retained for the duration of the Facility Operating License:

- a. Records and drawing changes reflecting unit design modifications made to systems and equipment described in the Final Safety Analysis Report.
- b. Records of new and irradiated fuel inventory, fuel transfers and assembly burnup histories.
- c. Records of radiation exposure for all individuals entering radiation control areas.
- d. Records of gaseous and liquid radioactive material released to the environs.
- e. Records of transient of operational cycles for those unit components identified in Table 5.7-1.

## ADMINISTRATIVE CONTROLS

- f. Records of reactor tests and experiments.
- g. Records of training and qualification for current members of the unit staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by the QA Manual.
- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the PCS and the SCR.
- l. Records of changes to the Core Protection Calculator System (CPCS) SOFTWARE. Changes to the CPCS SOFTWARE shall be made in accordance with methods approved by the NRC. These records shall include the following:
  - 1. Purpose of change.
  - 2. Detailed description of change including algorithms, changes to the assembly listings, checksums and disk identification numbers.
  - 3. Summary of validation test results.
- m. Records of Environmental Qualification which are covered under the provisions of paragraph 6.12.

### 6.11 RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

### 6.12 ENVIRONMENTAL QUALIFICATION

6.12.1 By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of License NPF-6 dated October 24, 1980.

## ADMINISTRATIVE CONTROLS

6.12.2 By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.