



6. The wind will not blow in a constant direction for more than a few hours at a time in most instances, that is, it has a tendency to shift direction. Since the doses are calculated on the basis of constant direction, this will produce a reduction in dose for the usual circumstance, although most sites have a finite probability of constant wind direction for as long as 2 or more days. The value of the reduction factor for this depends on the time assumed for the pressure to decay, and will vary from 2 to 50.
7. Another phenomena is the small variations in wind direction which happen in a few minutes' time. This is called wind meander, and makes the actual dose about a factor of 2 less than the calculated centerline dose used in the criteria.
8. Due to the much more rapid diffusion which takes place during lapse conditions, the dose during these conditions is insignificant compared to that which occurs during inversions. In general, inversions occur from 30% to 60% of the time at various locations, so this represents a reduction by a factor of 2 or 3.
9. Even though the particles which leak out of the containment vessel are very small, they will still have a tendency to fall out of the plume and deposit on the ground. This deposition will reduce the air concentration by a factor of 2 or 3, which will decrease the evacuation distance accordingly.
10. Reactors which are cooled by sodium will tend to release much less iodine, because it will react with the coolant and not be released. There is also less probability that such reactors will produce much pressure in the containment vessel, especially if an inert atmosphere is used to eliminate the fire hazard.
11. Organic-cooled reactors have a lower probability of producing a pressure in the containment vessel in case of a large accident. Hence, there may not even be a driving pressure to cause the activity to leak out from these reactors.
12. Some reactors may have a type of containment which holds in the fission products better than is possible with a conventional steel vessel. For example, the vapor suppression system filters the fission products through a pool of water which prevents them from becoming airborne. In addition, the water also condenses the steam, which removes the driving force causing leakage in a short time. These two factors reduce the

dose to the environs by a factor of 10 to 100.

(continued)

OFFICE ▶					
SURNAME ▶					
DATE ▶					

13. Another improvement in containment is the use of two concentric vessels, with the outer one vented to a high stack, so that all leakage from the inner, primary containment is channeled up the stack. In this way, one has an elevated release, rather than the ground-level type generally associated with other types of containment. This reduces the theoretical maximum ground concentration by a factor of 2.7, eliminates the close-in dose problem, and moves the maximum cut to such a distance that a number of other factors should be considered, such as those in items 5, 6, and 7 above.

OFFICE ▶	S-EB:DL&R					
SURNAME ▶	<i>RJA</i> RWaterfield:alp					
DATE ▶	10/11/60					