




FPL



**Florida Power & Light Company
St. Lucie Nuclear Plant
UNIT 2**

**STEAM GENERATOR OPERATIONAL
ASSESSMENT FOR CYCLE 13**

**PRESENTED TO NRR
MAY 2, 2002**

ENCLOSURE 2



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

AGENDA

Opening Remarks	Raj Kundalkar, VP Engineering
S/G Information Inspection Preparations Inspection Evolution	Gary Boyers, S/G Specialist
Operational Assessment	Brian Woodman, APTECH Eng.
Closing Remarks	Raj Kundalkar, VP Engineering

1



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

OPENING REMARKS - Raj Kundalkar, VP Engineering

Meeting Objective

- Review S/G Operational Assessment for Cycle 13
- Demonstrate Inspection Results Support Full Cycle Operation

FPL Philosophy

- Committed to Safe Operation
- Implementation of NEI 97-06, S/G Program Guidelines
- Incorporate Industry Experience
- Conservative & Proactive Approach to S/G Management

2



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

EOC 12 S/G Examinations

- 100% Bobbin Inspection Augmented by Extensive Plus Point Probe Inspections
- Preventatively Plugged the Most Susceptible Tubes with Dings

Post-Outage Work and Operational Assessment

- Historical Data Review Shows No Step Change in Degradation
- Multi-Cycle Model Successfully Benchmarks PSL-2 Experience
- Model Results Support Full Cycle Operation


3



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

S/G Design

- CE Model 3410
- 8411 Tubes / SG
- ~16.8 EFPY @ EOC 13
- A-600 HTMA Tubing
- CS Lattice Support System
- Explosive Expansion Tubesheet Joint
- Tubes Plugged
 - SG A - 474 (5.6%)
 - SG B - 539 (6.4%)
- T-Hot ~600°F




4



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Horizontal Support Provided by Eggcrate Supports (lattice bar)



5



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Inspection Plan for EOC 12

Inspection Plan

- Bobbin Probe: 100% Bobbin Probe Full Length
- Plus Point Probe: 100% of Hot Leg Top of Tubesheet
30% of Row 1 & 2 U-bends
30% of Hot Leg Dings > 5 Volts
Free Span Indications (New or Show Change)
- Plus Point Profile of All Potential Corrosion Indications
- Contingency Plan for Free Span Cracking
- In Situ Pressure Test as Required

6



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Inspection Preparations for EOC 12

Small Amplitude Axial Indications First Reported at Eggcrate Supports at EOC 11 were Incorporated into EOC 12 Inspection

- Updated Data Analyst Training & Performance Demonstration
- Refined Computer Data Screening (Secondary Analysis)
- 1 of 15 Indications Did Not Confirm on Alternate Bobbin Channel
- Confirmation on Alternate Bobbin Channels Eliminated for EOC 12

7



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Inspection Evolution for EOC 12

Number of Eggcrate Bobbin Indications Greater than Expected

- Over 900 Plus Point Diagnostic Examinations
 - Direct result from the guidelines change.
- Primarily at Lower Three Hot Leg Supports

Detection of Axial ODSCC at Dings

- Prompted Supplemental Training & Inspection Expansion
- 3 Periphery Tubes ~1" Above Hot Leg Tubesheet
- 3 Additional Tubes at Other Locations on Hot Leg

8



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Inspection Evolution for EOC 12

Plus Point Examinations at Dings

- All Dings Hot Leg Tubesheet to 1st Support
- All Dings in U-Bends and 90° Bends
- All Dings > 5 Volts 1st Hot Leg Support to the Diagonal Cold Leg Support
- All Dings >10 Volts in Cold Leg Straight Region

Bobbin Probe Qualified for Dings < 5 Volts

9



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

In Situ Pressure Testing for EOC 12

27 Indications Tested With No Burst or Leakage

<u>Mechanism</u>	<u>Tested</u>	<u>Pressure</u>
Axial ODSCC at Eggcrates	9	4950 -5000 psi
Axial ODSCC at Dents	5	4950 -5000 psi
Axial ODSCC at TTS	6	4950 -5000 psi
Axial IDSCC below TTS	2	4950 -5000 psi
Circ ODSCC at TTS	4	5550 -5600 psi
OD Volumetric TTS	1	4950 -5000 psi

Selection Criteria Exceeded EPRI Minimum Guidance

- Mechanism & Location
- Calculated Burst Pressure & Leakage
- Maximum Voltage, Depth, Length & Percent Degraded Area

10



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Extensive Historical Reviews Show Flaws at
Eggcrates Were Present in Prior Inspections

	INITIATION OF INDICATIONS				Total
	1997 EOC 9	1998 EOC 10	2000 EOC 11	2001 EOC 12	
S/G A	6	36	41	19	102
S/G B	35	68	69	39	211
Total	41	104	110	58	313*

*Note: 15 indications were initially reported at EOC 11
298 additional indications reported at EOC 12

11



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Conclusions from EOC 12 Historical Review Work

- Degradation Trend is Typical for Unit with A-600 MA Tubing
- Large Apparent Increase in ODSCC at Eggcrates is Due to Change in Data Analysis Reporting Criteria
- Growth of Axial Indications at Dings Occurred Over 2 or More Cycles
 - Preventatively Plugged the Most Susceptible Population of Dings
- Confirmation on Alternate Bobbin Data Channel is Inconsistent When Indication is at Edge of Eggcrate

12



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Outline of Operational Assessment Discussion

- General Description of Operational Assessment Model
- Application to ODSCC at Eggcrates
- Application to ODSCC at Dings
 - Probability of Detection for ODSCC at Dings

13



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Operational Assessment

- Assessment Of Structural/Leakage Integrity Relative To NEI 97-06 At EOC 13
- Monte Carlo Simulation Of Steam Generator Degradation
 - Tracks Initiation, Evolution And Detection Of Simulated Flaw Population Over Several Cycles/Multiple Inspections
 - Structural And Leakage Integrity Evaluated For Each Simulated Flaw Throughout Period Of Analysis
 - Output Includes:
 - Risk Of Tube Burst
 - Risk/Statistics Of Leakage Under Accident Conditions

14



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Basic Processes

- Initiation
 - Weibull Model
- Flaw Growth
 - Lognormal Model
- Detection
 - Logistic Model
- Repair on Detection
- Burst/Ligament Tearing
 - Framatome Model
- Leakage
 - PICEP Model with Fracture Mechanics Crack Opening Area

15



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Overview Axial ODSCC At Eggcrates

- Largest Number of Corrosion Indications in 2001
- Apparent Large Increase in Number of Indications
- Moderate Flaw Depth Distribution
- Extensive Profile Analysis Performed
- No In Situ Burst or Leakage Occurrences

16



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

PSL2 Results of Historical Review ODSCC at Eggcrates

	INITIATION OF INDICATIONS				Total
	1997 EOC 9	1998 EOC 10	2000 EOC 11	2001 EOC 12	
S/G A	6	36	41	19	102
S/G B	35	68	69	39	211
Total	41	104	110	58	313*

*Note: 15 indications were initially reported at EOC 11
298 additional indications reported at EOC 12


THE RATE OF INCREASE IN INDICATIONS IS CONSISTENT WITH INDUSTRY EXPERIENCE



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Axial ODSCC at Eggcrates - Bobbin Probe POD Model


- Basis for model
 - Multiple analyst site-specific performance demonstration using pulled tube data base
 - NRC ANL round robin results based on multiple analyst participation
 - Supported by PSL 1 pulled tubes






SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

PSL2 SG B Benchmark



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

PSL2 SGB Benchmark





SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Results Of Eggcrate Evaluation

	ADDITIONAL NUMBER OF INDICATIONS PREDICTED	PROBABILITY OF BURST AT 3xNODP
	EOC 13	EOC 13
S/G A	60	0.010
S/G B	100	0.036

Steam Generators Projected to Meet NEI 97-06 Requirements
at EOC 13

21



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Overview - ODSCC At Dings

- First Reported in 2001
- Small Number of Flaws [6]
- Non-random Distribution of Dings Near Tubesheet
 - Most High Amplitude Dings at Peripheral Locations
Based on Bobbin Probe
- Largest Flaws in Dings Near Tubesheet
- Thorough Look Back Evaluation
- No In Situ Burst or Leakage Occurrences

22



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Critical Model Elements

- Probability of Detection Model
 - Plus Point
 - Bobbin
 - Simulation Process
- Initiation of ODSCC In Dings
- ODSCC Flaw Growth Rate
- Flaw Length


23



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

+Pt POD Model Development for Axial ODSCC in Tube Dings

- Starting Point
 - Free-span +Pt Detection Performance for Free-span Cracking
 - This Performance Is the Limiting Upper Bound in the Absence of Tube Indentations
- Free-span Performance Is Then Degraded Based on the Estimated Impact of Tube Dings on Detection




24



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

+Pt POD Model Development for Axial ODSCC in Tube Dings

- Free-span "Misses" are Retained
 - Missed in the Absence of Tube Indentations
- Free-span Hits are Excluded
 - Detected in the Absence of Tube Indentations
- Hit/miss Data from Signal Superposition Study Added
 - Upper Extremes of the Explanatory Variable



25



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Westinghouse Ding/Defect Superposition Study

- In Situ pressure tested indications with a range in depths were superimposed on Unit 2 ding signals using eddy current analysis software
- Overall detection performance for the various test conditions is summarized below in a Hit / Miss table

Estimated Met Depth, %TW	R89L57 Largest V_{VM}	R12L28 Largest V_{PP}	R126L48 Median	R88L148 Mean
R8L144 – 33%	Miss	Hit	Hit	Hit
R47L51 – 42%	Miss	Hit	Hit	Hit
R133L91 – 42%	Hit	Hit	Hit	Hit
R53L137 – 47%	Hit	Hit	Hit	Hit
R109L65 – 54%	Hit	Hit	Hit	Hit
R118L64 – 73%	Hit	Hit	Hit	Hit
R117L61 – 82%	Hit	Hit	Hit	Hit


26



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

+Pt POD Model for Axial ODSCC in Tube Dings

- Worst Case Hit/Miss Data Used
 - Added to Free-span Miss Data as Input for Tube Ding POD
- Bootstrap Estimates to Study Sensitivity of Uncertainties in POD
- Best Estimate POD Justified for Input to the Operational Assessment




27



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Bobbin Coil Voltage Based POD Model




28



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

SIMULATION LOGIC FOR ODSCC AT DINGS : INSPECTION




29



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

POD FUNCTIONS - ODSCC AT DINGS



30



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Initiation of ODSCC in Dings

- Weibull Model Used for Initiation Process in Ding Population
 - Limiting Slope Parameter of 4 Assigned
 - Exceeds EPRI Comprehensive Report of Observations of Field Data
 - Scale Parameter Estimated Using OA Model
 - Scale Parameter Adjusted to Agree with EOC 12 Results


31



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Growth Rates

- Growth Rate Based On Extensive Field Observations
- Range Of Growth Rate Distributions Illustrated
- High Growth Rate Curve Used In ODSCC At Dings Evaluation




32



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Potential Flaw Length Distribution

- Flaw Length Distribution Determines Fraction Of Deep Flaws That Are Potential Burst Candidates
- Developed From PSL-2 2001 Ding Length Measurements



33



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Results of ODSCC at Dings Evaluation

	ADDITIONAL NUMBER OF INDICATIONS PREDICTED	PROBABILITY OF BURST AT 3xNODP
	EOC 13	EOC 13
S/G A	4	0.033
S/G B	1	0.007

- Conservative Model Elements
 - Growth
 - Burst Model
 - Flaw Length
 - No Credit Taken for Ligaments
 - Initiation
- Accommodates Risk Associated With New Mechanism

34



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

Summary of Operational Assessment

Steam Generator Predicted to Meet NEI 97-06 Performance
Criteria at EOC 13

- Predicted Leakage at MSLB \ll 1 GPM
- Predicted POB $<$ 0.10

35



SL 2 EOC 12 (11/01) STEAM GENERATOR OPERATIONAL ASSESSMENT

CLOSING REMARKS - Raj Kundalkar, Engineering VP

Our Operational Assessment Demonstrates:

- EOC 12 Inspections Provide a Thorough Assessment of S/G Condition
- The Rate of Increase in Indications is Consistent with Industry Experience
- Strong Assurance of Safe Operation Through the End of Cycle-13 Demonstrated by the Application of a Benchmarked Multi-Cycle Model.

Questions?

36