

July 6, 1988

Docket No. 50-368

Mr. T. Gene Campbell
Vice President, Nuclear
Operations
Arkansas Power and Light Company
Post Office Box 551
Little Rock, Arkansas 72203

Dear Mr. Campbell:

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDINGS OF NO SIGNIFICANT
IMPACT - CHANGES TO THE TECHNICAL SPECIFICATIONS REGARDING
THE HIGH PRESSURE SAFETY INJECTION PUMP SURVEILLANCE TEST
DIFFERENTIAL PRESSURE REQUIREMENT, ARKANSAS NUCLEAR ONE,
UNIT 2 (TAC NO. 66558)

Enclosed is the Environmental Assessment which relates to your application for
a change to the technical specifications for Arkansas Nuclear One, Unit 2.
The application dated October 28, 1987 (2CAN108706) requested approval of a
reduction in the required differential pressure produced during surveillance
testing by the high pressure safety injection pumps.

This assessment is being forwarded to the Office of the Federal Register for
publication.

Sincerely,

/s/

C. Craig Harbuck, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION

Docket File	NRC PDR	Local PDR	PD4 Reading
L. Rubenstein	J. Calvo	P. Noonan	C. Harbuck
G. Dick	OGC-Rockville	E. Jordan	J. Partlow
ACRS (10)	PD4 Plant File		

PD4/LA *[Signature]*
PNoonan
04/20/88

PD4/PM *[Signature]*
CHarbuck:sr
04/20/88

OGC-WF *[Signature]*
[Signature]
04/25/88

PD4/D *[Signature]*
JCalvo
07/06/88

DFOL
1/1



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

July 6, 1988

Docket No. 50-368

Mr. T. Gene Campbell
Vice President, Nuclear
Operations
Arkansas Power and Light Company
Post Office Box 551
Little Rock, Arkansas 72203

Dear Mr. Campbell:

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDINGS OF NO SIGNIFICANT
IMPACT - CHANGES TO THE TECHNICAL SPECIFICATIONS REGARDING
THE HIGH PRESSURE SAFETY INJECTION PUMP SURVEILLANCE TEST
DIFFERENTIAL PRESSURE REQUIREMENT, ARKANSAS NUCLEAR ONE,
UNIT 2 (TAC NO. 66558)

Enclosed is the Environmental Assessment which relates to your application for a change to the technical specifications for Arkansas Nuclear One, Unit 2. The application dated October 28, 1987 (2CAN108706) requested approval of a reduction in the required differential pressure produced during surveillance testing by the high pressure safety injection pumps.

This assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script, appearing to read "C. Harbuck".

C. Craig Harbuck, Project Manager
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. T. Gene Campbell
Arkansas Power & Light Company

Arkansas Nuclear One, Unit 2

cc:

Mr. Dan R. Howard, Manager
Licensing
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
C-E Power Systems
7910 Woodmont Avenue
Suite 1310
Bethesda, Maryland 20814

Mr. James M. Levine, Executive Director
Site Nuclear Operations
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Mr. Frank Wilson, Director
Division of Environmental Health
Protection
Department of Health
Arkansas Department of Health
4815 West Markham Street
Little Rock, Arkansas 72201

Mr. Nicholas S. Reynolds
Bishop, Cook, Percell & Reynolds
1400 L Street, N.W.
Washington, D.C. 20005-3502

Honorable William Abernathy
County Judge of Pope County
Pope County Courthouse
Russellville, Arkansas 72801

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Office of Executive Director for
Operations
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
1 Nuclear Plant Road
Russellville, Arkansas 72801

Ms. Greta Dicus, Director
Division of Environmental Health
Protection
Arkansas Department of Health
4815 West Markham Street
Little Rock, Arkansas 72201

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
1700 Rockville Pike, Suite 525
Rockville, Maryland 20852

UNITED STATES NUCLEAR REGULATORY COMMISSIONARKANSAS POWER AND LIGHT COMPANYARKANSAS NUCLEAR ONE, UNIT 2DOCKET NO. 50-368NOTICE OF ENVIRONMENTAL ASSESSMENT ANDFINDINGS OF NO SIGNIFICANT IMPACT

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-6 issued to Arkansas Power and Light Company, (the licensee), for operation of the Arkansas Nuclear One, Unit 2 (ANO-2) located at Russellville, Arkansas.

ENVIRONMENTAL ASSESSMENTIdentification of Proposed Action:

By letter dated October 28, 1987 (2CAN108706), the licensee requested a change in the plant Technical Specifications (TSs) to decrease the required differential pressure produced by the high pressure safety injection pumps during surveillance testing, from 1402.5 psid to 1360.4 psid.

The Need for Proposed Action:

The proposed TS change is needed because the current specification provides little margin for variation in pump performance. The proposed revision establishes a more realistic differential pressure requirement for the high pressure safety injection (HPSI) pumps which will increase operational flexibility. Recent analyses have shown that a lower differential pressure requirement will not adversely impact the original analysis results, and will result in only a very small reduction of the injection leg flow rates.

Environmental Impact of the Proposed Action:

The proposed reduction in the required differential pressure for the HPSI pumps was considered with respect to all the accident analyses in Chapter 15 of

the Final Safety Analysis Report (FSAR), and also with respect to the loss of coolant accident (LOCA) analysis in Chapter 6 of the FSAR. The proposed reduction does not increase the probability or consequences of a previously evaluated accident. Therefore the proposed changes will not increase to greater than previously determined, the probability of accident and post-accident radiological releases, nor otherwise affect radiological plant effluents. The Commission concludes that there are no significant radiological environmental impacts associated with the proposed TS changes.

With regard to potential non-radiological impacts, the proposed TS change involves features located entirely within the restricted area as defined in 10 CFR Part 20. This would not affect non-radiological plant effluents and would have no other environmental impact. Therefore, the Commission concludes that there are no significant non-radiological environmental impacts associated with the proposed action.

The Notice of Consideration of Issuance of Amendment to Facility Operating License and Opportunity for Prior Hearing regarding the proposed changes to the TS, was published in the Federal Register on December 28, 1987 (52 FR 48887). No request for hearing or petition for leave to intervene was filed following this notice.

Alternative to the Proposed Action:

Since the Commission concluded that there are no significant environmental effects that would result from the proposed action, any alternatives with equal or greater environmental impacts need not be evaluated.

The principal alternative would be to deny the requested amendment. This would not reduce environmental impacts of plant operation and would result in reduced operational flexibility.

Alternative Use of Resources:

This action does not involve the use of any resources beyond the scope of resources used during normal plant operation.

Agencies and Persons Consulted:

The Commission's staff reviewed the licensee's safety analysis and change to the TS that support the proposed amendment. The staff did not consult other agencies or persons.


FINDING OF NO SIGNIFICANT IMPACT

Based upon the foregoing environmental assessment, the Commission concluded that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the Commission has determined not to prepare an environmental impact statement for the proposed license amendment.

For further details with respect to this action, see the applications for license amendment dated October 28, 1987. Copies are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. 20555, and at the local public document room located at the Tomlinson Library, Arkansas Technical University, Russellville, Arkansas 72801.

Dated at Rockville, Maryland this 6th day of July 1988.

FOR THE NUCLEAR REGULATORY COMMISSION



Jose A. Calvo, Director
Project Directorate - IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation