

November 23, 1990

Docket No. 50-368

Mr. Neil S. Carns  
Vice President, Operations ANO  
Entergy Operations, Inc.  
Route 3 Box 137G  
Russellville, Arkansas 72801

Dear Mr. Carns:

SUBJECT: CORRECTION TO TECHNICAL SPECIFICATION PAGE 3/4 4-3  
AMENDMENT NO. 110 TO FACILITY LICENSE NO. NPF-6  
FOR ARKANSAS NUCLEAR ONE, UNIT NO. 2

The Nuclear Regulatory Commission (NRC) is submitting revised page 3/4 4-3 to the Technical Specifications (TS) for the Arkansas Nuclear One, Unit No. 2 (ANO-2). The previous TS page was issued by Amendment No. 110 to Facility Operating License No. NPF-6 dated November 1, 1990.

Correction is being made by incorporating previous TS changes (Amendment No. 109 dated October 17, 1990) which were inadvertently omitted on the November 1 change.

Enclosed is the revised TS page 3/4 4-3 for Amendment No. 110 dated November 1, 1990.

Sincerely,

ORIGINAL SIGNED BY:

Sheri R. Peterson, Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

DISTRIBUTION  
See Attached

cc w/enclosure:  
See next page

OFC	: PDIV-1/LA	: PDIV-1/PM	: PDIV-1/D	:	:	:	:
NAME	: LBerry:lb	: SPeterson	: TQuay	:	:	:	:
DATE	: 11/19/90	: 11/19/90	: 11/23/90	:	:	:	:

OFFICIAL RECORD COPY  
Document Name: CORRECTION LTR ANO2  
9011300199 901123  
PDR ADOCK 05000368  
P FDC

DFol  
11



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555

November 23, 1990

Docket No. 50-368

Mr. Neil S. Carns  
Vice President, Operations ANO  
Entergy Operations, Inc.  
Route 3 Box 137G  
Russellville, Arkansas 72801

Dear Mr. Carns:

SUBJECT: CORRECTION TO TECHNICAL SPECIFICATION PAGE 3/4 4-3  
AMENDMENT NO. 110 TO FACILITY LICENSE NO. NPF-6  
FOR ARKANSAS NUCLEAR ONE, UNIT NO. 2

The Nuclear Regulatory Commission (NRC) is submitting revised page 3/4 4-3 to the Technical Specifications (TS) for the Arkansas Nuclear One, Unit No. 2 (ANO-2). The previous TS page was issued by Amendment No. 110 to Facility Operating License No. NPF-6 dated November 1, 1990.

Correction is being made by incorporating previous TS changes (Amendment No. 109 dated October 17, 1990) which were inadvertently omitted on the November 1 change.

Enclosed is the revised TS page 3/4 4-3 for Amendment No. 110 dated November 1, 1990.

Sincerely,

A handwritten signature in cursive script that reads "Sheri R. Peterson".

Sheri R. Peterson, Project Manager  
Project Directorate IV-1  
Division of Reactor Projects - III  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc w/enclosure:  
See next page

Mr. Neil S. Carns  
Entergy Operations, Inc.

Arkansas Nuclear One, Unit 2

cc:

Mr. Donald C. Hintz  
Executive Vice President  
and Chief Operating Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, Mississippi 39286

Mr. Jerry Yelverton  
Director Nuclear Operations  
Arkansas Nuclear One  
Route 3 Box 137G  
Russellville, Arkansas 72801

Mr. Nicholas S. Reynolds  
Winston & Strawn  
1400 L Street, N.W.  
Washington, D.C. 20005-3502

Mr. Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Generation Division  
1700 Rockville Pike, Suite 525  
Rockville, Maryland 20852

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
1 Nuclear Plant Road  
Russellville, Arkansas 72801

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Office of Executive Director  
for Operations  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Honorable Joe W. Phillips  
County Judge of Pope County  
Pope County Courthouse  
Russellville, Arkansas 72801

Ms. Greta Dicus, Director  
Division of Environmental Health  
Protection  
Arkansas Department of Health  
4815 West Markam Street  
Little Rock, Arkansas 72201

Mr. Gerald Muench  
Vice President Operations Support  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, Mississippi 39286

Mr. Robert B. McGehee  
Wise, Carter, Child & Caraway  
P. O. Box 651  
Jackson, Mississippi 39205

Mr. Charles B. Brinkman, Manager  
Washington Nuclear Operations  
Combustion Engineering, Inc.  
12300 Twinbrook Parkway, Suite 330  
Rockville, Maryland 20852

Admiral Kinnaird R. McKee, USN (Ret)  
Post Office Box 41  
Oxford, Maryland 21654

Mr. Tom Nickels  
Arkansas Nuclear One  
Route 3, Box 137G  
Russellville, Arkansas 72801

REACTOR COOLANT SYSTEM

SAFETY VALVES - SHUTDOWN

LIMITING CONDITION FOR OPERATION.

---

3.4.2 A minimum of one pressurizer code safety valve shall be OPERABLE with a lift setting of 2500 PSIA +1, -3%\*#.

APPLICABILITY: MODES 4 AND 5.

ACTION:

With no pressurizer code safety valve OPERABLE, immediately suspend all operations involving positive reactivity changes and place an OPERABLE shutdown cooling loop into operation.

SURVEILLANCE REQUIREMENTS.

---

4.4.2 No additional Surveillance Requirements other than those required by Specification 4.0.5.

\*The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure. If found outside of a +1% tolerance band, the setting shall be adjusted to within  $\pm 1\%$  of the lift setting shown.

#Equivalent relief capacity during MODE 5 satisfies the requirements of this Specification. This allows both pressurizer code safety valves to be removed for testing and/or maintenance.

DISTRIBUTION

Docket File

NRC/LOCAL PDR

PDIV-1 Reading File

LBerry

SPeterson

TQuay

MVirgilio

WJones

GPA/PA

OGC

ARM/LFMB

DHagan

JCalvo

GHill (4)

ACRS (10)

PDIV-1 Plant File

RMullikin, RIV