

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

February 4, 1992

Docket No. 50-368

Mr. Neil S. Carns Vice President, Operations ANO Entergy Operations, Inc. Route 3 Box 137G Russellville, Arkansas 72801

Dear Mr. Carns:

SUBJECT: CLARIFICATION REGARDING THE SAFETY EVALUATION FOR AMENDMENT NO. 127 TO FACILITY OPERATING LICENSE NO. NPF-6 - ARKANSAS NUCLEAR ONE, UNIT 2 (ANO-2) (TAC NO. M80705)

On December 17, 1991, the Commission issued Amendment No. 127 to Facility Operating License No. NPF-6 for ANO-2. The amendment revises Technical Specification (TS) 4.8.1.1.2.C.8.c to provide for conserving starting air for emergency diesel generators in case an engine fails to start on a safety injection signal. The license amendment is effective as of the next refueling outage, currently scheduled for August 1992, in which the applicable design change will be implemented. Subsequent to further review of the Safety Evaluation (SE) for Amendment No. 127, the licensee, by telecon on January 14, 1992, identified items included in the staff's SE which needed clarification.

This letter provides the enclosed revised page to the December 17, 1991, SE which incorporates the clarifications identified by the licensee. These clarifications do not alter our previous conclusion that the proposed design change and license amendment are acceptable. Also enclosed is corrected TS page 3/4 8-3 which was not revised but

. (4-1

NRC FILL CONTER GI

9202110289 920204 PDR ADUCK 05000368 PDR PDR Mr. Neil S. Carns - 2 -

was provided as an overleaf page. Correction is being made by omitting Amendment No. 127 that was inadvertently incorporated on the overleaf page.

If you have any questions regarding this matter please contact us.

Sincerely,

ORIGINAL SIGNED BY Sheri R. Peterson, Project Manager Project Directorate IV-1 Division of Reactor Projects III/IV/V Office of Nuclear Reactor Regulation

Enclosures: As stated

cc w/enclosures: See next page

DISTRIBUTION:	Docket File		
NRC & LPDRs	PD4-1 r/f	BBoger	MVirgilio
JLarkins	PNoonan	SPeterson	OGC
DHagan	GHill (4)	WJones	CGrimes
ACRŠ (10)	GPA/PA	OC/LFMB	PD4-1 p∕f
ABBeach, RIV	•	·	

OFFICE	LA/PD4-DM	PM/PD4	D/PD4-1		
NAME	PNoonan	SPeterson	JLantins		
DATE	01/24/92	01/29/92	0 4/4/92		
OFFICIAL	RECORD COPY	D	OCUMENT NAME:	CORRECT	

Mr. Neil S. Carns Entergy Operations, Inc.

cc:

Mr. Donald C. Hintz Executive Vice President and Chief Operating Officer Entergy Operations, Inc. P. O. Box 31995 Jackson, Mississippi 39286

Mr. Jerry Yelverton General Manager, Plant Operations Entergy Operations, Inc. Route 3 Box 137G Russellville, Arkansas 72801

Mr. Nicholas S. Reynolds Winston & Strawn 1400 L Street, N.W. Washington, D.C. 20005-3502

Mr. Robert B. Borsum Licensing Representative B&W Nuclear Technologies 1700 Rockville Pike, Suite 525 Rockville, Maryland 20852

Senior Resident Inspector U.S. Nuclear Regulatory Commission 1 Nuclear Plant Road Russellville, Arkansas 72801

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 1000 Arlington, Texas 76011

Honorable Joe W. Phillips County Judge of Pope County Pope County Courthouse Russellville, Arkansas 72801

Ms. Greta Dicus, Director Division of Radiation Control and Emergency Management Arkansas Department of Health 4815 West Markham Street Little Rock, Arkansas 72205-3867 Arkansas Nuclear One, Unit 2

Mr. John R. McGaha Vice President, Operations Support Entergy Operations, Inc. P. O. Box 31995 Jackson, Mississippi 39286

Mr. Robert B. McGehee Wise, Carter, Child & Caraway P. O. Box 651 Jackson, Mississippi 39205

Mr. Charles B. Brinkman, Manager Washington Nuclear Operations ABB Combustion Engineering Nuclear Power 12300 Twinbrook Parkway, Suite 330 Rockville, Maryland 20852

Admiral Kinnaird R. McKee, USN (Ret) 214 South Morris Street Oxford, Maryland 21654

. .

Mr. James J. Fisicaro Director, Licensing Entergy Operations, Inc. Route 3, Box 137G Russellville, Arkansas 72801

## ELECTRICAL POWER SYSTEM

SURVEILLANCE REQUIREMENTS (Continued)

- 3. Verifying the fuel transfer pump can be started and transfers fuel from the storage system to the day tank.
- 4. Verifying the diesel starts from ambient condition and accelerates to at least 900 rpm in < 15 seconds.
- 5. Verifying the generator is synchronized, loaded to 2850 Kw in  $\leq$  60 seconds, and operates for > 60 minutes.
- 6. Verifying the diesel generator is aligned to provide standby power to the associated emergency busses.
- b. At least once per 92 days by verifying that a sample of diesel fuel from the fuel storage tank obtained in accordance with ASTM-D270-65, is within the acceptable limits specified in Table 1 of ASTM D975-74 when checked for viscosity, water and sediment.
- c. At least once per 18 months during shutdown by:
  - 1. Subjecting the diesel to an inspection in accordance with procedures prepared in conjunction with its manufacturer's recommendations for this class of standby service.
  - 2. Verifying that the automatic sequence time delay relays are OPERABLE at their setpoint  $\pm$  10% of the elapsed time for each load block.
  - 3. Verifying the generator capability to reject a load of  $\geq 596$  kw and maintain voltage at 4160  $\pm 500$  volts and frequency at 60  $\pm$  3 Hz.
  - 4. Verifying the generator capability to reject a load of 2850 Kw without exceeding 75% of the difference between nominal speed and the overspeed trip setpoint, or 15% above nominal, whichever is lower.
  - 5. Simulating a loss of offsite power by itself, and:
    - a) Verifying de-energization of the emergency busses and load shedding from the emergency busses.

- 2 -

The staff position on bypass of EDG protective trips is contained in Regulatory Guide 1.9, Revision 2, Position 7, which recommends that the EDG be automatically tripped on engine overspeed and generator differential overcurrent. All other EDG protective trips should be handled in one of two ways: 1) a trip should be implemented with two or more measurements for each trip actuation; or 2) a trip may be bypassed under accident conditions, provided that the operator has sufficient time to react appropriately to an abnormal EDG condition. The design of the bypass circuitry should include the capability for 1) testing the status and operability of the bypass circuits, 2) alarming in the control room for abnormal values of all bypass parameters, and 3) manually resetting the trip bypass function.

The reason for bypassing non-critical protective functions is to ensure that the EDG will be available to mitigate the consequences of a design basis accident (DBA). EDG availability to mitigate a DBA is more critical than protecting the engine against minor problems that are not immediately detrimental to EDG operation.

The licensee states that following modification the engine start failure trip function will be initiated from coincidence logic employing two measurements (engine speed and coolant pressure). The licensee asserts that a start failure trip will be generated after 10 seconds from a start signal only under the following conditions: 1) engine speed is less than 250 rpm and 2) jacket coolant pressure is less than 8 psig.

Our review of the licensee's submittal and of other information obtained during subsequent teleconferences with the licensee's representatives indicates that the proposed design does not meet the conventional coincidence logic requirement for the independent measurements used to generate the trip parameter. In fact, following an engine start signal, the start failure trip is generated after 10 seconds unless interrupted by an engine-speed-greaterthan-250-rpm signal or a jacket-coolant-pressure-greater-than-8-psig signal. It is the absence of both parameters that constitutes the start failure trip condition. Thus, the proposed design change does not introduce the potential--noted in Position 7 of Regulatory Guide 1.9--for spurious tripping of the diesel generator.

We have reviewed the licensee's submittal and have concluded that the proposed design change meets the intent of Regulatory Guide 1.9 and will enhance EDG availability during a spurious failure to start condition coincident with a loss of offsite power condition by conserving the engine-starting air supply. The change is therefore acceptable.

## 3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Arkansas State official was notified of the proposed issuance of the amendment. The State official had no comments.