

Mr. C. Randy Hutchinson
Vice President, Operations ANO
Entergy Operations, Inc.
1448 S. R. 333
Russellville, AR 72801

May 6, 1997

SUBJECT: ARKANSAS NUCLEAR ONE, UNIT NO. 2 - CORRECTION TO AMENDMENT NO. 181
RE: SPECIFIC VALUE FOR THE TOTAL REACTOR COOLANT SYSTEM VOLUME
FROM THE DESIGN FEATURES SECTION OF THE TECHNICAL SPECIFICATIONS

Dear Mr. Hutchinson:

On April 16, 1997, the Commission issued Amendment No. 181 to Facility Operating License No. NPF-6 for the Arkansas Nuclear One, Unit No. 2 (ANO-2). This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated December 9, 1996.

Amendment No. 181 included changes to TS page 5-5. Amendment No. 178, issued on January 14, 1997, also included changes to TS page 5-5. Due to the near simultaneous processing of the amendments, the Amendment No. 178 changes to TS page 5-5 were not included in Amendment No. 181.

Copies of the corrected TS page 5-5 are enclosed.

We regret any inconvenience this oversight may have caused. If you have any questions on this action, please call me at 301/415-1308.

Sincerely,

ORIGINAL SIGNED BY:

George Kalman, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-368

Enclosure: Corrected TS page 5-5

cc w/encls: See next page

NRC FILE CENTER COPY

DISTRIBUTION:

Docket File	PUBLIC	PD4-1 r/f
JRoe	CHawes	ACRS
OGC(15B18)	GHill (2)	JDyer, RIV
CGrimes	GKalman	JKilcrease, RIV r/f
EAdensam(EGA1)	LHurley, RIV	WBeckner

DFD/1

DOCUMENT NAME: AR297534.COR

To receive a copy of this document, indicate in the box C=Copy w/o attachment/enclosure E=Copy with attachment/enclosure N = No copy

OFFICE	PM:PD41	E	LA:PD41	E	OGC	
NAME	GKalman		CHawesCMH		Cmarco	
DATE	4/25/97		4/25/97		4/29/97	

OFFICIAL RECORD COPY

Dec 19/96
9705080331 970506
PDR ADOCK 05000368
PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 6, 1997

Mr. C. Randy Hutchinson
Vice President, Operations ANO
Entergy Operations, Inc.
1448 S. R. 333
Russellville, AR 72801

SUBJECT: ARKANSAS NUCLEAR ONE, UNIT NO. 2 - CORRECTION TO AMENDMENT NO. 181
RE: SPECIFIC VALUE FOR THE TOTAL REACTOR COOLANT SYSTEM VOLUME
FROM THE DESIGN FEATURES SECTION OF THE TECHNICAL SPECIFICATIONS

Dear Mr. Hutchinson:

On April 16, 1997, the Commission issued Amendment No. 181 to Facility Operating License No. NPF-6 for the Arkansas Nuclear One, Unit No. 2 (ANO-2). This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated December 9, 1996.

Amendment No. 181 included changes to TS page 5-5. Amendment No. 178, issued on January 14, 1997, also included changes to TS page 5-5. Due to the near simultaneous processing of the amendments, the Amendment No. 178 changes to TS page 5-5 were not included in Amendment No. 181.

Copies of the corrected TS page 5-5 are enclosed.

We regret any inconvenience this oversight may have caused. If you have any questions on this action, please call me at 301/415-1308.

Sincerely,

A handwritten signature in cursive script, reading "George Kalman", is written over a horizontal line.

George Kalman, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-368

Enclosure: Corrected TS page 5-5

cc w/encls: See next page

Mr. C. Randy Hutchinson
Entergy Operations, Inc.

Arkansas Nuclear One, Unit 2

cc:

Executive Vice President
& Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1999

Director, Division of Radiation
Control and Emergency Management
Arkansas Department of Health
4815 West Markham Street, Slot 30
Little Rock, AR 72205-3867

Winston & Strawn
1400 L Street, N.W.
Washington, DC 20005-3502

Manager, Rockville Nuclear Licensing
Framatome Technologies
1700 Rockville Pike, Suite 525
Rockville, MD 20852

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 310
London, AR 72847

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

County Judge of Pope County
Pope County Courthouse
Russellville, AR 72801

Vice President, Operations Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205

DESIGN FEATURES

5.5 METEOROLOGICAL TOWER LOCATION

5.5.1 The meteorological tower shall be located as shown on Figure 5.1-1.

5.6 FUEL STORAGE

CRITICALITY - SPENT FUEL

5.6.1.1 The spent fuel racks are designed and shall be maintained so that the calculated effective multiplication factor is no greater than 0.95 (including all known uncertainties) when the pool is flooded with unborated water.

CRITICALITY - NEW FUEL

5.6.1.2 The new fuel storage racks are designed and shall be maintained with a nominal 26.0 inch center-to-center distance between new fuel assemblies such that K_{eff} will not exceed 0.98 when fuel having a maximum enrichment of 5.0 weight percent U-235 is in place and aqueous foam moderation is assumed and K_{eff} will not exceed 0.95 (including a conservative allowance for uncertainties) when the storage area is flooded with unborated water.

DRAINAGE

5.6.2 The spent fuel storage pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 399' 10½".

CAPACITY

5.6.3 The spent fuel storage pool is designed and shall be maintained with a storage capacity limited to no more than 988 fuel assemblies.

5.7 COMPONENT CYCLIC OR TRANSIENT LIMITS

5.7.1 The components identified in Table 5.7-1 are designed and shall be maintained within the cyclic or transient limits of Table 5.7-1.

TABLE 5.7-1

COMPONENT CYCLIC OR TRANSIENT LIMITS

<u>COMPONENT</u>	<u>CYCLIC OR TRANSIENT LIMIT</u>	<u>DESIGN CYCLE OR TRANSIENT</u>
Reactor Coolant System	500 system heatup and cooldown cycles at rates $\leq 100^\circ\text{F/hr.}$	Heatup cycle - T_{avg} from $\leq 200^\circ\text{F}$ to $\geq 545^\circ\text{F}$; cooldown cycle - T_{avg} from $\geq 545^\circ\text{F}$ to $\leq 200^\circ\text{F}$.
	500 pressurizer heatup and cooldown cycles at rates $\leq 200^\circ\text{F/hr.}$	Heatup cycle - Pressurizer temperature from $\leq 200^\circ\text{F}$ to $\geq 653^\circ\text{F}$; cooldown cycle - Pressurizer temperature from $\geq 653^\circ\text{F}$ to $\leq 200^\circ\text{F}$.
	10 hydrostatic testing cycles.	RCS pressurized to 3110 psig with RCS temperature $\geq 60^\circ\text{F}$ above the most limiting components' NDTT value.
	200 leak testing cycles.	RCS pressured to 2250 psia with RCS temperature greater than minimum for hydrostatic testing, but less than minimum RCS temperature for criticality.
	400 reactor trip cycles.	Trip from 100% of RATED THERMAL POWER.
	40 turbine trip cycles with delayed reactor trip.	Turbine trip (total load rejection) from 100% of RATED THERMAL POWER followed by resulting reactor trip.
	200 seismic stress cycles.	Subjection to a seismic event equal to one half the design basis earthquake (DBE).