

Mr. C. Randy Hutchinson
 Vice President, Operations ANO
 Entergy Operations, Inc.
 1448 S. R. 333
 Russellville, AR 72801

February 26, 1999

SUBJECT: ARKANSAS NUCLEAR ONE, UNIT NO. 2 - WITHDRAWAL OF APPLICATION
 FOR LICENSE AMENDMENT TO FACILITY OPERATING LICENSE NO. NPF-6
 (TAC NO. M92435)

Dear Mr. Hutchinson:

By letter dated May 19, 1995 (2CAN059502), you applied for an amendment to Operating License No. NPF-6. The proposed change would have extended the allowed outage time (AOT) for a train of low pressure safety injection (LPSI) inoperable at Arkansas Nuclear One, Unit No. 2 from 72 hours to 7 days. Subsequently, by letter dated February 16, 1999 (2CAN029906), you withdrew this request. Therefore, the proposed change is considered to be withdrawn. If this information is not correct, please notify the Nuclear Regulatory Commission of your intended actions within 10 days of receipt of this letter.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

ORIGINAL SIGNED BY:
 M. Christopher Nolan, Project Manager
 Project Directorate IV-1
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket No. 50-368

Enclosure: Notice of Withdrawal

cc w/encl: See next page

DISTRIBUTION:

Docket File	PUBLIC	PD4-1 r/f
C. Hawes	K. Brockman, RIV	M. C. Nolan
OGC(15B18)	ACRS	S. Black
J. Hannon	J. Zwolinski	

Document Name: G:\ANO2FINA\WD95331.WPD

OFC	PM/PD4-1	LA/PD4-1	PD/PD4-1
NAME	MCNolan/vw	CHawes	JHannon
DATE	2/26/99	2/26/99	2/26/99
COPY	YES/NO	YES/NO	YES/NO

OFFICIAL RECORD COPY

NRC FILE CENTER COPY

9903090002 990226
 PDR ADDCK 05000368
 P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

February 26, 1999

Mr. C. Randy Hutchinson
Vice President, Operations ANO
Entergy Operations, Inc.
1448 S. R. 333
Russellville, AR 72801

SUBJECT: ARKANSAS NUCLEAR ONE, UNIT NO. 2 - WITHDRAWAL OF APPLICATION
FOR LICENSE AMENDMENT TO FACILITY OPERATING LICENSE NO. NPF-6
(TAC NO. M92435)

Dear Mr. Hutchinson:

By letter dated May 19, 1995 (2CAN059502), you applied for an amendment to Operating License No. NPF-6. The proposed change would have extended the allowed outage time (AOT) for a train of low pressure safety injection (LPSI) inoperable at Arkansas Nuclear One, Unit No. 2 from 72 hours to 7 days. Subsequently, by letter dated February 16, 1999 (2CAN029906), you withdrew this request. Therefore, the proposed change is considered to be withdrawn. If this information is not correct, please notify the Nuclear Regulatory Commission of your intended actions within 10 days of receipt of this letter.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script, appearing to read "M. Christopher Nolan".

M. Christopher Nolan, Project Manager
Project Directorate IV-1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-368

Enclosure: Notice of Withdrawal

cc w/encl: See next page

Mr. C. Randy Hutchinson
Entergy Operations, Inc.

Arkansas Nuclear One, Unit 1

cc:

Executive Vice President
& Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-199

Vice President, Operations Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Director, Division of Radiation
Control and Emergency Management
Arkansas Department of Health
4815 West Markham Street, Slot 30
Little Rock, AR 72205-3867

Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, MS 39205

Winston & Strawn
1400 L Street, N.W.
Washington, DC 20005-3502

Manager, Rockville Nuclear Licensing
Framatone Technologies
1700 Rockville Pike, Suite 525
Rockville, MD 20852

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 310
London, AR 72847

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

County Judge of Pope County
Pope County Courthouse
Russellville, AR 72801

UNITED STATES NUCLEAR REGULATORY COMMISSION

ENTERGY OPERATIONS, INC.

DOCKET NO. 50-368

ARKANSAS NUCLEAR ONE, UNIT NO. 2

NOTICE OF WITHDRAWAL OF APPLICATION FOR
AMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Entergy Operations, Inc. (the licensee) to withdraw its May 19, 1995, application for proposed amendment to Facility Operating License No. NPF-6 for Arkansas Nuclear One, Unit No. 2, located in Pope County, Arkansas.

The proposed amendment would have extended the allowed outage time (AOT) for a train of low pressure safety injection (LPSI) inoperable at Arkansas Nuclear One, Unit No. 2 from 72 hours to 7 days.

The Commission had previously issued a proposed no significant hazards consideration determination published in the FEDERAL REGISTER on August 2, 1995 (60 FR 39440). However, by letter dated February 16, 1999, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for the amendment dated May 19, 1995, and the licensee's letter dated February 16, 1999, which withdrew the application for the license amendment. The above documents are available for public

inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, N. W. Washington, DC, and at the Tomlinson Library, Arkansas Tech University, Russellville, AR 72801.

Dated at Rockville, Maryland, this 26th day February 1999.

FOR THE NUCLEAR REGULATORY COMMISSION



M. Christopher Nolan, Project Manager
Project Directorate IV-1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation