

Exelon Generation Company, LLC www.exeloncorp.com
Braidwood Station
35100 South Rt 53, Suite 84
Braceville, IL 60407-9619
Tel. 815-417-2000

May 16, 2002
BW020046

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Braidwood Station, Unit 2
Facility Operating License No. NPF-77
NRC Docket No. STN 50-457


Subject: Notification of Modification Completion in Support of License Amendment to Revise Technical Specification Requirements Associated with the Boron Dilution Protection System (BDPS)

Reference: Letter from M. Chawla (USNRC) to O. D. Kingsley (Exelon Generation Company, LLC), "Issuance of Amendments," dated April 6, 2001

In the referenced letter you requested notification of the completion of the modifications for each unit. The BDPS modification for Braidwood Station, Unit 2 was completed on May 6, 2002. This completes installation on both Units. The modification includes two redundant Volume Control Tank (VCT) high level alarms and two new alarm annunciator windows in the Main Control Room titled "Boron Dilution Alert Channel A" and "Boron Dilution Alert Channel B." The Channel A alarm has inputs from the new VCT high level alarm and a new Reactor Coolant System letdown divert valve (i.e., 2CV112A) position indication. The Channel B alarm has inputs from the new VCT high level alarm and the existing neutron flux doubling channels.

If you have any questions regarding this matter, please contact Ms. A. Ferko, Regulatory Assurance Manager at (815) 417-2699.

Respectfully,


James D. von Suskil
Site Vice President
Braidwood Station

cc: Regional Administrator – NRC Region III
NRC Senior Resident Inspector – Braidwood Station

A001