

JUL 13 1975

Dockets Nos. 50-277(278)

Philadelphia Electric Company
ATTN: Edward G. Bauer, Jr., Esquire
Vice President & General Counsel
2301 Market Street
Philadelphia, Pennsylvania 19101

Gentlemen:

The Commission has requested the Federal Register to publish the enclosed Notice of Proposed Issuance of Amendments to Facility Operating Licenses Nos. DPR-44 and DPR-56 for the Peach Bottom Atomic Power Station Units 2 and 3. The proposed amendments include changes to the Technical Specifications, and is in response to your request dated March 31, 1975 which was submitted in reply to our letter dated February 15, 1975. During our review of your response, a few changes were discussed and found mutually acceptable to you and to the NRC staff.

The amendments would define new temperature limits for the suppression pool water to provide additional assurance of maintaining primary containment integrity.

A copy of the related Safety Evaluation is also enclosed.

Sincerely,

George Lear, Chief
Operating Reactors Branch #3
Division of Reactor Licensing

Enclosures:

1. Federal Register Notice
2. Proposed Amendments
3. Safety Evaluation

cc: See next page

DISTRIBUTION:
 Docket ~~XXXXXX~~ BScharf (15)
 NRC PDR TJCarter
 Local PDR SVarga
 ORB#3 rdg CHebron
 OELD DEisenhut
 OI&E (3) ACRS (14)
 NDube AESTeefn
 BJones (4) gray file
 JMMcGough extra cps
 JSaltzman Abernathy
 SATEets
 CJDeBevec
 DJaffe
 GLear
 SKari

2/1

ll

OFFICE →	ORB#3	ORB#3	ORB#3	OELD	AD:RL/ORs	D:RL
SURNAME →	DeBevec	DJaffe/dg	GLear		KRGoller	AGiambusso
DATE →	6/ /75	6/ /75	6/ /75	6/ /75	6/ /75	6/ /75

Philadelphia Electric Company

cc: w/enclosures

Eugene J. Bradley
Philadelphia Electric Company
Assistant General Counsel
2301 Market Street
Philadelphia, Pennsylvania 19101

Anthony Z. Roisman, Esquire
Berlin, Roisman & Kessler
1712 N Street, N. W.
Washington, D. C. 20036

Albert R. Steel, Chairman
Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, Pennsylvania 17314

Wilmer P. Bolton
Chairman, Board of Supervisors
Drumore Township
R. D. #1
Holtwood, Pennsylvania 17532

Mr. R. A. Heiss, Coordinator
Pennsylvania State Clearinghouse
Governor's Office of State Planning
and Development
P. O. Box 1323
Harrisburg, Pennsylvania 17120

Raymond L. Hovis, Esquire
35 South Duke Street
York, Pennsylvania 17401

Troy B. Conner, Jr.
Conner, Hadlock & Knotts
1747 Pennsylvania Avenue, NW
Washington, D. C. 20006

W. W. Anderson, Esquire
Deputy Attorney General
Department of Justice
Second Floor - Capitol Annex
Harrisburg, Pennsylvania 17120

John B. Griffith, Esquire
Special Assistant Attorney
General, Maryland
Annapolis, Maryland 31401

Warren Rich, Esquire
Special Assistant Attorney
General, Maryland
Annapolis, Maryland 21401

Mr: Robert Blanco
Environmental Protection Agency
Region III Office
Curtis Building
6th and Walnut Street
Philadelphia, Pennsylvania 19106

Mrs. Louisa R. Yeagley
Martin Memorial Library
159 E. Market Street
York, Pennsylvania 17401

Philadelphia Electric Company
ATTN: W. T. Ullrich
Peach Bottom Atomic Power Station
R. D. #1
Delta, Pennsylvania 17314

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PHILADELPHIA ELECTRIC COMPANY
PUBLIC SERVICE ELECTRIC AND GAS COMPANY
DELMARVA POWER AND LIGHT COMPANY
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-277

PEACH BOTTOM ATOMIC POWER STATION UNIT 2

PROPOSED AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No.
License No. DPR-44

1. The Nuclear Regulatory Commission (the Commission) has found that;
 - A. The application for amendment by Philadelphia Electric Company, Public Service Electric and Gas Company, Delmarva Power and Light Company, and Atlantic City Electric Company (the licensees) dated March 31, 1975, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations; and
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.
2. Accordingly, the license is amended by a change to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.(C).2 of Facility License No. DPR-44 is hereby amended to read as follows:



"(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications, as revised by issued changes thereto through Change No. "

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A. Giambusso, Director
Division of Reactor Licensing
Office of Nuclear Reactor Regulation

Attachment:
Change No.
Technical Specifications

Date of Issuance:

ATTACHMENT TO PROPOSED AMENDMENT NO.

CHANGE NO. TO THE TECHNICAL SPECIFICATIONS

FACILITY OPERATING LICENSE NO. DPR-44

DOCKET NO. 50-277

Delete pages 165, 166, 189 and 190 from the Appendix A Technical Specifications and insert the attached replacement pages 165, 165a, 166, 189, 190, and 190a. The change areas on the revised pages are shown by marginal lines.

3.7 CONTAINMENT SYSTEMS

Applicability:

Applies to the operating status of the primary and secondary containment systems.

Objective:

To assure the integrity of the primary and secondary containment systems.

Specification:

A. Primary Containment

1. At any time that the nuclear system is pressurized above atmospheric pressure or work is being done which has the potential to drain the vessel, the pressure suppression pool water volume and temperature shall be maintained within the following limits except as specified in 3.7.A.2.
 - a. Minimum water volume - 122,000 ft³
 - b. Maximum water volume - 136,000 ft³
 - c. Maximum suppression pool temperature;
 - (1) During normal power operation 90F.
 - (2) During testing which adds heat to the suppression pool, the water temperature shall not exceed 10F above normal power operation limit specified in (1) above. In connection with such testing, the pool temperature must be reduced to below the normal power operation limit specified in (1) above within 24 hours.

4.7 CONTAINMENT SYSTEMS

Applicability:

Applies to the primary and secondary containment integrity.

Objective:

To verify the integrity of the primary and secondary containment.

Specification:

A. Primary Containment

1. The suppression chamber water level and temperature shall be checked once per day.
2. Whenever there is indication of relief valve operation or testing which adds heat to the suppression pool, the pool temperature shall be continually monitored and also observed and logged every 5 minutes until the heat addition is terminated.
3. Whenever there is indication of relief valve operation with the temperature of the suppression pool reaching 160F or more and the primary coolant system pressure greater than 200 psig, an external visual examination of the suppression chamber shall be conducted before resuming power operation.
4. A visual inspection of the suppression chamber interior, including water line regions, shall be made at each major refueling outage.

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

- (3) The reactor shall be scrammed from any operating condition if the pool temperature reaches 110F. Power operation shall not be resumed until the pool temperature is reduced below the normal power operation limit specified in (1) above.
- (4) During reactor isolation conditions, the reactor pressure vessel shall be depressurized to less than 200 psig at normal cooldown rates if the pool temperature reaches 120F.

LIMITING CONDITIONS FOR OPERATION

3.7.A Primary Containment

2. Primary containment integrity shall be maintained at all times when the reactor is critical or when the reactor water temperature is above 212°F and fuel is in the reactor vessel except while performing "open vessel" physics tests at power levels not to exceed 5 Mw(t).
3. If the primary containment integrity is breached when it is required by 3.7.A.2, that integrity shall be reestablished within 24 hours or the reactor placed in a cold shutdown condition within 24 hours.

SURVEILLANCE REQUIREMENTS

4.7.A Primary Containment2. Integrated Leak Rate Testing

- a. Integrated leak rate tests (ILRT's) shall be performed to verify primary containment integrity. Primary containment integrity is confirmed if the leakage rate does not exceed the equivalent of 0.5 percent of the primary containment volume per 24 hours at 49.1 psig.
- b. Integrated leak rate tests may be performed at either 49.1 psig or 25 psig, the leakage rate test period, extending to 24 hours of retained internal pressure. If it can be demonstrated to the satisfaction of those responsible for the acceptance of the containment structure that the leakage rate can be accurately determined during a shorter test period, the agreed-upon shorter period may be used.

Prior to initial operation, integrated leak rate tests must be performed at 49.1 and 25 psig (with the 25 psig test being performed prior to the 49.1 psig test) to establish the allowable leak rate (in percent of containment volume per 24 hours) at 25 psig as the lesser of the following values:

(L_a is 0.5 percent)

$$L_t = 0.5 \frac{L_{tm}}{L_{pm}}$$

T.S. Change #2

3.7.A & 4.7.A BASESPrimary Containment

The integrity of the primary containment and operation of the core standby cooling system in combination, limit the off-site doses to values less than those suggested in 10CFR100 in the event of a break in the primary system piping. Thus, containment integrity is specified whenever the potential for violation of the primary reactor system integrity exists. Concern about such a violation exists whenever the reactor is critical and above atmospheric pressure. An exception is made to this requirement during initial core loading and while the low power test program is being conducted and ready access to the reactor vessel is required. There will be no pressure on the system at this time, thus greatly reducing the chances of a pipe break. The reactor may be taken critical during this period; however, restrictive operating procedures will be in effect again to minimize the probability of an accident occurring. Procedures and the Rod Worth Minimizer would limit control worth such that a rod drop would not result in any fuel damage. In addition, in the unlikely event that an excursion did occur, the reactor building and standby gas treatment system, which shall be operational during this time, offer a sufficient barrier to keep off-site doses well below 10CFR100 limits.

The pressure suppression pool water provides the heat sink for the reactor primary system energy release following a postulated rupture of the system. The pressure suppression chamber water volume must absorb the associated decay and structural sensible heat released during primary system blowdown from 1035 psig. Since all of the gases in the drywell are purged into the pressure suppression chamber air space during a loss-of-coolant accident, the pressure resulting from isothermal compression plus the vapor pressure of the liquid must not exceed 62 psig, the suppression chamber maximum pressure. The design volume of the suppression chamber (water and air) was obtained by considering that the total volume of reactor coolant to be condensed is discharged to the suppression chamber and that the drywell volume is purged to the suppression chamber.

Using the minimum or maximum water volumes given in the specification, containment pressure during the design basis accident is approximately 49.1 psig which is below the maximum of 62 psig. Maximum water volume of 136,000 ft³ results in a downcomer submergency of 5' and the minimum volume of 122,000 ft³ results in a submergency approximately 12 inches less. The majority of the Bodega tests were run with a submerged length of 4 feet and with complete condensation. Thus, with respect to downcomer submergency, this specification is adequate. The maximum temperature at the end of blowdown tested during the Humbolt Bay and Bodega Bay tests was 170°F and this is conservatively taken to be the limit for complete condensation of the reactor coolant, although condensation would occur for temperatures above 170°F.

3.7.A & 4.7.A BASES (Cont'd.)

Should it be necessary to drain the suppression chamber, this should only be done when there is no requirement for core standby cooling systems operability as explained in basis 3.5.F.

Experimental data indicates that excessive steam condensing loads can be avoided if the peak temperature of the suppression pool is maintained below 160F during any period of relief valve operation with sonic conditions at the discharge exit. Specifications have been placed on the envelope of reactor operating conditions so that the reactor can be depressurized in a timely manner to avoid the regime of potentially high suppression chamber loadings.

In addition to the limits on temperature of the suppression chamber pool water, operating procedures define the action to be taken in the event a relief valve inadvertently opens or sticks open. As a minimum this action shall include: (1) use of all available means to close the valve, (2) initiate suppression pool water cooling heat exchangers, (3) initiate reactor shutdown, and (4) if other relief valves are used to depressurize the reactor, their discharge shall be separated from that of the stuck-open relief valve to assure mixing and uniformity of energy insertion to the pool.

Because of the large volume and thermal capacity of the suppression pool, the volume and temperature normally changes very slowly and monitoring these parameters daily is sufficiently to establish any temperature trends. By requiring the suppression pool temperature to be continually monitored and frequently logged during periods of significant heat addition, the temperature trends will be closely followed so that appropriate action can be taken. The requirement for an external visual examination following any event where potentially high loadings could occur provides assurance that no significant damage was encountered. Particular attention should be focused on structural discontinuities in the vicinity of the relief valve discharge since these are expected to be the points of highest stress.

3.7.A & 4.7.A BASES (Cont'd.)Inerting

The relatively small containment volume inherent in the GE-BWR pressure suppression containment and the large amount of zirconium in the core are such that the occurrence of a very limited (a percent or so) reaction of the zirconium and steam during a loss-of-coolant accident could lead to the liberation of hydrogen combined with an air atmosphere to result in a flammable concentration in the containment. If a sufficient amount of hydrogen is generated and oxygen is available in stoichiometric quantities, the subsequent ignition of the hydrogen in rapid recombination rate could lead to failure of the containment to maintain a low leakage integrity. The 4% oxygen concentration minimizes the possibility of hydrogen combustion following a loss-of-coolant accident.

The occurrence of primary system leakage following a major refueling outage or other scheduled shutdown is much more probable than the occurrence of the loss-of-coolant accident upon which the specified oxygen concentration limit is based. Permitting access to the drywell for leak inspections during a startup is judged prudent in terms of the added plant safety offered without significantly reducing the margin of safety. Thus, to preclude the possibility of starting the reactor and operating for extended periods of time with significant leaks in the primary system, leak inspections are scheduled during startup periods, when the primary system is at or near rated operating temperature and pressure. The 24-hour period to provide inerting is judged to be sufficient to perform the leak inspection and establish the required oxygen concentration.

The primary containment is normally slightly pressurized during periods of reactor operation. Nitrogen used for inerting could leak out of the containment but air could not leak in to increase oxygen concentration. Once the

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PHILADELPHIA ELECTRIC COMPANY
PUBLIC SERVICE ELECTRIC AND GAS COMPANY
DELMARVA POWER AND LIGHT COMPANY
ATLANTIC CITY ELECTRIC COMPANY

DOCKET NO. 50-278

PEACH BOTTOM ATOMIC POWER STATION UNIT 3

PROPOSED AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No.
License No. DPR-56

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Philadelphia Electric Company, Public Service Electric and Gas Company, Delmarva Power and Light Company, and Atlantic City Electric Company (the licensees) dated March 31, 1975, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations; and
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.
2. Accordingly, the license is amended by a change to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.(C).2 of Facility License No. DPR-56 is hereby amended to read as follows:



"(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications, as revised by issued changes thereto through Change No. "

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A. Giambusso, Director
Division of Reactor Licensing
Office of Nuclear Reactor Regulation

Attachment:
Change No.
Technical Specifications

Date of Issuance:

ATTACHMENT TO PROPOSED AMENDMENT NO.
CHANGE NO. TO THE TECHNICAL SPECIFICATIONS
FACILITY OPERATING LICENSE NO. DPR-56
DOCKET NO. 50-278

Delete pages 165, 166, 189 and 190 from the Appendix A Technical Specifications and insert the attached replacement pages 165, 165a, 166, 189, 190, and 190a. The change areas on the revised pages are shown by marginal lines.

3.7 CONTAINMENT SYSTEMS

Applicability:

Applies to the operating status of the primary and secondary containment systems.

Objective:

To assure the integrity of the primary and secondary containment systems.

Specification:

A. Primary Containment

1. At any time that the nuclear system is pressurized above atmospheric pressure or work is being done which has the potential to drain the vessel, the pressure suppression pool water volume and temperature shall be maintained within the following limits except as specified in 3.7.A.2.
 - a. Minimum water volume - 122,000 ft³
 - b. Maximum water volume - 136,000 ft³
 - c. Maximum suppression pool temperature:
 - (1) During normal power operation 90F.
 - (2) During testing which adds heat to the suppression pool, the water temperature shall not exceed 10F above normal power operation limit specified in (1) above. In connection with such testing, the pool temperature must be reduced to below the normal power operation limit specified in (1) above within 24 hours.

4.7 CONTAINMENT SYSTEMS

Applicability:

Applies to the primary and secondary containment integrity.

Objective:

To verify the integrity of the primary and secondary containment.

Specification:

A. Primary Containment

1. The suppression chamber water level and temperature shall be checked once per day.
2. Whenever there is indication of relief valve operation or testing which adds heat to the suppression pool, the pool temperature shall be continually monitored and also observed and logged every 5 minutes until the heat addition is terminated.
3. Whenever there is indication of relief valve operation with the temperature of the suppression pool reaching 160F or more and the primary coolant system pressure greater than 200 psig, an external visual examination of the suppression chamber shall be conducted before resuming power operation.
4. A visual inspection of the suppression chamber interior, including water line regions, shall be made at each major refueling outage.

LIMITING CONDITIONS FOR OPERATIONSURVEILLANCE REQUIREMENTS

- (3) The reactor shall be scrammed from any operating condition if the pool temperature reaches 110F. Power operation shall not be resumed until the pool temperature is reduced below the normal power operation limit specified in (1) above.
- (4) During reactor isolation conditions, the reactor pressure vessel shall be depressurized to less than 200 psig at normal cooldown rates if the pool temperature reaches 120F.

LIMITING CONDITIONS FOR OPERATION3.7.A Primary Containment

2. Primary containment integrity shall be maintained at all times when the reactor is critical or when the reactor water temperature is above 212°F and fuel is in the reactor vessel except while performing "open vessel" physics tests at power levels not to exceed 5 Mw(t).
3. If the primary containment integrity is breached when it is required by 3.7.A.2, that integrity shall be reestablished within 24 hours or the reactor placed in a cold shutdown condition within 24 hours.

SURVEILLANCE REQUIREMENTS4.7.A Primary Containment2. Integrated Leak Rate Testing

- a. Integrated leak rate tests (ILRT's) shall be performed to verify primary containment integrity. Primary containment integrity is confirmed if the leakage rate does not exceed the equivalent of 0.5 percent of the primary containment volume per 24 hours at 49.1 psig.
- b. Integrated leak rate tests may be performed at either 49.1 psig or 25 psig, the leakage rate test period, extending to 24 hours of retained internal pressure. If it can be demonstrated to the satisfaction of those responsible for the acceptance of the containment structure that the leakage rate can be accurately determined during a shorter test period, the agreed-upon shorter period may be used.

Prior to initial operation, integrated leak rate tests must be performed at 49.1 and 25 psig (with the 25 psig test being performed prior to the 49.1 psig test) to establish the allowable leak rate (in percent of containment volume per 24 hours) at 25 psig as the lesser of the following values:

(L_a is 0.5 percent)

$$L_t = 0.5 \frac{L_{tm}}{E_{pm}}$$

3.7.A & 4.7.A BASESPrimary Containment

The integrity of the primary containment and operation of the core standby cooling system in combination, limit the off-site doses to values less than those suggested in 10CFR100 in the event of a break in the primary system piping. Thus, containment integrity is specified whenever the potential for violation of the primary reactor system integrity exists. Concern about such a violation exists whenever the reactor is critical and above atmospheric pressure. An exception is made to this requirement during initial core loading and while the low power test program is being conducted and ready access to the reactor vessel is required. There will be no pressure on the system at this time, thus greatly reducing the chances of a pipe break. The reactor may be taken critical during this period; however, restrictive operating procedures will be in effect again to minimize the probability of an accident occurring. Procedures and the Rod Worth Minimizer would limit control worth such that a rod drop would not result in any fuel damage. In addition, in the unlikely event that an excursion did occur, the reactor building and standby gas treatment system, which shall be operational during this time, offer a sufficient barrier to keep off-site doses well below 10CFR100 limits.

The pressure suppression pool water provides the heat sink for the reactor primary system energy release following a postulated rupture of the system. The pressure suppression chamber water volume must absorb the associated decay and structural sensible heat released during primary system blowdown from 1035 psig. Since all of the gases in the drywell are purged into the pressure suppression chamber air space during a loss-of-coolant accident, the pressure resulting from isothermal compression plus the vapor pressure of the liquid must not exceed 62 psig, the suppression chamber maximum pressure. The design volume of the suppression chamber (water and air) was obtained by considering that the total volume of reactor coolant to be condensed is discharged to the suppression chamber and that the drywell volume is purged to the suppression chamber.

Using the minimum or maximum water volumes given in the specification, containment pressure during the design basis accident is approximately 49.1 psig which is below the maximum of 62 psig. Maximum water volume of 136,000 ft³ results in a downcomer submergency of 5' and the minimum volume of 122,000 ft³ results in a submergence approximately 12 inches less. The majority of the Bodega tests were run with a submerged length of 4 feet and with complete condensation. Thus, with respect to downcomer submergence, this specification is adequate. The maximum temperature at the end of blowdown tested during the Humbolt Bay and Bodega Bay tests was 170°F and this is conservatively taken to be the limit for complete condensation of the reactor coolant, although condensation would occur for temperatures above 170°F.

3.7.A & 4.7.A BASES (Cont'd.)

Should it be necessary to drain the suppression chamber, this should only be done when there is no requirement for core standby cooling systems operability as explained in basis 3.5.F.

Experimental data indicates that excessive steam condensing loads can be avoided if the peak temperature of the suppression pool is maintained below 160F during any period of relief valve operation with sonic conditions at the discharge exit. Specifications have been placed on the envelope of reactor operating conditions so that the reactor can be depressurized in a timely manner to avoid the regime of potentially high suppression chamber loadings.

In addition to the limits on temperature of the suppression chamber pool water, operating procedures define the action to be taken in the event a relief valve inadvertently opens or sticks open. As a minimum this action shall include: (1) use of all available means to close the valve, (2) initiate suppression pool water cooling heat exchangers, (3) initiate reactor shutdown, and (4) if other relief valves are used to depressurize the reactor, their discharge shall be separated from that of the stuck-open relief valve to assure mixing and uniformity of energy insertion to the pool.

Because of the large volume and thermal capacity of the suppression pool, the volume and temperature normally changes very slowly and monitoring these parameters daily is sufficiently to establish any temperature trends. By requiring the suppression pool temperature to be continually monitored and frequently logged during periods of significant heat addition, the temperature trends will be closely followed so that appropriate action can be taken. The requirement for an external visual examination following any event where potentially high loadings could occur provides assurance that no significant damage was encountered. Particular attention should be focused on structural discontinuities in the vicinity of the relief valve discharge since these are expected to be the points of highest stress.

PBAPS

3.7.A & 4.7.A BASES (Cont'd.)

Inerting

The relatively small containment volume inherent in the GE-BWR pressure suppression containment and the large amount of zirconium in the core are such that the occurrence of a very limited (a percent or so) reaction of the zirconium and steam during a loss-of-coolant accident could lead to the liberation of hydrogen combined with an air atmosphere to result in a flammable concentration in the containment. If a sufficient amount of hydrogen is generated and oxygen is available in stoichiometric quantities, the subsequent ignition of the hydrogen in rapid recombination rate could lead to failure of the containment to maintain a low leakage integrity. The 4% oxygen concentration minimizes the possibility of hydrogen combustion following a loss-of-coolant accident.

The occurrence of primary system leakage following a major refueling outage or other scheduled shutdown is much more probable than the occurrence of the loss-of-coolant accident upon which the specified oxygen concentration limit is based. Permitting access to the drywell for leak inspections during a startup is judged prudent in terms of the added plant safety offered without significantly reducing the margin of safety. Thus, to preclude the possibility of starting the reactor and operating for extended periods of time with significant leaks in the primary system, leak inspections are scheduled during startup periods, when the primary system is at or near rated operating temperature and pressure. The 24-hour period to provide inerting is judged to be sufficient to perform the leak inspection and establish the required oxygen concentration.

The primary containment is normally slightly pressurized during periods of reactor operation. Nitrogen used for inerting could leak out of the containment but air could not leak in to increase oxygen concentration. Once the

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AMENDMENTS TO LICENSE NOS. DPR-44&DPR-56 AND CHANGE TO TECHNICAL SPECIFICATIONS

SUPPRESSION POOL WATER TEMPERATURE LIMITS

PHILADELPHIA ELECTRIC COMPANY

PEACH BOTTOM UNITS 2 & 3

DOCKETS NOS. 50-277/278

Introduction

By letter dated March 31, 1975, the licensee, Philadelphia Electric Company requested a change in the Technical Specifications appended to Operating License Nos. DPR-56 and DPR-44 for the Peach Bottom Units 2 & 3 located in Peach Bottom, Pennsylvania. The proposed change in Technical Specifications was submitted in response to our request to the licensee dated February 15, 1975 and is responsive to the guidelines set forth in our letter. We have made additional modifications to these proposed Technical Specifications to improve the clarity and intent of the specification and its basis. The proposed change in Technical Specifications defines new temperature limits for the suppression pool water to provide additional assurance of maintaining primary containment function and integrity in the event of extended relief valve operation.

Discussion

Peach Bottom Units 2 & 3 are boiling water reactors (BWR) which are housed in Mark I primary containments. The Mark I primary containment consists of a drywell and a pressure suppression chamber (also referred to as the torus). The pressure suppression chamber, or torus, contains a pool of water and is designed to reduce the pressure during a postulated loss-of-coolant accident (LOCA) by condensing the steam released from the reactor primary system. The reactor system energy released by relief valve operation during operating transients also is released into the pool of water in the torus.



Experiences at various BWR plants with Mark I containments have shown that damage to the torus structure can occur from two phenomena associated with relief valve operations. Damage can result from the forces exerted on the structure when, on first opening the relief valves, steam and the air within the vent are discharged into the torus water. This phenomenon is referred to as steam vent clearing. The second source of potential structural damage stems from the vibrations which accompany extended relief valve discharge into the torus water if the pool water is at elevated temperatures. This effect is known as the steam quenching vibration phenomenon.

1. Steam Vent Clearing Phenomenon

With regard to the steam vent clearing phenomenon, we are actively reviewing this generic problem and in our letter dated February 15, 1975, we also requested each applicable licensee to provide information to demonstrate that the torus structure will maintain its integrity throughout the anticipated life of the facility. Because of apparent slow progression of the material fatigue associated with the steam vent clearing phenomenon, we have concluded that there is no immediate potential hazard resulting from this type of phenomenon; nevertheless, surveillance and review action on this matter by the NRC staff will continue in due course during this year.

2. Steam Quenching Vibration Phenomenon

The steam quenching vibration phenomenon became a concern as a result of occurrences at two European reactors. With torus pool water temperatures increased in excess of 170F due to prolonged steam quenching from relief valve operation, hydrodynamic fluid vibrations occurred with subsequent moderate to high relief valve flow rates. These fluid vibrations produced large dynamic loads in the torus structure and extensive damage to torus internal structures. If allowed to continue, the dynamic loads could have resulted in structural damage to the torus itself, due to material fatigue. Thus, the reported occurrences of the steam quenching vibration phenomenon at the two European reactors indicate that actual or incipient failure of the torus can occur from such an event. Such failure would be expected to involve cracking of the torus wall and loss of containment integrity. Moreover, if a LOCA occurred simultaneously with or after such an event, the consequences could be excessive radiological doses to the public. In comparison with the steam vent clearing phenomenon, the potential risk associated with the steam quenching vibration phenomenon (1) reflects the fact that a generally smaller safety margin^{1/} exists between the present license requirements on suppression pool temperature limits and the point at which damage could begin and (2) is more immediate.

^{1/} The difference, in pool water temperature, between the license limit(s) and the temperature at which structural damage might occur is the safety margin available to protect against the effects of the phenomenon discussed.

Evaluation

The existing Technical Specifications for Peach Bottom Units 2 and 3 limit the torus pool temperature of 90F during normal power operation. This temperature limit assures that the pool water has the capability to perform as a constantly available heat-sink with a reasonable operating temperature that can be maintained by use of heat exchangers whose secondary cooling water (the service cooling water) is expected to remain well below 90F. While this 90F limit provides normal operating flexibility, short-term temperatures permitted by operating procedures exceed the normal power operating temperature limit, but accommodates the heat release resulting from abnormal operation, such as relief valve malfunction, while still maintaining the required heat-sink (absorption) capacity of the pool water needed for the postulated LOCA conditions. However, in view of the potential risk associated with the steam quenching vibration phenomenon, it is necessary to modify the temperature limits now in the license Technical Specifications.

This action was, as discussed in our February 15, 1975 letter, first suggested by the General Electric Company (GE) who had earlier informed us of the steam quenching vibration occurrences at a meeting on November 1, 1974 and provided related information by letters to us dated November 7, and December 20, 1974. The December 20 letter stated that GE had informed all of its customers with operating BWR facilities and Mark I containments of the phenomenon and included in those communications GE's recommended interim operating temperature limits and proposed operating procedures to minimize the probability of encountering the damaging regime of the steam quenching vibration phenomenon.

Implementation of the GE recommended procedures and temperature limits by the proposed change to the Technical Specifications has been evaluated by the NRC staff as follows:

- a. The new short-term limit applicable to all conditions requires that the reactor be scrammed if the torus pool water temperature reaches 110F. This new limit and associated requirement to scram the reactor provides additional margin below the 170F temperature related to potential damage to the torus.
- b. For specific requirements associated with surveillance testing, i.e., testing of relief valves, the water temperature shall not exceed 10F above the normal power operation limit. This new limit applicable to surveillance testing of relief valves and RCIC or HPCI operation provides additional operating flexibility while still maintaining a maximum heat-sink capacity. The current limits in the Technical Specifications is a maximum suppression pool water temperature of 130F.
- c. For reactor isolation conditions, the new temperature limit is 120F, above which temperature the reactor vessel is to be depressurized. This new limit of 120F assures pool capacity for absorption of heat released to the torus while avoiding undesirable reactor vessel cooldown transients. Upon reaching 120F, the reactor is placed in the cold, shutdown condition at the fastest rate consistent with the technical specifications on reactor pressure vessel cooldown rates.

- d. In addition to the new limits on temperature of the torus pool water, discussion in the Bases includes a summary of operator actions to be taken in the event of a relief valve malfunction. These operating actions are taken in order to avoid the development of temperatures approaching the 170F threshold for potential damage by the steam quenching phenomenon.

Conclusion

We have concluded, based on the consideration discussed above that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Dated: JUL 16 1975

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKETS NOS. 50-277 and 50-278

PHILADELPHIA ELECTRIC COMPANY
PUBLIC SERVICE ELECTRIC AND GAS COMPANY
DELMARVA POWER AND LIGHT COMPANY
ATLANTIC CITY ELECTRIC COMPANY

NOTICE OF PROPOSED ISSUANCE OF AMENDMENT
TO FACILITY OPERATING LICENSE

The Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating Licenses Nos. DPR-44 and DPR-56 issued to Philadelphia Electric Company, Public Service Electric and Gas Company, Delmarva Power and Light Company, and Atlantic City Electric Company (the licensees), for operation of the Peach Bottom Atomic Power Station Units 2 and 3, located in Peach Bottom, York County, Pennsylvania.

The amendment would revise the provisions in the Technical Specifications relating to the temperature limits for the pressure suppression pool water, in accordance with the licensee's application for amendment, dated March 31, 1975.

Prior to issuance of the proposed license amendment, the Commission will have made the findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations.

By **8/25/75** the licensee may file a request for a hearing and any person whose interest may be affected by this proceeding may file a request for a hearing in the form of a petition for leave to intervene with respect to the issuance of the amendment to the subject facility operating license. Petitions for leave to intervene must be filed

under oath or affirmation in accordance with the provisions of Section 2.714 of 10 CFR Part 2 of the Commission's regulations. A petition for leave to intervene must set forth the interest of the petitioner in the proceeding, how that interest may be affected by the results of the proceeding, and the petitioner's contentions with respect to the proposed licensing action. Such petitions must be filed in accordance with the provisions of this FEDERAL REGISTER notice and Section 2.714, and must be filed with the Secretary of the Commission, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Docketing and Service Section, by the above date. A copy of the petition and/or request for a hearing should be sent to the Executive Legal Director, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, and to Eugene J. Bradley, Philadelphia Electric Company, Assistant General Counsel, 2301 Market Street, Philadelphia, Pennsylvania 19101, the attorney for the licensee.

A petition for leave to intervene must be accompanied by a supporting affidavit which identifies the specific aspect or aspects of the proceeding as to which intervention is desired and specifies with particularity the facts on which the petitioner relies as to both his interest and his contentions with regard to each aspect on which intervention is requested. Petitions stating contentions relating only to matters outside the Commission's jurisdiction will be denied.

All petitions will be acted upon by the Commission or licensing board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel. Timely petitions will be considered to determine whether a hearing should be noticed or another appropriate


order issued regarding the disposition of the petitions.

In the event that a hearing is held and a person is permitted to intervene, he becomes a party to the proceeding and has a right to participate fully in the conduct of the hearing. For example, he may present evidence and examine and cross-examine witnesses.

For further details with respect to this action, see the application for amendment dated March 31, 1975, which is available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C. and at the Martin Memorial Library, 159 E. Market Street, York, Pennsylvania 17401. The license amendment and the Safety Evaluation may be inspected at the above locations and a copy may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Reactor Licensing.

Dated at Bethesda, Maryland 16th this July, 1975.

FOR THE NUCLEAR REGULATORY COMMISSION



George Lear, Chief
Operating Reactors Branch #3
Division of Reactor Licensing