

DEC 1 6 1976

Distribution

✓  
Pocket

ORB #3

Local PDR

NRC PDR

VStello

Kgoller

TJCarter

Glear

CParrish

Everdery

Twambach

Attorney, OELD

OIAE (3)

DEisenhut

TBAbernathy

JRBuchanan

Vice President and General Counsel

ACRS (16)

2301 Market Street

Philadelphia, Pennsylvania 19101

Gentlemen:

RE: PEACH BOTTOM ATOMIC POWER STATION UNITS NOS. 2 AND 3

We are enclosing a corrected Specification 4.7.11.2 that has

been sent to you as part of the Standard Technical Specifications

(STS) for Fire Protection by letter dated December 2, 1976.

Sincerely,

Original signed by

George Lear, Chief

Operating Reactors Branch #3

Division of Operating Reactors

Enclosure:

Specification 4.7.11.2

cc w/encl:

See next page

*Const*

DATE	12/ /76	12/ /76	12/ /76	12/ /76	12/ /76
SURNAME	Twambach:mj	Everdery	Glear		
OFFICE	ORB #1	ORB #3	ORB #3		

Philadelphia Electric Company

- 2 -

cc:

Eugene J. Bradley  
Philadelphia Electric Company  
Assistant General Counsel  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr.  
Conner and Knotts  
1747 Pennsylvania Avenue, N. W.  
Washington, D. C. 20006

Raymond L. Hovis, Esquire  
35 South Duke Street  
York, Pennsylvania 17401

Warren K. Rich, Esquire  
Assistant Attorney General  
Department of Natural Resources  
Annapolis, Maryland 21401

Martin Memorial Library  
159 E. Market Street  
York, Pennsylvania 17401

NOV 03 1976

PLANT SYSTEMS

SPRAY AND/OR SPRINKLER SYSTEMS

LIMITING CONDITION FOR OPERATION

3.7.11.2 The spray and/or sprinkler systems located in the following areas shall be OPERABLE:

- a.
- b. (Plant dependent)
- c.

APPLICABILITY: All modes

ACTIONS:

With a spray and/or sprinkler system inoperable establish a continuous fire watch with backup fire suppression equipment in the unprotected area(s), and

- 1. In MODES 1, 2, 3 or 4 restore the system to OPERABLE status within 7 days or be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.
- 2. In MODES 5 or 6 restore the system to OPERABLE status within 7 days or prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within the next 10 days outlining the cause of inoperability and the plans for restoring the system to OPERABLE status.

SURVEILLANCE REQUIREMENTS

4.7.11.2 The spray and/or sprinkler systems shall be demonstrated to be OPERABLE:

- a. At least once per 92 days by cycling each testable valve through one complete cycle.
- b. At least once per 12 months:
  - 1. By performing a system functional test which includes simulated automatic actuation of the system and verifying that the automatic valves in the flow path actuate to their correct positions.
  - 2. By inspection of spray headers to verify their integrity
  - 3. By inspection of each nozzle to verify no blockage.
- c. At least once per 5 years by an air flow test of the open head spray and/or sprinkler system.