

REGULATORY DOCKET FILE COPY

OCTOBER 4 1979

Docket Nos. 50-277
and 50-278 ←

Mr. Edward G. Bauer, Jr.
Vice President and General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Dear Mr. Bauer:

Distribution

✓ Docket
ORB #3
NRR Reading
Local PDR
NRC PDR
DEisenhut
RVollmer
BGrimes
WGammill
JMiller
LShao
Tippolito
DVerrelli
PKreutzer
Atty, OELD
I&E (5)
BJones
JRBuchanan, NSIC

TERA
DBrinkman
ACRS (16)

By letter dated September 17, 1979 we transmitted Amendments Nos. 59 and 59 to Facility Operating License Nos. DPR-44 and DPR-56 for the Peach Bottom Atomic Power Station Units 2 and 3. The amendments revised the Technical Specifications to delete the restriction on fuel decay time prior to movement of fuel elements from the reactor vessel to the spent fuel pool.

Technical Specification pages 228 which were transmitted with the Amendments were in error in that paragraph D of the Limiting Conditions for Operation was inadvertently deleted. Please substitute the enclosed Instruction sheets and pages 228 for those transmitted with Amendments Nos. 59 and 59.

Sincerely,

Original Signed by
T. A. Ippolito

Thomas A. Ippolito, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Enclosures:
Instruction Sheets and Technical
Specification pages 228

cc w/enclosures:
See page 2

ccp

7910230120 *CP3*

| | | | | | | |
|-----------|---------------|-----------|-----------|--|--|--|
| OFFICE > | ORB #3 | ORB #3 | ORB #3 | | | |
| SURNAME > | PKreutzer:mjf | DVerrelli | Tippolito | | | |
| DATE > | 10/ /79 | 10/ /79 | 10/ /79 | | | |

Mr. Edward G. Bauer, Jr.
Philadelphia Electric Company

- 2 -

October 4, 1979

cc:

Eugene J. Bradley
Philadelphia Electric Company
Assistant General Counsel
2301 Market Street
Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr.
1747 Pennsylvania Avenue, N. W.
Washington, D. C. 20006

Raymond L. Hovis, Esquire
35 South Duke Street
York, Pennsylvania 17401

Warren K. Rich, Esquire
Assistant Attorney General
Department of Natural Resources
Annapolis, Maryland 21401

Philadelphia Electric Company
ATTN: Mr. W. T. Ullrich
Peach Bottom Atomic
Power Station
Delta, Pennsylvania 17314

Mr. R. A. Heiss, Coordinator
Pennsylvania State Clearinghouse
Governor's Office of State Planning
and Development
P. O. Box 1323
Harrisburg, Pennsylvania 17120

Albert R. Steel, Chairman
Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, Pennsylvania 17314

Edward Greenman
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Peach Bottom Atomic Power Station
P. O. Box 399
Delta, Pennsylvania 17314

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)

US EPA
Crystal Mall #2
Arlington, Virginia 20460

Region III Office
ATTN: EIS COORDINATOR
Curtis Building (Sixth Floor)
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

M. J. Cooney, Superintendent
Generation Division - Nuclear
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Government Publications Section
State Library of Pennsylvania
Education Building
Commonwealth and Walnut Streets
Harrisburg, Pennsylvania 17126

ATTACHMENT TO LICENSE AMENDMENT NO. 59

FACILITY OPERATING LICENSE NO. DPR-44

DOCKET NO. 50-277

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by amendment number and contains vertical lines indicating the area of change.

Remove

228

Insert

228

LIMITING CONDITIONS FOR OPERATIONSURVEILLANCE REQUIREMENTS

3.10.B (Cont'd.)

1. The SRM shall be inserted to the normal operating level. (Use of special moveable, dunking type detectors during initial fuel loading and major core alterations in place of normal detectors is permissible as long as the detector is connected to the normal SRM circuit.)
2. The SRM shall have a minimum of 3 cps with all rods fully inserted in the core.

C. Spent Fuel Pool Water Level

Whenever irradiated fuel is stored in the spent fuel pool, the pool water level shall be maintained at or above 8 1/2' above the top of the fuel.

D. Heavy Loads Over Spent Fuel

Loads in excess of 1000 lbs (excluding the rigging and transport vehicle) shall be prohibited from travel over fuel assemblies in the spent fuel storage pool.

4.10.B (Cont'd.)

C. Spent Fuel Pool Water Level

Whenever irradiated fuel is stored in the spent fuel pool, the water level shall be recorded daily.

ATTACHMENT TO LICENSE AMENDMENT NO. 59

FACILITY OPERATING LICENSE NO. DPR-56

DOCKET NO. 50-278

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by amendment number and contains vertical lines indicating the area of change.

Remove

228

Insert

228

LIMITING CONDITIONS FOR OPERATIONSURVEILLANCE REQUIREMENTS

3.10.B (Cont'd.)

1. The SRM shall be inserted to the normal operating level. (Use of special moveable, dunking type detectors during initial fuel loading and major core alterations in place of normal detectors is permissible as long as the detector is connected to the normal SRM circuit.)
2. The SRM shall have a minimum of 3 cps with all rods fully inserted in the core.

C. Spent Fuel Pool Water Level

Whenever irradiated fuel is stored in the spent fuel pool, the pool water level shall be maintained at or above 8 1/2' above the top of the fuel.

D. Heavy Loads Over Spent Fuel

Loads in excess of 1000 lbs (excluding the rigging and transport vehicle) shall be prohibited from travel over fuel assemblies in the spent fuel storage pool.

4.10.B (Cont'd.)

C. Spent Fuel Pool Water Level

Whenever irradiated fuel is stored in the spent fuel pool, the water level shall be recorded daily.