


August 28, 1960

To : The Honorable John A. McCone
From : ACRS
Subject: REACTOR SITE CRITERIA

1 You have asked that we supply you with a set of
2 criteria which could be used for judging the adequacy of pro-
3 posed sites for reactors. The ACRS has devoted considerable
4 time to this problem and has appointed a subcommittee which
5 also has devoted considerable time. A large part of our delay
6 in submitting site criteria stems from the fact that we believe
7 it is premature to establish quantitative limits on the variables
8 involved in site evaluations - especially if such limits will
9 appear in federal regulations. We recognize that the correctness
10 of the numbers which could be selected now cannot be proved by
11 experimental backup; and, therefore, these numbers give a false
12 sense of positiveness which cannot be supported upon detailed
13 scrutiny. Numbers chosen now will be expected to change as more
14 information develops. For example, a quantitative calculation
15 of dosage must include some estimate of the fraction of the total
16 fission product inventory which may be air-borne. This fraction
17 is currently under experimental examination and will be subject
18 to rapid change. The committee believes that the immutability of
19 quantitative numbers will stifle progress toward a better selection
20 of numbers. It is very true that the ideas and interpretations
21 from applicants themselves have played a major part in the for-
22 mulation of the current bases for site evaluation. It would be a
23 significant loss to stop the flow of new ideas from the applicants.
24 The committee also expects that the appearance of quantitative
25 numbers in a federal regulation will reduce the continual awareness
26 of the applicant that he has assumed a responsibility to be alert
27 to and to act on unforeseen disadvantages of a site even after the
28 site has been approved. The committee therefore advises that a
29 quantitative statement of site criteria not be included in federal
30 regulations. These comments do not mean that the ACRS has no bases
31 for judging the adequacy of sites. They merely emphasize that site
32 selection is still largely a matter of judgment.

33 Inasmuch as the ACRS has been making judgments on sites,
34 it may be helpful to review the framework on which these judgments
35 are being made.

36 It is a prerequisite, of course, that the reactor be
37 carefully designed, constructed, and inspected in a manner

 C/6

August 28, 1960

1 equivalent to that given boilers, bridges, and other structures
2 which may present public hazards. Also, these site criteria
3 are applicable only to those reactors on which definitive
4 experience has been developed. Reactors which are novel in
5 design or unproved as prototypes belong at isolated sites.
6 Thus, current site criteria are pertinent primarily to
7 pressurized water reactors, boiling water reactors, sodium
8 cooled thermal reactors, and organic moderated reactors-using
9 standard containment vessels.

10 Our site evaluations stem from several concepts.
11 These are overlapping, but not ~~a conflict~~: *of which*

12 (1) Almost everyone off-site should have a reasonably
13 good chance of not being seriously hurt if a credible reactor
14 accident should occur.

15 (2) The exposure to society in terms of integrated
16 man-remS should not be such as to cause a large shortening of
17 integrated lifetime or a significant genetic damage or a
18 significant increase in leukemia - should a credible reactor
19 accident occur.

20 (3) There should be an explicitly defined value to
21 society resulting from locating a plant at a proposed site,
22 rather than in a more isolated area.

23 (4) Should the most serious accident possible (not
24 credible) occur, the numbers of people killed should not be
25 catastrophic.

26 Incidentally, we reject, as premature, the concept
27 that damage to people from reactor accidents be no greater than
28 that accepted in other industries, although in the future this
29 might become a guiding principle. The reasons for this rejection
30 are twofold: We do not have sufficient information on the
31 probability of accidents to make use of this concept in site
32 evaluations. We do use, of course, the fact that the probability
33 of a serious accident is very low. Secondly, we recognize that
34 the atomic power business has not yet reached the status of
35 supplying an economic need in a manner similar to that of more
36 mature industries; and, therefore, arguments of taking customary
37 risks for the greater good of the public are somewhat weak. At
38 the same time, we do not want to imply that the restrictions
39 placed on site locations during the development life of atomic
40 power will necessarily be carried over to the period of maturity
41 of the atomic power industry.

42 The reduction of these concepts to a judgment as to
43 the adequacy of a proposed site requires further logic and the

August 28, 1960

introduction of some numerical estimates. We believe that the soul-searching analysis which is necessary at this stage should be done independently by the owner of the reactor, using the characteristics which are peculiar to his site and to his specific reactor. This step, we believe, is essential to developing his continuing alertness of his responsibility to the community surrounding the site. However, in committee deliberation, we balance his analysis against a generalized accident situation which serves the purpose of a reference point from which we can better understand the analysis submitted by the applicant.

Our generalized accident analysis assumes that a serious accident has occurred and predicts in rough terms the consequences of such an analysis. It is obvious that the generalized accident is an arbitrary artifact subject to change and has value only so far as it aids judgment. In the generalized accident, we must make numerical assumptions as to the amount and rate of radioactivity released (the source term), the dispersal of the radioactivity in the air and in the hydrosphere, and the effect of this radioactivity on people.

Source Term

An arbitrary accident is assumed to occur which results in the release of fission products into the containment shell. Roughly 100% of the total radioactive inventory gases, 50% of the halogens, and 5% of the bone seekers are assumed to be so released. It is then assumed that this mixture leaks out of containment sphere at a rate defined by the designed leak rate of the container. The reasoning back of this source term is admittedly loose. It stems primarily from a present inability to be convinced that coolant cannot be lost somehow from the reactor core, either by spontaneous fracture of some element in the primary system or by a fracture caused by mal-operation (instrumental or human) of the control rods. It is also tacitly assumed that in this accident the containment vessel will not rupture. The logic behind this assumption is that we require all of the components restraining the pressure of the primary system to be operating at temperatures above their nil-ductility temperature. We are therefore more confident, but not certain, that failure will occur by tearing rather than by brittle-fracture and that the probability of ejection of missiles which penetrate the containment shell is low. The necessary supporting structures and shielding also protect against missile damage.

Dispersal of the Radioactivity

Meteorology

In the generalized accident, we assume a Gaussian-type dilution of airborne activity using constants which reflect

1 unfavorable wind conditions, rather than average wind con-
2 ditions. The constants are a function of the local topography.
3 Those proposed by HEB, with the advice of the U.S. Weather
4 Bureau, are adequate for the generalized accident out to
5 10-20 miles. At about this distance, the constancy of wind
6 direction is lessened so that the air-borne radioactivity is
7 considered to be more or less uniformly distributed over a
8 large arc such as 45 to 60°.

9 Hydrology

10 The model for dispersal by hydrology is largely
11 influenced by the idea that the reactor complex should be
12 designed so that water movement can be stopped if the movement
13 is fast; and, if it is slow, such as percolation through the
14 ground, there is no need to expose people to this radioactivity
15 since plenty of time remains to take action. Thus, for any
16 site it is a requisite that ground water flows be amenable to
17 damming, and it must be established that underground flows are
18 slow and do not connect readily with water supply systems.

19 Effect of Radioactivity on People

20 The upper limit to the exposure to the public in the
21 generalized accident should be no higher than the maximum one -
22 in-a-lifetime emergency dose. This level has not been officially
23 set by AEC. We are arbitrarily choosing a figure of about 25 r
24 whole body or equivalent integrated dose for this level. This
25 figure is mentioned in Handbook 59 of the National Bureau of
26 Standards, Pages 69-70. It is also about what an adult individual
27 will have received at death from background radiation. The dosage
28 so far mentioned refers to limits to people when the people are
29 considered as independent individuals. When large numbers of
30 individuals are exposed to radiation, another limit also exists
31 because of genetic effects and because of the statistical nature
32 of induced leukemia and the shortening of the life span. The
33 limits of exposure to large groups of people are better expressed
34 in terms of integrated man-rem. We are tentatively using a
35 figure of 10⁷ man-rem for this limit for the people who might be
36 exposed to radiation doses falling between 1 and 25 rem.

37 The implication of these numbers is this. About a
38 reactor site, there should be an exclusion radius in which no one
39 resides. Surrounding this, there should be a region of low
40 population density, so low that individuals can be evacuated if
41 the need arises in a time which will prevent their receiving
42 more than a dose of 25 r. Beyond this evacuation area, there
43 should be no large cities (about 10,000) sufficiently close so
44 that the individuals in these cities might receive more than the
45 lower of the following: (1) 10⁷ man-rem in the generalized
46 accident, (2) 400 rem under the extremely improbable accident
47 in which the containment sphere fails completely to restrain all
48 radioactivity.

August 28, 1960

1 It is apparent that the committee is accepting for
2 its generalized accident that presented by HEB, plus the
3 addition of a restriction on total man-rems when large numbers
4 of people are exposed to low levels of radiation. The major
5 and important difference between the viewpoint of the ACRS and
6 that of HEB concerns the formalization of the generalized
7 accident into regulations. The committee wishes to emphasize
8 that it recommends against entering quantitative numbers into
9 the regulations on site locations at the present time because
10 the numbers have much less experimental backup than most other
11 numbers given regulation status.

12 We think it much more desirable to include in the
13 regulations general statements of site criteria. These general
14 statements, of course, can take any one of a number of different
15 forms. As a suggestion, the committee is presenting an attach-
16 ment to this letter - General Site Criteria - which we believe
17 to be adequate for the current need. In addition, we think that
18 it is highly desirable that individuals in HEB (and other informed
19 AEC employes) present as technical papers, but not as regulations,
20 their working approach to making judgments on the adequacy of
21 proposed reactor sites.

WPC:jmb
Attach.

GENERAL SITE CRITERIA

1 In judging whether or not a given site is suitable,
2 the following factors must be taken into consideration.

- 3 1. The amount of radioactive materials which
4 will be contained in the reactor under
5 planned conditions of operation - primarily
6 determined by the power level of the reactor
7 and the length of operating cycle.
- 8 2. The characteristics of the reactor, including
9 the reactor design, materials of construction,
10 and method of operation.
- 11 3. The probability and nature of release of
12 radioactive material. These quantities can
13 be bracketed from an intensive analysis of
14 what might fail in the reactor for any
15 reason whatsoever. Consideration should be
16 focused upon reactor design, materials of
17 construction, adequacy of inspection, method
18 of operation, and also on the experience
19 which has been gained from the operation of
20 this type and similar types of reactors.
- 21 4. The features of the surrounding environment
22 which may be damaged by the release of
23 radioactive material, including damage to
24 people, contamination of water supplies,
25 and the contamination of ground and crops.

26 It is emphasized that all power reactor plants should
27 be built in accordance with the best conservative engineering
28 principles and using materials which are of high quality.
29 These plants should be designed so that assurance can be given
30 that there will be no failure of their equipment, in the same
31 sense that assurance can be given that there will be no failure
32 of bridges, boilers, locomotives, automobiles, etc. Reactor
33 plants of types with which there is limited experience will be
34 required to be located in areas of low population density and
35 remote from important water supplies or cities or crops, unless
36 it can be shown that reliable barriers or devices will be used
37 to cope with the results of failures within the plant due to
38 unforeseen causes in compensation for the poor location.

39 In selecting the balance between designed safeguards and
40 isolation which these plants must have to provide an adequate
41 margin of safety against accidents which will endanger people,
42 consideration should be given to the damage which might result
43 from the maximum credible release of radioactivity.

General Site Criteria
Page 2

1 First, persons living in the immediate vicinity of the
2 exclusion area of the reactor plant may be subject to relative
3 high rates of radiation dosage. The estimated dose delivered
4 to these people should not exceed 25 rem to the whole body or
5 equivalent for meteorological conditions somewhat more pessi-
6 mistic than average conditions for the site. Accordingly, it
7 should be supportable that these people can take appropriate
8 action, such as evacuation or entering suitable shelters so
9 that almost everyone would have a reasonable chance of escaping
10 serious injury. This infers that a relatively few people would
11 be involved.

12 Second, the release of radioactive material should not
13 expose people to radiation doses which will result in a
14 statistically significant increase in leukemia or shortening
15 of life to large numbers of people.

16 Third, large numbers of people should not be exposed to
17 radiation doses which will significantly affect the genetic pool.

Handwritten notes:
18
19
20