

Posted
Correction to

Dockets Nos. 50-277/278

Mr. Edward G. Bauer, Jr.
Vice President & General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Dear Mr. Bauer:

DISTRIBUTION
Docket File
NRC PDR
Local PDR
PD#2 Reading File
RBernero
OGC-Bethesda
OPA
LHarmon
ACRS (10)
NThompson

Amat. 125 to DPR-56
TBarnhard (8)
EJordan
BGrimes
WJones
EButcher
LFMB
JPartlow
SNorris
RClark
PD#2 Plant File

On September 12, 1986, the Commission issued Amendments Nos. 121 and 125 to Facility Operating Licenses Nos. DPR-44 and DPR-56 for the Peach Bottom Atomic Power Station, Units Nos. 2 and 3. Page 214a included in the Amendments inadvertently did not reflect the changes approved in Amendments Nos. 115 and 119. The correct page 214a is enclosed for incorporation in the Technical Specifications.

We regret any inconvenience this change may have created.

Sincerely,

Original signed by
Richard J. Clark

Richard J. Clark, Project Manager
BWR Project Directorate #2
Division of BWR Licensing

Enclosures:
Page 214a for Units 2 and 3

cc w/enclosure:
See next page

OFFICIAL RECORD COPY

DBL:PD#2
SNorris
10/29/86

DBL:PD#2
RClark:cb
10/29/86

~~OGC - Bethesda~~
~~10/ /86~~

DBL:PD#2
DMuller
10/29/86

Mr. E. G. Bauer, Jr.
Philadelphia Electric Company

Peach Bottom Atomic Power Station,
Units 2 and 3

cc:

Mr. Eugene J. Bradley
Assistant General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr., Esquire
1747 Pennsylvania Avenue, N.W.
Washington, D.C. 20006

Thomas A. Deming, Esquire
Assistant Attorney General
Department of Natural Resources
Annapolis, Maryland 21401

Mr. R. Fleishmann, II, Manager
Peach Bottom Atomic Power Station
R. D. #1
Delta, Pennsylvania 17314

Mr. G. M. Leitch, Superintendent
Nuclear Generation Division
57-1
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Mr. Anthony J. Pietrofitta, General Manager
Power Production Engineering
Atlantic Electric
Post Office Box 1500
1199 Black Horse Pike
Pleasantville, New Jersey 08232

Resident Inspector
U.S. Nuclear Regulatory Commission
Peach Bottom Atomic Power Station
Post Office Box 399
Delta, Pennsylvania 17314

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. R. A. Heiss, Coordinator
Pennsylvania State Clearinghouse
Governor's Office of State Planning
and Development
Post Office Box 1323
Harrisburg, Pennsylvania 17120

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
Post Office Box 2063
Harrisburg, Pennsylvania 17120

Mr. Albert R. Steel, Chairman
Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, Pennsylvania 17314

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

6. The concentration of hydrogen downstream of the recombiners shall be limited to less than or equal to 2% by volume.
- With the concentration of hydrogen downstream of the recombiner greater than 2% but less than or equal to 4% by volume, restore the concentration to within the limit within 48 hours.
 - With the concentration of hydrogen downstream of the recombiner greater than 4% by volume, an orderly reduction of power shall be initiated within one hour to bring the hydrogen downstream of the recombiner to less than or equal to 2% by volume.
 - Except as specified in 3.8.C.6.d, two hydrogen monitors downstream of the recombiners shall be operable during power operation.
 - With the number of hydrogen monitors operable one less than required, operation may continue for up to 14 days provided grab samples are taken and analyzed daily. With both hydrogen monitors inoperable, operation may continue for up to 14 days provided grab samples are taken and analyzed every 4 hours during power operation.
6. *The concentration of hydrogen downstream of the recombiners shall be limited to less than or equal to 4% by volume.
- *With the concentration of hydrogen downstream of the recombiner greater than 4%, restore the concentration to within the limit within 48 hours.
 - *Except as specified in 3.8.C.6.c, one hydrogen monitor downstream of the recombiner shall be operable during power operation.
 - *With the number of hydrogen monitors operable less than required, operation may continue for up to 30 days provided grab samples are taken and analyzed every 4 hours during power operation.
- 6a. An instrument check of the operation of the hydrogen monitors shall be performed once per day.
- 6b. The hydrogen monitors and associated alarms downstream of the recombiner shall be calibrated once per month.
- 6c. Calibration shall include the use of standard gas samples containing a nominal:
- 1% hydrogen, balance nitrogen by volume.
 - 4% hydrogen, balance nitrogen by volume.
- *To become effective upon completion of the installation of the ambient charcoal treatment system.

LIMITING CONDITIONS FOR OPERATION

SURVEILLANCE REQUIREMENTS

6. The concentration of hydrogen downstream of the recombiners shall be limited to less than or equal to 2% by volume.
- With the concentration of hydrogen downstream of the recombiner greater than 2% but less than or equal to 4% by volume, restore the concentration to within the limit within 48 hours.
 - With the concentration of hydrogen downstream of the recombiner greater than 4% by volume, an orderly reduction of power shall be initiated within one hour to bring the hydrogen downstream of the recombiner to less than or equal to 2% by volume.
 - Except as specified in 3.8.C.6.d, two hydrogen monitors downstream of the recombiners shall be operable during power operation.
 - With the number of hydrogen monitors operable one less than required, operation may continue for up to 14 days provided grab samples are taken and analyzed daily. With both hydrogen monitors inoperable, operation may continue for up to 14 days provided grab samples are taken and analyzed every 4 hours during power operation.
6. *The concentration of hydrogen downstream of the recombiners shall be limited to less than or equal to 4% by volume.
- *With the concentration of hydrogen downstream of the recombiner greater than 4%, restore the concentration to within the limit within 48 hours.
 - *Except as specified in 3.8.C.6.c, one hydrogen monitor downstream of the recombiner shall be operable during power operation.
 - *With the number of hydrogen monitors operable less than required, operation may continue for up to 30 days provided grab samples are taken and analyzed every 4 hours during power operation.
- 6a. An instrument check of the operation of the hydrogen monitors shall be performed once per day.
- 6b. The hydrogen monitors and associated alarms downstream of the recombiner shall be calibrated once per month.
- 6c. Calibration shall include the use of standard gas samples containing a nominal:
- 1% hydrogen, balance nitrogen by volume.
 - 4% hydrogen, balance nitrogen by volume.
- *To become effective upon completion of the installation of the ambient charcoal treatment system.