Mr. George A. Hunger, Jr. Director-Licensing, MC 62A-1 PECO Energy Company Nuclear Group Headquarters Correspondence Control Desk P.O. Box No. 195 Wayne, Pennsylvania 19087-0195

SUBJECT: APPENDIX J EXEMPTION FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT 3 (TAC NO. M91731)

Dear Mr. Hunger:

. · . -

The Commission has issued the enclosed Exemption from certain requirements of Appendix J to 10 CFR Part 50 for the Peach Bottom Atomic Power Station, Unit 3 in response to your letter dated February 22, 1995. The exemption permits a one-time 60-day extension of the test period for Type B and C tests for certain containment penetrations described in your letter. The bases for our findings are contained in the enclosed Safety Evaluation.

A copy of the Exemption is being forwarded to the Office of the Federal Register for publication.

Sincerely,

Joseph W. Shea, Project Manager Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket No. 50-278

Enclosures:

- 1. Exemption
- 2. Safety Evaluation

cc w/enclosures: See next page Enclosures: 1. Exemption 2. Safety Evaluation cc w/enclosures: See next page	9505150104 PDR ADOCK P	750425 050002 PD	- R R R R R R R R R R R R R R R R R R		COPY	
DISTRIBUTION:	FJordan	0	GC	ΟΡΑ		
PUBLIC	SVarga	V	McCree, EDC) OC/LFD	СВ	
PDI-2 Reading	JZwolinski	A	CRS(4)	RBarre	tt	103
WRUSSell/FM1ragl1a P7immerman	JStolz	() ()	Anderson, H DA	(GN-1		
Jl jeberman	MO'Brien (2)	i Gi	$H_{11}(2)$			/
N/		,		X		
PDI-2:LAN PDI-2:PM	SCSB/BC+	DGC	P&I-2:AD	ADRYTON	DEDRHE	
MO'Brien Skearavl	RBarrett (Marco	JStolz	JZwo inski	SVarga	
3/21/95 2/11/95	3/23/95	t/6/95	4/1095	1/x1795	a 1/95	
OFFICIAL RECORD COPY			Ϋ́Ι.		$\langle \mathbf{U} \rangle$	
FILENAME: c:\PEACH\TYP	EBC.EXM					611
1200	02				\mathcal{D}	KUL .
					6	i



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

April 25, 1995

Mr. George A. Hunger, Jr. Director-Licensing, MC 62A-1 PECO Energy Company Nuclear Group Headquarters Correspondence Control Desk P.O. Box No. 195, Wayne, Pennsylvania 19087-0195

SUBJECT: APPENDIX J EXEMPTION FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT 3 (TAC NO. M91731)

Dear Mr. Hunger:

The Commission has issued the enclosed Exemption from certain requirements of Appendix J to 10 CFR Part 50 for the Peach Bottom Atomic Power Station, Unit 3 in response to your letter dated February 22, 1995. The exemption permits a one-time 60-day extension of the test period for Type B and C tests for certain containment penetrations described in your letter. The bases for our findings are contained in the enclosed Safety Evaluation.

A copy of the Exemption is being forwarded to the Office of the Federal Register for publication.

Sincerely.

Joseph W. Shea, Project Manager Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket No. 50-278

Enclosures:

- 1. Exemption
- 2. Safety Evaluation

cc w/enclosures: See next page Mr. George A. Hunger, Jr. PECO Energy Company

cc:

J. W. Durham, Sr., Esquire Sr. V.P. & General Counsel PECO Energy Company 2301 Market Street, S26-1 Philadelphia, Pennsylvania 19101

PECO Energy Company ATTN: Mr. G. R. Rainey, Vice President Peach Bottom Atomic Power Station Route 1, Box 208 Delta, Pennsylvania 17314

PECO Energy Company ATTN: Regulatory Engineer, A4-5S Peach Bottom Atomic Power Station Route 1, Box 208 Delta, Pennsylvania 17314

Resident Inspector U.S. Nuclear Regulatory Commission Peach Bottom Atomic Power Station P.O. Box 399 Delta, Pennsylvania 17314

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406

Mr. Roland Fletcher Department of Environment 201 West Preston Street Baltimore, Maryland 21201

A. F. Kirby, III External Operations - Nuclear Delmarva Power & Light Company P.O. Box 231 Wilmington, DE 19899 Peach Bottom Atomic Power Station, Units 2 and 3

Mr. Rich R. Janati, Chief Division of Nuclear Safety Pennsylvania Department of Environmental Resources P. O. Box 8469 Harrisburg, Pennsylvania 17105-8469 Board of Supervisors Peach Bottom Township R. D. #1 Delta, Pennsylvania 17314 Public Service Commission of Maryland **Engineering Division** Chief Engineer 6 St. Paul Centre Baltimore, MD 21202-6806 Mr. Richard McLean Power Plant and Environmental **Review** Division Department of Natural Resources B-3, Tawes State Office Building Annapolis, Maryland 21401 Mr. John Doering, Chairman Nuclear Review Board

Nuclear Review Board PECO Energy Company 965 Chesterbrook Boulevard Mail Code 63C-5 Wayne, Pennsylvania 19087

Dr. Judith Johnsrud National Energy Committee Sierra Club 433 Orlando Avenue State College, PA 16803

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

In the Matter of

PECO ENERGY COMPANY PUBLIC SERVICE ELECTRIC AND GAS COMPANY DELMARVA POWER AND LIGHT COMPANY ATLANTIC CITY ELECTRIC COMPANY

Docket No. 50-278

(Peach Bottom Atomic Power Station, Unit 3)

EXEMPTION

Ι.

PECO Energy Company, et al. (PECo, the licensee), is the holder of Operating License No. DPR-56, which authorizes operation of the Peach Bottom Atomic Power Station, Unit 3, at steady state reactor core power levels not in excess of 3293 megawatts thermal. The license provides, among other things, that the licensee is subject to the rules, regulations and orders of the Commission now or hereafter in effect.

The plant is a boiling water reactor located at the licensee's site in York County, Pennsylvania.

II.

Section 50.54(o) of 10 CFR Part 50 requires that primary reactor containments for water cooled power reactors be subject to the requirements of Appendix J to 10 CFR Part 50. Appendix J contains the leakage test requirements, schedules, and acceptance criteria for tests of the leak tight integrity of the primary reactor containment and systems and components which penetrate the containment.

9505150129 950425 PDR ADOCK 05000278 PDR PDR Section III.D.2(a) of Appendix J to 10 CFR Part 50 requires that Type B leak rate tests, except for air locks, be performed during reactor shutdown for refueling, or other convenient intervals, but in no case at intervals greater than 2 years. Type B tests are intended to detect local leaks and to measure leakage across each pressure-containing or leakage-limiting boundary for certain reactor containment penetrations.

Section III.D.3 of Appendix J to 10 CFR Part 50 requires that Type C leak rate tests be performed during each reactor shutdown for refueling but in no case at intervals greater than 2 years. Type C tests are intended to measure containment isolation valve leakage rates for certain containment isolation valves.

III.

By letter dated February 22, 1995, the licensee requested a one-time exemption from the requirements of Appendix J, Sections III.D.2(a) and III.D.3 for a period of 60 days for the isolation valves or leakage boundaries for 80 penetrations. In its request, the licensee provided a list of the affected penetrations and associated plant-specific leak test procedures, the date when the leak tests had last been performed and the date when the current leak test will expire.

The licensee has implemented a 24-month operating cycle schedule at the Peach Bottom facility. The last refueling outage for Unit 3, 3RO9, commenced in September 1993 and ended in November 1993 and the next refueling outage, 3R10 is scheduled to commence no later than September 30, 1995. The leak tests for which the licensee has requested schedular exemption were last

- 2 -

conducted during refueling outage 3R09, based on the information provided in the licensee's application. The licensee has stated that the affected leak tests require either that safety systems be isolated or require access to the drywell, either of which would require the reactor to be shutdown.

The licensee has divided the affected leak tests into two categories: 1) those that require shutdown reactor conditions but come due prior to the latest scheduled commencement of 3R10 on September 30, 1995, and 2) those that require reactor shutdown conditions and come due after the scheduled commencement of 3R10. There are 52 leak test surveillance procedures affecting 47 penetrations or penetration groups in the first category. These tests and penetrations are listed in Table 1 of the licensee's February 22, 1995 request. The earliest of these tests falls due on August 12, 1995, up to 49 days prior to the scheduled shutdown. The licensee has requested an exemption for 60 days which will allow the unit to operate until the beginning of the planned outage without shutting down to perform leak tests and which will allow for flexibility in planning the leak tests during the outage.

There are 28 leak test surveillance procedures affecting 29 penetrations in the second category described previously. These tests are listed in Table 2 of the licensee's February 22, 1995 submittal. The licensee has requested an exemption of 60 days to allow for flexibility in planning these leak tests during the outage. The licensee stated that all of the affected penetrations will be leak tested prior to restart from 3R10.

- 3 -

- 4 -

The licensee presented information in support of its request for a 60-day extension of the Type B and C test intervals. The maximum allowable leakage rate for maintaining primary containment (L_a - minimum pathway leakage) is 125,417 cc/min. The as-found total Type B and C minimum pathway leakage rate observed during Unit 3 refueling outage 3RO9 during the fall of 1993 was 33,434 cc/min. The as-left leak rate for that same outage was 27,188 cc/min.

PECo stated that an extension of the leak test interval to allow for 49 days of operation is not likely to significantly decrease the margin between as-found leak rates and L.

PECo also stated that the remainder of the total 60-day extension, requested for outage planning flexibility, will have minimal safety significance since the unit will be in cold shutdown. Primary containment integrity is not required during cold shutdown.

The licensee provided information regarding the requirements of 10 CFR 50.12, "Specific Exemptions." With respect to the requirements of 10 CFR 50.12(a)(1), the licensee stated that the requested action is authorized by law in that no prohibition of law exists which would preclude the activities which would be authorized by the exemption. In addition, the licensee stated that, for the reasons discussed above, the requested exemption does not present an undue risk to the public health and safety. Finally, the licensee stated that containment leak rate testing is not considered in the common defense and security of the nation.

 \sim

With respect to the requirements of 10 CFR 50.12(a)(2)(iii), the licensee stated that special circumstances are present because compliance with the strict requirements of Appendix J would result in hardships significantly in excess of those contemplated when the regulation was adopted. The licensee stated that at the time the regulation was adopted, a presumption was made that a 2-year test interval would easily accommodate performance of the required tests during an operating cycle. However, development of new core designs have resulted in cycles of 24 months, or longer. Performance of the tests at the 24-month frequency would result in undue financial hardship resulting from extended reactor shutdown beyond that intended by the regulation with little or no compensatory increase in the level of safety or quality.

۷.

Based on the above, the staff finds there is reasonable assurance that the containment leakage-limiting function will be maintained and that a forced outage to perform Type B and C tests is not necessary. Therefore, the staff finds the requested exemption, to allow the Type B and C test intervals for the penetrations listed in the licensee's February 22, 1995 request to be extended for 60 days from their current expiration date, to be acceptable. The exemption request has been evaluated in a safety evaluation dated April 25, 1995.

- 5 -

Accordingly, the Commission has determined that, pursuant to 10 CFR Part 50.12(a), the requested exemption is authorized by law, will not present an undue risk to the public health and safety, and is consistent with the common defense and security. The Commission finds that the special circumstances as required by 10 CFR Part 50.12(a)(2) are present. The Commission's finding is based on the information provided by the licensee regarding 10 CFR Part 50.12(a)(2)(iii). In addition, as specified in 50.12(a)(2)(ii), special circumstances are present whenever the application of the regulation in the particular circumstance would not serve the underlying purpose of the rule or is not necessary to achieve the underlying purpose of the rule. The underlying purpose of the rule is to ensure that the components comprising the primary containment boundary are maintained and leak tested at periodic and appropriate intervals. The 24-month maximum interval was originally expected to bound the typical operating cycle, including a limited amount of mid-cycle outage time. The advent of advanced fuel types has made it possible to operate the facility for 24 months with minimal, if any, mid-cycle outage time. Strict adherence to the 24-month maximum interval is not necessary to meet the underlying purpose of the rule in that, taking into consideration the 60-day extension, the components that comprise the primary containment boundary will still be tested at a frequency that is appropriate to those components and their application. In addition, the 60-day extension represents a minimal increase in the existing 24-month interval required by the rule. Therefore, the staff finds the requested temporary exemption, to allow the Type B and C test intervals for penetrations described in the

- 6 -

licensee's February 22, 1995 letter, to be extended for 60 days, to be acceptable.

An exemption is hereby granted from the requirements of Sections III.D.2(a) and III.D.3 of Appendix J to 10 CFR Part 50, which requires that Type B and C tests be performed during each reactor shutdown for refueling but in no case at intervals greater than 2 years, for a period of 60 days from the expiration of the current leak test for the affected penetrations.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will have no significant impact on the quality of the human environment (60 FR 19968).

This exemption is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/S/

Steven A. Varga, Director Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Dated at Rockville, Maryland this 25tbday of April 1995

. .

- m	pl		1			/
PDI-2:LA	PDI-2): PM	SCSB/bg	OGC	PQI 2:AD	ADRI 🗸	B.ORPE
MO'Brien	JShea	RBayvett	CMarco	JStolz	JZwoy in	ki svanga
3/11/95	2 12/95	3 /23 /95	4/6/95	4 / 1/ 95	K0/95	17/95
	V					



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION SUPPORTING

AN EXEMPTION FROM 10 CFR PART 50, APPENDIX J REQUIREMENTS FOR

CONTAINMENT LEAK RATE TESTING

PECO ENERGY COMPANY

PUBLIC SERVICE ELECTRIC AND GAS COMPANY

DELMARVA POWER AND LIGHT COMPANY

ATLANTIC CITY ELECTRIC COMPANY

PEACH BOTTOM ATOMIC POWER STATION, UNIT 3

DOCKET NO. 50-278

1.0 INTRODUCTION

9505150138 950425

ADOCK OS

000278

PDR

By letter dated February 22, 1995, PECO Energy Company (PECo, the licensee) requested a one-time schedular exemption from the requirements of 10 CFR Part 50, Appendix J, Sections III.D.2(a) and III.D.3. The schedular exemption would extend the interval for Type B and C local leak rate tests (LLRT) for certain Peach Bottom Atomic Power Station, Unit 3 (Unit 3) containment penetrations for 60 days beyond the requirements of 10 CFR Part 50, Appendix J. The affected penetrations and valves or boundaries are listed in Table 1 and Table 2.

Appendix J requires that these tests be performed at every refueling outage, but with the interval not to exceed 2 years. PECo performed LLRTs on the affected penetrations between August 10, 1993 and November 5, 1993 just prior to and during refueling outage 3RO9. The Peach Bottom Atomic Power Station units are currently operating on a 24-month refueling outage schedule; the next Unit 3 refueling outage, 3R10, is scheduled to commence no later than September 30, 1995.

The licensee divided the affected penetrations into two groups: 1) those that require shutdown reactor conditions but come due prior to the scheduled commencement of 3R10 on September 30, 1995 (see attached Table 1), and 2) those that require reactor shutdown conditions and come due after the scheduled commencement of 3R10 (see attached Table 2). The licensee presented information to justify an LLRT extension for theses two groups. The staff's evaluation of the licensee's justification is provided below.

2.0 EVALUATION

2.1 <u>Need For Extending The Test Interval By 60 Days</u>

The licensee has stated that those components in Table 1 cannot be tested at power for two reasons. Many of the Table 1 penetrations require access to the drywell in order to conduct the tests. The drywell is inaccessible during power operations. Certain penetrations of those listed in Table 1 require safety systems to be isolated which is unadvisable during power operation. Therefore, a shutdown would be required in order to completely test all of the affected penetrations.

The licensee presented a description of the special circumstances that would result in hardship or other costs significantly in excess of those contemplated when Appendix J was adopted. The licensee has adopted improved technology reactor fuel which allows operation on a 24-month operating cycle. Performance of the affected penetration leak tests within the strict 24-month requirements of Appendix J would require an extended or early plant shutdown. Granting of the exemption would allow operation for the 49 remaining days in the planned operating cycle. In addition, the requested 60-day exemption would allow flexibility when scheduling the performance of the affected LLRT (both Table 1 and Table 2 penetrations) during the outage. PECo stated that little or no safety benefit would result from an early extended shutdown for the purpose of performing the affected LLRTs.

2.2 <u>Leak Rate Test Performance History</u>

The licensee presented information in support of their request for a 60-day extension of the Type B and C test intervals. The maximum allowable leakage rate for maintaining primary containment (L_a - minimum pathway leakage) is 125,417 cc/min for Unit 3. The as-found total Type B and C minimum pathway leakage rate observed during Unit 3 refueling outage 3R09 during the fall of 1993 was 33,434 cc/min. The as-left leak rate for that same outage was 27,188 cc/min. The licensee stated that an extension of the leak test interval to allow for 49 days of operation is not likely to decrease the margin between as-found leak rates and L_a .

PECo also stated that the remainder of the total 60-day extension, requested for outage planning flexibility, will have minimal safety significance since the unit will be in cold shutdown. Primary containment integrity is not required during cold shutdown.

The staff reviewed the leak rate information presented by the licensee and concurs that an additional 49 days of operation at power will not significantly decrease the margin between the expected as-found leak rates and the maximum allowable total leak rate L_a . The balance of the requested 60-day exemption provides reasonable flexibility for test planning under conditions in which primary containment integrity will not be required.

2.3 Intent of Appendix J

The staff notes that the 2-year interval requirement for Type B and C components is intended to be often enough to prevent significant deterioration from occurring and long enough to permit the tests to be performed during plant outages. Leak rate testing of the penetrations during plant shutdown is preferable because of the lower radiation exposures to the plant personnel. Moreover, as noted before, some penetrations cannot be tested at power. For penetrations that cannot be tested during power operation, or for which testing at power is inadvisable as discussed above, the increase in confidence in containment integrity following a successful test is not significant enough to justify a plant shutdown specifically to perform the tests so close to the end of the 2-year time period.

3.0 CONCLUSION

Based on the above evaluation, the staff finds that the requested temporary exemption, to allow the Type B and C tests intervals for those penetrations listed in Table 1 and Table 2 to be extended 60 days from their current expiration date, to be acceptable.

Principal Contributor: J. Shea

Date: April 25, 1995

TABLE 1

· · ·

...

-

LEAK TESTS EXPIRING PRIOR TO SEPTEMBER 30, 1995

PENETRATION	EXPIRATION OF	
NUMBERS	RATE TEST	AFFECTED VALVE NUMBERS
N-212	09/10/95	RCIC Stop Check O-Ring
N-21 ·	09/21/95	DW Service Air
N-102B	09/21/95	DW Breathing Air Iso Valve
N-35	09/21/95	TIP Ball Valves
N-150	09/16/95	Test Nozzle (N-150)
N-250	09/11/95	Test Nozzle (N-250)
N-200-A	09/19/95	Torus Manway O-Rings
N-2	09/16/95	DW Airlock O-Rings
N-35 A-G	09/13/95	TIP Penetration O-Rings
N-219	08/28/95	Torus Purge Exhaust
	08/19/95	"A" CAD Analyzer Iso Valve
N-25	09/18/95	DW Purge Supply; A0-3523
N-205B	09/19/95	Torus Vacuum Breaker "A"
	09/11/95	3502A, 26A O-Rings
N-205A	08/27/95	Torus Vacuum Breaker "B"
	08/27/95	3502B, 26B O-Rings
N-26	09/15/95	AO-3506, 3507 O-Rings
	08/28/95	Instrument N2 Compress Suction
	08/12/95	"B" CAD Analyzer Iso Valve
N-51C	08/15/95	"C" CAD Analyzer Iso Valve
N-201A	09/19/95	3AS197 DW to Torus Exp
N-201B	09/19/95	3AS197 DW to Torus Exp
N-201C	09/03/95	3BS197 DW to Torus Exp

LEAK TESTS EXPIRING PRIOR TO SEPTEMBER 30, 1995 (Con't)

N-201D	09/03/95	3BS197 DW to Torus Exp
N-201E	09/25/95	3CS197 DW to Torus Exp
N-201F	09/25/95	3CS197 DW to Torus Exp
N-201G	09/04/95	3DS197 DW to Torus Exp
N-201H	. 09/04/95	3DS197 DW to Torus Exp
N-17	09/22/95	RPV Head Spray
N-211B	09/29/95	"A" Torus Cooling & Spray
	09/22/95	"A" Torus Cool & Spray Packing
N-39B	09/22/95	"A" Containment Spray
	09/22/95	"A" Containment Spray Packing
N-13B	09/23/95	"A" RHR Pump Discharge
N-225	09/23/95	RCIC Pump Suction
	09/24/95	Torus Water Cleanup
N-212	09/24/95	RCIC Turbine Exhaust 10" Line
	09/26/95	RCIC Turbine Exhaust 2" Line
N-217B	09/24/95	RCIC Vacuum Relief Valve
	09/23/95	HPCI Vacuum Relief Valve Packing
	09/23/95	HPCI Vacuum Reilef Valve
N-16B	09/22/95	"A" Core Spray Loop
N-102BC	09/23/95	"A" ADS Backup N2 Supply
N-47	09/23/95	"B" ADS Backup N2 Supply
N-227	09/22/95	HPCI Pump Suction
N-214	09/23/95	HPCI Turbine Exhaust
	09/23/95	HPCI Stop Check O-Rings
	09/23/95	HPCI Turbine Exhaust 2" Line

 \sim

LEAK TESTS EXPIRING PRIOR TO SEPTEMBER 30, 1995 (Con't)

.

•

SDV	09/26/95	Scram Discharge Volume
N-9A	09/25/95	FW Check Valve 28A
N-35C	09/27/95	TIP Purge Supply
N-110 A-H '	09/23/95	RPV Stabilizer Manways
N-7	09/28/95	30S199 Expansion Joints
N-9	09/28/95	30S199 Expansion Joints
N-11	09/28/95	30S198 Expansion Joints
N-12	09/28/95	30S198 Expansion Joints
N-13	09/29/95	30S200 Expansion Joints
N-16	09/29/95	30S200 Expansion Joints
N-213A	09/04/95	Torus Drain O-Ring
N-213B	09/04/95	Torus Drain O-Ring

.

TABLE 2

 \sim

•••

LEAK TESTS EXPIRING ON OR AFTER SEPTEMBER 30, 1995

PENETRATION NUMBERS	EXPIRATION OF CURRENT LEAK RATE TEST	AFFECTED VALVE NUMBERS
N-42	10/03/95	Standby Liquid Control
N-16A	10/10/95	Core Spray "B" Loop
N-22	09/30/95	"A" Inst N2 to D/W
N-52F	10/01/95	"B" Inst N2 to D/W
N-218A	10/03/95	Inst N2 to Torus/DW Vac
N-18	10/03/95	DW Flor Drain Sump Disch
N-19	10/01/95	DW Equip Drain Sump Disch
N-11	10/08/95	HPCI Steam Supply
N-206	10/07/95	Torus Level Instrument
N-8	10/23/95	Main Steam Line Drain
N-57	10/26/95	Main Steam Sample
N-12	10/18/95	Shutdown Cooling
N-39A	10/22/95	"B" Containment Spray
	10/15/95	"B" Cont. Spray Packing
N-13A	10/16/95	"B" RHR Pump Discharge
N-211A	10/24/95	"B" Torus Cooling & Spray
	10/15/95	"B" Torus Cool & Spray Packing
N-14	10/28/95	RWCU Pump Suction
N-10	10/25/95	RCIC Steam Supply
N-23	10/17/95	RBCW DW Isolation
N-24	10/17/95	RBCW DW Isolation
N-53	10/21/95	DW Chilled Water
N-54	10/21/95	DW Chilled Water
N-55	10/21/95	DW Chilled Water

TABLE 2 (cont.)

· . .

.

LEAK TESTS EXPIRING ON OR AFTER SEPTEMBER 30, 1995

N-56	10/21/95	DW Chilled Water
N-9A	10/25/95	"A" FW Check Valve
N-9B	10/28/95	"B" FW Check Valve
	10/26/95	FW Check Valve 28B
DW Head	11/07/95	DW Head Seal
N-200B	10/25/95	Torus Manway O-Ring
N-1	11/07/95	DW Equipment Access
N-41	11/01/95	Recirculation Sample