

**From:** "AS.HUNJAN" <hunjan@igcar.ernet.in>  
**To:** "CAG@nrc.gov" <CAG@nrc.gov>  
**Date:** 6/5/02 1:28AM  
**Subject:** Draft Regulatory Guide GD - 1118

5/13/02  
 67 FR 32069  
 (1)

Dear Sir,

I have studied the above mentioned DG. I have no suggestion to make. However, I wish that application of single failure criteria to all the I & C system be covered under this document. It should apply not only to the Safety System as stated in the guide, but also to non safety system having high safety significance viz. over head crane and handling equipment within Containment Building and similar machines that move over Spent Fuel Storage Area.

With regards,

A.S. Hunjan,  
 Scientific Officer (H),  
 Room # 421, HBB,  
 Indira Gandhi Centre for Atomic Research,  
 P.O. Kalpakkam, 603102,  
 India.

RECEIVED  
 JUN 11 2002 11:25  
 Rules and Regulations  
 Division

Temp plot = ADM-013

E-RIDS = ADM-03  
 add = A. Berañek (AFB)  
 S.K. Aggarwal (SKA)