OFFICE OF ENFORCEMENT NOTIFICATION OF SIGNIFICANT ENFORCEMENT ACTION

Licensee: Carolina Power & Light Co. (EA-02-067)

(Shearon Harris) Docket No. 50-400

Subject: ISSUANCE OF FINAL SIGNIFICANCE DETERMINATION AND NOTICE OF

VIOLATION

This is to inform the Commission that a WHITE Significance Determination Process (SDP) finding and associated Notice of Violation will be issued on or around June 13, 2002, to Carolina Power & Light Co. as a result of inspections at the Shearon Harris Nuclear Power Plant. This WHITE finding, an issue with low to moderate increased importance to safety, which may require additional NRC inspections, concerned a failure of foreign material exclusion (FME) controls revealed when several pieces of foreign material were discovered in the containment sump suction piping to the A Residual Heat Removal (RHR) pump in October, 2001. This condition rendered the RHR pump inoperable in the sump recirculation mode at least for the operating cycle from April 15, 2000, to September 22, 2001, representing a violation of the licensee's FME procedures and of the plant's Technical Specifications. Accordingly, a Notice of Violation associated with a WHITE finding is being issued.

It should be noted that the licensee has not been specifically informed of this action. The schedule of issuance and notification are:

Mailing of Final Significance Determination and Notice of Violation

Telephone Notification of licensee

June 13, 2002

June 13, 2002

Contacts: D.J. Nelson, OE, 415-3280

J. Luehman, OE, 415-2741

Distribution:

<u>OWFN</u>	<u>OWFN</u>	TWFN	Regional Offices
Chairman Meserve	EDO	OCFO	RI RII
Comm. Dicus	DEDR	OP CENTER	RIII RIV
Comm. Diaz	DEDE	NMSS	
Comm. McGaffigan	OE	OIG	
Comm. Merrifield	OGC	OCIO	MAIL
SECY	NRR	RES	ADAMS
OCA	OI	ACRS	
PA	SP		
IP			

OE: ESDJNelson
06/10/2002

OE:DD
JLuehman
06/10/2002

ADAMS ACCESSION NO. ML021610579