

---

# **GSI-191, "ASSESSMENT OF DEBRIS ACCUMULATION ON PWR SUMP PERFORMANCE"**

## **STATUS OF NRC ACTIVITIES**



Ralph Architzel  
May 30, 2002

---

## **SUMMARY FROM MARCH 28 NEI/OG MEETING**

- **The GSI-191 parametric study has demonstrated that sump blockage is credible concern, even for smaller breaks.**
- **Risk numbers suggest that issue requires a regulatory response.**
- **Plant-specific analyses are necessary to determine susceptibility to sump clogging and best resolution.**
- **NRR has initiated its GL process, but will provide an opportunity for an industry developed solution.**

---

## **TOPICS PROPOSED IN MARCH NEI/OG MEETING**

- **Industry initiatives to employ interim measures for operator action to compensate for potential screen blockage until plant-specific corrective actions implemented**
- **Industry development of a JCO/schedular supplement to the JCO developed by the NRC**
- **Address the means for NRC review of the Industry Evaluation Guide which is intended to be used for plant specific assessments**

---

## NRC PLAN FOR RESOLUTION/CURRENT STATUS

- **RESOLUTION PROCESS** for GSI-191 will be industry-led and NRC-monitored.
- NEI described 2-step sump evaluation program in 3/28/02 public meeting
  - performing inventory of potential debris sources (4/02)
  - debris generation, transport and head-loss methodology (9/03)
- NRC involvement necessary because:
  - NEI's program does not comprehensively address regulatory needs
  - NEI's program is voluntary in both scope and schedule
  - NRC oversight is commensurate with safety significance

---

## **NRC PLAN FOR RESOLUTION/CURRENT STATUS (cont)**

- NRC plans to issue a GL to request that licensees:
  - commit to NEI's program or alternative
  - take interim compensatory actions
  - submit key information to the NRC
- NRC also plans to develop TIs to inspect licensees' actions, including:
  - containment debris source inventories
  - plant modifications
- NRC plans to use sample audits to perform detailed verification of licensees' sump-clogging evaluations

---

## REQUIRED SUPPORT

- NRR SPLB Lead
- NRR Projects - Generic Letter Review
- Region Inspection Activities Planned
- LANL Contracted for Technical Support
  - Analysis tools CASINOVA/BLOCKAGE available
- RES Support:
  - revise RG 1.82 for PWRs
  - publish a NUREG/CR summarizing sump-clogging information
  - advise NRR in interactions with industry

GSI-191 Resolution Schedule		
Date (mm/yy)	Task	Responsible Organization
08/02	Publication of guidance for performing inventory of containment debris sources	NEI
08/02 - 09/04	Performance of an inventory to characterize potential debris sources during next refueling outage	Licensees
09/02 - 09/04	Inspection of licensees' containment walkdowns and interim compensatory measures with a Temporary Instruction	NRC
01/03	Issuance of GL concerning GSI-191	NRC
04/03	Submission of interim GL response (response to include a description of interim compensatory measures, a justification for the planned resolution schedule, and a commitment to the NEI program or alternative)	Licensees
10/03	Publication of guidance for licensees' evaluations of sump clogging susceptibility	NEI
10/03 - 02/05	Performance of an evaluation to determine sump clogging susceptibility	Licensees
02/04 - 06/05	Submission of final GL response (response to include evaluation results, a summary of actions taken, any plans for modifications, and a JCO, if any necessary modifications will not be performed immediately)	Licensees
02/04 - 12/06	Performance of plant modifications during next refueling outage, as necessary	Licensees

---

GSI-191 Resolution Schedule		
Date (mm/yy)	Task	Responsible Organization
02/04 - 01/07	Inspection of licensees' modifications and other evaluation activities with a Temporary Instruction	NRC
02/04 - 01/07	Verification of licensees' evaluations of sump clogging susceptibility through sample audits	NRC
2007	Resolution and closure of GSI-191	NRC



# PWR Industry Program to Address GSI 191 Issues: Project Plan Update

Timothy S. Andreychek  
Westinghouse Electric Co., LLC  
andreyts@westinghouse.com  
(412)-374-6246

May 30, 2002

May 30, 2002

PWR\_Industry\_GSI-191\_Program\_Status\_1

1

## PWR Industry Program to Address GSI-191 Issues: Update

### Presentation Overview

- Review
  - Industry Action
  - Program Objectives
  - Key Features of PWR Industry Program
  - Program Overview
  - Schedule
- Status of Activities
- NRC Concerns from March 28, 2002 Meeting
- Summary

May 30, 2002

PWR\_Industry\_GSI-191\_Program\_Status\_1

2

## PWR Industry Program to Address GSI-191 Issues: Update

### Industry Action

- Industry response to NRC RES recommendation
  - PWR's should evaluate their sumps and take corrective actions as necessary
  - Take lead on issue resolution
- Benefits recognized to a coordinated effort among WOG, CEOG, BWOG, and NEI
- Desire to coordinate with anticipated NRC generic communication

May 30, 2002

PWR\_Industry\_GSI-191\_Program\_Status\_1

3

## PWR Industry Program to Address GSI-191 Issues: Update

### Program Objectives

- Quantify impact of potential PWR containment debris sources on ECCS performance (10CFR50.46)
- Develop tool set and resolution framework for industry to use in resolution of GSI 191 at plant level
  - Consistent evaluation approach and close-out will expedite issue resolution
- Maintain open communication with NRC and industry during program implementation
- To develop comprehensive and structured program
  - Relative safety significance allows for this objective

May 30, 2002

PWR\_Industry\_GSI-191\_Program\_Status\_1

4

## PWR Industry Program to Address GSI-191 Issues: Update

### Key Features of the PWR Industry Program

- Addresses GSI-191 issues directly
- Organized, logical structure of tasks and products
- Commitment by all three PWR Owners Groups
  - To the program
  - To the plan to accomplish the program
  - To active participation in NEI PWR Sump Performance Task Force
- Actions are proceeding per schedule

May 30, 2002

PWR\_Industry\_GSI-191\_Program\_Status\_1

5

## PWR Industry Program to Address GSI-191 Issues: Update

### Program Overview

Program Step 1

Program Coordination and  
Solicitation of Industry Comment

Program Step 2

Utility Configuration Assessment

Program Step 3

Industry Development of PWR Industry Evaluation Guide  
Methodology and Corrective Action

Program Step 4

Plant Specific IEG Application

Program Step 5

Plant Specific Corrective Actions

Program Step 6

Plant Specific Issue Resolution / Close Out

May 30, 2002

PWR\_Industry\_GSI-191\_Program\_Status\_1

6

# PWR Industry Program to Address GSI 191 Issues: Update

## Schedule

Work Product	NRC Meeting	Finish Date
Issue NEI-02-01, Condition Assessment Guidance	N/A	4/2002
Data Evaluation and Needs Identification	8/15/2002	9/20/2002
Document methodology, guidance on use of data, selection of break locations, use of probabilities, etc.	9/27/2002	10/31/2002
Develop Sump Performance Evaluation Tools	11/31/2002	1/17/2003
Sensitivity Studies	1/31/2003	2/21/2003
Draft Sump Performance Evaluation Guidance	3/28/2003	4/25/2003
Sump Performance Evaluation Sensitivities	5/16/2003	6/27/2003
Decision Analysis Tools / Final Program Documents	8/22/2003	9/26/2003

Notes: Finish Date is date documentation is released  
Overall industry implementation of program guidance follows 9/26/2003

May 30, 2002

PWR\_Industry\_GSI-191\_Program\_Status\_1

7

# PWR Industry Program to Address GSI-191 Issues: Update

## Status of Activities

- NEI-02-01, Condition Assessment Guidelines
  - Issued April 5, 2002 to NEI Administrative Points of Contact
  - Copy provided to NRC
  - Implemented at several plants during 2002 Spring Outages
  - NEI workshop planned for July 2002
- Data Evaluation and Needs Identification
  - Currently being performed
  - Activity on schedule

May 30, 2002

PWR\_Industry\_GSI-191\_Program\_Status\_1

8

---

# **NRC STAFF COMMENTS ON NEI 02-01, "CONDITION ASSESSMENT GUIDELINES: DEBRIS SOURCES INSIDE PWR CONTAINMENTS"**



Presented by: John Lehning, NRR/DSSA/SPLB  
May 30, 2002

---

---

## **GENERAL COMMENTS**

- **Generally, the NRC staff finds NEI 02-01 to be reasonable and thorough**
- **However, the NRC staff has identified several areas where guidance should be improved**
  - **Additional scoping considerations**
  - **Certain guidance may be overly flexible or possibly contrary to NRC staff expectations**

---

## **NECESSITY OF CONTAINMENT WALKDOWNS**

- **NEI guidance suggests that licensees with adequate records may not need to perform containment walkdowns**
- **The NRC staff believes containment walkdowns are essential, though depth of investigation be reduced by good record-keeping**

---

## CONSIDERATION OF RETURN FLOWPATHS

- **NEI guidance lacks specific direction on walkdowns of containment flowpaths**
- **The NRC staff believes that insufficient information may be collected on flowpaths from upper elevations of containment to the sump**
  - **Debris accumulation at “choke-points” in return flow paths can divert water from sump & reduce expected NPSH margin**
  - **If interdicting structures (e.g. floor grating) will be credited with stopping large debris, there must be a documented basis**



---

## **PRIMARY PIPE BREAK LOCATIONS**

- **NEI guidance does not provide specific direction on the locations of pipe breaks to be considered**
- **The NRC staff believes that PWR licensees should approach break locations similar to BWRs**
  - **Staff position documented in SER on URG and RG 1.82**
  - **Analysis should consider break locations which are most limiting for NPSH requirements**
  - **For compliance with 10 CFR 50.46, it is not sufficient to consider only high-stress locations**

---

## **SECONDARY PIPE BREAK LOCATIONS**

- **NEI guidance does not emphasize secondary system high-energy line breaks**
- **Secondary pipe breaks such as a MSLB may require containment sprays to maintain peak containment pressure below design value**
  - **If spray recirculation is necessary for successful mitigation of a secondary break, sump evaluation must consider expected debris loads**
  - **Otherwise, secondary pipe break analysis must demonstrate that spray recirculation is unnecessary**

---

## **ZONE OF INFLUENCE**

- **NEI guidance recommends using line-of-sight considerations for determining scope of walkdown**
- **The NRC staff believes that the guidance concerning the “direct line-of-sight” criterion is not precisely defined**
  - **Guidance does not adequately consider the reflection of jet impingement and pressure waves to zones beyond direct line-of-sight**
  - **Guidance does not include the caution that credit to intervening structures should be applied only to qualified, robust, and large structures**

---

## **ZONE OF INFLUENCE**

- **NEI guidance suggests the use of a 12-D sphere for walkdown purposes, which may be truncated due to line-of-sight considerations**
- **The NRC staff does not have assurance that this truncated spherical approach appropriately models the volume over which energy dissipation from the pipe break would actually occur**
  - **12-D sphere is based on an approximation**
  - **Any new modeling approach should have a realistic technical basis**

---

## COMMENTS ON INSULATION TYPES

- **NEI guidance suggests that a 12-D sphere is sufficient for surveying all insulation materials**
- **Debris can be generated from unjacketed calcium-silicate insulation (and similar insulation types) due to erosion caused by the impingement of hot spray water**
- **NEI guidance does not emphasize the distinction between different types of reflective metallic insulation (RMI)**
- **RMI behaves quite differently based upon its material composition (e.g., stainless steel, aluminum) and construction (e.g., spot-welded, reinforced)**

---

## **TREATMENT OF COATINGS**

- **NEI guidance suggests that coatings addressed under GL 98-04 programs may be considered to have a negligible contribution to sump clogging**
- **The NRC staff believes that it is unrealistic not to include all coatings within the scope of plant-specific evaluations**
  - **Unqualified coatings would be an expected debris source**
  - **NRC's acceptance of GL 98-04 responses does not imply that coatings are an insignificant factor in an integrated evaluation of recirculation sump performance**

---

## **DETAILS OF SUMP DESIGN**

- **NEI guidance does not emphasize the collection of sump design details through a walkdown or a review of sump screen structural capability**
- **The NRC staff believes that sump design details have a significant effect upon sump clogging and that a physical inspection of sump would add value**
  - **As-constructed details of sump may have minor, yet significant differences from design**
  - **Structural design of sump screens may not account for loadings due to currently expected debris accumulation**

---

## **CONDITION OF INSULATION**

- **NEI guidance emphasizes determining the type of insulation and its fastening and jacketing, but not the condition of these items**
- **The NRC staff believes that walkdowns should describe the general condition of insulation and fastening and jacketing materials**
  - **Destruction pressure of degraded materials may be less than experimental values**
  - **Degraded insulation materials may already be handled in a licensee's corrective action program**



---

## **REACTOR VESSEL INSULATION**

- **NEI guidance does not specifically recommend surveying all insulation on the reactor vessel (though “vessel heads” is specified as a potential target area)**
- **Reactor vessel could potentially be a target for debris generation as a result of postulated breaks**