

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.3.2.4	Perform MASTER RELAY TEST.	31 days on a STAGGERED TEST BASIS
SR 3.3.2.5	Perform COT.	92 days
SR 3.3.2.6	Perform SLAVE RELAY TEST.	92 days <u>OR</u> 18 months for Westinghouse type AR relays with AC coils
SR 3.3.2.7	<p>-----NOTES-----</p> <p>1. Verification of relay setpoints not required.</p> <p>2. Actuation of final devices not included</p> <p>-----</p> <p>Perform TADOT.</p>	31 days
SR 3.3.2.8	<p>-----NOTE-----</p> <p>Verification of setpoint not required for manual initiation functions.</p> <p>-----</p> <p>Perform TADOT.</p>	18 months
SR 3.3.2.9	<p>-----NOTE-----</p> <p>This Surveillance shall include verification that the time constants are adjusted to the prescribed values.</p> <p>-----</p> <p>Perform CHANNEL CALIBRATION.</p>	18 months

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
SR 3.3.6.2 Perform ACTUATION LOGIC TEST.	31 days on a STAGGERED TEST BASIS
SR 3.3.6.3 Perform MASTER RELAY TEST.	31 days on a STAGGERED TEST BASIS
SR 3.3.6.4 Perform COT.	92 days
SR 3.3.6.5 Perform SLAVE RELAY TEST.	92 days <u>OR</u> 18 months for Westinghouse type AR relays with AC coils
SR 3.3.6.6 Not Used.	
SR 3.3.6.7 Perform CHANNEL CALIBRATION.	18 months