

September 18, 1992

Docket No. 50-483

Mr. Donald F. Schnell
Senior Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

DISTRIBUTION:

PD33 Gray	EGreenman, RIII
Docket Files	NRC & Local PDRs
PD33 r/f	BBoger
JZwolinski	JHannon
RWharton	PKreutzer
OGC	DHagan
GHill(4)	Wanda Jones
CCarpenter	ACRS(10)
OPA	OC/LFMB

Dear Mr. Schnell:

SUBJECT: CORRECTION TO AMENDMENT NO. 73 TO FACILITY OPERATING LICENSE NO. NPF-30 (TAC NO. M84230)

On August 21, 1992, the Commission issued Amendment No. 73 in response to your application dated August 11, 1992.

The amendment granted a one-time only extension to the surveillance interval specified for Technical Specification (TS) Surveillance 4.3.1.1, Table 4.3-1, Functional Unit 1 (Manual Trip) by adding a footnote to Note 16 which states that "complete verification of OPERABILITY of the manual reactor trip switch circuitry shall be performed prior to startup from the first shutdown to Mode 3 occurring after August 7, 1992." TS page 3/4 3-12a was inadvertently issued with two typographical errors. A corrected page 3/4 3-12a is enclosed.

Please accept our apologies for the inconvenience this error may have caused you.

Sincerely,

Original signed by C. E. Carpenter for:

L. Raynard Wharton, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
TS page 3/4 3-12a

cc w/enclosure: See next page

LA/PD33	PM/PD33	D/PD33		
PKreutzer	CCarpenter	JHannon		
08/17/92	08/18/92 CC	08/18/92		

OFFICIAL RECORD COPY
FILENAME: CAL84230. CLR

DF01

9209280189 920918
PDR ADOCK 05000483
P PDR

NRC FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

September 18, 1992

Docket No. 50-483

Mr. Donald F. Schnell
Senior Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Dear Mr. Schnell:

SUBJECT: CORRECTION TO AMENDMENT NO. 73 TO FACILITY OPERATING LICENSE NO.
NPF-30 (TAC NO. M84230)

On August 21, 1992, the Commission issued Amendment No. 73 in response to your application dated August 11, 1992.

The amendment granted a one-time only extension to the surveillance interval specified for Technical Specification (TS) Surveillance 4.3.1.1, Table 4.3-1, Functional Unit 1 (Manual Trip) by adding a footnote to Note 16 which states that "complete verification of OPERABILITY of the manual reactor trip switch circuitry shall be performed prior to startup from the first shutdown to Mode 3 occurring after August 7, 1992." TS page 3/4 3-12a was inadvertently issued with two typographical errors. A corrected page 3/4 3-12a is enclosed.

Please accept our apologies for the inconvenience this error may have caused you.

Sincerely,

A handwritten signature in black ink, appearing to read "L. Raynard Wharton".

L. Raynard Wharton, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
TS page 3/4 3-12a

cc w/enclosure: See next page

TABLE 4.3-1 (Continued)

TABLE NOTATIONS

- (10) Setpoint verification is not required.
- (11) Following maintenance or adjustment of the Reactor trip breakers, the TRIP ACTUATING DEVICE OPERATIONAL TEST shall include independent verification of the Undervoltage and Shunt trips.
- (12) At least once per 18 months during shutdown, verify that on a simulated Boron Dilution Doubling test signal the normal CVCS discharge valves will close and the centrifugal charging pumps suction valves from the RWST will open within 30 seconds.
- (13) Deleted
- (14) Deleted
- (15) The surveillance MODES specified for these channels in Table 4.3-2 are more restrictive and, therefore, applicable.
- (16) The TRIP ACTUATING DEVICE OPERATIONAL TEST shall independently verify the OPERABILITY¹ of the Undervoltage and Shunt Trip circuits for the Manual Reactor Trip function. The test shall also verify the OPERABILITY of the Bypass Breaker trip circuit.
- (17) Local manual shunt trip prior to placing breaker in service.
- (18) Automatic Undervoltage Trip.

¹ Complete verification of OPERABILITY of the manual reactor trip switch circuitry shall be performed prior to startup from the first shutdown to Mode 3 occurring after August 7, 1992.

Mr. D. F. Schnell
Union Electric Company

Callaway Plant
Unit No. 1

cc:

Cermak Fletcher Associates
18225 Flower Hill Way #A
Gaithersburg, Maryland 20879-5334

Gerald Charnoff, Esq.
Thomas A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N. Street, N.W.
Washington, D.C. 20037

Mr. T. P. Sharkey
Supervising Engineer,
Site Licensing
Union Electric Company
Post Office Box 620
Fulton, Missouri 65251

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
RR#1
Steedman, Missouri 65077

Mr. Alan C. Passwater, Manager
Licensing and Fuels
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Manager - Electric Department
Missouri Public Service Commission
301 W. High
Post Office Box 360
Jefferson City, Missouri 65102

Regional Administrator
U.S. NRC, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. Ronald A. Kucera, Deputy Director
Department of Natural Resources
P.O. Box 176
Jefferson City, Missouri 65102

Mr. Bart D. Withers
President and Chief
Executive Officer
Wolf Creek Nuclear Operating
Corporation
P.O. Box 411
Burlington, Kansas 66839

Mr. Dan I. Bolef, President
Kay Drey, Representative
Board of Directors Coalition
for the Environment
6267 Delmar Boulevard
University City, Missouri 65130