

January 6, 1994

Docket No. 50-483

Mr. Donald F. Schnell  
Senior Vice President - Nuclear  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

Dear Mr. Schnell:

SUBJECT: CORRECTION TO AMENDMENT NO. 85 - CALLAWAY PLANT, UNIT NO. 1  
(TAC NO. M84887)

Amendment No. 85, issued on December 9, 1993, inadvertently added or deleted words to Pages 3/4 3-20, 3/4 3-20a and 3/4 3-27. The pages are reissued with the appropriate overleaf pages. We are sorry for any inconvenience this oversight may have caused.

Sincerely,  
Original signed by L. Raynard Wharton  
L. Raynard Wharton, Project Manager  
Project Directorate III-3  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

cc: w/enclosure  
See next page

DISTRIBUTION:

<del>Docket File</del>	CGrimes	ETomlinson
NRC & Local PDRS	ACRS (10)	GHill
PD 3-3 Reading	OPA	
JRoe	OC/LFDCB	
JZwolinski	Region III, DRP	
JHannon	DHagan	
MRushbrook	GBagchi	
LRWharton	OGC	

OFFICE	PDIII-3:LA:DRPW	PDIII-3:PM:DRPW	PDIII-3:PD:DRPW
NAME	MRushbrook	LRWharton/bj	JHannon
DATE	1/05/94	1/05/94	1/5/94

OFFICIAL RECORD

DOCUMENT NAME: G:\CALLAWAY\CALCORA85.COR

**NRC FILE CENTER COPY**

9401130289 940106  
PDR ADOCK 05000483  
P PDR

DF01

Mr. D. F. Schnell  
Union Electric Company

Callaway Plant  
Unit No. 1

cc:

Cermak Fletcher Associates  
18225 Flower Hill Way #A  
Gaithersburg, Maryland 20879-5334

Gerald Charnoff, Esq.  
Thomas A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

Mr. S. E. Sampson  
Supervising Engineer,  
Site Licensing  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251

U.S. Nuclear Regulatory Commission  
Resident Inspectors Office  
8201 NRC Road  
Steedman, Missouri 65077-1302

Mr. Alan C. Passwater, Manager  
Licensing and Fuels  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

Manager - Electric Department  
Missouri Public Service Commission  
301 W. High  
Post Office Box 360  
Jefferson City, Missouri 65102

Regional Administrator  
U.S. NRC, Region III  
801 Warrenville Road  
Lisle, Illinois 60532-4351

Mr. Ronald A. Kucera, Deputy Director  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, Missouri 65102

Mr. Neil S. Carns  
President and Chief  
Executive Officer  
Wolf Creek Nuclear Operating  
Corporation  
P.O. Box 411  
Burlington, Kansas 66839

Mr. Dan I. Bolef, President  
Kay Drey, Representative  
Board of Directors Coalition  
for the Environment  
6267 Delmar Boulevard  
University City, Missouri 65130

TABLE 3.3-3 (Continued)

TABLE NOTATION

- # Trip function may be blocked in this MODE below the P-11 (Pressurizer Pressure Interlock) Setpoint.
- ## Trip function automatically blocked above P-11 and may be blocked below P-11 when Safety Injection on low steam line pressure is not blocked.
- ### Trip function may be blocked just before shutdown of the last operating main feedwater pump and restored just after the first main feedwater pump is put into service (following its startup trip test).
- \* The provisions of Specification 3.0.4 are not applicable.
- \*\* One in Separation Group 1 and one in Separation Group 4.
- \*\*\* The de-energization of one train of BOP ESFAS actuation logic and actuation relays renders two of the four channels inoperable. Action Statement 21 applies to both Functional Units 6.c and 6.g in this case.
- \*\*\*\*The provisions of Specification 3.0.4 are not applicable in Modes 5 and 6.
- + Only the shutdown portion of one sequencer is required to be OPERABLE in Modes 5 and 6 which corresponds to the OPERABLE Emergency Diesel Generator.
- ++ Operability is only required for associated OPERABLE bus in Modes 5 and 6.

ACTION STATEMENTS

- ACTION 14 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, be in at least HOT STANDBY within 12 hours and in COLD SHUTDOWN within the following 30 hours; however, one channel may be bypassed for up to 4 hours for surveillance testing per Specification 4.3.2.1, provided the other channel is OPERABLE.
- ACTION 15 - With the number of OPERABLE channels one less than the Total Number of Channels, operation may proceed until performance of the next required ANALOG CHANNEL OPERATIONAL TEST provided the inoperable channel is placed in the tripped condition within 1 hour.
- ACTION 16 - With the number of OPERABLE channels one less than the Total Number of Channels, operation may proceed provided the inoperable channel is placed in the bypass condition and the Minimum Channels OPERABLE requirement is met. One additional channel may be bypassed for up to 4 hours for surveillance testing per Specification 4.3.2.1
- ACTION 17 - With less than the Minimum Channels OPERABLE requirement, operation may continue provided the containment purge supply and exhaust valves are maintained closed.

TABLE 3.3-3 (CONTINUED)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
8. Loss of Power					
a. 4 kV Bus Undervoltage -Loss of Voltage	4/Bus	2/Bus	3/Bus	1, 2, 3, 4, 5++, 6++	19*
b. 4 Kv Bus Undervoltage -Grid Degraded Voltage	4/Bus	2/Bus	3/Bus	1, 2, 3, 4, 5++, 6++	19*
9. Control Room Isolation					
a. Manual Initiation	2	1	2	All	26****
b. Automatic Actuation Logic and Actuation Relays (SSPS)	2	1	2	1, 2, 3, 4	26
c. Automatic Actuation Logic and Actuation Relays (BOP ESFAS)	2	1	2	All	26****
d. Phase "A" Isolation	See Item 3.a above for all Phase "A" Isolation initiating functions and requirements.				
10. Load Shedder Emergency Load Sequencer	2-1/Train	1/Train	2-1/Train	1, 2, 3, 4, 5+, 6+	25
11. Engineered Safety Features Actuation System Interlocks					
a. Pressurizer Pressure, P-11	3	2	2	1, 2, 3	20
b. Reactor Trip, P-4	4-2/Train	2/Train	2/Train	1, 2, 3	22

CALLAWAY - UNIT 1

3/4 3-19

Amendment No. 89, 85

TABLE 3.3-3 (continued)

ACTION STATEMENTS (continued)

- ACTION 18 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- ACTION 19 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:
- a. The inoperable channel is placed in the tripped condition within 1 hour, and
  - b. The Minimum Channels OPERABLE requirement is met; however, the inoperable channel may be bypassed for up to 2 hours for surveillance testing of other channels per Specification 4.3.2.1.
- ACTION 20 - With less than the Minimum Channels OPERABLE, within 1 hour determine by observation of the associated permissive annunciator window(s) that the interlock is in its required state for the existing plant condition, or apply Specification 3.0.3.
- ACTION 21 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN within the following 6 hours; however, one channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1 provided the other channel is OPERABLE.
- ACTION 22 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours and in at least HOT SHUTDOWN within the following 6 hours.
- ACTION 23 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or declare the associated valve inoperable and take the ACTION required by Specification 3.7.1.5.
- ACTION 24 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, declare the affected auxiliary feedwater pump inoperable and take the ACTION required by Specification 3.7.1.2.

TABLE 3.3-4 (CONTINUED)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>ALLOWANCE (TA)</u>	<u>TOTAL Z</u>	<u>SENSOR ERROR (S)</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
8. Loss of Power (Continued)					
b. 4 kV Undervoltage - Grid Degraded Voltage	0.78	0.53	0	107.47V (120V Bus) w/119s delay	107.47 ± 0.38V (120V Bus) w/119±11.6s delay
9. Control Room Isolation					
a. Manual Initiation	N.A.	N.A.	N.A.	N.A.	N.A.
b. Automatic Actuation Logic and Actuation Relays (SSPS)	N.A.	N.A.	N.A.	N.A.	N.A.
c. Automatic Actuation Logic and Actuation Relays (BOP ESFAS)	N.A.	N.A.	N.A.	N.A.	N.A.
d. Phase "A" Isolation	See Item 3.a. above for all Phase "A" Isolation Trip Setpoints and Allowable Values.				
10. Load Shedder Emergency Load Sequencer	N.A.	N.A.	N.A.	N.A.	N.A.
11. Engineered Safety Features Actuation System Interlocks					
a. Pressurizer Pressure, P-11	N.A.	N.A.	N.A.	≤ 1970 psig	≤ 1981 psig
b. Reactor Trip, P-4	N.A.	N.A.	N.A.	N.A.	N.A.

CALLAWAY - UNIT 1

3/4 3-27

Amendment No. 7A,85  
Correction letter of 1/6/94

TABLE 3.3-4 (Continued)

TABLE NOTATIONS

- \*Time constants utilized in the lead-lag controller for Steam Pressure-Low are  $\tau_1 \geq 50$  seconds and  $\tau_2 \leq 5$  seconds. CHANNEL CALIBRATION shall ensure that these time constants are adjusted to these values.
- \*\*The time constant utilized in the rate-lag controller for Steam Line Pressure-Negative Rate-High is greater than or equal to 50 seconds. CHANNEL CALIBRATION shall ensure that this time constant is adjusted to this value.