

May 3, 1995

Mr. Donald F. Schnell
Senior Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, MO 63166

SUBJECT: CORRECTION TO AMENDMENT NOS. 96 AND 97 TO FACILITY OPERATING LICENSE
NO. NPF-30 - CALLAWAY, UNIT 1 (TAC NOS. M90168 AND M90477)

Dear Mr. Schnell:

The Commission has issued Amendment Nos. 96 and 97 to Facility Operating License No. NPF-30 for the Callaway Plant, Unit 1. These amendments revised the Technical Specifications (TS) in response to your applications dated August 4, 1994, as supplemented on March 14, 1995, and March 28, 1995, and September 8, 1994.

The corrected amendments replace TS pages that did not include overleaf pages. A list of pages to be replaced is included to clarify this correction. We regret any inconvenience this might have caused you.

Sincerely,

ORIGINAL SIGNED BY:

L. Raynard Wharton, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosures: 1. List of corrected TS pages
2. TS pages w/overleaf pages included

Distribution:

Docket File ACRS (4)
PUBLIC OPA
PD3-3 Reading RJones
GSchwenk OGC
OC/LFDCB EAdensam
LPhillips GHills (2)
WAxelson, RIII

cc w/encls: See next page

DOCUMENT NAME: G:\CALLAWAY\CAL96&97.COR

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure
"N" = No copy

OFFICE	PD33:LA <i>JFC</i>	E	PD33:PM	E	PD33:RD <i>JFC</i>
NAME	DFoster-Curseen		LRWharton/bam		GMarcus
DATE	4/25/95		5/3/95		5/3/95

OFFICIAL RECORD COPY

NRC FILE CENTER COPY

090031
9505100221 950503
PDR ADOCK 05000483
P PDR

DFD



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

May 3, 1995

Mr. Donald F. Schnell
Senior Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, MO 63166

SUBJECT: CORRECTION TO AMENDMENT NOS. 96 AND 97 TO FACILITY OPERATING LICENSE
NO. NPF-30 - CALLAWAY, UNIT 1 (TAC NOS. M90168 AND M90477)

Dear Mr. Schnell:

The Commission has issued Amendment Nos. 96 and 97 to Facility Operating License No. NPF-30 for the Callaway Plant, Unit 1. These amendments revised the Technical Specifications (TS) in response to your applications dated August 4, 1994, as supplemented on March 14, 1995, and March 28, 1995, and September 8, 1994.

The corrected amendments replace TS pages that did not include overleaf pages. A list of pages to be replaced is included to clarify this correction. We regret any inconvenience this might have caused you.

Sincerely,

A handwritten signature in black ink that reads "L. Raynard Wharton".

L. Raynard Wharton, Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosures: 1. List of corrected TS pages
2. TS pages w/overleaf
pages included

cc w/encls: See next page

Mr. D. F. Schnell
Union Electric Company

Callaway Plant
Unit No. 1

cc:

Professional Nuclear
Consulting, Inc.
19041 Raines Drive
Derwood, Maryland 20855

Gerald Charnoff, Esq.
Thomas A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N. Street, N.W.
Washington, D.C. 20037

Mr. H. D. Bono
Supervising Engineer,
Site Licensing
Union Electric Company
Post Office Box 620
Fulton, Missouri 65251

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
8201 NRC Road
Steedman, Missouri 65077-1302

Mr. Alan C. Passwater, Manager
Licensing and Fuels
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Manager - Electric Department
Missouri Public Service Commission
301 W. High
Post Office Box 360
Jefferson City, Missouri 65102

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, Illinois 60523-4351

Mr. Ronald A. Kucera, Deputy
Director
Department of Natural Resources
P. O. Box 176
Jefferson City, Missouri 65102

Mr. Neil S. Carns
President and Chief
Executive Officer
Wolf Creek Nuclear Operating
Corporation
P. O. Box 411
Burlington, Kansas 66839

Mr. Dan I. Bolef, President
Kay Drey, Representative
Board of Directors Coalition
for the Environment
6267 Delmar Boulevard
University City, Missouri 65130

Mr. Lee Fritz
Presiding Commissioner
Callaway County Court House
10 East Fifth Street
Fulton, Missouri 65251

LIST OF AFFECTED APPENDIX A TECHNICAL SPECIFICATION PAGES

CHANGED IN AMENDMENT NOS. 96 AND 97

DOCKET NO. 50-483

The revised pages are identified by the captioned amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages, indicated by an asterisk, are also provided to maintain document completeness.

REMOVE

INSERT

3/4 6-14

3/4 6-14

B 3/4 1-3

B 3/4 1-3

B 3/4 1-4*

B 3/4 1-4*

B 3/4 5-3*

B 3/4 5-3*

B 3/4 5-4

B 3/4 5-4

B 3/4 6-3

B 3/4 6-3

B 3/4 6-4

B 3/4 6-4

B 3/4 9-1

B 3/4 9-1

B 3/4 9-2*

B 3/4 9-2*

CONTAINMENT SYSTEMS

RECIRCULATION FLUID pH CONTROL (RFPC) SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.2.2 The RFPC System shall be OPERABLE with each of the two storage baskets (one within the confines of each of the two containment recirculation sumps) containing a minimum of 30", but not to exceed 36.8" (uniform depth), of granular trisodium phosphate dodecahydrate (TSP-C).

APPLICABILITY: MODES 1, 2, 3, and 4

ACTION:

With the RFPC System inoperable, restore the system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours; restore the RFPC System to OPERABLE status within the next 48 hours or be in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.2.2 The RFPC System shall be demonstrated OPERABLE at least once per 18 months by verifying that:

- a. One TSP-C storage basket is in place in the confines of each containment recirculation sump, and
- b. Both baskets show no evidence of structural distress or abnormal corrosion, and
- c. Each basket contains between 30" and 36.8" (uniform depth) of granular TSP-C.

9505100227 950503
PDR ADOCK 05000483
P PDR

REACTIVITY CONTROL SYSTEMS

BASES

BORATION SYSTEMS (Continued)

With the RCS temperature below 200°F, one Boration System is acceptable without single failure consideration on the basis of the stable reactivity condition of the reactor and the additional restrictions prohibiting CORE ALTERATIONS and positive reactivity changes in the event the single Boron Injection System becomes inoperable.

The limitation for a maximum of one centrifugal charging pump to be OPERABLE and the Surveillance Requirement to verify all charging pumps except the required OPERABLE pump to be inoperable in MODES 4, 5, and 6 provides assurance that a mass addition pressure transient can be relieved by the operation of a single PORV or an RHR suction relief valve.

The boron capability required below 200°F is sufficient to provide a SHUTDOWN MARGIN of 1% $\Delta k/k$ after xenon decay and cooldown from 200°F to 140°F. This condition requires either 2968 gallons of 7000 ppm borated water from the boric acid storage tanks or 14,076 gallons of 2350 ppm borated water from the RWST.

The contained water volume limits include allowance for water not available because of discharge line location and other physical characteristics.

The limits on contained water volume and boron concentration of the RWST also ensure a minimum equilibrium sump pH of 7.1 for the solution recirculated within Containment after a LOCA. This pH level minimizes the evolution of iodine and minimizes the effect of chloride and caustic stress corrosion on mechanical systems and components.

The OPERABILITY of one Boration System during REFUELING ensures that this system is available for reactivity control while in MODE 6.

3/4.1.3 MOVABLE CONTROL ASSEMBLIES

This specifications of this section ensure that: (1) acceptable power distribution limits are maintained, (2) the minimum SHUTDOWN MARGIN is maintained, and (3) the potential effects of rod misalignment on associated accident analyses are limited. OPERABILITY of the control rod position indicators is required to determine control rod positions and thereby ensure compliance with the control rod alignment and insertion limits. Verification that the Digital Rod Position indicator agrees with the demanded position within ± 12 steps at 24, 48, 120 and 228 steps withdrawn for the Control Banks and 18, 210 and 228 steps withdrawn for the Shutdown Banks provides assurance that the Digital Rod Position Indicator is operating correctly over the full range of indication. Since the Digital Rod Position System does not indicate the actual shutdown rod position between 18 steps and 210 steps, only points in the indicated ranges are picked for verification of agreement with demanded position. Shutdown and control rods are positioned at 225 steps or higher for fully withdrawn.

REACTIVITY CONTROL SYSTEMS

BASES

MOVABLE CONTROL ASSEMBLIES (Continued)

For purposes of determining compliance with Specification 3.1.3.1, any immovability of a control rod initially invokes ACTION statement 3.1.3.1.a. Subsequently, ACTION statement 3.1.3.1.a may be exited and ACTION statement 3.1.3.1.d invoked if either the rod control urgent failure alarm is illuminated or an electrical problem is detected in the rod control system. The rod is considered trippable if the rod was demonstrated OPERABLE during the last performance of Surveillance Requirement 4.1.3.1.2 and met the rod drop time criteria of Specification 3.1.3.4 during the last performance of Surveillance Requirement 4.1.3.4.

The ACTION statements which permit limited variations from the basic requirements are accompanied by additional restrictions which ensure that the original design criteria are met. Misalignment of a rod requires measurement of peaking factors and a restriction in THERMAL POWER. These restrictions provide assurance of fuel rod integrity during continued operation. In addition, those safety analyses affected by a misaligned rod are reevaluated to confirm that the results remain valid during future operation.

The power reduction and shutdown time limits given in ACTION statements 3.1.3.2.a.2, 3.1.3.2.b.2, and 3.1.3.2.c.2, respectively, are initiated at the time of discovery that the compensatory actions required for POWER OPERATION can no longer be met.

The maximum rod drop time restriction is consistent with the assumed rod drop time used in the safety analyses. Measurement with T_{avg} greater than or equal to 551°F and with all reactor coolant pumps operating ensures that the measured drop times will be representative of insertion times experienced during a Reactor trip at operating conditions.

Control rod positions and OPERABILITY of the rod position indicators are required to be verified on a nominal basis of once per 12 hours with more frequent verifications required if an automatic monitoring channel is inoperable. These verification frequencies are adequate for assuring that the applicable LCOs are satisfied.

EMERGENCY CORE COOLING SYSTEMS

BASES

ECCS SUBSYSTEMS (Continued)

The centrifugal charging pump maximum total pump flow Surveillance Requirement ensures the maximum injection flow limit of 550 gpm is not exceeded. This value of flow is comprised of the total flow to the four branch lines of 469 gpm and a seal injection flow of 79 gpm plus 2 gpm for instrument uncertainties.

The safety injection pump maximum total pump flow Surveillance Requirement ensures the maximum injection flow limit of 675 gpm is not exceeded. This value of flow includes a nominal 30 gpm of mini-flow.

The test procedure places requirements on instrument accuracy (20 inches of water column for the charging branch lines and 10 inches of water column for the safety injection branch lines) and setting tolerance (30 inches of water column for both the charging and safety injection branch lines) such that branch line flow imbalance remains within the assumptions of the safety analyses.

The maximum and minimum potential pump performance curves, in conjunction with the maximum and minimum flow Surveillance Requirements, the maximum total system resistance, and the test procedure requirements, ensure that the assumptions of the safety analyses remain valid.

The surveillance flow and differential pressure requirements are the Safety Analysis Limits and do not include instrument uncertainties. These instrument uncertainties will be accounted for in the surveillance test procedure to assure that the Safety Analysis Limits are met.

The Surveillance Requirements for leakage testing of ECCS check valves ensure that a failure of one valve will not cause an inter-system LOCA. The Surveillance Requirement to vent the ECCS pump casings and accessible, i.e., can be reached without personnel hazard or high radiation dose, discharge piping ensures against inoperable pumps caused by gas binding or water hammer in ECCS piping.

3/4.5.5 REFUELING WATER STORAGE TANK

The OPERABILITY of the refueling water storage tank (RWST) as part of the ECCS ensures that a sufficient supply of borated water is available for injection by the ECCS in the event of a LOCA. The limits on RWST minimum volume and boron concentration ensure that: (1) sufficient water is available within containment to permit recirculation cooling flow to the core, and (2) the reactor will remain subcritical in the cold condition following mixing of the RWST and the RCS water volumes assuming all the control rods are out of the core. These assumptions are consistent with the LOCA analyses.

Revised by NRC Letter dated:
May 3, 1995

EMERGENCY CORE COOLING SYSTEMS

BASES

REFUELING WATER STORAGE TANK (Continued)

The contained water volume limit includes an allowance for water not usable because of tank discharge line location or other physical characteristics.

The limits on contained water volume and boron concentration of the RWST also ensure a minimum equilibrium sump pH of 7.1 for the solution recirculated within containment after a LOCA. This pH level minimizes the evolution of iodine and minimizes the effect of chloride and caustic stress corrosion on mechanical systems and components.

CONTAINMENT SYSTEMS

BASES

3/4.6.1.7 CONTAINMENT VENTILATION SYSTEM

The 36-inch containment purge supply and exhaust isolation valves are required to be closed and blank flanged during plant operations since these valves have not been demonstrated capable of closing during a LOCA or steam line break accident. Maintaining these valves closed and blank flanged during plant operation ensures that excessive quantities of radioactive material will not be released via the Containment Purge System. To provide assurance that the 36-inch containment purge valves cannot be inadvertently opened, the valves are blank flanged.

The use of the containment mini-purge lines is restricted to the 18-inch purge supply and exhaust isolation valves since, unlike the 36-inch valves, the 18-inch valves are capable of closing during a LOCA or steam line break accident. Therefore, the SITE BOUNDARY dose guideline values of 10 CFR Part 100 would not be exceeded in the event of an accident during containment purging operation. Operation will be limited to 2000 hours during a calendar year. The total time the Containment Purge (vent) System isolation valves may be open during MODES 1, 2, 3, and 4 in a calendar year is a function of anticipated need and operating experience. Only safety-related reasons; e.g., containment pressure control or the reduction of airborne radioactivity to facilitate personnel access for surveillance and maintenance activities, should be used to support additional time requests. Only safety-related reasons should be used to justify the opening of these isolation valves during MODES 1, 2, 3, and 4 in any calendar year regardless of the allowable hours.

Leakage integrity tests with a maximum allowable leakage rate for containment purge supply and exhaust isolation valves will provide early indication of resilient material seal degradation and will allow opportunity for repair before gross leakage failures could develop. The 0.60 L_a leakage limit of Specification 3.6.1.2b. shall not be exceeded when the leakage rates determined by the leakage integrity tests of these valves are added to the previously determined total for all valves and penetrations subject to Type B and C tests.

3/4.6.2 DEPRESSURIZATION AND COOLING SYSTEMS

3/4.6.2.1 CONTAINMENT SPRAY SYSTEM

The OPERABILITY of the Containment Spray System ensures that containment depressurization and cooling capability will be available in the event of a LOCA or steam line break. The pressure reduction and resultant lower containment leakage rate are consistent with the assumptions used in the safety analyses.

The Containment Spray System and the Containment Cooling System are redundant to each other in providing post-accident cooling of the Containment atmosphere. However, the Containment Spray System also provides a mechanism for removing iodine from the containment atmosphere and therefore the time requirements for restoring an inoperable spray system to OPERABLE status have been maintained consistent with that assigned other inoperable ESF equipment.

CONTAINMENT SYSTEMS

BASES

3/4.6.2.2 RECIRCULATION FLUID pH CONTROL (RFPC) SYSTEM

The operability of the RFPC System ensures that there exists adequate TSP-C in the containment such that a post-LOCA equilibrium sump pH of greater than or equal to 7.1 is maintained during the recirculation phase. The minimum depth of 30" ensures that 9000 lbm of TSP-C is available for dissolution to yield a minimum equilibrium sump pH of 7.1. This pH level minimizes the evolution of iodine and minimizes the effect of chloride and caustic stress corrosion on mechanical systems and components. The upper limit of 36.8" corresponds to the basket design capacity.

3/4.6.2.3 CONTAINMENT COOLING SYSTEM

The OPERABILITY of the Containment Cooling System ensures that: (1) the containment air temperature will be maintained within limits during normal operation, and (2) adequate heat removal capacity is available when operated in conjunction with the Containment Spray System during post-LOCA conditions.

The Containment Cooling System and the Containment Spray System are redundant to each other in providing post-accident cooling of the Containment atmosphere. As a result of this redundancy in cooling capability, the allowable out-of-service time requirements for the Containment Cooling System have been appropriately adjusted. However, the allowable out-of-service time requirements for the Containment Spray System have been maintained consistent with that assigned other inoperable ESF equipment since the Containment Spray System also provides a mechanism for removing iodine from the containment atmosphere.

3/4.6.3 CONTAINMENT ISOLATION VALVES

The OPERABILITY of the containment isolation valves ensures that the containment atmosphere will be isolated from the outside environment in the event of a release of radioactive material to the containment atmosphere or pressurization of the containment and is consistent with the requirements of GDC 54 thru 57 of Appendix A to 10 CFR Part 50. Containment isolation within the time limits specified for those isolation valves designed to close automatically ensures that the release of radioactive material to the environment will be consistent with the assumptions used in the analyses for a LOCA.

3/4.6.4 COMBUSTIBLE GAS CONTROL

The OPERABILITY of the equipment and systems required for the detection and control of hydrogen gas ensures that this equipment will be available to maintain the hydrogen concentration within containment below its flammable limit during post-LOCA conditions. Either recombiner unit (or the Purge System) is capable of controlling the expected hydrogen generation associated with: (1) zirconium-water reactions, (2) radiolytic decomposition of water, and (3) corrosion of metals within containment. The Hydrogen Purge Subsystem discharges directly to the Emergency Exhaust System. Operation of the Emergency Exhaust System with the heaters operating for at least 10 continuous hours in a 31-day period is sufficient to reduce the buildup of moisture on the adsorbers and HEPA filters. These hydrogen control systems are consistent with the recommendations of Regulatory Guide 1.7, "Control of Combustible Gas Concentrations in Containment Following a Loss-of-Coolant Accident," Revision 2, November 1978.

3/4.9 REFUELING OPERATIONS

BASES

3/4.9.1 BORON CONCENTRATION

The limitations on reactivity conditions during REFUELING ensure that: (1) the reactor will remain subcritical during CORE ALTERATIONS, and (2) a uniform boron concentration is maintained for reactivity control in the water volume having direct access to the reactor vessel. The limitation on K_{eff} of no greater than 0.95 is sufficient to prevent reactor criticality during refueling operations. The locking closed of the required valves during refueling operations precludes the possibility of uncontrolled boron dilution of the filled portions of the Reactor Coolant System via the CVCS blending tee. This action prevents flow to the RCS of unborated water by closing all automatic flow paths from sources of unborated water. Administrative controls will limit the volume of unborated water which can be added to the refueling pool for decontamination activities in order to prevent diluting the refueling pool below the limits specified in the LCO. These limitations are consistent with the initial conditions assumed for the boron dilution incident in the safety analyses.

3/4.9.2 INSTRUMENTATION

The OPERABILITY of the Source Range Neutron Flux Monitors ensures that redundant monitoring capability is available to detect changes in the reactivity condition of the core.

3/4.9.3 DECAY TIME

The minimum requirement for reactor subcriticality prior to movement of irradiated fuel assemblies in the reactor vessel ensures that sufficient time has elapsed to allow the radioactive decay of the short-lived fission products. This decay time is consistent with the assumptions used in the fuel handling accident radiological consequence and spent fuel pool thermal-hydraulic analyses.

3/4.9.4 CONTAINMENT BUILDING PENETRATIONS

The requirements on containment building penetration closure and OPERABILITY ensure that a release of radioactive material within containment will be restricted from leakage to the environment. The OPERABILITY and closure restrictions are sufficient to restrict radioactive material release from a fuel element rupture based upon the lack of containment pressurization potential while in the REFUELING MODE.

The OPERABILITY of this system ensures the containment purge penetrations will be automatically isolated upon detection of high radiation levels within containment. The OPERABILITY of this system is required to restrict the release of radioactive materials from the containment atmosphere to the environment.

The restriction on the setpoint for GT-RE-22 and GT-RE-33 is based on a fuel handling accident inside the Containment Building with resulting damage to one fuel rod and subsequent release of 0.1% of the noble gas gap activity, except for 0.3% of the Kr-85 gap activity. The setpoint concentration of $5E-3 \mu\text{Ci/cc}$ is equivalent to approximately 150 mR/hr submersion dose rate.

3/4.9.5 COMMUNICATIONS

The requirement for communications capability ensures that refueling station personnel can be promptly informed of significant changes in the facility status or core reactivity conditions during CORE ALTERATIONS.

9505120266 950503
PDR ADDCK 05000483
P

REFUELING OPERATIONS BASES

3/4.9.6 REFUELING MACHINE

The OPERABILITY requirements for the refueling machine and auxiliary hoist ensure that: (1) manipulator cranes will be used for movement of drive rods and fuel assemblies, (2) each crane has sufficient load capacity to lift a drive rod or fuel assembly, and (3) the core internals and reactor vessel are protected from excessive lifting force in the event they are inadvertently engaged during lifting operations.

3/4.9.7 CRANE TRAVEL - SPENT FUEL STORAGE FACILITY

The restriction on movement of loads in excess of the nominal weight of a fuel and control rod assembly and associated handling tool over other fuel assemblies in the storage pool areas ensures that in the event this load is dropped: (1) the activity release will be limited to that contained in a single fuel assembly, and (2) any possible distortion of fuel in the storage racks will not result in a critical array. This assumption is consistent with the activity release assumed in the safety analyses.

The spent fuel pool transfer gates are excluded from this restriction because with a limited gate lift height, the spent fuel pool racks will absorb the impact of a dropped gate without damage to fuel assemblies. In addition, redundant trolleys and supports are used when moving the gates to preclude dropping a gate on the spent fuel racks, the time and distance the gates are moved over fuel is minimized as much as practical, and gate travel over fuel assemblies containing RCCAs is prohibited. The spent fuel pool transfer gates are only moved for refueling activities, fuel handling system maintenance, and to change gate seals.

3/4.9.8 RESIDUAL HEAT REMOVAL AND COOLANT CIRCULATION

The requirement that at least one residual heat removal (RHR) loop be in operation ensures that: (1) sufficient cooling capacity is available to remove decay heat and maintain the water in the reactor vessel below 140F as required during the REFUELING MODE, and (2) sufficient coolant circulation is maintained through the core to minimize the effect of a boron dilution incident and prevent boron stratification.

The requirement to maintain a 1000 gpm flowrate ensures that there is adequate flow to prevent boron stratification. The RHR flow to the RCS will provide adequate cooling to prevent exceeding 140F and to allow flowrates which provide additional margin against vortexing at the RHR pump suction while in partial drain operation.

The requirement to have two RHR loops OPERABLE when there is less than 23 feet of water above the reactor vessel flange ensures that a single failure of the operating RHR loop will not result in a complete loss of residual heat