

Beaver Valley RELAP5 PTS Analysis

David Bessette, USNRC

Robert Beaton, ISL, Inc.



Beaver Valley T/H Analysis

- Model received from Westinghouse was developed from the HB Robinson plant model.
- Model needed modifications/corrections to run a null transient (maintain quasi-steady conditions).
- Trip setpoints used by Westinghouse were licensing values. Best-Estimate plant setpoint values are used (obtained from current Tech Specs).



Beaver Valley T/H Analysis

- Transient runs (such as reactor trip/turbine trip) were made to “shake down” the model. Corrections were made based on the results of these runs.
- Control variables were added to compute quantities of interest to PTS analysis (i.e., minimum downcomer temperature, etc.)



Sump Recirculation

- ECCS water injection switches from RWST to sump recirculation when RWST volume drops to 287,000 gallons
- Is potentially important to PTS risk predictions since ECC injection temperature will increase from 50°F to 124°F at switchover
- Assumptions
 - constant sump temperature of 124°F
 - containment sprays come on between 365 sec (for 1.0” SBLOCA) to 302 sec (for 22” SBLOCA)



Beaver Valley T/H Analysis

- List of transients was based on input from NRC, Sandia and SAIC
- Events selected to identify runs that provide broad coverage of possible PTS sequences.
- There are also some runs that we would expect to be relatively benign (however, as we have seen we cannot simply assume that they are not of concern).



Beaver Valley T/H Analysis

- Preliminary Transient Events Include:
 - LOCA Spectrum (1.0 inch through 8.0 inch)
 - Reactor Trip w/Stuck Open Primary Relief Valve (PORV, SRV)
 - Reactor Trip w/Stuck Open Secondary Side Valves (1, 2, and 3 stuck valves)
 - Main Steam Line Break
 - Steam Generator Tube Rupture




Beaver Valley T/H Analysis




- Average Downcomer Fluid Temperature, Pressure and Downcomer Wall Heat Transfer Coefficient are passed to FAVOR
- Preliminary FAVOR results indicate medium LOCAs dominate RPV failure
- FAVOR analysis of other plants indicates that stuck pressurizer relief valves which reclose are significant risk contributors




BV PTS – 8.0 inch Surge Line Break (Case 007)




BV PTS – 5.657 inch Surge Line Break (Case 006)






BV PTS – 4.0 inch Surge Line Break (Case 005)




BV PTS – 2.828 inch Surge Line Break (Case 004)




BV PTS – RTT w/Feed and Bleed (Case 031)



BV PTS – RTT w/2 Stuck Open Pressurizer SRVs (Case 034)



BV PTS – RTT w/2 Stuck Open Pzr SRV's which reclose (Case 062)



Beaver Valley T/H Analysis

- Additional Transient Events to be Simulated
 - Larger LOCA's (up to 22" hot leg breaks)
 - Stuck valves which reclose after system depressurized
 - Events which start from Hot Zero Power
 - Others based on PRA?

