

November 1, 1995

Mr. Donald F. Schnell
Senior Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

SUBJECT: CORRECTION TO AMENDMENT NO. 102 TO FACILITY OPERATING LICENSE
NO. NPF-30 - CALLWAY PLANT, UNIT 1 (TAC NO. M92051)

Dear Mr. Schnell:

On August 21, 1995, the Commission issued Amendment No. 102 to Facility Operating License No. NPF-30 for the Callaway Plant, Unit 1. The amendment revised the Technical Specifications (TS) in response to your application dated April 17, 1995, as supplemented by letter dated June 30, 1995. The amendment revised TS 2.2.1, Table 2.2-1. The changes addressed reducing repeated alarms and partial reactor trips by revising the Overpower Delta-T (OPΔT) setpoint function.

Due to an administrative error, the text on page B 2-6a was not carried over to the revised page B 2-6a. Enclosed is a correct copy of that page. We apologize for any inconvenience this may have caused.

Sincerely,

Original signed by:

Kristine M. Thomas, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure: Page B 2-6a

cc w/encl: See next page

DISTRIBUTION:

Docket
PDIV-2 Reading
PUBLIC
JRoe
EAdensam
WBateman
KThomas
EPeyton
OGC
GHill (2)

CGrimes
ACRS
DKirsch, Region IV
JDyer, Region IV
LHurley, Region IV

Document Name: CAL.COR

OFC	PDIV-2	PDIV-2	
NAME	EPeyton	KThomas	KNT
DATE	11/1 /95	11/1 /95	

OFFICIAL RECORD COPY

030073
9511060030 951101
PDR ADOCK 05000483
P PDR

NRC FILE CENTER COPY

DF0111
01-1

November 1, 1995

Mr. Donald F. Schnell
Senior Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

SUBJECT: CORRECTION TO AMENDMENT NO. 102 TO FACILITY OPERATING LICENSE
NO. NPF-30 - CALLWAY PLANT, UNIT 1 (TAC NO. M92051)

Dear Mr. Schnell:

On August 21, 1995, the Commission issued Amendment No. 102 to Facility Operating License No. NPF-30 for the Callaway Plant, Unit 1. The amendment revised the Technical Specifications (TS) in response to your application dated April 17, 1995, as supplemented by letter dated June 30, 1995. The amendment revised TS 2.2.1, Table 2.2-1. The changes addressed reducing repeated alarms and partial reactor trips by revising the Overpower Delta-T (OPΔT) setpoint function.

Due to an administrative error, the text on page B 2-6a was not carried over to the revised page B 2-6a. Enclosed is a correct copy of that page. We apologize for any inconvenience this may have caused.

Sincerely,

Original signed by:

Kristine M. Thomas, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure: Page B 2-6a

cc w/encl: See next page

DISTRIBUTION:

Docket
PDIV-2 Reading
PUBLIC
JRoe
EAdensam
WBateman
KThomas
EPeyton
OGC
GHill (2)

CGrimes
ACRS
DKirsch, Region IV
JDyer, Region IV
LHurley, Region IV

Document Name: CAL.COR

OFC	PDIV-2	PDIV-2	
NAME	EPeyton	KThomas KMT	
DATE	11/1 /95	11/1 /95	

OFFICIAL RECORD COPY

Mr. D. F. Schnell

- 2 -

cc w/encl:

Professional Nuclear
Consulting, Inc.
19041 Raines Drive
Derwood, Maryland 20855

Gerald Charnoff, Esq.
Thomas A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N. Street, N.W.
Washington, D.C. 20037

Mr. H. D. Bono
Supervising Engineer,
Site Licensing
Union Electric Company
Post Office Box 620
Fulton, Missouri 65251

U.S. Nuclear Regulatory Commission
Resident Inspector Office
8201 NRC Road
Steedman, Missouri 65077-1302

Mr. Alan C. Passwater, Manager
Licensing and Fuels
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Manager - Electric Department
Missouri Public Service Commission
301 W. High
Post Office Box 360
Jefferson City, Missouri 65102

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavilion
611 Ryan Plaza Drive, Suite 400
Arlington, Texas 76011-8064

Mr. Ronald A. Kucera, Deputy Director
Department of Natural Resources
P.O. Box 176
Jefferson City, Missouri 65102

Mr. Neil S. Carns
President and Chief Executive Officer
Wolf Creek Nuclear Operating Corporation
P.O. Box 411
Burlington, Kansas 66839

Mr. Dan I. Bolef, President
Kay Drey, Representative
Board of Directors Coalition
for the Environment
6267 Delmar Boulevard
University City, Missouri 65130

Mr. Lee Fritz
Presiding Commissioner
Callaway County Court House
10 East Fifth Street
Fulton, Missouri 65151

LIMITING SAFETY SYSTEM SETTINGS

BASES

Pressurizer Pressure

In each of the pressurizer pressure channels, there are two independent bistables, each with its own Trip Setting to provide for a High and Low Pressure trip thus limiting the pressure range in which reactor operation is permitted. The Low Setpoint trip protects against low pressure which could lead to DNB by tripping the reactor in the event of a loss of reactor coolant pressure.

On decreasing power the Low Setpoint trip is automatically blocked by P-7 (a power level of approximately 10% of RATED THERMAL POWER with turbine impulse chamber pressure at approximately 10% of full power equivalent); and on increasing power, automatically reinstated by P-7.

The High Setpoint trip functions in conjunction with the pressurizer relief and safety valves to protect the Reactor Coolant System against system overpressure.

Pressurizer Water Level

The Pressurizer High Water Level trip is provided to prevent water relief through the pressurizer safety valves. On decreasing power the Pressurizer High Water Level trip is automatically blocked by P-7 (a power level of approximately 10% of RATED THERMAL POWER with a turbine impulse chamber pressure at approximately 10% of full power equivalent); and on increasing power, automatically reinstated by P-7.

Reactor Coolant Flow

The Low Reactor Coolant Flow trips provide core protection to prevent DNB by mitigating the consequences of a loss of flow resulting from the loss of one or more reactor coolant pumps.

On increasing power above P-7 (a power level of approximately 10% of RATED THERMAL POWER or a turbine impulse chamber pressure at approximately 10% of full power equivalent) an automatic Reactor trip will occur if the flow in more than one loop drops below 90% of nominal full loop flow. Above P-8 (a power level of approximately 48% of RATED THERMAL POWER) an automatic Reactor trip will occur if the flow in any single loop drops below 90% of nominal full loop flow. Conversely, on decreasing power between P-8 and P-7 an automatic Reactor trip will occur on low reactor coolant flow in more than one loop and below P-7 the trip function is automatically blocked.

9511060037 951101
PDR ADDCK 05000483
P PDR