

July 15, 1996

Mr. Donald Schnell  
Senior Vice President - Nuclear  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

SUBJECT: AMENDMENT NO. 113 TO FACILITY OPERATING LICENSE NO. NPF-30 -  
CALLAWAY PLANT, UNIT 1 (TAC NO. M94801)

Dear Mr. Schnell:

On June 28, 1996, the Commission issued Amendment No. 113 to Facility Operating License No. NPF-30 for the Callaway Plant, Unit 1. The amendment revised the allowed outage times for component cooling water motor operated containment isolation valves, removed the list of containment isolation valves from the technical specifications, and allowed containment penetration check valves to be used as isolation devices.

Due to an administrative error, page 1-2 of the technical specifications did not reflect the change that was made by Amendment No. 111 to Facility Operating License No. NPF-30 issued on May 28, 1996. Enclosed is a correct page 1-2.

We apologize for any inconvenience this may have caused.

Sincerely,

Kristine M. Thomas, Project Manager  
Project Directorate IV-2  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure: Page 1-2

cc w/encl: See next page

DISTRIBUTION:

Docket	ACRS
PUBLIC	EPeyton
PDIV-2 Reading	GHill (2)
JRoe	LHurley, RIV
JDyer, RIV	JKilcrease, RIV
OGC	
WBateman	
WJohnson, RIV	
CBerlinger	
KThomas	

Document Name: CALLA.COR

OFC	PDIV-2	PDIV-2	PDIV-2 <i>Fee</i>
NAME	<i>esp</i> EPeyton:esp	<i>KMT</i> KThomas	<i>WB</i> WBateman
DATE	7/12/96	7/15/96	7/15/96

OFFICIAL RECORD COPY

1/1  
DFD

9607180010 960715  
PDR ADOCK 05000483  
P PDR

NRC FILE CENTER COPY

CP-1

July 15, 1996

Mr. Donald Schnell  
Senior Vice President - Nuclear  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

SUBJECT: AMENDMENT NO. 113 TO FACILITY OPERATING LICENSE NO. NPF-30 -  
CALLAWAY PLANT, UNIT 1 (TAC NO. M94801)

Dear Mr. Schnell:

On June 28, 1996, the Commission issued Amendment No. 113 to Facility Operating License No. NPF-30 for the Callaway Plant, Unit 1. The amendment revised the allowed outage times for component cooling water motor operated containment isolation valves, removed the list of containment isolation valves from the technical specifications, and allowed containment penetration check valves to be used as isolation devices.

Due to an administrative error, page 1-2 of the technical specifications did not reflect the change that was made by Amendment No. 111 to Facility Operating License No. NPF-30 issued on May 28, 1996. Enclosed is a correct page 1-2.

We apologize for any inconvenience this may have caused.

Sincerely,

Kristine M. Thomas, Project Manager  
Project Directorate IV-2  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-483  
Enclosure: Page 1-2  
cc w/encl: See next page

DISTRIBUTION:

Docket  
PUBLIC  
PDIV-2 Reading  
JRoe  
JDyer, RIV  
OGC  
WBateman  
WJohnson, RIV  
CBerlinger  
KThomas  
ACRS  
EPeyton  
GHill (2)  
LHurley, RIV  
JKilcrease, RIV

Document Name: CALLA.COR

OFC	PDIV-2	PDIV-2	PDIV-2 <i>see</i>
NAME	<i>esp</i> EPeyton:esp	<i>KMT</i> KThomas	<i>for</i> WBateman
DATE	7/12/96	7/15/96	7/15/96

OFFICIAL RECORD COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

July 16, 1996

Mr. Donald Schnell  
Senior Vice President - Nuclear  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

SUBJECT: AMENDMENT NO. 113 TO FACILITY OPERATING LICENSE NO. NPF-30 -  
CALLAWAY PLANT, UNIT 1 (TAC NO. M94801)

Dear Mr. Schnell:

On June 28, 1996, the Commission issued Amendment No. 113 to Facility Operating License No. NPF-30 for the Callaway Plant, Unit 1. The amendment revised the allowed outage times for component cooling water motor operated containment isolation valves, removed the list of containment isolation valves from the technical specifications, and allowed containment penetration check valves to be used as isolation devices.

Due to an administrative error, page 1-2 of the technical specifications did not reflect the change that was made by Amendment No. 111 to Facility Operating License No. NPF-30 issued on May 28, 1996. Enclosed is a correct page 1-2.

We apologize for any inconvenience this may have caused.

Sincerely,

*Kristine M Thomas*

Kristine M. Thomas, Project Manager  
Project Directorate IV-2  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure: Page 1-2

cc w/encl: See next page

Mr. D. F. Schnell

- 2 -

cc w/enc1.

Professional Nuclear  
Consulting, Inc.  
19041 Raines Drive  
Derwood, Maryland 20855

Gerald Charnoff, Esq.  
Thomas A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

Mr. H. D. Bono  
Supervising Engineer,  
Site Licensing  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251

U.S. Nuclear Regulatory Commission  
Resident Inspector Office  
8201 NRC Road  
Steedman, Missouri 65077-1302

Mr. G. L. Randolph, Vice President  
Nuclear Operations  
Union Electric Company  
P.O. Box 620  
Fulton, Missouri 65251

Manager - Electric Department  
Missouri Public Service Commission  
301 W. High  
Post Office Box 360  
Jefferson City, Missouri 65102

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Harris Tower & Pavilion  
611 Ryan Plaza Drive, Suite 400  
Arlington, Texas 76011-8064

Mr. Ronald A. Kucera, Deputy Director  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, Missouri 65102

Mr. Neil S. Carns  
President and Chief Executive Officer  
Wolf Creek Nuclear Operating Corporation  
P.O. Box 411  
Burlington, Kansas 66839

Mr. Dan I. Bolef, President  
Kay Drey, Representative  
Board of Directors Coalition  
for the Environment  
6267 Delmar Boulevard  
University City, Missouri 63130

Mr. Lee Fritz  
Presiding Commissioner  
Callaway County Court House  
10 East Fifth Street  
Fulton, Missouri 65151

Mr. Alan C. Passwater, Manager  
Licensing and Fuels  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

Mr. J. V. Laux, Manager  
Quality Assurance  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251

## DEFINITIONS

### CONTAINMENT INTEGRITY

1.7 CONTAINMENT INTEGRITY shall exist when:

- a. All penetrations required to be closed during accident conditions are either:
  - 1) Capable of being closed by an OPERABLE containment automatic isolation valve system, or
  - 2) Closed by manual valves, blind flanges, or deactivated automatic valves secured in their closed positions, except for valves that are open under administrative control as permitted by Specification 3.6.3.
- b. All equipment hatches are closed and sealed.
- c. Each air lock is in compliance with the requirements of Specification 3.6.1.3.
- d. The sealing mechanism associated with each penetration (e.g., welds, bellows, or O-rings) is OPERABLE.
- e. The containment leakage rates are determined per Specification 4.6.1.1.d and are within the limits listed in the Containment Leakage Rate Testing Program of Specification 6.8.4.g.
- f. Structural integrity is assured via the program described in Specification 6.8.5.c.

### CONTROLLED LEAKAGE

1.8 CONTROLLED LEAKAGE shall be that seal water flow from the reactor coolant pump seals.

### CORE ALTERATION

1.9 CORE ALTERATION shall be the movement or manipulation of any component within the reactor vessel with the vessel head removed and fuel in the vessel. Suspension of CORE ALTERATION shall not preclude completion of movement of a component to a safe conservative position.

### CORE OPERATING LIMITS REPORT

1.10 The CORE OPERATING LIMITS REPORT (COLR) is the unit specific document that provides core operating limits for the current operating reload cycle. The cycle specific core operating limits shall be determined for each reload cycle in accordance with Specification 6.9.1.9. Plant operation within these operating limits is addressed in individual specifications.

### DOSE EQUIVALENT I-131

1.11 DOSE EQUIVALENT I-131 shall be that concentration of I-131 (microCurie/gram) which alone would produce the same thyroid dose as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The thyroid dose conversion factors used for this calculation shall be those listed in Table III of TID-14844, "Calculation of Distance Factors for Power and Test Reactor Sites."