

March 20, 1998

Mr. Garry L. Randolph
Vice President and Chief Nuclear Officer
Union Electric Company
Post Office Box 620
Fulton, Missouri 65251

SUBJECT: ENVIRONMENTAL ASSESSMENT OF REQUEST FOR EXEMPTION FROM
10 CFR 50.60 - CALLAWAY PLANT, UNIT 1 (TAC NO. M99607)

Dear Mr. Randolph:

Enclosed for your information is a copy of an "Environmental Assessment and Finding of No Significant Impact." This assessment relates to your application dated August 22, 1997, which requested an exemption from certain requirements of 10 CFR 50.60, "Acceptance Criteria for Fracture Prevention Measures for Lightwater Nuclear Power Reactors for Normal Operation." This section requires all power reactors to meet the fracture toughness and material surveillance program requirements for the reactor coolant pressure boundary set forth in Appendices G and H to 10 CFR Part 50.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

Original Signed By

Barry C. Westreich, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure: Environmental Assessment

cc w/encl: See next page

DISTRIBUTION:

Docket
PUBLIC
PDIV-2 Reading
EAdensam
WBateman
BWestreich
EPeyton
OGC
ACRS
TEssig
PGwynn, Region IV

*For previous concurrences
see attached ORC
Document Name: CAL99607.EA

OFC	PDIV-2	PDIV-2	PGEB*	OGC ^{RWV} NLO
NAME	BWestreich	EPeyton	TEssig	RWeisman
DATE	2/19/98	2/19/98	2/18/98	2/15/98

OFFICIAL RECORD COPY

OFFICIAL RECORD COPY

9803250024 980320
PDR ADOCK 05000483
P PDR

CP-1

Mr. Garry L. Randolph

- 2 -

March 20, 1998

cc w/encl:

Professional Nuclear
Consulting, Inc.
19041 Raines Drive
Derwood, Maryland 20855

Gerald Charnoff, Esq.
Thomas A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N. Street, N.W.
Washington, D.C. 20037

Mr. H. D. Bono
Supervising Engineer
Quality Assurance Regulatory Support
Union Electric Company
Post Office Box 620
Fulton, Missouri 65251

U.S. Nuclear Regulatory Commission
Resident Inspector Office
8201 NRC Road
Steedman, Missouri 65077-1302

Mr. J. V. Laux, Manager
Quality Assurance
Union Electric Company
Post Office Box 620
Fulton, Missouri 65251

Manager - Electric Department
Missouri Public Service Commission
301 W. High
Post Office Box 360
Jefferson City, Missouri 65102

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavilion
611 Ryan Plaza Drive, Suite 400
Arlington, Texas 76011-8064

Mr. Ronald A. Kucera, Deputy Director
Department of Natural Resources
P.O. Box 176
Jefferson City, Missouri 65102

Mr. Otto L. Maynard
President and Chief Executive Officer
Wolf Creek Nuclear Operating Corporation
P.O. Box 411
Burlington, Kansas 66839

Mr. Dan I. Bolef, President
Kay Drey, Representative
Board of Directors Coalition
for the Environment
6267 Delmar Boulevard
University City, Missouri 63130

Mr. Lee Fritz
Presiding Commissioner
Callaway County Court House
10 East Fifth Street
Fulton, Missouri 65151

Mr. Alan C. Passwater, Manager
Licensing and Fuels
Union Electric Company
Post Office Box 66149
St. Louis, Missouri 63166-6149

Mr. Gene Gunn (5)
Environmental Review Coordinator
999 18th Street, Suite 500
Denver, Colorado 80202-2405

UNITED STATES NUCLEAR REGULATORY COMMISSION

UNION ELECTRIC COMPANY

DOCKET NO. 50-483

CALLAWAY PLANT, UNIT 1

ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an exemption from certain requirements of its regulations for Facility Operating License No. NPF-30, issued to Union Electric Company (the licensee), for operation of the Callaway Plant, Unit 1, located in Callaway County, Missouri.

ENVIRONMENTAL ASSESSMENT

Identification of the Proposed Action:

The proposed action would exempt Union Electric Company from the requirements of 10 CFR 50.60, which requires all power reactors to meet the fracture toughness and material surveillance program requirements for the reactor coolant pressure boundary set forth in Appendices G and H to 10 CFR Part 50. The proposed exemption would allow Union Electric to apply American Society for Mechanical Engineers (ASME) Code Case N-514 for determining Callaway's cold overpressurization mitigation system (COMS) pressure setpoint.

The proposed action is in accordance with the licensee's application for exemption dated August 22, 1997.

The Need for the Proposed Action:

The proposed exemption is needed to support an amendment to the Callaway Technical Specifications which will revise the heatup, cooldown and COMS curves. The use of ASME

Code Case N-514 would allow an increased operating band for system makeup and pressure control.

Environmental Impacts of the Proposed Action:

The Commission has completed its evaluation of the proposed action and concludes that application of Code Case N-514 represents a special circumstance in accordance with 10 CFR 50.12(a)(2)(ii) on specific exemptions, such that the specific requirements of 10 CFR 50.60 and Appendix G are "...not necessary to achieve the underlying purpose of the rule," which in this case is to protect the reactor vessel from brittle failure.

The change will not increase the probability or consequences of accidents, no changes are being made in the types of any effluents that may be released offsite, and there is no significant increase in the allowable individual or cumulative occupational radiation exposure. Accordingly, the Commission concludes that there are no significant radiological environmental impacts associated with the proposed action.

With regard to potential nonradiological impacts, the proposed action does involve features located entirely within the restricted area as defined in 10 CFR Part 20. It does not affect nonradiological plant effluents and has no other environmental impact. Accordingly, the Commission concludes that there are no significant nonradiological environmental impacts associated with the proposed action.

Alternatives to the Proposed Action:

Since the Commission has concluded there is no measurable environmental impact associated with the proposed action, any alternatives with equal or greater environmental impact need not be evaluated. As an alternative to the proposed action, the staff considered denial of the proposed action. Denial of the application would result in no change in current

environmental impacts. The environmental impacts of the proposed action and the alternative action are similar.

Alternative Use of Resources:

This action does not involve the use of any resources not previously considered in the Final Environmental Statement for the Callaway Plant dated March 1975.

Agencies and Persons Consulted:

In accordance with its stated policy, on March 19, 1998, the staff consulted with the Missouri State Official, Mr. Tom Lange of the Missouri Department of Natural Resources, regarding the environmental impact of the proposed action. The State official had no comments.

FINDING OF NO SIGNIFICANT IMPACT


Based upon the environmental assessment, the Commission concludes that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the Commission has determined not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the licensee's letter dated August 22, 1997, which is available for public inspection at the Commission's Public Document Room, The German Building, 2120 L Street, NW., Washington, DC, and at the local public

document room located at the University of Missouri-Columbia, Elmer Ellis Library, Columbia, Missouri 65201-5149.

Dated at Rockville, Maryland, this 20th day of March 1998.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in black ink, appearing to read 'B. Westreich', with a large, stylized flourish at the end.

Barry C. Westreich, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation