



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

Docket No.: STN 50-483

MAR 28 1985

MEMORANDUM FOR: James R. Miller, Chief  
Operating Reactors Branch No. 3  
Division of Licensing

FROM: B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY NOTICE - NOTICE OF  
ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

Union Electric Company, Docket No. 50-483, Callaway Plant, Unit 1, Callaway  
County, Missouri

Date of application for amendment: December 28, 1984

Brief description of amendment: The amendment has been revised to incorporate  
a November 30, 1985 deadline for completion of environmental qualification  
of electrical equipment important to safety instead of the presently imposed  
deadline of March 31, 1985.

Date of issuance: March 28, 1985

Effective date: March 28, 1985

Facility Operating License No. NPF-30: Amendment revised the Technical  
Specifications.

Date of initial notice in Federal Register: January 23, 1985 (50 FR 3056)

The Commission's related evaluation of the amendment is contained in a Safety  
Evaluation, dated March 28, 1985. No significant hazards consideration  
comments received: No.

Contact: J. A. Stevens, NRR  
x27144

8504100356 850328  
PDR ADOCK 05000483  
P PDR

Local Public Document Room locations: Fulton City Library, 709 Market Street, Fulton, Missouri 65251 and Olin Library of Washington University, Skinker and Lindell Boulevard, St. Louis, Missouri 63130.

151  
B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing

cc: J. Stevens  
P. O'Connor  
M. Rushbrook  
T. Alexion  
P. Kreutzer

CONCURRENCES:

DL:LB#1  
MRushbrook:es  
3/1/85

DL:LB#1  
JStevens  
3/11/85

DL:LB#1  
TAlexion  
3/11/85

DL:LB#1  
PO'Connor  
3/1/85

OELD  
3/1/85

DL:LB#1  
BJYoungblood  
3/1/85

DIST:

Docket File

NRC PDR  
Local PDR  
PRC System  
NSIC  
HDenton  
HThompson  
JStevens  
PO'Connor  
MRushbrook (2)  
OELD

see  
work  
done  
in  
Stenton  
JB



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

MAR 28 1985

Docket No.: STN 50-483

Mr. D. F. Schnell  
Vice President - Nuclear  
Union Electric Company  
P. O. Box 149  
St. Louis, MO 63166

Dear Mr. Schnell:

Subject: Callaway Plant, Unit 1 - Amendment No. 5 to License NPF-30

The Commission has issued the enclosed Amendment No. 5 to Operating License NPF-30 for the Callaway Plant, Unit 1. The amendment consists of a change to License Condition 2.C.(3)(a) of Facility Operating License NPF-30 in response to your application dated December 28, 1984, which requested a November 30, 1985 deadline for the environmental qualification of electrical equipment important to safety.

A copy of the related Safety Evaluation is enclosed. The notice of issuance will be included in the Commission's next regular monthly Federal Register Notice.

Sincerely,

A handwritten signature in cursive script, reading "B. J. Youngblood", is written over the typed name.

B. J. Youngblood, Chief  
Licensing Branch No. 1  
Division of Licensing

Enclosures:

1. Amendment No. 5 to NPF-30
2. Safety Evaluation Report

cc: See next page

8504100364 850328  
PDR ADOCK 05000483  
P PDR

CALLAWAY

Mr. D. F. Schnell  
Vice President - Nuclear  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

cc: Mr. Nicholas A. Petrick  
Executive Director - SNUPPS  
5 Choke Cherry Road  
Rockville, Maryland 20850

Gerald Charnoff, Esq. :  
Thomas A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
1800 M Street, N. W.  
Washington, D. C. 20036

Mr. J. E. Birk  
Assistant to the General Counsel  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

Mr. John Neisler  
U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
RR#1  
Steedman, Missouri 65077

Mr. Donald W. Capone, Manager  
Nuclear Engineering  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

A. Scott Cauger, Esq.  
Assistant General Counsel for the  
Missouri Public Service Comm.  
Post Office Box 360  
Jefferson City, Missouri 65101

Ms. Marjorie Reilly  
Energy Chairman of the League of  
Women Voters of Univ. City, MO  
7065 Pershing Avenue  
University City, Missouri 63130

Mr. Donald Bollinger, Member  
Missourians for Safe Energy  
6267 Delmar Boulevard  
University City, Missouri 63130

Mayor Howard Steffen  
Chamois, Missouri 65024

Professor William H. Miller  
Missouri Kansas Section, American  
Nuclear Society  
Department of Nuclear Engineering  
1026 Engineering Building  
University of Missouri  
Columbia, Missouri 65211

Mr. Robert G. Wright  
Assoc. Judge, Eastern District  
County Court, Callaway County,  
Missouri  
Route #1  
Fulton, Missouri 65251

Lewis C. Green, Esq.  
Green, Hennings & Henry  
Attorney for Joint Intervenors  
314 N. Broadway, Suite 1830  
St. Louis, Missouri 63102

Mr. Earl Brown  
School District Superintendent  
Post Office Box 9  
Kingdom City, Missouri 65262

Mr. Harold Lottman  
Presiding Judge, Dasconade County  
Route 1  
Owensville, Missouri 65066

Mr. John G. Reed  
Route #1  
Kingdom City, Missouri 65262

Mr. Dan I. Bolef, President  
Kay Drey, Representative  
Board of Directors Coalition  
for the Environment  
St. Louis Region  
6267 Delmar Boulevard  
University City, Missouri 63130

cc: Regional Administrator  
U. S. NRC, Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Mr. Ronald A. Kucera, Deputy Director  
Department of Natural Resources  
P. O. Box 176  
Jefferson City, Missouri 65102

Mr. Glenn L. Koester :  
Vice President - Nuclear  
Kansas Gas and Electric Company  
201 North Market Street  
Post Office Box 208  
Wichita, Kansas 67201

Eric A. Eisen, Esq.  
Birch, Horton, Bittner and Moore  
Suite 1100  
1140 Connecticut Avenue, N. W.  
Washington, D. C. 10036



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

UNION ELECTRIC COMPANY

DOCKET NO. 50-483

CALLAWAY PLANT, UNIT 1


AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 5  
License No. NPF-30

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Union Electric Company (the licensee), dated December 28, 1984, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public; and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, Facility Operating License No. NPF-30 is amended by changing License Condition 2.C.(3)(a) to read as follows:
  - (3) Environmental Qualification (Section 3.11, SSER #3)\*
    - (a) Prior to November 30, 1985, UE shall environmentally qualify all electrical equipment according to the provisions of 10 CFR 50.49.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Harold R. Deaton, Director  
Office of Nuclear Reactor Regulation

Date of Issuance: MAR 28 1985



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
SUPPORTING AMENDMENT NO. 5 TO FACILITY OPERATING LICENSE NO. NPF-30

UNION ELECTRIC COMPANY

CALLAWAY PLANT, UNIT 1

DOCKET NO. STN 50-483

1.0 INTRODUCTION

By letter dated December 28, 1984, Union Electric Company (the licensee) requested an amendment to Facility Operating License No. NPF-30 for operation of the Callaway Plant in Callaway County, Missouri.

The amendment approves a revision to License Condition 2.C.(3)(a) of Facility Operating License No. NPF-30.

2.0 EVALUATION

License Condition 2.C.(3)(a) has been revised to incorporate a November 30, 1985 deadline for completion of environmental qualification of electrical equipment important to safety instead of the presently imposed March 31, 1985 deadline.

By letter dated December 21, 1984, SNUPPS indicated that all required equipment qualification programs for Balance of Plant equipment have been completed, and all required NSSS qualification programs have been completed by Westinghouse with the exception of ESE-43, ESE-44, and HE-7. The SNUPPS submittal included revised Justifications for Interim Operation (JIOs) applicable to NSSS qualification programs ESE-43 and ESE-44, "Incore Thermocouples, Connectors and Reference Junction Box." Thus, with these revisions, all outstanding JIOs applicable to the Callaway plant are up-to-date. SNUPPS stated that the three remaining qualification programs have not been completed due to test complications. These three qualification programs are currently scheduled to be completed as follows: ESE-43 by August 6, 1985; ESE-44 by October 4, 1985; and HE-7 by September 27, 1985. The licensee has stated that all outstanding JIOs are adequate to support safe plant operation until the qualification programs are completed by the revised November 30, 1985 deadline.

The staff has reviewed the licensee's submittal and has concluded that the request for extension is timely and demonstrates good cause for the requested extension. The staff concurs with the licensee's conclusion that all outstanding JIOs will remain valid through November 30, 1985 and that the equipment will not have any significant degradation during this extended time period. Based on the information and analyses provided the staff finds that the requested schedule change is acceptable and License Condition 2.C.(3)(a) may be revised accordingly.

8504100376 850328  
PDR ADDCK 05000483  
P PDR



### 3.0 ENVIRONMENTAL CONSIDERATION

This amendment involves a change to a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant change in the types or significant increase in the amounts of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR Section 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

### 4.0 CONCLUSION

We have concluded, based on the considerations discussed above, that:

- (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner; and
- (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: MAR 28 1985

Principal Contributors:

J. A. Stevens, LB#1

A. Masciantonio, EQB