



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
REGARDING PROJECTED VALUES OF MATERIAL PROPERTIES
FOR FRACTURE TOUGHNESS REQUIREMENTS
FOR PROTECTION AGAINST PRESSURIZED THERMAL SHOCK EVENTS

UNION ELECTRIC COMPANY

CALLAWAY PLANT

DOCKET NO. 50-483

INTRODUCTION

As required by 10 CFR 50.61, "Fracture Toughness Requirements for Protection Against Pressurized Thermal Shock" (PTS Rule) which was published in the Federal Register July 23, 1985, the licensee for each operating pressurized water reactor "shall submit projected values of RT_{PTS} (at the inner vessel surface) of reactor vessel beltline materials by giving values from the time of submittal to the expiration date of the operating license. The assessment must specify the bases for the projection including the assumptions regarding core loading patterns. This assessment must be submitted by January 23, 1986, and must be updated whenever changes in core loadings, surveillance measurements or other information indicate a significant change in projected values."

By letter dated January 21, 1986, the Union Electric Company, licensee for the Callaway plant, submitted information on the material properties and the fast neutron fluence ($E > 1.0$ MeV) of the reactor pressure vessel in compliance with the requirements of 10 CFR 50.61 (Reference 1). The NRC Staff reviewed the pressure vessel material properties and found them acceptable (Reference 2). The following evaluation concerns the estimation of the fluence to the pressure vessel to the end of the current license and the corresponding value of the RT_{PTS} .

EVALUATION OF THE MATERIAL ASPECTS

The controlling beltline material from the standpoint of PTS susceptibility was identified to be the lower shell plate R2708-1.

The material properties of the controlling material and the associated margin and chemistry factor were reported to be:

	<u>Utility Submittal</u>	<u>Staff Evaluation</u>
CU (copper content, %)	0.08	0.08
Ni (nickel content, %)	0.60	0.60
I (Initial RT_{NDT} , °F)	50	50
M (Margin, °F)	--	48
CF (Chemistry Factor, °F)	--	44.4

8612190008 861215
PDR ADOCK 05000483
P PDR

The controlling material has been properly identified. The justifications given for the copper and nickel contents and the initial RT_{NDT} are acceptable. The margin has been derived from consideration of the bases for these values, following the PTS Rule, Section 50.61 of 10 CFR Part 50. Assuming that the reported values of fluence are correct, Equation 1 of the PTS rule governs, and the chemistry factor is as shown above.

The methodology of the fluence calculation was based on the discrete ordinates code DOT with an ENDF/B-IV based cross section set. The scattering is treated with a P_1 approximation. However, a conservative 20% allowance was made for the flux estimate compared to a P_3 estimate. An additional 20% was added for uncertainties and another 20% for future core design changes. The total increase amounts to a factor of 1.73 for a peak fast fluence ($E > 1.0$ MeV) of 3.63×10^{19} n/cm². The methodology and the approximations used are acceptable.

The equation specified in 10 CFR 50.61, as applicable for the Callaway Plant is:

$$RT_{PTS} = I + M + (-10 + 470 \times Cu + 350 \times CuxNi) \times f^{0.27}$$

where: I = Initial Rt_{NDT} = 50°F
M = Uncertainty Margin = 48°F
Cu = w/o Copper in lower shell plate R2708-1 = 0.08
Ni = w/o Nickel in lower shell plate R2708-1 = 0.60
f = Peak Azimuthal Fluence ($E > 1.0$ MeV) lower shell plate R2708-1
in units of 10^{19} n/cm² = 3.63

Therefore, to the end of 32 effective full power years:

$$RT_{PTS} = 50 + 48 + (-10 + 470 \times 0.08 + 350 \times 0.08 \times 0.60) \times 3.63^{0.27} \\ = 98 + 44.4 \times 1.416 = 160.9^\circ F$$

which is lower than 270°F, the applicable PTS rule screening criterion and is acceptable. It should be noted that the above fluence represents less than 2.5% of the fluence required to meet the 10 CFR 50.61 screening criteria.

In view of:

- (a) the Pressure-Temperature updating requirements for the fracture toughness of the beltline material in 10 CFR 50 Appendix G, and
- (b) the fact that the RT_{PTS} value is readily available from the calculation of the Pressure Temperature limits, and
- (c) the staff desire to be informed on the current value of the RT_{PTS} for all PWRs,

we request that the licensee submit a re-evaluation of the RT_{PTS} and a comparison to the prediction of Reference 1 along with the future Pressure-Temperature operating limits which are required by 10 CFR 50 Appendix G.* It should be noted that this re-evaluation is a requirement by 10 CFR 50.61, whenever core loadings, surveillance measurements, or other information indicate a significant change in projected values.

*. This request for information is covered under OMB clearance No. 3150-0011.

Docket No.: 50-483

15 DEC 1986

Mr. D. F. Schnell
Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Dear Mr. Schnell:

Subject: Projected Values of Material Properties for Fracture Toughness
Requirements for Protection Against Pressurized Thermal Shock
Events

We have reviewed your letter dated January 21, 1986 which was submitted in response to the Pressurized Thermal Shock (PTS) Rule, 10 CFR 50.61, for the Callaway Plant. We have found the material properties of reactor vessel belt-line materials, the projected fluence at the inner surface of the reactor vessel for the end of life of the plant, and the calculated RT_{PTS} for the end of life of the plant to be acceptable. The calculated RT_{PTS} is below the screening criteria of 270°F at 32 EFPY which is beyond the expiration date of the license and, therefore, meets the requirements of the PTS Rule.

The PTS Rule requires that the projected assessment of the RT_{PTS} must be updated whenever changes in core loadings, surveillance measurements or other information (including changes in capacity factor) indicate a significant change in the projected values. This ensures that the licensees will track the accumulated fluence for the limiting beltline materials throughout the life of the plant to verify that their assumptions remain valid. In this regard we request that you submit a re-evaluation of the RT_{PTS} and comparison with the predicted value in any future Pressure-Temperature submittals which are submitted as required by 10 CFR 50, Appendix G.

Our associated Safety Evaluation is enclosed.

Sincerely,

Paul W. O'Connor, Project Manager
PWR Project Directorate #4
Division of PWR Licensing-A

Enclosure: As stated

cc w/enclosure: See next page

Distribution:

Docket File	MDuncan	JPartlow
NRC PDR	PO'Connor	BGrimes
Local PDR	BJYoungblood	EJordan
PRC System	OGC-Bethesda	NThompson
PWR#4 rdg	ACRS (10)	

Pwr
PWR#4/DPWR-A
PO'Connor/mac
12/14/86

MDuncan
PWR#4/DPWR-A
MDuncan
12/12/86

BJYoungblood
PWR#4/DPWR-A
BJYoungblood
12/15/86

8612190002 861215
PDR ADOCK 05000483
P PDR

Mr. D. F. Schnell
Union Electric Company

Callaway Plant
Unit No. 1

cc:

Mr. Nicholas A. Petrick
Executive Director - SNUPPS
5 Choke Cherry Road
Rockville, Maryland 20850

Lewis C. Green, Esq.
Green, Hennings & Henry
Attorney for Joint Intervenors
314 N. Broadway, Suite 1830
St. Louis, Missouri 65251

Gerald Charnoff, Esq.
Thomas A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N. W.
Washington, D. C. 20037

Ms. Marjorie Reilly
Energy Chairman of the League of
Women Voters of Univ. City, MO
7065 Pershing Avenue
University City, Missouri 63130

Mr. J. E. Birk
Assistant to the General Counsel
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Mr. Donald Bollinger, Member
Missourians for Safe Energy
6267 Delmar Boulevard
University City, Missouri 63130

U. S. Nuclear Regulatory Commission
Resident Inspectors Office
RR#1
Steedman, Missouri 65077

Mr. Dan I. Bolef, President
Kay Drey, Representative
Board of Directors Coalition
for the Environment
St. Louis Region
6267 Delmar Boulevard
University City, Missouri 63130

Mr. Donald W. Capone, Manager
Nuclear Engineering
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Chris R. Rogers, P.E.
Manager - Electric Department
301 W. High
Post Office Box 360
Jefferson City, Missouri 65102

Regional Administrator
U. S. NRC, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. Ronald A. Kucera, Deputy Director
Department of Natural Resources
P. O. Box 176
Jefferson City, Missouri 65102

Mr. Glenn L. Koester
Vice President - Nuclear
Kansas Gas and Electric Company
201 North Market Street
Post Office Box 208
Wichita, Kansas 67201