

October 8, 1987

*Correction to Amdt 27
to NPF-30*

Docket No. 50-483

Distribution:

<u>Docket File</u>	Wanda Jones
NRC & Local PDRs	EButcher
GHolahan	ACRS(10)
DWigginton	GPA/PA
PKreutzer	ARM/PFMB
TAlexion	Grey File
OGC-Bethesda	
DHagan	
EJordan	
JPartlow	
TBarnhart (4)	

Mr. Donald F. Schnell
Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Dear Mr. Schnell:

On September 21, 1987, the Commission issued Amendment No. 27 to Facility Operating License No. NPF-30 for the Callaway Plant, Unit 1, in response to your application dated March 30, 1987. The amendment revised the requirements for reporting iodine spiking from a short-term report to an item which is to be included in the Annual Report, and eliminated the requirement to shut down the plant after 800 hours of operation with a dose equivalent I-131 value of 1 microcurie/gram or greater.

Page 3/4 4-26 of the Technical Specifications inadvertently contained a typographical error, as you called to our attention by telephone call on October 6, 1987. Enclosed is a corrected page 3/4 4-26 with corresponding backup page.

Please accept our apologies for any inconvenience this error may have caused you.

Sincerely,

/s/

Thomas W. Alexion, Project Manager
Project Directorate III-3
Division of Reactor Projects

Enclosure:
TS page 3/4 4-26

Office: LA/PDIII-3
Surname: PKreutzer
Date: 10/8/87

PM/PDIII-3
TAlexion/r1
10/8/87

PD/PDIII-3
DWigginton
10/ /87

Mr. D. F. Schnell
Union Electric Company

Callaway Plant
Unit No. 1

cc:

Dr. J. O. Cermack
CFA Inc.
4 Professional Dr., Suite 110
Gaithersburg, MD 20879

Gerald Charnoff, Esq.
Thomas A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N. W.
Washington, D. C. 20037

Mr. T. P. Sharkey
Supervisor, Compliance
Union Electric Company
Post Office Box 620
Fulton, Missouri 65251

U. S. Nuclear Regulatory Commission
Resident Inspectors Office
RR#1
Steedman, Missouri 65077

Mr. Alan C. Passwater, Manager
Licensing and Fuels
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Manager - Electric Department
Missouri Public Service Commission
301 W. High
Post Office Box 360
Jefferson City, Missouri 65102

Regional Administrator
U. S. NRC, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. Ronald A. Kucera, Deputy Director
Department of Natural Resources
P. O. Box 176
Jefferson City, Missouri 65102

Mr. Bart D. Withers
President and Chief
Executive Officer
Wolf Creek Nuclear Operating
Corporation
P. O. Box 411
Burlington, Kansas 66839

Mr. Dan I. Bolef, President
Kay Drey, Representative
Board of Directors Coalition
for the Environment
St. Louis Region
6267 Delmar Boulevard
University City, Missouri 63130

REACTOR COOLANT SYSTEM

LIMITING CONDITION FOR OPERATION

ACTION (Continued)

MODES 1, 2, 3, 4, and 5:

With the specific activity of the reactor coolant greater than 1 micro-Curie per gram DOSE EQUIVALENT I-131 or greater than 100/E microCuries per gram of gross radioactivity, perform the sampling and analysis requirements of Item 4.a) of Table 4.4-4 until the specific activity of the reactor coolant is restored to within its limits.

SURVEILLANCE REQUIREMENTS

4.4.8 The specific activity of the reactor coolant shall be determined to be within the limits by performance of the sampling and analysis program of Table 4.4-4.

8710260316 871008
PDR ADOCK 05000483
P PDR

REACTOR COOLANT SYSTEM

LIMITING CONDITION FOR OPERATION

ACTION (Continued)

MODES 1, 2, 3, 4, and 5:

With the specific activity of the reactor coolant greater than 1 micro-Curie per gram DOSE EQUIVALENT I-131 or greater than 100/E microCuries per gram of gross radioactivity, perform the sampling and analysis requirements of Item 4.a) of Table 4.4-4 until the specific activity of the reactor coolant is restored to within its limits.

SURVEILLANCE REQUIREMENTS

4.4.8 The specific activity of the reactor coolant shall be determined to be within the limits by performance of the sampling and analysis program of Table 4.4-4.