

May 4, 1989

Docket No. 50-483

Mr. Donald F. Schnell  
Senior Vice President - Nuclear  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

DISTRIBUTION:

<u>Docket Files</u>	NRC & Local PDRs
PDIII-3 r/f	GHolahan
MVirgilio	JHannon
TAlexion	PKreutzer
OGC-WF1	DHagan
EJordan	BGrimes
TMeek(4)	WandaJones
EButcher	ACRS(10)
GPA/PA	ARM/LFMB
PDIII-3 Gray Files	

Dear Mr. Schnell:

SUBJECT: CORRECTION TO AMENDMENT NOS. 43 AND 44 TO FACILITY OPERATING LICENSE  
NO. NPF-30

On April 14 and 19, 1989, the Commission issued Amendment Nos. 43 and 44, respectively, to Facility Operating License No. NPF-30 for the Callaway Plant, Unit 1. The amendment revised the Technical Specifications in response to your applications dated August 30, 1988 and October 25, 1988.

Your staff identified to us some typographical errors on four pages of the Technical Specifications issued with Amendment Nos. 43 and 44. Some of these errors occurred as a result of misinterpretation of the draft changes you submitted, others were as a result of having to retype some of the TS pages to reposition text.

The pages in question, 3/4 3-3, 3/4 3-36(a), 3/4 1-4 and 3/4 6-14, have been corrected per our discussion. The identified pages, with their corresponding overleaf pages where appropriate, are enclosed herewith.

Please accept our apologies for the inconvenience these errors may have caused you.

Sincerely,

/s/

Thomas W. Alexion, Project Manager  
Project Directorate III-3  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosure:

TS pages 3/4 3-3, 3/4 3-36(a),  
3/4 1-4 and 3/4 6-14

cc w/enclosures:

See next page

Office: LA/PDIII-3  
Surname: PKreutzer  
Date: 5/3/89

PM/PDIII-3  
TAlexion/tg  
5/4/89

PD/PDIII-3  
JHannon  
5/4/89

8905190017 890504  
PDR ADDCK 05000483  
P PNU

Mr. D. F. Schnell  
Union Electric Company

Callaway Plant  
Unit No. 1

cc:

Dr. J. O. Cermack  
CFA Inc.  
4 Professional Dr., Suite 110  
Gaithersburg, MD 20879

Gerald Charnoff, Esq.  
Thomas A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N Street, N. W.  
Washington, D. C. 20037

Mr. T. P. Sharkey  
Supervising Engineer,  
Site Licensing  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
RR#1  
Steedman, Missouri 65077

Mr. Alan C. Passwater, Manager  
Licensing and Fuels  
Union Electric Company  
Post Office Box 149  
St. Louis, Missouri 63166

Manager - Electric Department  
Missouri Public Service Commission  
301 W. High  
Post Office Box 360  
Jefferson City, Missouri 65102

Regional Administrator  
U. S. NRC, Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Mr. Ronald A. Kucera, Deputy Director  
Department of Natural Resources  
P. O. Box 176  
Jefferson City, Missouri 65102

Mr. Bart D. Withers  
President and Chief  
Executive Officer  
Wolf Creek Nuclear Operating  
Corporation  
P. O. Box 411  
Burlington, Kansas 66839

Mr. Dan I. Bolef, President  
Kay Drey, Representative  
Board of Directors Coalition  
for the Environment  
St. Louis Region  
6267 Delmar Boulevard  
University City, Missouri 63130

TABLE 3.3-1 (Continued)

## REACTOR TRIP SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
11. Pressurizer Water Level-High	3	2	2	1	6#
12. Reactor Coolant Flow-Low					
a. Single Loop (Above P-8)	3/loop	2/loop in any operating loop	2/loop in each operating loop	1	6#
b. Two Loops (Above P-7 and below P-8)	3/loop	2/loop in two operating loops	2/loop each operating loop	1	6#
13. Steam Generator Water Level Low-Low					
a. Steam Generator Water Level Low-Low (Adverse Containment Environment)	4/stm. gen.	2/stm. gen. in any operating stm. gen.	3/stm. gen. each operating stm. gen.	1, 2	6#, 7, (1)
b. Steam Generator Water Level Low-Low (Normal Containment Environment)	4/stm. gen.	2/stm. gen. in any operating stm. gen.	3/stm. gen. each operating stm. gen.	1, 2	7, 13#, (1)
c. Vessel $\Delta T$ (Power-1, Power-2)	4	2	3	1, 2	11 # (1)
d. Containment Pressure - Environmental Allowance Modifier	4	2	3	1, 2	11 # (1)

CALLAWAY - UNIT 1

3/4 3-3

Amendment No. 17, 43

8905190021 890504  
PDR ADDCK 05000483  
PNU

TABLE 3.3-1 (Continued)  
REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
14. Undervoltage-Reactor Coolant Pumps	4-2/bus	2-1/bus	3	1	6#(1)
15. Underfrequency-Reactor Coolant Pumps	4-2/bus	2-1/bus	3	1	6#
16. Turbine Trip					
a. Low Fluid Oil Pressure	3	2	2	1	6#
b. Turbine Stop Valve Closure	4	4	1	1	11#
17. Safety Injection Input from ESF	2	1	2	1, 2	9

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION  
SURVEILLANCE REQUIREMENTS

FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	ANALOG CHANGE OPERATIONAL TEST	TRIP ACTUATING DEVICE OPERATIONAL TEST	ACTUATION LOGIC TEST	MASTER RELAY TEST	SLAVE RELAY TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED
6. Auxiliary Feedwater (Continued)								
f. Loss-of-Offsite Power	N.A.	R	N.A.	M	N.A.	N.A.	N.A.	1, 2, 3
g. Trip of All Main Feedwater Pumps	N.A.	N.A.	N.A.	R	N.A.	N.A.	N.A.	1, 2
h. Auxiliary Feedwater Pump Suction Pressure-Low	S	R	M	N.A.	N.A.	N.A.	N.A.	1, 2, 3
7. Automatic Switchover to Containment Sump								
a. Automatic Actuation Logic and Actuation Relays (SSPS)	N.A.	N.A.	N.A.	N.A.	M(1)	M(1)	Q(3)	1, 2, 3, 4
b. RWST Level - Low-Low Coincident With Safety Injection	S	R	M	N.A.	N.A.	N.A.	N.A.	1, 2, 3, 4
	See Item 1 above for all Safety Injection Surveillance Requirements.							
8. Loss of Power								
a. 4 kV Undervoltage-Loss of Voltage	N.A.	R	N.A.	M	N.A.	N.A.	N.A.	1, 2, 3, 4
b. 4 kV Undervoltage-Grid Degraded Voltage	N.A.	R	N.A.	M	N.A.	N.A.	N.A.	1, 2, 3, 4

## REACTIVITY CONTROL SYSTEMS

SHUTDOWN MARGIN -  $T_{avg} \leq 200^{\circ}\text{F}$

### LIMITING CONDITION FOR OPERATION

---

3.1.1.2 The SHUTDOWN MARGIN shall be greater than or equal to 1%  $\Delta k/k$ .

APPLICABILITY: MODE 5.

ACTION:

With the SHUTDOWN MARGIN less than 1%  $\Delta k/k$ , immediately initiate and continue boration at greater than or equal to 30 gpm of a solution containing greater than or equal to 7000 ppm boron or equivalent until the required SHUTDOWN MARGIN is restored.

### SURVEILLANCE REQUIREMENTS

---

4.1.1.2 The SHUTDOWN MARGIN shall be determined to be greater than or equal to 1%  $\Delta k/k$ :

- a. Within 1 hour after detection of an inoperable control rod(s) and at least once per 12 hours thereafter while the rod(s) is inoperable. If the inoperable control rod is immovable or untrippable, the SHUTDOWN MARGIN shall be verified acceptable with an increased allowance for the withdrawn worth of the immovable or untrippable control rod(s); and
- b. At least once per 24 hours by consideration of the following factors:
  - 1) Reactor Coolant System boron concentration,
  - 2) Control rod position,
  - 3) Reactor Coolant System average temperature,
  - 4) Fuel burnup based on gross thermal energy generation,
  - 5) Xenon concentration, and
  - 6) Samarium concentration.

## REACTIVITY CONTROL SYSTEMS

### MODERATOR TEMPERATURE COEFFICIENT

#### LIMITING CONDITION FOR OPERATION

---

3.1.1.3 The moderator temperature coefficient (MTC) shall be:

- a. Less positive than +5 pcm/°F for power levels up to 70% RATED THERMAL POWER and a linear ramp from that point to 0 pcm/°F at 100% RATED THERMAL POWER for the all rods withdrawn, beginning of cycle life (BOL) condition; and
- b. Less negative than  $-4.1 \times 10^{-4} \Delta k/k/°F$  for the all rods withdrawn, end of cycle life (EOL), RATED THERMAL POWER condition.

APPLICABILITY: Specification 3.1.1.3a. - MODES 1 and 2\*#.  
Specification 3.1.1.3b. - MODES 1, 2 and 3#.

ACTION:

- a. With the MTC more positive than the limit of Specification 3.1.1.3a. above, operation in MODES 1 and 2 may proceed provided:
  1. Control rod withdrawal limits are established and maintained sufficient to restore the MTC to within the above limits within 24 hours or be in HOT STANDBY within the next 6 hours. These withdrawal limits shall be in addition to the insertion limits of Specification 3.1.3.6;
  2. The control rods are maintained within the withdrawal limits established above until a subsequent calculation verifies that the MTC has been restored to within its limit for the all rods withdrawn condition; and
  3. A Special Report is prepared and submitted to the Commission pursuant to Specification 6.9.2 within 10 days, describing the value of the measured MTC, the interim control rod withdrawal limits, and the predicted average core burnup necessary for restoring the positive MTC to within its limit for the all rods withdrawn condition.
- b. With the MTC more negative than the limit of Specification 3.1.1.3b. above, be in HOT SHUTDOWN within 12 hours.

---

\* With  $K_{eff}$  greater than or equal to 1.

# See Special Test Exception Specification 3.10.3.

## CONTAINMENT SYSTEMS

### 3/4.6.2 DEPRESSURIZATION AND COOLING SYSTEMS

#### CONTAINMENT SPRAY SYSTEM

##### LIMITING CONDITION FOR OPERATION

---

3.6.2.1 Two independent Containment Spray Systems shall be OPERABLE with each Containment Spray System capable of taking suction from the RWST and transferring suction to the containment sump.

APPLICABILITY: MODES 1, 2, 3, and 4.

##### ACTION:

With one Containment Spray System inoperable, restore the inoperable Containment Spray System to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours; restore the inoperable Containment Spray System to OPERABLE status within the next 48 hours or be in COLD SHUTDOWN within the following 30 hours.

##### SURVEILLANCE REQUIREMENTS

---

4.6.2.1 Each Containment Spray System shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each valve (manual, power-operated, or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position;
- b. By verifying, that on recirculation flow, each pump develops a discharge pressure of greater than or equal to 250 psig when tested pursuant to Specification 4.0.5;
- c. At least once per 18 months during shutdown, by:
  - 1) Verifying that each automatic valve in the flow path actuates to its correct position on a Containment Pressure-High-3 (CSAS) test signal, and
  - 2)# Verifying that each spray pump starts automatically on a Containment Pressure-High-3 (CSAS) test signal.
- d. At least once per 5 years by performing an air or smoke flow test through each spray header and verifying each spray nozzle is unobstructed.

#The specified 18 month frequency may be waived for Cycle I provided the surveillance is performed prior to restart following the first refueling outage or June 1, 1986, whichever occurs first. The provisions of Specification 4.0.2 are reset from performance of this surveillance.



## CONTAINMENT SYSTEMS

### SPRAY ADDITIVE SYSTEM

#### LIMITING CONDITION FOR OPERATION

---

3.6.2.2 The Spray Additive System shall be OPERABLE with:

- a. A spray additive tank containing a volume of between 4340 and 4540 gallons of between 31% and 34% by weight NaOH solution, and
- b. Two spray additive eductors each capable of adding NaOH solution from the chemical additive tank to a Containment Spray System pump flow.

APPLICABILITY: MODES 1, 2, 3, and 4.

#### ACTION:

With the Spray Additive System inoperable, restore the system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours; restore the Spray Additive System to OPERABLE status within the next 48 hours or be in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.6.2.2 The Spray Additive System shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each valve (manual, power-operated, or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position;
- b. At least once per 6 months by:
  - 1) Verifying the contained solution volume in the tank, and
  - 2) Verifying the concentration of the NaOH solution by chemical analysis.
- c. At least once per 18 months during shutdown, by verifying that each automatic valve in the flow path actuates to its correct position on a Containment Pressure-High-3 (CSAS) test signal; and
- d. At least once per 5 years by verifying
  - 1) Each eductor flow rate is greater than or equal to 52 gpm using the RWST as the test source throttled to 17 psig at the eductor inlet, and
  - 2) The lines between the spray additive tank and the eductors are not blocked by verifying flow.