

Table 3.3.1-1 (page 5 of 7)
Reactor Trip System Instrumentation

Note 1: Overtemperature ΔT

The Overtemperature ΔT Function Allowable Value shall not exceed the following NOMINAL TRIP SETPOINT by more than 4.3% of RTP.

$$\Delta T \frac{(1 + \tau_1 s)}{(1 + \tau_2 s)} \left(\frac{1}{1 + \tau_3 s} \right) \leq \Delta T_0 \left\{ K_1 - K_2 \frac{(1 + \tau_4 s)}{(1 + \tau_5 s)} \left[T \frac{1}{(1 + \tau_6 s)} - T' \right] + K_3 (P - P') - f_1(\Delta I) \right\}$$

Where: ΔT is measured RCS ΔT by loop narrow range RTDs, °F.
 ΔT_0 is the indicated ΔT at RTP, °F.
 s is the Laplace operator, sec⁻¹.
 T is the measured RCS average temperature, °F.
 T' is the nominal T_{avg} at RTP, ≤ 585.1 °F.

P is the measured pressurizer pressure, psig
 P' is the nominal RCS operating pressure, = 2235 psig

- K_1 = Overtemperature ΔT reactor NOMINAL TRIP SETPOINT, as presented in the COLR,
- K_2 = Overtemperature ΔT reactor trip heatup setpoint penalty coefficient, as presented in the COLR,
- K_3 = Overtemperature ΔT reactor trip depressurization setpoint penalty coefficient, as presented in the COLR,
- τ_1, τ_2 = Time constants utilized in the lead-lag controller for ΔT , as presented in the COLR,
- τ_3 = Time constants utilized in the lag compensator for ΔT , as presented in the COLR,
- τ_4, τ_5 = Time constants utilized in the lead-lag controller for T_{avg} , as presented in the COLR,
- τ_6 = Time constants utilized in the measured T_{avg} lag compensator, as presented in the COLR, and,
- $f_1(\Delta I)$ = a function of the indicated difference between top and bottom detectors of the power-range nuclear ion chambers; with gains to be selected based on measured instrument response during plant startup tests such that:

- (i) for $q_t - q_b$ between the "positive" and "negative" $f_1(\Delta I)$ breakpoints as presented in the COLR; $f_1(\Delta I) = 0$, where q_t and q_b are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and $q_t + q_b$ is total THERMAL POWER in percent of RATED THERMAL POWER;

(continued)

Table 3.3.1-1 (page 6 of 7)
Reactor Trip System Instrumentation

- (ii) for each percent imbalance that the magnitude of $q_t - q_b$ is more negative than the $f_1(\Delta I)$ "negative" breakpoint presented in the COLR, the ΔT Trip Setpoint shall be automatically reduced by the $f_1(\Delta I)$ "negative" slope presented in the COLR; and
- (iii) for each percent imbalance that the magnitude of $q_t - q_b$ is more positive than the $f_1(\Delta I)$ "positive" breakpoint presented in the COLR, the ΔT Trip Setpoint shall be automatically reduced by the $f_1(\Delta I)$ "positive" slope presented in the COLR.

Note 2: Overpower ΔT

The Overpower ΔT Function Allowable Value shall not exceed the following NOMINAL TRIP SETPOINT by more than 2.6% of RTP.

$$\Delta T \frac{(1 + \tau_1 s)}{(1 + \tau_2 s)} \left(\frac{1}{1 + \tau_3 s} \right) \leq \Delta T_0 \left\{ K_4 - K_5 \frac{\tau_7 s}{1 + \tau_7 s} \left(\frac{1}{1 + \tau_6 s} \right) T - K_6 \left[T \frac{1}{1 + \tau_6 s} - T^* \right] - f_2(\Delta I) \right\}$$

Where: ΔT is measured RCS ΔT by loop narrow range RTDs, °F.
 ΔT_0 is the indicated ΔT at RTP, °F.
 s is the Laplace transform operator, sec^{-1} .
 T is the measured RCS average temperature, °F.
 T^* is the nominal T_{avg} at RTP, ≤ 585.1 °F.

- K_4 = Overpower ΔT reactor NOMINAL TRIP SETPOINT as presented in the COLR,
- K_5 = $0.02/^\circ\text{F}$ for increasing average temperature and 0 for decreasing average temperature,
- K_6 = Overpower ΔT reactor trip heatup setpoint penalty coefficient as presented in the COLR for $T > T^*$ and $K_6 = 0$ for $T \leq T^*$,
- τ_1, τ_2 = Time constants utilized in the lead-lag controller for ΔT , as presented in the COLR,
- τ_3 = Time constants utilized in the lag compensator for ΔT , as presented in the COLR,
- τ_6 = Time constants utilized in the measured T_{avg} lag compensator, as presented in the COLR,
- τ_7 = Time constant utilized in the rate-lag controller for T_{avg} , as presented in the COLR, and
- $f_2(\Delta I)$ = a function of the indicated difference between top and bottom detectors of the power-range nuclear ion chambers; with gains to be selected based on measured instrument response during plant startup tests such that:

(continued)