

June 10, 2002

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Stop P1-137  
Washington, DC 20555-0001

ULNRC-04676



Gentlemen:

**DOCKET NUMBER 50-483  
CALLAWAY PLANT UNIT 1  
UNION ELECTRIC CO.  
FACILITY OPERATING LICENSE NPF-30  
LICENSEE EVENT REPORT 2002-008-00  
Non-conservative Technical Specification Allowable Value for Main Steam Line  
Pressure Negative Rate**

The enclosed licensee event report is submitted in accordance with 10CFR50.73(a)(2)(ii)(B), to report a non-conservative Technical Specification Allowable Value for Main Steam Line Pressure Negative Rate.

*Warren A. Witt*  
Warren A. Witt  
Manager, Callaway Plant

WAW/ewh

Enclosure

IE22

ULNRC04676

June 10, 2002

Page 2

cc: Mr. Ellis W. Merschoff  
Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-8064

Senior Resident Inspector  
Callaway Resident Office  
U.S. Nuclear Regulatory Commission  
8201 NRC Road  
Steedman, MO 65077

Mr. Jack N. Donohew (2 copies)  
Licensing Project Manager, Callaway Plant  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Mail Stop 7E1  
Washington, DC 20555-2738

Manager, Electric Department  
Missouri Public Service Commission  
PO Box 360  
Jefferson City, MO 65102

Mr. John O'Neill  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street N.W.  
Washington, DC 20037

Records Center  
Institute of Nuclear Power Operations  
700 Galleria Parkway  
Atlanta, GA 30339

Mr. Scott Bauer  
Regulatory Affairs  
Palo Verde NGS  
P. O. Box 52034, Mail Station 7636  
Phoenix, AZ 85072-2034

Mr. Dennis Buschbaum  
Comanche Peak SES  
P.O. Box 1002  
Glen Rose, TX 76043

Mr. Scott Head  
Supervisor, Licensing  
South Texas Project NOC  
Mail Code N5014  
P.O. Box 289  
Wadsworth, TX 77483

Mr. Pat Nugent  
Supervisor, Licensing  
Pacific Gas & Electric  
Mail Stop 104/5/536  
P.O. Box 56  
Avila Beach, CA 93424

<b>NRC FORM 366</b> (7-2001)		<b>U.S. NUCLEAR REGULATORY COMMISSION</b>			APPROVED BY OMB NO. 3150-0104		EXPIRES 7-31-2004			
<b>LICENSEE EVENT REPORT (LER)</b>										
(See reverse for required number of digits/characters for each block)										
1. FACILITY NAME <b>CALLAWAY PLANT UNIT 1</b>					2. DOCKET NUMBER <b>05000 483</b>			3. PAGE <b>1 OF 4</b>		
4. TITLE <b>Non-conservative Technical Specification Allowable Value for Main Steam Line Pressure Negative Rate</b>										
5. EVENT DATE			6. LER NUMBER			7. REPORT DATE			8. OTHER FACILITIES INVOLVED	
MO	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REV NO	MO	DAY	YEAR	FACILITY NAME	DOCKET NUMBER
04	18	2002	2002	008	00	06	7	2002		05000
11. THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR ' : (Check all that apply)										
9. OPERATING MODE		1		20.2201(b)		20.2203(a)(3)(ii)		<input checked="" type="checkbox"/> 50.73(a)(2)(ii)(B)		50.73(a)(2)(ix)(A)
10. POWER LEVEL		100		20.2201(d)		20.2203(a)(4)		50.73(a)(2)(iii)		50.73(a)(2)(x)
				20.2203(a)(1)		50.36(c)(1)(i)(A)		50.73(a)(2)(iv)(A)		73.71(a)(4)
				20.2203(a)(2)(i)		50.36(c)(1)(ii)(A)		50.73(a)(2)(v)(A)		73.71(a)(5)
				20.2203(a)(2)(ii)		50.36(c)(2)		50.73(a)(2)(v)(B)		OTHER Specify in Abstract below or in NRC Form 366A
				20.2203(a)(2)(iii)		50.46(a)(3)(ii)		50.73(a)(2)(v)(C)		
				20.2203(a)(2)(iv)		50.73(a)(2)(i)(A)		50.73(a)(2)(v)(D)		
				20.2203(a)(2)(v)		50.73(a)(2)(i)(B)		50.73(a)(2)(vii)		
				20.2203(a)(2)(vi)		50.73(a)(2)(i)(C)		50.73(a)(2)(viii)(A)		
				20.2203(a)(3)(i)		50.73(a)(2)(ii)(A)		50.73(a)(2)(viii)(B)		
<b>12. LICENSEE CONTACT FOR THIS LER</b>										
NAME <b>Mark A. Reidmeyer</b>						TELEPHONE NUMBER (Include Area Code) <b>(573) 676-4306</b>				
<b>13. COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT</b>										
CAUSE	SYSTEM	COMPONENT	MANU-FACTURER	REPORTABLE TO EPIX	CAUSE	SYSTEM	COMPONENT	MANU-FACTURER	REPORTABLE TO EPIX	
<b>14. SUPPLEMENTAL REPORT EXPECTED</b>						<b>15. EXPECTED SUBMISSION DATE</b>		MONTH	DAY	YEAR
YES (If yes, complete EXPECTED SUBMISSION DATE)					<input checked="" type="checkbox"/>	NO				
16. ABSTRACT (Limit to 1400 spaces, i.e., approximately 15 single-spaced typewritten lines)										
<p>On 4/18/2002, during an extent of condition review concerning the neutron flux positive rate trip function, a concern was identified where Technical Specification (T/S) Table 3.3.2-1, Allowable Value for the Steam Line Pressure Negative Rate - High (HNPR), is less restrictive than the Safety Analyses Limit (SAL) credited in the Callaway Mode 3 Main Steam Line Break (MSLB) analysis.</p> <p>T/S lists the allowable value for the HNPR function as less than or equal to 124 psi. T/S Bases lists the Nominal Trip Setpoint (NTS) for the HNPR function as less than or equal to 100 psi. The Safety Analysis Limit (SAL) for the HNPR function is 100 psi. Consequently, the current T/S allows the HNPR function to be set at a value less conservative than the value assumed in the safety analysis.</p> <p>Corrective actions being evaluated include either decreasing the T/S Allowable Value from less than or equal to 124 psi to less than or equal to 100 psi, or revising the Callaway Mode 3 MSLB analysis to credit a HNPR SAL greater than or equal to 124 psi.</p> <p>Because the plant was operating in Mode 1, there were no immediate operability concerns. A Generic Letter 91-18 Operability Determination was completed which included the required compensatory actions for T/S compliance if the plant is taken to Mode 3 with reactor coolant system pressure below the P-11 setpoint of 1970 psig.</p>										

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)	DOCKET (2) NUMBER (2)	LER NUMBER (6)			PAGE (3)
Callaway Plant Unit 1	05000483	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	2 OF 4
		2002	- 008	- 00	

NARRATIVE (If more space is required, use additional copies of NRC Form 366A) (17)

I. DESCRIPTION OF THE REPORTABLE EVENT

A. REPORTABLE EVENT CLASSIFICATION

This event is reportable per 10 CFR 50.73(a)(2)(ii)(B), an unanalyzed condition.

B. PLANT OPERATING CONDITIONS PRIOR TO THE EVENT

Callaway Plant was in Mode 1 at 100 percent power.

C. STATUS OF STRUCTURES, SYSTEMS OR COMPONENTS THAT WERE INOPERABLE AT THE START OF THE EVENT AND THAT CONTRIBUTED TO THE EVENT

There were no structures, systems, or components inoperable at the time of discovery and that contributed to this event.

D. NARRATIVE SUMMARY OF THE EVENT, INCLUDING DATES AND APPROXIMATE TIMES

On 4/18/2002, during an extent of condition review concerning the neutron flux positive rate trip function, a concern was identified where Technical Specification (T/S) Table 3.3.2-1, Allowable Value for the Steam Line Pressure Negative Rate - High (HNPR), is less restrictive than the Safety Analyses Limit (SAL) credited in the Callaway Mode 3 Main Steam Line Break (MSLB) analysis.

T/S lists the Allowable Value for the HNPR function as less than or equal to 124 psi. T/S Bases lists the Nominal Trip Setpoint (NTS) for the HNPR function as less than or equal to 100 psi. The Safety Analysis Limit (SAL) for the HNPR function is 100 psi. Consequently, the T/S allow the HNPR function to be set at a value less conservative than the value assumed in the safety analysis.

During startup or shutdown evolutions when safety injection on low Pressurizer pressure or low steamline pressure is blocked below Permissive P-11 (Pressurizer pressure less than 1970 psig), the HNPR rate signal is enabled by P-11 to provide steamline isolation. With Reactor Coolant System (RCS) Avg greater than 450 degrees F, steamline isolation will be provided by the HNPR signal for break sizes greater than or equal to 0.02 sq. ft. Final Safety Analysis Report (FSAR) Steam System Piping Failure Analysis credits main steamline isolation on two out of three HNPR signals in any one loop during cooldown and heatup operations below P-11.

Corrective actions being evaluated include either decreasing the T/S Allowable Value from less than or equal to 124 psi to less than or equal to 100 psi or revising the Callaway Mode 3 MSLB analysis to credit a HNPR SAL greater than or equal to 124 psi.

Because the plant was operating in Mode 1, there were no immediate operability concerns. A Generic Letter 91-18 Operability Determination was completed. This evaluation included the required compensatory actions for T/S compliance if the plant is taken to Mode 3 with reactor coolant system pressure below the P-11 setpoint of 1970 psig.

E. METHOD OF DISCOVERY OF EACH COMPONENT, SYSTEM FAILURE, OR PROCEDURAL ERROR

This condition was identified during a review concerning the neutron flux positive rate trip function.

**LICENSEE EVENT REPORT (LER)**

FACILITY NAME (1)	DOCKET (2) NUMBER (2)	LER NUMBER (6)			PAGE (3)
Callaway Plant Unit 1	05000483	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	3 OF 4
		2002	- 008	- 00	

NARRATIVE (If more space is required, use additional copies of NRC Form 366A) (17)

II. EVENT DRIVEN INFORMATION

A. SAFETY SYSTEMS THAT RESPONDED

Not Applicable.

B. DURATION OF SAFETY SYSTEM INOPERABILITY

This T/S item is applicable in Mode 3 below the P-11 (Pressurizer pressure less than or equal to 1970 psig) interlock. At the time of discovery, Callaway Plant was in Mode 1, and thus there was no immediate inoperability. During past plant shutdowns, this situation would have been applicable while below P-11 until the Main Steam Isolation Valves were closed. This typically is of a short duration while the plant transitions between Modes.

C. SAFETY CONSEQUENCES AND IMPLICATIONS OF THE EVENT.

This does not pose a significant safety consequence due to the plant parameters necessary to render this circumstance applicable. Typically, this unique combination of plant pressure and system lineups is only experienced while transitioning between Modes and is of a short duration. Additionally, a historical review of related surveillance documents revealed that the electronic circuitry associated with the T/S HNPR setpoint is extremely reliable. This review, consisting of sixty-nine surveillance documents, found that the HNPR setpoint bistables were always within calibration tolerances. Based upon the demonstrated reliability of the electronic circuitry and the rarity of operating the plant within the limited conditions necessary for this scenario, this does not pose a significant safety consequence.

III. CAUSE OF THE EVENT

Generic evaluations conducted by Westinghouse led to the incorrect selection of 124 psi as the T/S Table 3.3.2-1 Allowable Value for Steam line pressure high negative rate.

IV. CORRECTIVE ACTIONS

Corrective actions being evaluated include either decreasing the T/S Allowable Value from less than or equal to 124 psi to less than or equal to 100 psi, or revising the Callaway Mode 3 MSLB analysis to credit a HNPR SAL greater than or equal to 124 psi.

A Generic Letter 91-18 Operability Determination was completed. This evaluation included the required compensatory actions for T/S compliance if the plant is taken to Mode 3 with reactor coolant system pressure below the P-11 setpoint of 1970 psig.

V. PREVIOUS SIMILAR EVENTS

A review was conducted of LERs and Callaway Corrective Action Requests (CARs) covering the period of 4/18/99 to 5/29/02. There were no previous LERs or CARs documenting a similar event or occurrence.

**LICENSEE EVENT REPORT (LER)**

FACILITY NAME (1)	DOCKET (2) NUMBER (2)	LER NUMBER (6)			PAGE (3)
Callaway Plant Unit 1	05000483	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	4 OF 4
		2002	- 008	- 00	

**NARRATIVE** (If more space is required, use additional copies of NRC Form 366A) (17)

VI. ADDITIONAL INFORMATION

The system and component codes listed below are from the IEEE Standard 805-1984 and IEEE Standard 803A-1984 respectively.

System: JG

Component: Not Applicable -- there was no faulted component.