

1 replace something, you put a barrier there or you do  
2 some operating things in there, some events. The  
3 program requires them to evaluate to determine whether  
4 the qualified life remains what it was 20 years ago  
5 when the equipment was qualified.

6 MR. MAYFIELD: This is Mike Mayfield. Let  
7 me take you to -- Jose's provided, I think, a good  
8 summary on the technical side. The process, we'll  
9 transmit our findings and recommendations to NRR for  
10 the implementation based on our discussions with Jose  
11 and the Management. I think the anticipation is this  
12 will go into their generic communication process and,  
13 like you say, will go to some voluntary action. I  
14 think that's prejudging a bit. I'm not quite sure  
15 today what will come out of that process, but I think  
16 the expectation that they have expressed is it will go  
17 into their generic communication process and play out  
18 from there.

19 MEMBER LEITCH: So would the expectation  
20 be that we would hear another presentation once we  
21 know what those actions are?

22 MR. CALVO: It all depends how much you  
23 want to know about EQ. That will be fine. We'll be  
24 happy to do it.

25 MR. MAYFIELD: I think if the Committee

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 asked for that, then the staff would be prepared to  
2 support that request as well.

3 MEMBER LEITCH: I see. Fine. We're  
4 running -- we have three more minutes to go here.

5 MR. AGGARWAL: Okay. I'll do 30 seconds.  
6 The industry practices, as described by NEI in their  
7 letter, in the staff's opinion, seems to be educate  
8 but the plant-specific practices are not known to us.  
9 Again, as I stated earlier, walk down to look for any  
10 visible sign of degradation we find can be proven  
11 useful and effective, as compared to nothing.

12 MR. CHOKSHI: Okay. I think just to the  
13 summary, and already we touched on this, and I think  
14 Mr. Mayfield described, our recommendation is to the  
15 NRR, and we have been discussing this with NRR, is to  
16 look at the dissemination of this information while  
17 they generate a communication process. And I think  
18 it's important to, as itemized here, the results of  
19 the tests and potential implications so that the  
20 licensees can evaluate the results of the tests for  
21 themselves a summary of Okonite.

22 And I think that one of the things is all  
23 of this information the last item, the importance of  
24 the knowledge of operating environment and hot spots  
25 is really critical to address many of these issues by

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 doing reanalysis, understanding the remaining margins,  
2 remaining life. So I really think that information  
3 needs to get out and then the communication process  
4 should determine the level of the communication or any  
5 other subsequent actions. So it is, as noted in the  
6 transmittal memo to you and in the technical  
7 assessment, we are following this to NRR with a  
8 recommendation that they use the generic communication  
9 process for dissemination of our findings. So that's  
10 the overall presentation with the technical assessment  
11 and where we stand.

12 MR. AGGARWAL: And, certainly, we look  
13 forward to receiving a letter from you in terms of  
14 your advice, comments which we will cooperate and  
15 finally submit to the Director of NRR.

16 MR. MAYFIELD: That concludes our  
17 presentation.

18 MEMBER POWERS: I have to say that in some  
19 sense this is the kind of research you wish NRC had  
20 more time to do, where you can go through and do a  
21 technical assessment in the field, not necessarily  
22 coming up with anything regulatory but saying, "Hey,  
23 guys, these are the things that we worry about, maybe  
24 you ought to worry about them." It's kind of a nice  
25 thing for a regulatory body to be able to do,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 summarize a field, show some data, show some concerns  
2 and show some ways of handling it. It's kind of nice.

3 MR. AGGARWAL: I wish we have unlimited  
4 funding and unlimited time.

5 MEMBER POWERS: Yes, yes.

6 MEMBER LEITCH: Any other questions?

7 MEMBER POWERS: Well, have you thought  
8 about mining the heavy section steel funds?

9 (Laughter.)

10 MEMBER LEITCH: Mr. Chairman? I turn it  
11 back to you, Mr. Chairman.

12 CHAIRMAN APOSTOLAKIS: Thank you, Mr.  
13 Leitch. Thank you, gentlemen. Appreciate you coming  
14 here. Our next -- we're supposed to continue with  
15 this. I don't like that. We'll take eight minutes  
16 and be back at 2:50.

17 (Whereupon, the foregoing matter went off  
18 the record at 2:41 p.m. and went back on  
19 the record at 2:51 p.m.)

20 CHAIRMAN APOSTOLAKIS: The next item is  
21 the development of reliability/availability,  
22 performance indicators and industry trends. The  
23 cognizant member is Dr. Bonaca, so Mario, please lead  
24 us through this maze.

25 VICE CHAIRMAN BONACA: Well, in order to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 identify and evaluate potential new PIs, the Agency's  
2 conducting a pilot program, monitoring the  
3 unavailability and the unreliability of several risk-  
4 significant systems identified through the Phase 1  
5 performance indicators. The pilot includes an attempt  
6 to integrate unavailability and unreliability for each  
7 set of the system, train into a risk-informed PI  
8 called Pilot Mitigating System Performance Indicators.  
9 I hope I quoted it correctly.

10 We received an update on this issue at the  
11 Subcommittee last Thursday. The staff is here to  
12 present this work. They have pointed out to us that  
13 this is work in progress. This is the first of  
14 several updates, two or three updates they plan to  
15 give us. At this stage, don't expect a letter from  
16 us, but this is an important update for us. I believe  
17 during this presentation the staff will also discuss  
18 performance and accountability reports determination,  
19 that no statistically significant adverse industry  
20 trends in the performance that are identified for  
21 2001.

22 With that, I'll pass the presentation to  
23 Mr. Baranowsky.

24 MR. BARANOWSKY: Okay. Thank you, Dr.  
25 Bonaca. Let me go to the first viewgraph. As you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 said, the purpose of this presentation that I'm going  
2 to give, which is going to be divided into two parts,  
3 one that I'll give and one that Tom Boyce will give.  
4 The first one is on an overview of the reliability and  
5 availability performance indicator pilot program,  
6 which is being done for the reactor oversight process,  
7 as led by NRR and supported by the Office of Research.  
8 And it's an informational briefing. I've identified  
9 in this first viewgraph what the content of this  
10 discussion will be, a little bit on the background,  
11 some of the problems that we're trying to solve, some  
12 insights that we derive from studies that were done on  
13 risk-based performance indicators, a very brief  
14 discussion of the technical approach that we're  
15 taking.

16 We're also going to mention the issues  
17 that were raised at the Subcommittee because we want  
18 to make sure we're capturing those for when the next  
19 time we come we want to address those properly. And  
20 then we'll talk about some conclusions and the  
21 implementation schedule.

22 Just briefly on the background, SECY 99-  
23 007, which is sort of the base document for the  
24 reactor oversight process, did identify that the  
25 performance indicators that were proposed and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 promulgated as part of that paper had some limitations  
2 in them because they were put together in basically a  
3 few-months time frame, and they borrow heavily on  
4 existing performance indicators which were known to  
5 have limitations in terms of their risk-informed  
6 characteristics.

7           During the first couple of years, the  
8 reactor oversight process and a number of technical  
9 issues came up that have to do with how the indicators  
10 are formulated and deal with incidents in their  
11 accounting. And, as such, a working group was  
12 formulated and the Office of Research participated in  
13 this working group and suggested that some of the  
14 technical work that we had done in the performance  
15 indicator project could be used to solve many of the  
16 problems, but not necessarily everything.

17           So the reliability and availability  
18 performance monitoring approach that was selected for  
19 the mitigating systems can be described as but one  
20 aspect of an area of improvement in the reactor  
21 oversight process, and so we're looking to at least  
22 move forward step-wise in making some improvements  
23 there.

24           The problems that we are trying to address  
25 in this project are as follows:   The current

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 performance indicators, in particular for the  
2 mitigating systems, include design basis functions  
3 along with the risk-significant functions, and that  
4 sometimes provides improper importance to the design  
5 basis functions that are not risk-significant, and so  
6 there's a desire to make a correction there. The  
7 thresholds of performance used in the current  
8 performance indicators are generic, one-size-fits-all,  
9 and there have been a number of problems identified  
10 about the lack of being risk-informed in that regard  
11 because of the variation in risk from plant to plant,  
12 especially for different mitigating systems.

13 The demand failures were accounted for as  
14 an unavailability of sorts in the so-called fault  
15 exposure hours, and they end up, in many cases,  
16 providing an overestimate of the risk significance of  
17 what the demand failures actually result in in terms  
18 of their impact on plant risk. And there are no  
19 performance indicators currently in the ROP that are  
20 directed toward the support systems.

21 The unavailabilities of the support  
22 systems are currently cascaded onto the  
23 unavailabilities of the monitored system. And the  
24 concern there is that the monitored system is being,  
25 in terms of its unreliability and unavailability, is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 being dominated by the support systems, or at least it  
2 can be. And so we're looking for an indicator that  
3 can give us information about the monitored system in  
4 addition to the support systems.

5 VICE CHAIRMAN BONACA: Now, isn't there a  
6 major problem with the PIs, the fact that the  
7 thresholds that are risk-based are kind of unrealistic  
8 because one single PI has to raise the core damage  
9 frequency by a significant amount.

10 MR. BARANOWSKY: Yes.

11 VICE CHAIRMAN BONACA: And we know in real  
12 life that doesn't happen. I mean it's usually a  
13 combination of things.

14 MR. BARANOWSKY: Right. Actually, part of  
15 that problem has to do with the selection of the PIs,  
16 and the other part has to do with the formulation.  
17 The one in particular that you run into that problem  
18 the most with is the initiating event performance  
19 indicator where all reactor trips for all plants are  
20 treated equally. Well, if you look at the risk  
21 significance of different initiating events that  
22 involve reactor trips, you can easily see orders of  
23 magnitude difference in their risk significance.

24 And if you want to capture that correctly,  
25 you have to have a more risk-based formulation to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 reflect that such that the more risk-significant  
2 failures would have a less tolerance than the less  
3 risk-significant ones, and you wouldn't put equal  
4 weighting on them. And then you would come up with a  
5 different threshold, if you will.

6 And the approach that we're taking on the  
7 mitigating systems could actually be used on the  
8 initiating event systems. We might look at that in  
9 the future to correct that one. I'm not sure we run  
10 into the same thing on the mitigating systems, but  
11 that's a correct point.

12 So let me just cover some of the problems  
13 that we are trying -- that we think that these  
14 modified performance indicators will correct. First  
15 of all, we worked to make sure that the risk-  
16 significant safety functions are the ones that are  
17 captured in the performance measurement. Now, the  
18 performance indicators, the way they're formulated,  
19 they account for a plant-specific design and operating  
20 characteristics through the use of available risk  
21 models and data. And available risk models are  
22 basically the site-specific PRA for the licensee, and  
23 I think I'll mention later that the NRC will be doing  
24 parallel analyses using our own risk models in the  
25 form of the standardized plant analysis risk models or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 SPAR models.

2           The demand failures are now accounted for  
3 correctly in the reliability formulation. They allow  
4 for the accumulation of failures to be more  
5 appropriately counted in the performance indicator.  
6 The performance indicators are going to now include  
7 separate indicators for the cooling water systems that  
8 provide support to the mitigating systems for which we  
9 currently have performance indicators, and that will  
10 eliminate the cascading problem and sort of an unfair  
11 count, if you will, of the indication of performance  
12 in those other frontline systems. But it will also  
13 treat the support systems according to their risk  
14 significance in the model.

15           The other thing I want to mention is that  
16 we believe that this pilot addresses at least some of  
17 the things that were raised by the ACRS, maybe not  
18 every single question. But the issue of the plant-  
19 specific thresholds is addressed. The technical basis  
20 for the choice of sampling intervals, we believe that  
21 was covered primarily in our risk-based performance  
22 indicator report, but we still will provide additional  
23 basis to have a complete package in this application.

24           And there was also an indication that the  
25 action levels should be related explicitly to risk

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 metrics, such as CDF and LERF, and I think we have at  
2 least an improvement in that area from what we had  
3 before.

4 Okay. Just to quickly go over the  
5 insights from the Phase 1 study of the risk-based  
6 performance indicator report, because that was the  
7 technical foundation even though the formulations are  
8 a little different now, but that was the technical  
9 foundation for what we're proposing in these  
10 performance indicators.

11 We identified that there were enough risk-  
12 significant differences amongst the plants that we had  
13 to have plant-specific thresholds for both  
14 unavailability and unreliability, and the mitigating  
15 system performance indicators will handle that. The  
16 unavailability and unreliability indicators were found  
17 to provide an objective in risk-informed indication of  
18 plant performance. And by that I mean they're  
19 logically connected to risk. You can actually trace  
20 what element of risk is associated with these  
21 indicators fairly directly.

22 And they provide broader coverage of risk  
23 than the current indicators, which we mapped out in  
24 that report, which I believe was NUREG 17.53. We  
25 mapped out the coverage that the performance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 indicators gave in terms of systems equipment and  
2 accident sequences. Do I have that right? And we  
3 looked at this for an example of 44 plants, so we have  
4 a pretty good feeling that we have good coverage  
5 there.

6 We did find that doing performance  
7 indicators for component cooling water and service  
8 water systems were a problem. But the formulation  
9 that we're proposing now using importance measures  
10 solves the problem of having many complex models to  
11 deal with, and I think it's really a step forward that  
12 allows us to incorporate a simple formulation to  
13 represent a more complex situation.

14 And the last thing is we did use some data  
15 analysis using Bayesian update approaches, which,  
16 based on our statistical analysis, we were able to  
17 I'll say minimize practically the likelihood of false  
18 positive and false negative indications. What we're  
19 interested in there is if there is a performance issue  
20 that's because of statistical issues is not showing up  
21 but that could be, say, read in the current oversight  
22 process, we have a very, very, very small likelihood  
23 that we would miss that performance issue.

24 On the other hand, if there is not a  
25 performance issue, there is a relatively small, not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 quite as small, but a smaller likelihood that we're  
2 going to call it a performance issue. I mean you have  
3 to make some balances on these things. You can't get  
4 them to be all completely small. And we looked at  
5 different approaches. And in fact that's still an  
6 open issue, but it's an item that I think is the  
7 strength of looking at some of the statistics involved  
8 when you go through these formulations.

9 Now, the mitigating system performance  
10 index, or indicator, was formulated a little bit  
11 differently from that which we used in the risk-based  
12 performance indicator project in that we're directly  
13 looking at a change in cord damage frequency as an  
14 index. And it's an index because it's incomplete but  
15 it accounts for the elements of plant design and  
16 operation and risk that are accounted for in the  
17 current indicators, at least, as a minimum. They  
18 might account for more, but at least accounts for  
19 those. It's primarily at the Level 1 from a PRA point  
20 of view, full power.

21 Also, the indicator has two elements to  
22 it, the unavailability and unreliability, which during  
23 the risk-based performance indicators, when we worked  
24 with the metrics of unreliability and unavailability,  
25 defined properly, we had trouble combining them in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 other than a complex model, almost a full PRA. When  
2 we came up with a similar formulation, we were able to  
3 combine them in something that's at least easy to look  
4 at, even if the bases behind the weighting factors is  
5 -- well, it's a little bit complex.

6 And also we're baselining performance  
7 similar to the principles espoused in SECY 99-007  
8 wherein we are trying to look at the 1997 time period  
9 as a baseline. And that's still an issue to be  
10 covered in future studies and presentations to this  
11 group as we move along.

12 So just to move down on this particular  
13 next chart, you see that the mitigating system  
14 performance index is an unavailability index plus an  
15 unreliability index, and one of the nice  
16 characteristics of this is it allows some balancing of  
17 unavailability and unreliability or if both are  
18 declining, then they're properly accounted for,  
19 instead of having separate indications looked at  
20 independently, as if one's frozen and looking at the  
21 other, and this matches up with the maintenance rule.  
22 So it was -- one of the major concerns that we have  
23 about the maintenance rule was accounting for  
24 unavailability and unreliability differently and then  
25 the combination of these things differently, and I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 think we've solved most of that here.

2 MEMBER ROSEN: And it's attractive to me  
3 too, because you can have a system that's perfectly  
4 available but highly unreliable because you run it all  
5 the time and you haven't maintained it, or one that's  
6 totally reliable and completely unavailable because  
7 you never run it and you're always maintaining it.  
8 But here -- and, clearly, the licensees have to make  
9 that balance. And, clearly, this indicator, because  
10 of its mathematical formulation, allows you kind of --  
11 it portrays the balance.

12 MR. BARANOWSKY: And the other thing  
13 that's nice about breaking these two things out is, as  
14 we discussed at the Subcommittee, the unavailability  
15 indicator covers maintenance downtime and corrective  
16 actions, whereas the unreliability one covers whether  
17 it performs as indicated when it's tried. And that  
18 helps you focus any look, if you will, as a regulator  
19 in terms of what kind of follow-up actually it would  
20 take if, let's say, this indicator were to go over  
21 some threshold. And it's also, I think, useful for  
22 licensees to look at it that way, which they do in the  
23 maintenance rule, so it's consistent with that.

24 The next chart just shows a list of the  
25 systems. Basically, we have -- for boiling water

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 reactors, we have three cooling water systems that are  
2 more or less what I would call your front line ECCS  
3 type systems: The emergency diesel generators, which  
4 are part of the emergency AC power system, and then  
5 the support system cooling, which in most cases  
6 involves systems with the name emergency service  
7 water, reactor building closed cooling water or  
8 turbine building closed cooling water systems or their  
9 equivalent. And then for the PWRs, we have injection  
10 systems represented by high-pressure injection and the  
11 RHR for low pressure considerations, the auxiliary  
12 feedwater system, again the emergency diesel  
13 generators and again the support system cooling  
14 functions with some different names.

15 Now, let's talk a little bit about the  
16 limitations of performance indicators, because we  
17 spent a long time, I mean months, going over what can  
18 and can't be captured by these performance indicators.  
19 The performance indicators are meant to look at an  
20 accumulation of information over a period of time, one  
21 to three years or so, and then draw some inference  
22 about performance. Individual incidents are meant to  
23 be covered by a risk assessment type indication. So  
24 what we did was we identified the types of individual  
25 --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 VICE CHAIRMAN BONACA: The STP.

2 MR. BARANOWSKY: The SDP, for example.  
3 SDP Phase 2, Phase 3 type activity. And so what we  
4 did was we went over, well, what are the kinds of  
5 things that can and can't be reasonably captured and  
6 have good statistical characteristics for us to  
7 measure performance with? And we have this list here,  
8 like common cost failures. We know that they have a  
9 risk significance, but we can't track enough years to  
10 get common cause failure into the reliability  
11 formulation, but over time the common cause failure  
12 impact on the risk-importance measure, whether it's  
13 Fussell-Vesely or Birnbaum, will show up.

14 So it's counted for in time, and it's  
15 instantaneous, if you will, implications in the  
16 reactor oversight program inspection process will be  
17 captured through the SDP. And the same goes with  
18 passive failures. And there's a few systems  
19 components that are highly reliable. The system is  
20 highly risk-significant, and single failures over a  
21 period of one to three years don't have very good  
22 statistical characteristics to them, and those also  
23 would be looked at as if they were a rare event in  
24 risk space.

25 Okay. Now --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   MEMBER ROSEN:    If you're done talking  
2                   about the limitations

3                   MR. BARANOWSKY:  No, I'm not done.  Well,  
4                   I'm done with that limitation.  I'm going to talk  
5                   about some of the -- we're going to look at a number  
6                   of technical issues, which we don't -- we wouldn't say  
7                   they're limitations but they're still open in terms of  
8                   how to make a final formulation on them.

9                   MEMBER ROSEN:       Well,  of  all  the  
10                  limitations that you've mentioned, the most important  
11                  one is one you really didn't call out as a limitation.  
12                  And that to me is that this only covers at-power  
13                  situations.  Risk doesn't go on a holiday when you  
14                  take a plant off the line.

15                  MR. BARANOWSKY:  Yes.

16                  MEMBER ROSEN:  And so the shutdown risk is  
17                  important, even though there are people in this Agency  
18                  who don't think that.  It's my view that it's fairly  
19                  important.  And depending upon exactly what you do  
20                  during shutdown, PWRs and mid-loop, for instance,  
21                  create a lot of risk during that period.

22                  MR. BARANOWSKY:  Yes.  I think --

23                  MEMBER ROSEN:  If you don't go to mid-  
24                  loop, well, okay, maybe you don't have a risky outage.  
25                  But mid-loop operation especially hot early mid-loop

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is a risk configuration. So I think when you're  
2 setting up an index program like this, if you're not  
3 looking at shutdown risk, you're not showing the whole  
4 scope, and that's one of the -- to me that's the  
5 principal limitation.

6 MR. BARANOWSKY: Okay. That's an  
7 excellent point, and we looked at that in our risk-  
8 based performance indicator study. And one of the  
9 things that we found that was a problem with the  
10 current indicators and even the current maintenance  
11 rule implementation was that the performance of  
12 equipment during shutdown was being overlaid on top of  
13 the performance of equipment during power, and the  
14 risk metric being used was the at-power risk measure,  
15 which really is erroneous.

16 We did a fairly good look at this and  
17 concluded that we don't have enough data during  
18 shutdown to look at reliability and unavailability in  
19 the cumulative sense that we do in these performance  
20 indicators, but that we could look at what occurred  
21 during shutdown and the different modes that occur  
22 during shutdown, including like mid-loop, as you said,  
23 and make a judgment call about the risk implications  
24 of shutdown operations that could improve the way the  
25 significance determination process, as opposed to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 performance indicators, can take a look at the  
2 implications of shutdown in the reactor oversight  
3 process.

4 So we're working with NRR now to take  
5 those insights and try and get them into the shutdown  
6 significance determination process. If we had the  
7 shutdown risk models, we could use risk metrics for  
8 unavailability and unreliability that were appropriate  
9 for shutdown, but we don't have those.

10 MEMBER ROSEN: I don't think I want to  
11 tell you how to do this, because I don't know, but I  
12 do know that it's a big hole and that you ought to be  
13 working towards ultimately including risk during  
14 shutdown in these programs.

15 MR. BARANOWSKY: We're going to have  
16 shutdown risk models for SPAR because we need it for  
17 the Accident Sequence Precursor Program. As you say,  
18 you get enough risk during shutdown that we have to be  
19 able to evaluate that. I suspect that -- and that  
20 won't take a long time. I think it's a couple of  
21 years to have pretty good models, at least in terms of  
22 what we know today about shutdown risk, maybe not some  
23 new stuff. But we should be able to look -- first,  
24 we'll have the reactor oversight process, significance  
25 determination process incorporate the insights from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the risk-based performance indicator study in this  
2 area, and then, if it's appropriate after discussions  
3 perhaps with this group and others, we'll look at  
4 whether other performance indicators make any sense if  
5 we have the risk models to set the thresholds by.  
6 Otherwise I don't have a way to do it. I can't set  
7 them with the at-power models, which is really all we  
8 have available.

9 MEMBER ROSEN: Well, I don't think you  
10 should have -- let the excellent be the enemy of the  
11 good in this case. You should try to find something  
12 rational to do to begin to measure risk during  
13 shutdown and try to put that into the program. Maybe  
14 it's something as simple as duration in hot early mid-  
15 loop.

16 MR. BARANOWSKY: Yes. That's exactly  
17 right.

18 MEMBER ROSEN: And time runs from  
19 subcriticality, some kind of index like that.

20 MR. BARANOWSKY: Are you sure you didn't  
21 read our report? Okay. Why don't we cover that at  
22 the next ACRS Subcommittee meeting, because I think we  
23 did a nice job in looking at that and see if it  
24 answers your questions or if you have other issues  
25 that you think we need to look at.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ROSEN: You say you're going to  
2 cover it when?

3 MR. BARANOWSKY: At the next Subcommittee  
4 meeting, which we're going to have -- proposing in  
5 November.

6 CHAIRMAN APOSTOLAKIS: He's proposing two  
7 more.

8 MEMBER ROSEN: Good.

9 MR. BARANOWSKY: We had so much fun at the  
10 last one.

11 CHAIRMAN APOSTOLAKIS: One of the few  
12 staff members who loves us.

13 MR. BARANOWSKY: I'll bring the doughnuts.

14 MEMBER ROSEN: We can do something to get  
15 him not to love us.

16 MR. BARANOWSKY: That would be hard.  
17 Okay. The next -- so we're going to look at a lot of  
18 things during the next several months, and we're going  
19 to report back to you on that. Let's go to the next  
20 one.

21 Just quickly, let me summarize here what  
22 I think were the highlights of the Subcommittee  
23 meeting that we had on May 30. You were looking for  
24 the reasons and justification for the selection of the  
25 baseline values that we had. That was an issue that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 was discussed quite extensively. There were questions  
2 raised about use of the thresholds that are currently  
3 in place and we derived from SECY 99-007. We're going  
4 to talk about that.

5 And then also there was quite a bit of  
6 discussions about the formulation that we had for the  
7 PI, including the use of Fussell-Vesely in different  
8 parameters in that equation, and we're going to put  
9 that all together in a white paper of sorts before --  
10 if you'll allow us to have another Subcommittee  
11 meeting, we'll do it then, and you'll see in my  
12 schedule we're shooting for a November time frame.

13 CHAIRMAN APOSTOLAKIS: Good.

14 MR. BARANOWSKY: And we'll also be able to  
15 report on some of the initial implementation  
16 activities and issues that come from the pilot,  
17 presuming it gets off the ground at that point.

18 So to conclude, I think the maintenance of  
19 the mitigating system performance index approach is  
20 based on risk insights, and one of its strengths is  
21 that it accounts for plant-specific design and  
22 operating characteristics through the use of the  
23 available risk models and the data. Currently, we're  
24 using the Fussell-Vesely importance measure. We might  
25 look at Birnbaum and some other possibilities to see

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 if they have better characteristics.

2 We're treating demand failures in an  
3 unreliability context. We're using Bayesian update to  
4 get the best statistical treatment that we can. The  
5 risk-significant safety functions are now a  
6 significant focus for the success criteria in  
7 determining what's a failure and what's not a failure  
8 that goes into the performance indicators. And we're  
9 going to be able to, we think, incorporate the cooling  
10 water systems that provide support to the more front  
11 line systems. We can balance unreliability and  
12 unavailability or if they both go up or both go down,  
13 the indicator covers that. It's a fairly objective  
14 indication because of its link to the risk model.

15 We've identified limitations. You've  
16 brought another one up here. We're wide open to hear  
17 more and see if we can either address them or make  
18 sure that they're accounted for in the significance  
19 determination process. And we believe that this  
20 indicator provides the right vehicle for making an  
21 appropriate risk characterization of performance  
22 that's related to reliability and availability of  
23 equipment.

24 So we have a schedule, as indicated here.  
25 We're going to have a workshop to go over how one can

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 implement the formulation that's been proposed. We're  
2 going to try and start the pilot around August 1,  
3 somewhere around there. We think that around  
4 November, depending on your concurrence, we might be  
5 ready to come back, talk about some of these technical  
6 issues and how things are going. The pilot will end,  
7 the data collection and sort of online trial period,  
8 if you will, in February. We'll take about six months  
9 to assess that, but in that six-month period, we'd  
10 like to have another briefing to let you know how  
11 things are coming, because I think, ultimately, we  
12 would like to get some kind of a letter from the  
13 Committee, and that's probably around the summer of  
14 2003.

15 CHAIRMAN APOSTOLAKIS: You'd like some  
16 kind of a letter or a good letter?

17 MR. BARANOWSKY: Some kind of good letter.  
18 (Laughter.)

19 That's all I have to say.

20 CHAIRMAN APOSTOLAKIS: Any --

21 MEMBER ROSEN: You have another plant  
22 participating in the pilot --

23 MR. BARANOWSKY: Oh, sorry.

24 MEMBER ROSEN: -- slide. You don't want  
25 to put that up.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. BARANOWSKY: Right. Go ahead and show  
2 that if you want.

3 MEMBER ROSEN: Because it reminds me of  
4 the punchline in Casablanca, "Round up the usual  
5 suspects."

6 MR. BARANOWSKY: Some of them are there.

7 MEMBER ROSEN: Well, when are we going to  
8 see a list of people participating in the pilots with  
9 another name on it, other than "usual suspects?" I'd  
10 like to see some spreading a little bit.

11 CHAIRMAN APOSTOLAKIS: Palo Verde is  
12 there, South Texas is there.

13 MR. BARANOWSKY: Actually, South Texas is  
14 just -- is a relatively recent addee, because we have  
15 been working this group of pilots, and South Texas  
16 wasn't there on the first list.

17 MEMBER ROSEN: Yes, but it's one of the  
18 usual suspects. But I'm talking about seeing some  
19 plant that's new to the game.

20 MR. BARANOWSKY: Davis-Besse?

21 MEMBER ROSEN: Perhaps.

22 MR. BARANOWSKY: But I think this group  
23 will be --

24 MEMBER POWERS: Let me -- I'm not sure I  
25 understand the question. I look at this list and I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 say, hey, this is a pretty good cross-section. I got  
2 Hope Creek and Salem on one end and I got Palo Verde  
3 and that damn thing off in Texas someplace on the  
4 other end. That's a fair cross-section.

5 MEMBER ROSEN: Well, I'm just talking  
6 about some plant that has not participated at  
7 developing new capabilities and getting into the --  
8 you know, I'm just railing at the idea that it's  
9 always the same plants that --

10 MEMBER POWERS: I mean just to have  
11 somebody participate that's for participation sake  
12 doesn't strike me as very useful.

13 MEMBER ROSEN: Well, it has much more to  
14 do with --

15 MR. BARANOWSKY: Tom Houghton from NEI  
16 would like to address that.

17 CHAIRMAN APOSTOLAKIS: We have a comment  
18 from the industry.

19 MR. HOUGHTON: Tom Houghton, NEI.

20 MEMBER ROSEN: Is there a law against  
21 that?

22 MR. HOUGHTON: Actually, comparing pilots  
23 before -- Limerick's new, they haven't participated;  
24 Millstone's not participated; Surry has not  
25 participated, Braidwood has not participated, Palo

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 Verde, San Onofre and South Texas have not been  
2 pilots. None of those have been pilots before, so we  
3 do have quite a different --

4 MEMBER ROSEN: You're talking about here  
5 in this particular program.

6 MR. HOUGHTON: Well, in the reactor  
7 oversight process.

8 MEMBER ROSEN: I'm talking about the use  
9 of risk techniques in general.

10 CHAIRMAN APOSTOLAKIS: He's broadening the  
11 issue.

12 MEMBER ROSEN: And Dana accuses me of  
13 prosteltizing, and I plead guilty. The idea being  
14 that the more people get involved in the formulation  
15 of these kinds of things, the more likely we are going  
16 to have smoother implementation, more broader  
17 implementation.

18 MR. BARANOWSKY: Tom, what about the --

19 MR. HOUGHTON: We also do have, I don't  
20 know whether it's a good name to use or not, but  
21 plants that are shadowing this process, so we will  
22 have probably I would guess an equal number of plants  
23 that are going to play along with the process but not  
24 be officially in it. So it will be quite broader.

25 MR. BARANOWSKY: And we expect the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 workshop to have a large spectrum of participants, and  
2 probably when we have summary meeting afterward to go  
3 over issues and how they're resolved, I think not only  
4 these shadow plants but others will be involved.

5 Okay. So we'll, with your agreement, come  
6 back in November or thereabouts.

7 VICE CHAIRMAN BONACA: Thank you. That  
8 was a good update. And now we have the report on no  
9 statistically significant adverse industry trends.

10 MR. BOYCE: Good afternoon. I'm Tom Boyce  
11 of the Inspection Program Branch of NRR, and I'll be  
12 presenting the industry trends portion of this  
13 briefing.

14 We're going to be covering today some of  
15 the background for the program, how we communicate  
16 with stakeholders, the process for identifying and  
17 addressing industry trends, other results for fiscal  
18 year 2001 and where we're headed in the future.

19 As background, one of the performance goal  
20 measures in the NRC strategic plan is that there be no  
21 statistically significant adverse industry trends in  
22 safety performance. That was put in place in about  
23 1998/1999. NRR picked that up in 2000 from research,  
24 and we implemented the ITP in 2001. One of our key  
25 outputs is to make sure we address this performance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 goal measure.

2 CHAIRMAN APOSTOLAKIS: So the key words  
3 here are "statistically significant," right?

4 MR. BOYCE: Well --

5 CHAIRMAN APOSTOLAKIS: Because you can  
6 have a single event that is risk significant, but then  
7 that's because it's a single event it will not fall  
8 under this, would it?

9 MR. BOYCE: Right. There's a second  
10 performance goal measure which we think would capture  
11 that on the Accident Sequence Precursor Program.

12 CHAIRMAN APOSTOLAKIS: Yes, that ASP.

13 MR. BOYCE: Right. And so in terms of  
14 reporting to Congress and addressing the issue, that  
15 would be covered. It would remain to be seen the  
16 contribution of that individual event to changes in  
17 the industry indicators.

18 CHAIRMAN APOSTOLAKIS: Yes, but then we  
19 wouldn't call that a trend if it's a single --

20 MR. BOYCE: That's correct. It would  
21 probably be an outlier, which I think was your -- I  
22 think you brought that up in the Subcommittee, the  
23 Davis-Besse example.

24 CHAIRMAN APOSTOLAKIS: Within four days I  
25 can be consistent.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   MR. BOYCE: The two purpose of the program  
2                   are align with the NRC strategic plan and the first is  
3                   to provide a means to confirm that the nuclear  
4                   industry is maintaining the operating and safety  
5                   performance of nuclear power plants. And the second  
6                   is by clearly communicating that performance to  
7                   enhance stakeholder confidence in the efficacies of  
8                   the NRC's processes.

9                   Speaking of communications with  
10                  stakeholders, this is how we do it. We put the  
11                  industry indicators up on the NRC's web site. Those  
12                  were first put in August of last year. They were  
13                  taken down temporarily post-9-11, and they're back up  
14                  as of a few months ago. We provide an annual report  
15                  to the Commission. We've provided two reports so far.  
16                  One was in June of 2001 and one was April of this  
17                  year. I believe you have copies of both of those  
18                  Commission papers.

19                  We provide an annual report to Congress as  
20                  part of the NRC's performance and accountability  
21                  report. And, finally, these indicators are presented  
22                  at various conferences with industry. A most recent  
23                  example might be the Regulatory Information Conference  
24                  in March, the American Nuclear Society presentations  
25                  and several others I'm aware of.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   This slide depicts the process for  
2 identifying and addressing industry trends. In  
3 general terms, we apply statistical techniques to each  
4 of the indicators in the program, and we look for what  
5 amounts to an upward trend in any of the trend lines.  
6 If we saw an upward trend, we would take a look at the  
7 underlying issues and assess the safety significance.  
8 For example, if SCRAMS were to go up, as Pat alluded  
9 to earlier, there's many reasons for SCRAMS to go up,  
10 but that would be our first indicator that we need to  
11 go take a look at the underlying causes.

12                   Based on what we found and the safety  
13 significance of what we found, we would then take the  
14 appropriate Agency response in accordance with our  
15 processes for addressing generic issues. These  
16 processes are the generic communications process in  
17 NRR and the generic safety issues process in the  
18 Office of Research. Finally, there's an annual review  
19 as part of the Agency action review meeting, and this  
20 is a group of senior managers of the NRC.

21                   This is a snapshot of the results of the  
22 ITP for fiscal year 2001. Bottom line, we have  
23 identified no adverse trends based on eight indicators  
24 that were developed by the former Office of AEOD as  
25 well as the Accident Sequence Precursor Program. We

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 are trying to develop additional indicators that are  
2 derived from the plant-specific information submitted  
3 as part of the ROP. They would cover all the  
4 cornerstones in the reactor oversight process. We  
5 initially kicked off this program in April of 2000, so  
6 we do not yet have four years worth of data. However,  
7 we did --

8 MEMBER POWERS: You mentioned the ASP  
9 Program, that you didn't find any trends. Did you  
10 happen to look to see if there was any trend for  
11 shutdown accidents to be more or less prevalent than  
12 they had in the past? The ASP important accident  
13 events.

14 MR. BOYCE: I'll take the first cut and  
15 then perhaps Pat will fill in. As part of the  
16 industry trends program, we use a single indicator  
17 which is total counts of ASP events, and so shutdown  
18 events would just be a small subset of that, we hope.  
19 And there was --

20 MEMBER POWERS: A big subset of that?

21 MR. BOYCE: Well, actually, I don't know  
22 because we didn't look into it, but Pat's group  
23 produces a separate SECY paper for the ASP Program,  
24 SECY 02-041, I think, was the most recent one. I  
25 don't know whether that issue was addressed as part of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that Commission paper.

2 MR. BARANOWSKY: Yes. We do look at  
3 shutdown events in more of an ad hoc manner, because  
4 we don't have the tools for shutdown analysis that we  
5 have for the at-power conditions.

6 MEMBER POWERS: Why don't you have those  
7 good tools?

8 MR. BARANOWSKY: We're trying to develop  
9 them based on resources available.

10 MEMBER POWERS: Why don't you have more  
11 resources available?

12 MR. BARANOWSKY: You would have to talk to  
13 the powers that be.

14 MEMBER ROSEN: He is the powers that be.  
15 (Laughter.)

16 MEMBER POWERS: What particular suite of  
17 language should appear in our research report that  
18 would say these guys have been struggling along unable  
19 to analyze shutdown precursor events with any kind of  
20 adequacy, and they need the tools to do that better,  
21 and therefore should have resources to do that better.

22 MR. BARANOWSKY: To be fair about it, if  
23 that was said a few years ago, we probably would have  
24 the tools now, but we are embarked on getting those  
25 tools in place. I don't know that we could go any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 faster than we can right now, because we have to have  
2 people who can manage the work and who can do the  
3 work, and there's just limits to who's available.

4 MEMBER POWERS: I've heard that story for  
5 four years, Pat.

6 MR. BARANOWSKY: I don't think so.

7 MEMBER POWERS: We're working on this  
8 stuff, we're working on this stuff, we're working on  
9 this stuff.

10 MR. BARANOWSKY: We actually have  
11 schedules now.

12 MEMBER POWERS: And I've got Steve over  
13 there telling me that the world -- the spin angular  
14 momentum of the Earth is about to come to an end if we  
15 don't put better attentions to shutdown risk.

16 MEMBER ROSEN: Dana always exaggerates the  
17 importance of my remarks. I'm grateful but it's not  
18 quite the spin angular momentum that's --

19 MR. BARANOWSKY: The shutdown risk, from  
20 what we've seen, is not 50 percent of the accident  
21 sequence precursors, and I'm fairly confident that  
22 it's not that high.

23 MEMBER ROSEN: What did you say?

24 MR. BARANOWSKY: I don't believe it's 50  
25 percent.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MEMBER ROSEN: Of what you've seen so far.

2 MR. BARANOWSKY: Of what I would see if I  
3 did even a really complete accident sequence precursor  
4 analysis.

5 MEMBER ROSEN: Your zero information guess  
6 it would be one-sixteenth of the set of ASP events.  
7 So I mean if it's anything more than a sixteenth,  
8 Steve's probably right.

9 MR. BARANOWSKY: Yes.

10 MEMBER ROSEN: The spin angular momentum  
11 of the Earth is --

12 MR. BARANOWSKY: It's about 20 percent or  
13 so, it looks like.

14 MEMBER ROSEN: I've got a calculation for  
15 you right now. It only applies -- the real risk is  
16 PWR. Two-thirds of the plants are PWRs. It's half of  
17 the risk of two-thirds.

18 MR. BARANOWSKY: I'm saying around 20  
19 percent.

20 MEMBER ROSEN: That's two-twelfths, right?

21 CHAIRMAN APOSTOLAKIS: Two-sixths.

22 MEMBER ROSEN: No, two-sixths, right, half  
23 of the risk of two-thirds.

24 CHAIRMAN APOSTOLAKIS: Which is one-third.

25 MEMBER ROSEN: One-third.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. BARANOWSKY: Which is well within the  
2 uncertainty.

3 MEMBER POWERS: Yes. And the zero  
4 information guess would be six percent.

5 MEMBER ROSEN: Right. Define high. I say  
6 it's six times that.

7 MEMBER POWERS: Yes. So you're saying  
8 it's six times that. And these guys don't have the  
9 tools to analyze it exactly. I mean, you know, if I  
10 were you, I would really complain. You're just not  
11 getting the support you need.

12 MR. BARANOWSKY: Well, as I said, we are  
13 developing the tools now. I believe the Commission  
14 has pretty much said we need to get on with developing  
15 the accident sequence analysis capabilities and SPAR  
16 models for the spectrum of capabilities --

17 MEMBER SIEBER; When do you shutdown?

18 MEMBER POWERS: When do we see the  
19 shutdown?

20 MR. BARANOWSKY: I believe so because  
21 we've provided that in our budget discussions, and  
22 there seems to be support for it.

23 CHAIRMAN APOSTOLAKIS: Shutdown and fire  
24 what?

25 MEMBER SIEBER; Shutdown and fire and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 operations is, in my opinion, guessing -- a third, a  
2 third, a third.

3 MEMBER ROSEN: That's the whole --

4 CHAIRMAN APOSTOLAKIS: Is that what the  
5 Commission said, Jack.

6 MEMBER SIEBER; That's what I'm saying.

7 CHAIRMAN APOSTOLAKIS: Oh, you're saying  
8 that.

9 MEMBER SIEBER; So fire and operations.

10 MEMBER POWERS: Let me ask a question.  
11 Where would I go to look at the program plan for  
12 developing these tools?

13 MR. BARANOWSKY: That's excellent. I  
14 believe we've supplied, but we'll supply you again,  
15 with the SPAR model development plan, which includes  
16 this information, and I can guarantee you'll have that  
17 shortly.

18 MEMBER POWERS: And I'll be just delighted  
19 and thrilled.

20 MR. BARANOWSKY: You'll call me up you'll  
21 be so delighted.

22 CHAIRMAN APOSTOLAKIS: And the spin  
23 angular momentum of the Earth will be preserved.

24 MR. BARANOWSKY: Preserved.

25 MR. BOYCE: All right. Thanks for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 fielding that one, Pat.

2 MEMBER POWERS: Now, wait, you don't get  
3 away scott-free here.

4 MR. BOYCE: Oh. Well, I'm sure there will  
5 be other opportunities.

6 MEMBER POWERS: Okay. What about the  
7 inspection force? What kind of information do they  
8 get?

9 MR. BOYCE: Well, you're right, I didn't  
10 want to draw fire, but I did want to say that we're  
11 not just doing PIs as part of our oversight of  
12 licensees. We do have inspectors that go out in the  
13 field and are looking very closely at these things,  
14 and we do have inspection procedures that are tailored  
15 to shutdowns. Part of that inspection process --

16 MEMBER POWERS: Okay. So they find  
17 something now. They want to do a significance  
18 determination process. What do they do?

19 MR. BOYCE: Well, there is a shutdown SDP.  
20 There are many deficiencies in that shutdown SDP.

21 CHAIRMAN APOSTOLAKIS: Based on what? How  
22 did they develop it?

23 MR. BOYCE: Perhaps we can come back on  
24 this before I --

25 CHAIRMAN APOSTOLAKIS: Yes. Okay. I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 think we should.

2 MR. BOYCE: -- get in trouble here. But

3 --

4 MEMBER POWERS: Well, I think you should  
5 -- you and Pat ought to get together and go complain  
6 to the powers that be. You're not getting the support  
7 you need.

8 CHAIRMAN APOSTOLAKIS: Well, if there has  
9 to be any complaints to the powers, I want to add a  
10 couple things.

11 (Laughter.)

12 CHAIRMAN APOSTOLAKIS: Whoever has the  
13 most power will maybe have a meeting about  
14 complaining.

15 MR. BOYCE: Let me point out another,  
16 perhaps, weakness in our program right now. The  
17 performance goal measure talks -- really only looks at  
18 trends, and if you look at the indicators that we have  
19 right now, they start in about 1998 -- 1988, excuse  
20 me. And those trends, most of them show an  
21 exponential type of decay, and some of the indicators  
22 might be approaching asymptotic limits in terms of  
23 improvements in performance. It's very difficult to  
24 say that for sure, but that's what it looks like it  
25 appears. And so it's inevitable that at some point

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 we'll have a trend line that goes up. And what we're  
2 trying to do is rather than be tied to our process  
3 that would have us react to something that may or may  
4 not have safety significance, we're trying to  
5 establish thresholds based on the safety significance.

6 An example would be SCRAMS. Right now,  
7 we're averaging about 0.85 SCRAMS per plant per year,  
8 whereas back in 1988, plants were averaging on the  
9 order of two and a half to three SCRAMS per plant per  
10 year. So if there was an uptick of 0.85 to one, we're  
11 not sure that that would be a change in the safety  
12 performance of the plants, and so we're trying to  
13 establish a rational basis. And that's most of the  
14 development work that's ongoing, and I'll get to that  
15 in just a second.

16 If we are able to develop these more risk-  
17 informed thresholds and get them in place, it would  
18 enable us to change the performance goal measure to  
19 something similar to what the Accident Sequence  
20 Precursor Program uses, which is something like no  
21 more than one ASP event per year. It would mean no  
22 more than one indicator exceeds a certain threshold  
23 per year, just to provide an example of our current  
24 thinking.

25 Finally, we're also developing additional

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 indicators that we might be able to use in the  
2 program. An example is we developed on the order of  
3 15 initiating event indicators. Those were provided  
4 in SECY 02-058, which I think you have a copy of. And  
5 we're taking a look at those and seeing the  
6 applicability of the program. One of the -- for  
7 example, steam generator tube ruptures is a very  
8 infrequent event that you can't really monitor well on  
9 a plant-specific basis, but you can do a lot better  
10 monitoring them on an industry level, so we're taking  
11 a look at those.

12 MEMBER POWERS: And it's really  
13 remarkable, because when you look at that -- and, like  
14 you say, you can't ask real detailed questions because  
15 it doesn't happen often enough to do that -- but if  
16 you take broad integrals, it's constant. It's a  
17 constant rate of steam generator tube ruptures. I  
18 mean it defies logic. I mean you would think it would  
19 go up as steam generators get old, but it doesn't seem  
20 to.

21 MEMBER ROSEN: Well, that's because a lot  
22 of steam generators are being replaced. They're not  
23 getting older, on average.

24 MEMBER POWERS: But there was a period of  
25 time they were.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER ROSEN: Well, that's true.

2 MEMBER POWERS: And it didn't change.

3 MEMBER ROSEN: But that's because the  
4 industry made heroic efforts to avoid those kinds of  
5 things in that time period.

6 MR. BOYCE: And I think the NRC oversight  
7 helped and contributed, just to put in a plug.

8 (Laughter.)

9 MEMBER ROSEN: This had something to do  
10 with it and that's the degree of heroism required.

11 MR. BOYCE: A lot of these initiating  
12 events were based on the work that was done earlier in  
13 NUREG 57.50, if you're familiar with that NUREG. And  
14 we're also trying to bring up to date some of the  
15 system reliability and component reliability studies  
16 that research has done in the past.

17 The rest of this presentation describes  
18 where we are in terms of threshold development, and  
19 what we'd like to do is just give you an introduction  
20 here and then come back sometime this fall to give you  
21 more details on where we are. We would probably  
22 piggyback with the MSPI work that's being done. I'm  
23 not sure we need at least two more presentations, as  
24 Pat talked about, but we'd definitely like to come  
25 back.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 CHAIRMAN APOSTOLAKIS: In November.

2 MR. BOYCE: Probably the most important  
3 bullet here to take away is that industry thresholds  
4 differ from plant-specific thresholds in that while  
5 we're working on models for each of the plants and  
6 we're getting there, there isn't an industry-level  
7 model right now, and so the challenge is to come up  
8 with a rational way to get an industry-level risk.

9 MEMBER POWERS: Maybe I didn't follow.  
10 Why would I want to have this?

11 MR. BOYCE: Well, what we're trying to do  
12 is get to the -- if you have a model to use -- well,  
13 we don't have a model, but what we're trying to get to  
14 is risk-informed thresholds.

15 MEMBER POWERS: But why wouldn't I want to  
16 make those -- I mean I'm surprised that Dr.  
17 Apostolakis isn't climbing down your throat right now  
18 saying, "The one thing that we've learned in all of  
19 our risk studies is it's very plant-specific." Why  
20 aren't you climbing down his throat, Dr. Apostolakis?

21 CHAIRMAN APOSTOLAKIS: I wasn't paying  
22 attention.

23 (Laughter.)

24 MR. BOYCE: Well, I think I --

25 MEMBER ROSEN: Let me suggest a different

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 strategy perhaps or a strategy. But is it not true  
2 that the risk of the industry today, a snapshot, is  
3 the sum of core damage frequencies over all the plants  
4 divided by the number of plants?

5 MR. BOYCE: That's, in essence, really  
6 what he's talking about, and that's why, for instance,  
7 when you trend steam generator tube ruptures, you  
8 know, they're made of all individual plants and hardly  
9 any of them have tube, but you want to know what's  
10 happening in the industry, you look at the collection,  
11 but it has to be in a risk context so that when you  
12 count these things you don't weigh things way out of  
13 balance incorrectly. So I'm agreeing with what you're  
14 saying. I don't have all those models in place. I  
15 think I was agreeing.

16 MEMBER POWERS: He's just giving you a  
17 real nice model. He says get the industry by doing  
18 the plant-specifics and selling.

19 MR. BOYCE: Actually, that is one of our  
20 options that I'll get to. Some of this is a --

21 MEMBER POWERS: Why would you want to do  
22 anything different?

23 MR. BOYCE: Timing. We need something in  
24 place sooner. The SPAR models aren't going to be  
25 available, and licensees, PRAs may give slightly

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 different results than the SPAR models, and we need to  
2 come to agreement with all the stakeholders as to what  
3 constitutes the appropriate model to use. So we're  
4 trying to get thresholds sooner. It may be that we do  
5 get to exactly what you just described.

6 MEMBER ROSEN: I'm not sure I understand  
7 your -- I don't know whether your answer -- understand  
8 your answer. I mean after all, you can call up the  
9 risk supervisor at each plant and ask him what his  
10 current CDF is. Of course, it changes as they do  
11 Bayesian updates, but you could get a snapshot. He'd  
12 say -- and you'd have to make your question quite  
13 specific. You'd say, "Give me your best shot at your  
14 internal events plus shutdown where your interval  
15 events, if it includes fire, not giving a separate  
16 fire number." So the guy gives you three numbers and  
17 you add them up and you do that to the next plant.  
18 Now, there are some plants that are not going to give  
19 you all those numbers. You have to have a little  
20 asterisk in your column where you make an estimate  
21 maybe, but at the bottom of the line, you're going to  
22 -- at the end of this, you're going to construct a  
23 table and you're going to press a button and it's  
24 going to add it up --

25 CHAIRMAN APOSTOLAKIS: Isn't that already

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 in the IPE?

2 MEMBER ROSEN: IPE, so, you know.

3 CHAIRMAN APOSTOLAKIS: Well, we start with  
4 that, but then we make the phone calls.

5 MEMBER ROSEN: Yes, you make the phone  
6 calls, because IPE is so far out of date, you know,  
7 that was 1988. It's 20 years --

8 CHAIRMAN APOSTOLAKIS: That's when the  
9 letter came out, the IPEs were done later. But you're  
10 right, I mean there will be updates and so on. But  
11 the point is that you can have a table tomorrow.

12 MEMBER ROSEN: Yes.

13 CHAIRMAN APOSTOLAKIS: And then start  
14 calling people to --

15 MEMBER ROSEN: Well, yes. You could have  
16 a table from IPE tomorrow or you could have -- in two  
17 weeks, you could have this other table.

18 CHAIRMAN APOSTOLAKIS: That's correct.

19 MR. BOYCE: Okay.

20 CHAIRMAN APOSTOLAKIS: My experience with  
21 this thing is that it takes about two and a half to  
22 three years for people to go to plant-specific stuff.  
23 I don't know why. Look at the ROP. Now they're  
24 talking about plant-specific. This is a semi-  
25 empirical observations.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER ROSEN: But what is it that takes  
2 two and a half years? I'm asking.

3                   CHAIRMAN APOSTOLAKIS: They initial the  
4 system.

5                   VICE CHAIRMAN BONACA: If we keep this  
6 way, it will take two, three years to finish this up.

7                   CHAIRMAN APOSTOLAKIS: And that will be --  
8 okay, let's move on.

9                   MR. BOYCE: The other thing I'd like to  
10 point out is this approach lends itself most readily  
11 to the initiating events in mitigating systems  
12 cornerstones. There's five other cornerstones where  
13 we do need to develop some sort of indicator, and  
14 those other cornerstones, as examples, are things like  
15 occupational radiation exposure, public radiation  
16 exposure, emergency preparedness, safeguards and  
17 physical security. And the approach that we're  
18 talking about here it would not be applicable in those  
19 cornerstones.

20                   So having said that, what we're going to  
21 try and do is develop a -- jump ahead on my slides --  
22 develop an expert panel where we would build on the  
23 work done in the initiating events and mitigating  
24 systems cornerstones and see how it might apply to the  
25 other cornerstones and try and look for consistencies

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 in approach, not just risk approach but also  
2 statistical approach.

3 So bear with me and let me complete the  
4 presentation. In concept, we're looking at a couple  
5 of different kinds of thresholds. The one we've  
6 talked about up to this point could be termed an  
7 action threshold. It's where we actually take an  
8 Agency response, a preprogrammed Agency response and  
9 we would also report it to Congress. We could also  
10 contemplate more of a lower threshold which would give  
11 us more of an early warning that there is something  
12 developing. And this might -- we're not really sure  
13 how we might use it, but it might lead to information  
14 notices sent out to industry or perhaps generic safety  
15 inspections by the staff. In addition, we may  
16 continue to monitor trends so that we can identify  
17 issues before it manifests themselves as safety  
18 problems in our indicators. Next slide.

19 Here's some of the characteristics we'd  
20 like in thresholds. Next slide. This slide talks  
21 about the process for establishing the thresholds.  
22 The important element here is we're going to establish  
23 an expert panel, give them inputs from risk and  
24 statistical information. We're going to have experts  
25 on that panel in each of the cornerstones, and we're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 going to try and come up with a rational basis for  
2 establishing the thresholds.

3 CHAIRMAN APOSTOLAKIS: You know, as part  
4 of the input to the panel, you can do what Mr. Rosen  
5 suggested, develop the table, plant-specific stuff,  
6 and give it to the panel and let them process it.

7 MR. BOYCE: Right.

8 CHAIRMAN APOSTOLAKIS: That would be a  
9 simple thing to do. If they decide to come back with  
10 generic thresholds, then that's their judgment, but I  
11 doubt it. But they probably could --

12 VICE CHAIRMAN BONACA: You'll have apples  
13 and oranges in that table. That was the only --

14 MEMBER ROSEN: Yes. There's a lot of  
15 apples and oranges now.

16 CHAIRMAN APOSTOLAKIS: What if you have  
17 generic thresholds, then what do you do? You take the  
18 apples and oranges and make a fruit salad.

19 VICE CHAIRMAN BONACA: I understand. All  
20 I'm saying is if you get an expert panel, let them --  
21 hopefully they'll be expert enough to try to sort out  
22 --

23 CHAIRMAN APOSTOLAKIS: But they don't have  
24 access to this information. Not every expert reads  
25 the summary reports. This is just an additional input

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and let them take care of it.

2 MEMBER ROSEN: One comment on apples and  
3 oranges. The peer certification process is making it  
4 more like apples like two kinds of apples: Granny  
5 Smith apples and red delicious apples. Because it's  
6 forcing a convergence of the numbers, so that's a good  
7 thing.

8 MEMBER POWERS: Yes. Well, I think George  
9 would argue that it's forcing a convergence to  
10 crabapples.

11 MEMBER ROSEN: Well, having gone through  
12 one recently, I know for sure that it's forcing  
13 improvements. Now, if it's forcing improvements as  
14 much elsewhere as it was in the plant that I'm  
15 familiar with, then that's a good thing.

16 MEMBER POWERS: The ones I'm familiar with  
17 you're right, it's certainly forcing some people to  
18 make some -- I mean I think everybody ends up having  
19 to make some changes and improvements in their PRA.  
20 But I think George would argue it's improving to a  
21 consistent level of mediocrity.

22 MEMBER ROSEN: I don't think so. Hossein,  
23 what do you think? You know the peer process pretty  
24 well.

25 MR. HAMZEHEE: I'd rather be quiet today.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 (Laughter.)

2 MEMBER ROSEN: I don't want you to. You  
3 know too much. I'd like to hear what you think.

4 MEMBER POWERS: I mean I think the point  
5 that George would make if he weren't being so quiet  
6 over there --

7 CHAIRMAN APOSTOLAKIS: Shy, I'm shy.

8 MEMBER POWERS: -- uncharacteristically  
9 quiet, retiring, is there is not yet such a strong  
10 incentive for the licensee to lean forward in the  
11 trenches in PRA technology, because the benefits are  
12 not so transparently coming to him.

13 MEMBER ROSEN: Yes. I think that's true  
14 about leaning forward in the trenches, doing new  
15 things, and that's a little bit why I was  
16 proselytizing about the selection of the usual  
17 suspects in previous presentations. But as to coming  
18 up to the level that's expected in the peer  
19 certification, that is happening, so there's a push  
20 there or a pull up to that level. Beyond that, yes,  
21 you're correct, there's not a whole lot of incentive  
22 to --

23 VICE CHAIRMAN BONACA: On the other hand,  
24 we have groups of plants out there, okay, where if you  
25 go and look at their stuff, they have to support the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 development and dimensions of the PRA. They have  
2 roughly one person here or less oftentimes versus this  
3 program, some of them have had four people assigned to  
4 one plant for ten, 15 years. And that is not  
5 changing. That's where I'm saying --

6 MEMBER ROSEN: That's where you're wrong.  
7 I think what's happening in the industry is there is  
8 more manpower going into this across the board.

9 VICE CHAIRMAN BONACA: I'm not denying it  
10 is increasing but just two years ago we went to see a  
11 plant and we had one person there. And we're talking  
12 about Davis-Besse, and now you're about to bring  
13 Davis-Besse into this process.

14 CHAIRMAN APOSTOLAKIS: It was amazing the  
15 kind of stuff he was promising to do.

16 VICE CHAIRMAN BONACA: Yes. It was  
17 amazing what they promised that they would do by  
18 October, including the update and everything else.  
19 What I'm trying to say -- and I don't want to make  
20 point of Davis-Besse -- what I'm saying is there's an  
21 unevenness there that still are --

22 MEMBER ROSEN: Yes. It's clear that  
23 there's an unevenness, but I think that the trend is  
24 in the right direction across the board. There will  
25 be places where it's very uneven. And it's to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 point that it's a Level 3 with one person. When you  
2 get two people, then you realize you can only do a  
3 Level 2. You get six people, then they start  
4 complaining they really can't do the Level 1 right.

5 CHAIRMAN APOSTOLAKIS: It goes back.

6 MEMBER ROSEN: And when you have South  
7 Texas with a dozen people, then the whole thing's a  
8 mess, because that's when they find all the problems.

9 CHAIRMAN APOSTOLAKIS: We are really  
10 running out of time here.

11 VICE CHAIRMAN BONACA: Can we please --  
12 yes, let's complete this presentation.

13 CHAIRMAN APOSTOLAKIS: Do you have any  
14 conclusions?

15 MR. BOYCE: That we'll come back to?  
16 These are some of the technical approaches. Some of  
17 them are statistically based, some of them are PRA-  
18 based. One intriguing one is to follow the example  
19 set at the MSPI and perhaps, and Pat alluded to it, we  
20 develop a roll-up indicator for the initiating events.  
21 We have right now on the order of 15 initiating  
22 events, and we may be able to roll them up into a  
23 single index. That's tipping our hand a little bit.  
24 We're exploring that heavily right now. Or some  
25 combination of the above. And we'll get back to you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN APOSTOLAKIS: Good.

2 MR. BOYCE: Here's some of the technical  
3 questions. I won't go through them, but there are  
4 several questions that have been brought up as part of  
5 this forum that we also need to look at.

6 CHAIRMAN APOSTOLAKIS: Why does Congress  
7 want this information?

8 MR. BOYCE: Well, I'm not sure I have the  
9 background answer to that question, but --

10 CHAIRMAN APOSTOLAKIS: What do they do  
11 with it?

12 MR. BARANOWSKY: I can answer it. It's  
13 required of all agencies through the performance and  
14 accountability reporting requirement to pick agency-  
15 wide performance indicators that are a measure of how  
16 well we're doing.

17 CHAIRMAN APOSTOLAKIS: Oh, so it's just an  
18 --

19 MR. BARANOWSKY: For instance, the FAA  
20 might have certain accident or near-miss rates that  
21 they track. We track precursors, we track performance  
22 of plants and other things, there's a lot of things.  
23 And so we're required by law to do that.

24 MR. SATURIUS: And we picked them. We did  
25 it to ourselves. We picked the no significant adverse

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 trends as a reporting requirement.

2 CHAIRMAN APOSTOLAKIS: Okay.

3 MR. BOYCE: That's part of the GPRA,  
4 Government Performance and Results Act of 1993. My  
5 answer was why does Congress want to know about all  
6 the details that we're providing at a high level if we  
7 exceed one of these thresholds, and it's to keep them  
8 aware of what's going on in the nuclear industry.

9 CHAIRMAN APOSTOLAKIS: Okay.

10 MR. BOYCE: All right. Schedule? This  
11 you've not seen before. At the Subcommittee, we  
12 didn't have this particular slide. But we've asked  
13 Research to give us thresholds for the first two  
14 cornerstones by the end of July. We would digest  
15 those, interact with stakeholders from industry, we'd  
16 come back to the ACRS and we would try and use those  
17 and, as I said, expand the approach as it can be  
18 applied to the other cornerstones.

19 We think we'll have thresholds for the  
20 other cornerstones in about the September time frame.  
21 We're going to be looking at changing the performance  
22 goal measures sometime this fall. That would be part  
23 of the budget process. Somewhere in here we're going  
24 to be coming back to the Subcommittee, and, again,  
25 that would be piggybacking on the MSPI. We've got our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 annual Commission paper in March of next year, and we  
2 think we'll have final thresholds developed an in  
3 place sometime during FY '03. That would conclude my  
4 portion of the brief.

5 VICE CHAIRMAN BONACA: And we'll be glad  
6 to have an update in the fall, piggyback on the other  
7 one, performance indicators. Thank you for the  
8 presentation. Any questions? If none, back to you  
9 with ten minutes.

10 CHAIRMAN APOSTOLAKIS: We did? Okay.  
11 Thank you very much. We'll recess until 4:10.

12 (Whereupon, the foregoing matter went off  
13 the record at 3:56 p.m. and went back on  
14 the record at 4:12 p.m.)

15 CHAIRMAN APOSTOLAKIS: Quiet. The last  
16 topic of the day is technical and policy issues  
17 related to advanced reactors. Dr. Kress will Chair  
18 the session.

19 MR. KRESS: Thank you, Mr. Chairman. The  
20 fact that we have such high-powered and respected  
21 people here attests to the importance of this issue.  
22 You know, with the new technology in advanced  
23 reactors, it may be difficult to figure out how to fit  
24 them in to the current licensing system. And in the  
25 process of doing so, there are a number of policy and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 technical issues that will have to be faced up.

2 And, you know, I've articulated a number  
3 of these in the past, and the staff is making some  
4 studies to I think go to the Commission with, and say,  
5 "These are the policy issues that we need to resolve  
6 before we can proceed to license or certify these  
7 advanced reactors." So we're going to hear about the  
8 -- I guess it's still a preliminary document this  
9 time, and I guess either Ashok or Farouk is going to  
10 start us off.

11 MR. ELTAWILA: I see that Ashok is the  
12 lead presenter, so I'm here to support him.

13 (Laughter.)

14 MR. THADANI: Not correct. We'll take  
15 care of that in a moment. Farouk is actually going to  
16 go through the presentation. But I do want to share  
17 some thoughts with you. We had a -- we briefed the  
18 Commission on March 19 on research programs and again  
19 towards the end of May, and Tom participated in that  
20 meeting -- Commission brief on advanced reactors. One  
21 of the things I noted during our brief was the  
22 absolute importance of making sure we lay out,  
23 particularly for non-light-water reactor technologies,  
24 we lay out a clear understanding of what our  
25 expectations are in terms of safety. And you'll hear

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 a little bit about safety goals, their incompleteness  
2 and a number of issues related to the whole concept of  
3 defending that.

4 And I indicated that the point that it  
5 would take great deal of intellectual capital to be  
6 able to develop these things, and they would require  
7 -- my view is they would require interaction and  
8 discussions with a number of people who have had  
9 considerable experience in sort of thinking about  
10 these safety principles and where is the country  
11 going. What is really meant by this expectation that  
12 the future reactors would be safer than the current  
13 class? What does that really mean?

14 So we've just started. We're looking  
15 forward to, I think, considerable dialogue with you,  
16 and we'll be talking to others. We're looking at some  
17 options of what sort of help we need to get to go  
18 forward in this particular area. And then there are  
19 the technical issues. Our intention is to get some  
20 information up to the Commission fairly soon, but we  
21 do need to get the research plan to the Commission I  
22 think it's fall of this year. And before we do that,  
23 we would like to have some of your thoughts reflected  
24 in the paper that we'd like to send to the Commission.

25 With that, I think Farouk is going to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 raise all the key points.

2 CHAIRMAN APOSTOLAKIS: When is the paper  
3 going up, Ashok?

4 MR. THADANI: I think fall of '02.

5 CHAIRMAN APOSTOLAKIS: The fall?

6 MR. THADANI: Do we have a date?

7 MR. ELTAWILA: The final paper is last day  
8 of fall, so December 22. Christmas.

9 (Laughter.)

10 CHAIRMAN APOSTOLAKIS: This is the only  
11 ACRS meeting?

12 MR. ELTAWILA: No, no. This is what we  
13 send you a pre-decision, a copy of that paper for your  
14 consideration. That paper is going to the Commission  
15 this coming June just to try to scope the problem and  
16 the issue that we are working on. And then we'll have  
17 public workshop, discuss the issue in public workshop,  
18 have another discussion with you.

19 So just to start wit the discussion here,  
20 this is an outline of my presentation. I'm going to  
21 start with the purpose of the briefing and give you  
22 some background about some of the advanced reactor  
23 issues that we are working on. And as Ashok  
24 indicated, the Commission has certain expectations  
25 about enhanced margin of safety for advanced reactor,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 so I'm going to touch on that briefly. And I'm going  
2 to discuss relationship to international center.

3 In this presentation and in the paper that  
4 you have, we focus on five policy issues that have  
5 technical basis, but there are a lot of other policy  
6 issues that are addressed in other Commission papers.  
7 I'm going to touch on them, but I'm not going to get  
8 into them in detail.

9 The five policy issues here, the reason we  
10 group together in this paper, because they are all  
11 interrelated. If you work on one of them or any  
12 decision that we make on one of them will affect the  
13 other decisions. That's why we would like to address  
14 them in group. And then I will discuss our future  
15 plan later.

16 MR. KRESS: Farouk, I presume among those  
17 five issues assume among them would be the role that  
18 PRA and high-level risk acceptance criteria might  
19 play. That's cross-cutting through all of them.

20 MR. THADANI: Yes. And it is one of the  
21 major issues.

22 MR. ELTAWILA: That's the first issue,  
23 event selection and role of PRA that's embedded in  
24 that issue.

25 MR. KRESS: That's embedded, yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. ELTAWILA: And we have Scott Newberry  
2 and Mary Drouin here to help me if I stumble on  
3 anything.

4 The purpose of the briefing, I think we --  
5 originally, we thought that we are going to wait until  
6 we finished the pre-application review of the Exelon  
7 PPMR before we go to the Commission on Policy  
8 Decisions. With the cancellation of the PPMR, we  
9 recognized that I think that these policy issues are  
10 of vital importance to the advanced reactor type of  
11 the gas reactor type, the PBMR and GT-MHR. And we  
12 have done work in the past in this area.

13 So based on the work that we have done  
14 thus far with Exelon and the work that we have done in  
15 the '80s and '90s on other advanced reactor type like  
16 the CANDU and MHTGR, that's the old GE design, we  
17 believe that we have sufficient information right now  
18 to go to the Commission with our recommendation on the  
19 policy issue.

20 CHAIRMAN APOSTOLAKIS: But did the Exelon  
21 action have any impact on the policy issues that you  
22 are proposing? I mean it seems to me that you have  
23 more time now, don't you?

24 MR. ELTAWILA: We don't believe -- we have  
25 more time, but I think it will be much better if the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Commission makes its expectation clear. If we make  
2 our expectation clear, what is this future design  
3 going to look like, what's the capability that we  
4 require of this design, the designer will be able to  
5 cope with that and incorporate them in their design.  
6 If we wait until we have a design here to review, our  
7 decision might impact them and cause a backfit and  
8 things like that. So it's better.

9 CHAIRMAN APOSTOLAKIS: It's better because  
10 you have more time to think about it.

11 MEMBER WALLIS: Well, I think it's very  
12 appropriate that you set the rules before the design.

13 MR. ELTAWILA: That's what we're trying --

14 MEMBER WALLIS: Because the safety would  
15 be enhanced, because they will design to the rules,  
16 not to try to fix them after.

17 CHAIRMAN APOSTOLAKIS: You used the word,  
18 "cancellation." I'm not sure that's what Exelon used.

19 MR. THADANI: No, it's not cancellation.  
20 It's that they're getting out of this business. But  
21 let me -- I'm glad -- the points that Graham are very  
22 important. You recall we talked to you about the  
23 vision and mission of the Office of Research some time  
24 ago, and in that is one element which is making sure  
25 the Agency is prepared for future challenges and is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 not an impediment to any specific technology in terms  
2 of saying -- someone comes to the table and we say,  
3 "Well, it's going to take us seven years." So it is  
4 essential for us, we believe, to go forward and for us  
5 to be setting some ground rules, which the designers,  
6 as Farouk noted also, can take advantage of. There  
7 would be -- I think this actually is a much more  
8 stable way to go forward.

9 CHAIRMAN APOSTOLAKIS: Yes. But my point  
10 is that if you had an application, say, coming in the  
11 next year or so, then you look at these policy issues  
12 perhaps with a different eye, and say, "Well, gee, how  
13 much of the current system can I use, " and so on.  
14 And now that you have a little more time, it seems to  
15 me the policy issues should be a little different, and  
16 they should be really what they ought to be.

17 MR. THADANI: Yes. And one other piece of  
18 information I want to give you is I have talked to the  
19 Department of Energy to get their sense of what they  
20 see future is going to look like.

21 CHAIRMAN APOSTOLAKIS: Right.

22 MR. THADANI: And they continue to tell  
23 me, I've had discussions with Bill Magwood. He  
24 continues to tell me that he sees the gas cool  
25 technology in the future for this country. So he

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 still believes it's an important element.

2 MEMBER POWERS: Ashok, Magwood's just come  
3 down with his definition of what his Gen-4 reactors  
4 are, and he's come up with six. He's got a gas  
5 coolant fast reactor, he's got a -- are you ready for  
6 this, Tom?

7 MR. KRESS: I know what you're saying.

8 MEMBER POWERS: A molten coolant reactor.

9 MR. KRESS: Yes.

10 MEMBER POWERS: He's got a --

11 MEMBER ROSEN: Liquid metal reactor.

12 MR. KRESS: Yes.

13 MEMBER POWERS: -- metal reactor. He's  
14 got something called a lead battery, which is kind of  
15 hilarious. Super critical water reactor, and then  
16 he's got the one that's the cat's meow of them all, a  
17 very high temperature gas reactor.

18 MR. KRESS: Right.

19 MEMBER ROSEN: Remember, those are  
20 reactors that their Gen-4 Program has been studying  
21 and for implementation into 2030. This is not next  
22 year.

23 MR. THADANI: That was going to be my  
24 point. There's a distinction here, and Bill Magwood  
25 made a presentation recently, I think to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Commission also, and he pointed out what he believes  
2 over the next ten years is likely to happen. And then  
3 Generation 4 basically is 2030 to 2050 is what --

4 CHAIRMAN APOSTOLAKIS: Just about the time  
5 when we'll retire, right?

6 MR. THADANI: I want to enjoy a few years  
7 of my life.

8 (Laughter.)

9 MR. KRESS: But I think the policy issues  
10 that you selected address all those reactor types.

11 MR. THADANI: That's exactly right.

12 MEMBER WALLIS: George, you can tell your  
13 grandchildren then that you had a role in making this  
14 possible when it happens.

15 CHAIRMAN APOSTOLAKIS: What do you mean?  
16 I'll still be on the ACRS.

17 (Laughter.)

18 CHAIRMAN APOSTOLAKIS: Let's go on,  
19 Farouk.

20 MEMBER ROSEN: But I want to be sure --  
21 before you go on, I want to be sure that the outcome  
22 of that is, I understand, is that we're going to move  
23 forward in a way to enable those things to be  
24 possible, not just look at gas-cooled pebble bed  
25 reactors. Is that correct?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. THADANI: Yes. I think a lot of this  
2 will really aid, not just in terms of gas-cooled  
3 technologies but other technologies as well, yes.

4 MEMBER ROSEN: It should.

5 MR. ELTAWILA: I want to make a point here  
6 that these five issues are not new. We have  
7 interacted with these issues with another ACRS  
8 committee in the '90s and the Commission, and we  
9 issued the SECY 93-092, same five issues. And the  
10 Commission approved the staff recommendations in an  
11 SRM dated July 13, 1993, but because of the change in  
12 Commission, the ACRS, the staff and our experience  
13 with risk-informed regulations, all of these led us to  
14 go and revisit these issues, put them back in front of  
15 you. We'd like to get your feedback and then go to  
16 the Commission with either the same recommendation or  
17 different recommendation, but they are not new issues.

18 MR. KRESS: Yes. The resolution of those  
19 issues were LWR-specific, as best I remember, back in  
20 '93.

21 MR. ELTAWILA: And they were written in  
22 terms of the CANDU, the MHTGR, or whatever it was, and  
23 the Pius. So they were really for the advanced  
24 reactor in general, not for the light- water reactor.  
25 We would like to have a continuous interaction with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 you. For example, at this stage, what we'd like for  
2 you to see if we identified this issue, provide enough  
3 clarity about them and what is your views about them?  
4 Eventually, it will come back to you after we have  
5 interaction with the stakeholder and discuss our final  
6 recommendation to the Commission. Whether you send us  
7 letter now or towards the end, that's completely up to  
8 you.

9 CHAIRMAN APOSTOLAKIS: At the end, you  
10 will want one.

11 MR. ELTAWILA: We definitely will want one  
12 at the end, but if you want to send us one right now  
13 to help us, that would be --

14 MR. THADANI: We would appreciate it,  
15 certainly, even if you have any views that you want to  
16 put forth, be they in our discussions or if you want  
17 to advise the Commission if you disagree with anything  
18 that we say here or in the paper.

19 MR. KRESS: We can certainly do that. I  
20 don't know if we can address that third sub-bullet  
21 under the third bullet yet, but we can give you  
22 comments on the first two sub-bullets.

23 MR. ELTAWILA: Okay. That would be great.  
24 As I indicated earlier, we have other activities where  
25 we are developing a risk-informed performance-based

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 regulatory framework. That will be a technology-  
2 neutral framework so we can use it for any kind of  
3 reactor design. I'm not going to talk about it here,  
4 but it's going to be a part of the RIRIP updates  
5 that's due to the Commission in June of this year.

6 MEMBER SIEBER; I would hope that it's not  
7 a two-stage either/or system between deterministic and  
8 risk-informed for advanced reactors. I would like to  
9 see it just risk-informed to sort of force the context  
10 into that kind of thinking as opposed to giving  
11 alternatives.

12 MR. ELTAWILA: It's not alternative. It's  
13 together, I believe, that's whenever it's possible  
14 that you can use the performance-based regulatory  
15 framework --

16 MEMBER SIEBER; That would be the  
17 requirement to use that.

18 MR. THADANI: I think, certainly, there  
19 will have to be some sort of high-level risk-informed  
20 approach.

21 MEMBER SIEBER; Right.

22 MR. THADANI: But that -- when you go to  
23 some specific designs --

24 MEMBER SIEBER; There will be  
25 determinants.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. THADANI: -- you might find there is  
2 such limitations --

3 MEMBER SIEBER; Right.

4 MR. THADANI: -- in trying to meet those  
5 high-level goals that you may have to resort to some  
6 other considerations.

7 MR. SALSBERG: No, but you won't have  
8 alternative rules.

9 MR. THADANI: No. Our intention is not to  
10 have alternatives.

11 CHAIRMAN APOSTOLAKIS: And there will be  
12 no two-track system.

13 MR. THADANI: No.

14 CHAIRMAN APOSTOLAKIS: Two-tier system.

15 MR. THADANI: That's not the intent.

16 MR. ELTAWILA: Just for background  
17 information, we completed the preapplication review  
18 for the AP-1000, PBMR preapplication activities. We  
19 are continuing to work with Exelon, trying to close  
20 out and document where most of the information that we  
21 received on our request for additional information.  
22 We expect additional preapplication activities, like  
23 GE is meeting with us sometime this month about GE-  
24 ESBWR, which is a 1,200 megawatt electric, which  
25 builds on the ABWR and on the SBWR that was under

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 review here at the Commission a few years ago. And  
2 Framatome is proposing SWR1000 and another is NG-  
3 CANDU, which is new generation CANDU. So all these  
4 are preapplication that's on the horizon, so the staff  
5 will be --

6 CHAIRMAN APOSTOLAKIS: Why do you say  
7 they're possible? Do you have any indications of  
8 anybody that they might actually come?

9 MR. ELTAWILA: They are all -- GE-ESBWR is  
10 coming to discuss --

11 MR. THADANI: They sent a letter in April.

12 MR. ELTAWILA: Yes, they sent a letter in  
13 April. We have a meeting with them this month. We  
14 had already a meeting with Framatome, and we're  
15 planning to have another meeting with them in August.  
16 NG-CANDU, or AACL, they are coming June 19.

17 CHAIRMAN APOSTOLAKIS: Oh, so there is  
18 already contact.

19 MR. ELTAWILA: There is a contact with  
20 these --

21 CHAIRMAN APOSTOLAKIS: What does ESBWR  
22 stand for?

23 MR. ELTAWILA: European Simplified Boiling  
24 Water Reactor, but eventually it will become Economics  
25 Simplified Boiling Water Reactor.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 CHAIRMAN APOSTOLAKIS: So they will apply  
3 for a green card, I assume. The European reactor will  
4 apply for a green card?

5 (Laughter.)

6 MR. ELTAWILA: That's one of the policy  
7 issues that we need to discuss.

8 CHAIRMAN APOSTOLAKIS: It's a policy  
9 issue.

10 MEMBER ROSEN: We'll ask them if they have  
11 any business here, and they'll say, "No, not yet."  
12 And we'll say, "Well, come back when you do."

13 MR. ELTAWILA: Again, many of the issues  
14 that developed in the course of our review have  
15 resulted in generic policy implication, like the legal  
16 and financial issue, and we issued a SECY paper. We  
17 are planning to provide the Commission in the June  
18 time frame with a technical paper in conjunction with  
19 the policy papers. So to facilitate a policy  
20 decision, we want them to see the underlying technical  
21 basis for our recommendation.

22 VICE CHAIRMAN BONACA: What is the NG-  
23 CANDU?

24 MR. ELTAWILA: New generation CANDU.  
25 That's --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. THADANI: As I understand, it's slight  
2 enrichment -- I think they're moving away from natural  
3 uranium. And we would certainly be interested in  
4 getting better understanding of things like the  
5 coefficient and so on.

6 VICE CHAIRMAN BONACA: Yes. That was the  
7 one that has to be no good.

8 MEMBER FORD: I have a question. With all  
9 these reactors coming up for reapplication, how many  
10 of them can you in fact address, given the people, the  
11 resources you have?

12 MR. THADANI: Let me -- right now, there  
13 is a significant issue about budget. Obviously, the  
14 Commission has not made any decisions about 2004  
15 budget, and they may want to make some changes even in  
16 2003 budget before the Appropriations Committee does  
17 its thing for 2003 budget. Our plans currently do not  
18 include consideration of -- review of any designs  
19 other than an HGDR and AP-1000, and we have some  
20 limited resources we've identified in the outyears.  
21 I think it was -- Farouk, you'll have to correct me --  
22 Iris, I think we put some in the outyears, some  
23 resources.

24 MR. ELTAWILA: That's correct.

25 MR. THADANI: So we could discuss with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Westinghouse and others the key thermalhydraulic issue  
2 and the testing issues upfront. So we put some  
3 resources for that. If ESBWR or SWR1000 or NG-CANDU  
4 come in, the Commission is going to have to make some  
5 decisions about how to do allocation of resources.

6 CHAIRMAN APOSTOLAKIS: But you have to  
7 respond if they come in. I mean it's not --

8 MR. ELTAWILA: That's correct.

9 MR. THADANI: Yes.

10 CHAIRMAN APOSTOLAKIS: You can't tell them  
11 we can't do it.

12 MR. THADANI: Well, we can say we can do  
13 it, but it seems to me one option would be to get in  
14 the line and maybe it will take us longer time because  
15 of resource considerations.

16 CHAIRMAN APOSTOLAKIS: That's the last  
17 thing you want to do. I mean --

18 MR. THADANI: I'm not suggesting that  
19 that's what -- it's a Commission decision in the end.

20 CHAIRMAN APOSTOLAKIS: Right.

21 MEMBER ROSEN: Is there a problem, to some  
22 degree, ameliorated by attempting to do things  
23 generically, to set some criteria generically?

24 MR. KRESS: Oh, yes, that would help  
25 tremendously. I think we're off the subject, though.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I mean this is your guy's business, you can figure  
2 that out.

3 CHAIRMAN APOSTOLAKIS: Maybe we can go to  
4 the issues at some point. Thank you, Farouk.

5 MR. ELTAWILA: You're welcome. I think  
6 one of the -- well, that's the important issue here,  
7 the Commission expectation about enhanced safety, what  
8 we mean by enhanced safety.

9 CHAIRMAN APOSTOLAKIS: Shouldn't we  
10 quantify them first, though, the margins, instead of  
11 talking about them?

12 MR. ELTAWILA: That's a very good  
13 question.

14 CHAIRMAN APOSTOLAKIS: Are you going to  
15 have it somewhere there to quantify the margins of  
16 safety?

17 MR. ELTAWILA: Not during this  
18 presentation. Hopefully, as part of our work, we will  
19 be able to try to come up with methodology to quantify  
20 the margin of safety.

21 CHAIRMAN APOSTOLAKIS: Yes. I mean I  
22 remember when we were discussing Option 3 here, Mary  
23 and your colleagues, what was it, a year ago. They  
24 agreed also that that would be something useful to do.  
25 In fact, you write it in the report. It's in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)



1 report that the margins of safety should be  
2 quantified.

3 MEMBER WALLIS: First of all, you have to  
4 --

5 CHAIRMAN APOSTOLAKIS: Because then you  
6 can have the --

7 MR. THADANI: That's right.

8 CHAIRMAN APOSTOLAKIS: Sorry?

9 MR. THADANI: First you need to -- when we  
10 talk about some high-level safety principles, it seems  
11 to me that they will have to incorporate within them  
12 some discussion of what sort of confidence level one  
13 is looking at at that level. If one were to define  
14 that, then one has to go forward and try and  
15 understand what the margins are and what do we really  
16 mean by certain level of confidence. And the thinking  
17 that we've gone through so far is that is the general  
18 path that we're going to have to at least consider and  
19 hear options and so on. As to where we end up, I  
20 don't know.

21 CHAIRMAN APOSTOLAKIS: In PRA, what we  
22 have really quantified so far is the defense in-depth  
23 measures.

24 MR. THADANI: Yes.

25 CHAIRMAN APOSTOLAKIS: But we have not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 touched the safety margins.

2 MR. THADANI: Correct.

3 CHAIRMAN APOSTOLAKIS: We have taken the  
4 success criteria, as given to us by the vendor, and  
5 then we work with those.

6 MR. THADANI: That's right.

7 CHAIRMAN APOSTOLAKIS: Okay?

8 MR. THADANI: That's right.

9 MR. KRESS: When the Commission talked  
10 about enhanced safety margins for the advanced  
11 reactors, I think they had in mind a better safety  
12 status. It's not the margins we normally talk about.

13 MR. THADANI: I wanted to come back to  
14 George's point, because one of the things we don't do  
15 well -- whoops, I think I turned off something.

16 MR. KRESS: An SBO.

17 MR. THADANI: Nice to have some control  
18 here. In PRA, George, I guess common uncertainties  
19 are sometimes done well.

20 CHAIRMAN APOSTOLAKIS: Right.

21 MR. THADANI: But the model uncertainties  
22 are not done well at all. And what we're trying to  
23 do, and not just in the context of the advanced  
24 reactors, but we're trying to make sure that we have  
25 efforts underway to try and understand what sort of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 model uncertainties exist. And one of the issues that  
2 I'm exploring, the staff is looking at now, Farouk's  
3 staff is looking at, is if we want to modify 50.46 to  
4 look for functional reliability of ECCS, I suppose we  
5 establish some criteria, ten to the minus X, whatever  
6 it is. And we say but you should do realistic  
7 analysis, which is good.

8 Now, let me take you to another event  
9 path, if you will. I don't want to assume any systems  
10 failing, but I want to understand what things can go  
11 wrong in terms of the implicit models in the code.  
12 How much confidence do I have in that? Shouldn't  
13 there be some relationship of what one might call  
14 model uncertainties to establishing some system  
15 reliability requirements? And Jack Rosenthal in  
16 Farouk's division is going forward to take a look at  
17 that.

18 We're making slow progress, but those are  
19 the kinds of things I hope we'll take advantage of as  
20 we go forward on these new designs.

21 MEMBER WALLIS: Ashok, in a totally risk-  
22 based world, you wouldn't need margins of safety. I  
23 mean they would be inherent in your choice of the risk  
24 basis and you might -- you would be able to trade off  
25 margin here against margin there --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. THADANI: Exactly.

2 MEMBER WALLIS: -- that the risk basis  
3 would give you. And then you would be able to tell  
4 the public really that we're assuring a certain level  
5 of risk. And how it's done by the industry is up to  
6 them.

7 MEMBER ROSEN: But a totally risk-based  
8 world is impossible, because -- in principle, because  
9 model uncertainty, things that you don't know about,  
10 can't be included.

11 MEMBER WALLIS: I'm sorry, risk-based  
12 regulations can form. Not the world, it's the  
13 regulations, they can be risk-based. Then you have to  
14 deal with these uncertainties.

15 CHAIRMAN APOSTOLAKIS: In any case, the  
16 issue of margins is right now outside the PRA,  
17 essentially. I mean we are really working with the  
18 defense in-depth measures and we're quantifying them.  
19 If we have redundant systems, we know how to do that.  
20 We do this, we do that. We are not including, of  
21 course, passive areas, but it would be nice to have  
22 all those so we'll be able to make tradeoffs and have  
23 a better idea how well we meet the goals.

24 MEMBER ROSEN: I think some future  
25 reactors will have to --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN APOSTOLAKIS: And these are  
2 future reactors.

3 MEMBER ROSEN: And we'll have to treat  
4 passive failures in future reactors in PRA --

5 CHAIRMAN APOSTOLAKIS: Sure.

6 MEMBER ROSEN: -- because of the nature of  
7 the design.

8 VICE CHAIRMAN BONACA: Although, I mean  
9 for new reactors you have such -- there's a challenge  
10 because databases are not available. A lot of  
11 information there is not, so there will be very large  
12 uncertainties.

13 CHAIRMAN APOSTOLAKIS: So we've had a long  
14 discussion on a slide that Farouk has not even  
15 described yet.

16 (Laughter.)

17 MR. ELTAWILA: So the Commission has  
18 expressed expectation in the advanced reactor policy  
19 statement and in the severe accident policy statement,  
20 for example, and both of them indicate that they  
21 expect the new design to have better margin or better  
22 safety than existing reactor.

23 Just to highlight two points that for the  
24 advanced reactor the Commission encouraged the  
25 simplified reactor inherently safe and use passive

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 feature, although that's very good but it poses a  
2 tremendous challenge to PRA, because now the system is  
3 responding to phenomenology rather than a component  
4 failure. And we really don't have experience in doing  
5 that work so that the passive system reliability  
6 becomes an important issue.

7 CHAIRMAN APOSTOLAKIS: Let me come back to  
8 the previous sub-bullet.

9 MR. ELTAWILA: Okay.

10 CHAIRMAN APOSTOLAKIS: I guess B, "Safer  
11 than current reactors." You have to be very careful  
12 with that. And the reason why I'm saying this is  
13 several years ago DOE had an office and their highest  
14 priority was to build a new production reactor. That  
15 was before Mr. Gorbachev came to Washington to meet  
16 with Mr. Bush. And DOE being very ambitious, said  
17 that our new production reactor will be safer than the  
18 commercial reactors. Then when it came time to  
19 actually implement that they had a big problem. What  
20 does safer mean? Is it supposed to be safer than the  
21 best reactor out there? Is it supposed to be safer  
22 than the average? What does it mean?

23 And what was at stake was millions of  
24 dollars, okay? Because all it takes is a very  
25 progressive utility with an excellent reactor and so

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 on to reach very low levels of core damage frequency,  
2 and then the new production reactor had to be safer  
3 than that. Okay? And they had the restrictions  
4 regarding the sites. One was Savannah River, the  
5 other one was somewhere else. Well, you know, the  
6 seismic risk was more or less there, so you have to be  
7 a little careful when you phrase these things.

8 MR. ELTAWILA: I agree with you. I'm  
9 going to give you my own --

10 MR. KRESS: That's exactly what he meant  
11 by this being a policy issue is what did the  
12 Commission mean by statements like that?

13 MR. THADANI: That's the point here.

14 CHAIRMAN APOSTOLAKIS: Well, then I'm just  
15 elaborating on it.

16 MR. THADANI: Let me read you something  
17 from I think this is the severe accident policy.

18 CHAIRMAN APOSTOLAKIS: This was a real  
19 case, though.

20 MR. THADANI: As you know, there are three  
21 relevant policy statements. One is severe accident  
22 policy statement, the other is advanced reactor policy  
23 statement and then the standardization policy  
24 statement. Those are the relevant policy statements  
25 that we're talking about. And I'm just -- let me

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 quote from I think it's the severe accident policy  
2 statement. "The Commission fully expects that vendors  
3 engaged in designing new standard plants will achieve  
4 a higher standard of severe accident safety  
5 performance than their previous designs."

6 And the point here is there is some sort  
7 of expectation of improved safety. What does that  
8 mean? And that's the same question we asked, Tom was  
9 there, of the Commission. We need to be able to  
10 articulate what that really means.

11 MR. KRESS: And the Commission said, "You  
12 tell us."

13 MR. THADANI: Yes.

14 CHAIRMAN APOSTOLAKIS: Well, usually they  
15 would like to see some options, and then they pick  
16 around. What I'm saying is there was a real case  
17 where people were enthusiastic, it will be safer than  
18 the -- and then they had to eat their words. They  
19 just couldn't afford to be safer.

20 MR. ELTAWILA: As a minimum, provide the  
21 same degree of protection as current plants, and I  
22 think that's the second part. And I really think the  
23 issue of safer, and that's my own interpretation, is  
24 that there were a lot of uncertainties in the severe  
25 accident at that time and the expectation that by

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 resolving this severe accident issue you will be able  
2 to understand them better and you can make a better  
3 safety case.

4 MR. KRESS: They can provide a higher  
5 level of confidence in your review of your safety.

6 MEMBER POWERS: When we started looking at  
7 probabilistic approaches to, "Oh, we want to make  
8 plants safe," we very quickly realized that if you  
9 look at prevention systems, you can only go so far  
10 with them. Eventually, you get to the point where  
11 having redundancy and even diversity in systems  
12 actually starts costing you safety rather than  
13 helping. And so you had to have what has come to be  
14 called a balance between prevention and mitigation.  
15 And that became pretty much a pretty good guide for  
16 what we were trying to do in the area of safety.

17 Now we see people coming forward with more  
18 advanced reactors, and one that comes immediately to  
19 mind are the AP series of reactors. What you're  
20 saying, "Gee, we've done this PRA analysis on this  
21 thing, and our prevention systems are tremendous and  
22 they give us CDFs of ten to the minus seventh and  
23 things like that." And, you know, how do we react to  
24 that?

25 You can look at their probabilistic risk

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 assessment, and if it's like most probablistic risk  
2 assessments, there are things you can quibble on, but  
3 you don't find things that say that this absolutely  
4 wrong, that the prevention systems just aren't this  
5 good. But, quite frankly, you don't believe it. And  
6 so do we still have to -- I mean do we have to evolve  
7 this concept of a balance between prevention and  
8 mitigation or are we just changing the balance between  
9 prevention and mitigation? Where do you see this  
10 going here?

11 MR. ELTAWILA: Again, that's one of the  
12 policy issues that we are asking the Commission, and  
13 I think I'm -- how about if we wait until we get to  
14 that issue and see the question that we're asking are  
15 the right questions and we'll see where we develop the  
16 technical basis for that.

17 MR. KRESS: I'd like to point out on the  
18 third bullet to the Committee that these guys have  
19 been listening to us. You could probably find every  
20 one of those in one of our letters or another.

21 CHAIRMAN APOSTOLAKIS: What does RIRIP  
22 mean, risk-informed rest in peace?

23 (Laughter.)

24 MR. ELTAWILA: That's exactly what it is.  
25 That's Commission definition of that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN BONACA: On the question of  
2 should a higher level require that, I think simply by  
3 placing some requirements for containment for severe  
4 accidents from the current generation, you would  
5 already, in a qualitative sense, set up a higher level  
6 of expectation in safety. Right now we see everything  
7 which is severe accidents beyond design basis to make  
8 some portions of that part of design basis.

9 MR. THADANI: I think it's useful to touch  
10 Dana's point, it seems to me. AP-600, for example.  
11 I mean we had a clear path, clear guidance from the  
12 Commission as Part 52 of our regulations, and then  
13 referring to Part 50; that is, you meet our  
14 regulations, that you address all unresolved safety  
15 issues and high- and medium-priority generic safety  
16 issues, that you conduct a PRA and if it identifies  
17 areas for enhancement, you conceded those.

18 And then we went beyond and we looked at  
19 their words about reliability of decay heat, both in  
20 the context of core damage and containment response.  
21 And we looked at some challenges to containment,  
22 particularly early challenges, to see what sort of  
23 features could be added to significantly reduce those  
24 threats. And there's no question, at least in my --  
25 well, in addition to that, obviously, the rule says

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 they need to meet our safety goals also.

2 Now, one can always use that approach, but  
3 is that the most efficient way for new designs? And  
4 my own sense is that there is a better way to go at  
5 it. But it needs to be borne out through some real  
6 work, and we're just at the beginning of that.

7 MEMBER POWERS: I mean your first policy  
8 issue hints at the problem. We can go ahead and say,  
9 meet the safety goals and they'll have exactly the  
10 same problem the current plants have, and it's very  
11 difficult to tell whether you are or not, so you end  
12 up using a surrogate. And you raise that question of  
13 the current metrics, and I've seen a lot of people  
14 raising that question, and for the life of me it  
15 puzzles me. Because I look at CDF, core damage  
16 frequency, and I say, well, some of these reactors  
17 don't undergo core damage the way I look at core  
18 damage, but I sure as hell know what a core damage  
19 event in them is as much as I do one in a zircalloy  
20 clad oxide fuel one. I mean it didn't strike me as a  
21 tremendous leap of imagination has to be gotten to  
22 change that CDF into -- I mean you're just changing  
23 the letters a little bit, but then number's about  
24 exactly the same.

25 MR. THADANI: I think the point here is

1 more than just the CDF itself. Do we want to stay  
2 with the same value of LERF that we've been using? Do  
3 we want to stay with the statements we made for AP-600  
4 and others, 24-hour containment integrity for those  
5 certain threats? Is that what we want to stay with?

6 MEMBER POWERS: Yes. Now, that's -- those  
7 are real questions, because --

8 MR. THADANI: Yes. And those are the  
9 things we're talking about.

10 MEMBER POWERS: And the containment versus  
11 confinement debate comes up.

12 MR. THADANI: Yes.

13 MEMBER POWERS: And, you know, some of the  
14 words I've seen on that have been interesting to me,  
15 and I'd just point out that the Savannah River  
16 reactors were designed with confinements, and those  
17 confinements, when we think about confinements and  
18 terrorist or sabotage acts, sometimes we think they're  
19 orthogonal with those confinements, were designed to  
20 take an airburst from a nuclear weapon. So you can  
21 design a confinement to be perfectly robust. It's  
22 just a different approach than a containment, and --

23 CHAIRMAN APOSTOLAKIS: Also, it seems to  
24 me the words, "prevention" and "mitigation" refer to  
25 a particular point, in this case, CDF, I mean core

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 damage. You want to prevent it, and then if it  
2 happens, you want to mitigate the consequences. What  
3 if you don't have a core damage pivotal event, but you  
4 now have a frequency consequence, I mean release  
5 curve? Again, it's not obvious to me what prevention  
6 and mitigation means in that case because you will  
7 have different frequency regions.

8 MEMBER POWERS: Well, I think, George --  
9 I think -- when I said it didn't take a big leap for  
10 me to translate CDF to something applicable to, say,  
11 a coded particle fuel reactor in a large graphite  
12 block, it seems to me that the only thing that counts  
13 is when you release fission products.

14 CHAIRMAN APOSTOLAKIS: Yes.

15 MEMBER POWERS: If the only thing we did  
16 was damage core, we wouldn't care. And, of course,  
17 that's one of the great attractions, the molten salt  
18 reactor. You could probably damage the core a lot  
19 and not release any fission products at all, because  
20 they'd absorb into the molten salt.

21 And when you look at frequency consequence  
22 curves, I mean, yes, in reality, they're nice, smooth  
23 curves and whatnot, but they have a sharp cliff, and  
24 when you go over that cliff you know that that's  
25 different than when you're just slowly degrading down.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN APOSTOLAKIS: And also it depends  
2 on where you're releasing. It could be outside, could  
3 be somewhere inside.

4 MEMBER POWERS: But it only counts if it  
5 gets to the great out outdoors.

6 CHAIRMAN APOSTOLAKIS: If it isn't  
7 outdoors, it doesn't matter.

8 MR. THADANI: But that is not the point.  
9 I think we're going to have to think this through to  
10 balance and design. I think that's -- I believe you  
11 said that, and let me use an example: Reactor  
12 pressure vessel today. We want to be sure, have  
13 pretty high confidence that it's very, very unlikely  
14 that you'll fail reactor pressure vessel. What are  
15 potential challenges to the integrity of the pressure  
16 vessel? Should you somehow divide the balance and  
17 design? Does that mean that you have frequency of  
18 challenge and the conditional probability of vessel  
19 failure? Do you have to build that in in the vessel  
20 to get balance because you're trying now kind of two  
21 different things.

22 MR. KRESS: Sure, you're allocating among  
23 sequences, and I think you --

24 MR. THADANI: That's why I think frequency  
25 consequence --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. KRESS: Yes, yes.

2 MR. THADANI: -- you still have to think  
3 about other factors.

4 MR. KRESS: You do, but I think this  
5 question of prevention versus mitigation has to be  
6 rethought. In the first place, we don't have any  
7 guidelines on what that balance ought to be. If you  
8 look at the current plants, you get some conditional  
9 containment failure probabilities of 0.8. That's like  
10 not having a containment at all. And then, by the  
11 other token, you get some down around 0.01. So we  
12 don't have good guidance on what that ought to be, and  
13 in my view, some of the concepts, the molten salt, for  
14 example, or the tri-cell coated fuel particle taps do  
15 both their prevention and mitigation in one concept.  
16 And I think that ought to be a way to think about it.

17 And I really think the overall view ought  
18 to be do we meet high-level risk acceptance criteria  
19 at a sufficient level of confidence? And the way you  
20 build defense in-depth in that, in my mind, is to talk  
21 about the uncertainties, and what you want to do is  
22 balance that uncertainty across all these frequency  
23 ranges.

24 CHAIRMAN APOSTOLAKIS: But the uncertainty

25 --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1                   MEMBER POWERS: The problem I've always  
2 had with that, you know, "Let's talk about the  
3 uncertainties," is that's great but you guys won't.  
4 The only uncertainties that ever get discussed --  
5 usually uncertainties aren't discussed at all. All we  
6 get is point estimates, even from you guys, Ashok.  
7 Today we didn't.

8                   MR. THADANI: I accept the criticism.

9                   MEMBER POWERS: But when we do get  
10 uncertainties, all we get these mamby-pamby little  
11 various -- this adhesion coefficient or something  
12 like, nobody coming in and asking really where the  
13 uncertainty is and whatnot. And so whereas you're  
14 right, perhaps, though I don't actually agree with  
15 you, but I will concede you have a point in principle,  
16 I think in practical fact it can't be done. And  
17 you're forced to come where I'm much more comfortable  
18 is saying, what if the codes and analyses are wrong?  
19 And that's where you start addressing defense in-  
20 depth.

21                   CHAIRMAN APOSTOLAKIS: And margins, I  
22 think, not just defense in-depth. They go together,  
23 although defense in-depth is the first thing that  
24 comes to mind.

25                   MR. KRESS: My view is --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: I won't argue with you on  
2 that.

3 MR. KRESS: My view, Dana, is that the  
4 uncertainties are a measure of how wrong the codes are  
5 if you could quantify them.

6 MEMBER POWERS: It's a measure that you  
7 never make.

8 MR. KRESS: Yes. We ought to be able to  
9 do it better.

10 CHAIRMAN APOSTOLAKIS: No, but you see I  
11 think what happens --

12 MEMBER WALLIS: If you haven't made up to  
13 now, it's going to be made.

14 CHAIRMAN APOSTOLAKIS: But what's going to  
15 happen, guys, is the typical thing that engineers and  
16 scientists do. Even if they try to quantify them,  
17 they will quantify the uncertainties in the hardware,  
18 in the processes, perhaps, and so on. I'm willing to  
19 bet that nobody will come here and say, "And if we  
20 build this reactor and we have these regulations, the  
21 licensee will ignore this particular program and that  
22 will lead to all sorts of problems," because we don't  
23 think that way, and yet that's a major uncertainty.

24 MEMBER POWERS: Well, I mean what are the  
25 chances we're going to build one and say, "And I bet

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you this guy let's the boric acid chew through the  
2 head."

3 CHAIRMAN APOSTOLAKIS: Well, that's what  
4 I meant, that we heard today that the inspection  
5 program -- that was a conclusion of the root cause  
6 analysis -- was good enough. It's just that it was  
7 not implemented right, and the AIT report concludes  
8 the same thing. That's its first conclusion, in fact.  
9 They said it was pretty good, but if you don't have  
10 the -- now, do you design the reactor with that kind  
11 of uncertainty in mind? I doubt it very much; I don't  
12 think anyone would do that.

13 MEMBER WALLIS: You have the same thing  
14 with codes, and we know that when we say  
15 thermalhydraulic code, different people get different  
16 answers depending on how they use it. So you've got  
17 the human factor there too, someone who's careless use  
18 of a code, predicts something which is really not a  
19 good answer and then uses it is just as careless as  
20 the guy who let's boric acid sit --

21 MR. KRESS: We design reactors now with  
22 our general design criteria and our design basis  
23 accidents, and we take account of that by talking  
24 about single failure criteria, but we don't deal with  
25 it in there. Where we deal that is in the other parts

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 of the regulations having to do with the reactor  
2 oversight, inspection. I don't see a reason why we  
3 have to change those parts of the regulations. I  
4 think what we're dealing with here is trying to design  
5 a regulatory system that helps a reactor design get  
6 certified in the first place. And then these other  
7 issues I can deal with them in other parts of  
8 regulatory space.

9 CHAIRMAN APOSTOLAKIS: Maybe you want to  
10 use different words there that will be safe enough.

11 MR. KRESS: Oh, safe enough, yes.

12 CHAIRMAN APOSTOLAKIS: And also realistic.  
13 You know, it pains me to admit this, but I think there  
14 is some point to the structure of this interpretation  
15 of Defense in-depth, because people are wrong. I  
16 thought it was a joke but people do make mistakes.

17 MEMBER POWERS: Not at MIT.

18 CHAIRMAN APOSTOLAKIS: Well, but we don't  
19 design them, unfortunately.

20 The second conclusion of the AIT report  
21 was tat a BNW owner's group underestimated the rate of  
22 corrosion by at least a factor of two. Now who would  
23 have said that in a study, in a PRA, that they will do  
24 these calculations but they may also be wrong with  
25 some probability? You can't say that. First of all,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 people will be all over you. But it's something  
2 that's inconceivable, and yet people do do those  
3 things.

4 MEMBER WALLIS: You figure that in.  
5 Certainly, I use the code example. I mean you know  
6 something about the accuracy or uncertainty in the  
7 predictions of codes, and you do build it in.

8 CHAIRMAN APOSTOLAKIS: See, that's the  
9 thing --

10 MEMBER WALLIS: But it's not formulated in  
11 a quantitative way. You certainly bring it into your  
12 consideration when you're making a decision, but it's  
13 not formulated. What you're asking for is some  
14 quantitative measure.

15 CHAIRMAN APOSTOLAKIS: Well, I'm not  
16 asking for it. I think it's some uncertainty that we  
17 don't even think of.

18 MR. KRESS: Anyway, I think this --

19 CHAIRMAN APOSTOLAKIS: Make the system  
20 more robust because you never know what's going to  
21 happen, that kind of thing.

22 MR. KRESS: I think this discussion points  
23 out a lot of formidable challenges these guys have.

24 MR. ELTAWILA: Mr. Chairman, I'm less than  
25 one-third of my presentation, and I have 15 minutes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 No, I need guidance. There is no way I can go through  
2 the whole -- are you allowing me time or you want me  
3 to finish at certain time?

4 CHAIRMAN APOSTOLAKIS: Use your judgment  
5 and skip some things.

6 MR. ELTAWILA: I will skip something, but  
7 I'd really like to highlight here on that viewgraph is  
8 that the Commission had expectation that new reactor  
9 will have containment equivalent to large, dry  
10 containment. Of course, they meant light water  
11 reactor. They did not mean at that time gas core  
12 reactor. And the basis for that they approved a  
13 confinement versus a containment in the policy paper.  
14 So I'm bringing it upfront here.

15 Some of the policy issues that Mary's  
16 going to address in her Commission paper are should we  
17 be looking at different cornerstones in our regulatory  
18 framework? For example, radiation protection for  
19 worker, security and safeguards. These are a couple  
20 of the issues. Should we be considering lead  
21 contamination as part of our -- the metrics of the --

22 MEMBER POWERS: Cornerstone issue. I  
23 could imagine that you might have well to enhance your  
24 safety and security just because of the current  
25 environment, but let me ask you, do you think that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 you're getting enough mileage out of the known risk-  
2 informed cornerstones that you have, that you need to  
3 look for others of those? You know, radiation  
4 protection, health security, things like that. I mean  
5 they're the stepchildren of the cornerstones as it is.  
6 Do you need more stepchildren?

7 MR. ELTAWILA: No, but that's all. The  
8 Commission said no before, yes?

9 MEMBER POWERS: It seems to me I would not  
10 waste a lot of time on that. The lane contamination  
11 really is something that they need to decide, but I  
12 think we know what the answer is going to be.

13 MR. ELTAWILA: Yes. I think the issue of  
14 defense in-depth I think Tom alluded to it. When you  
15 have the tri-cell particle that performs both the  
16 function of prevention and mitigation and the fuel  
17 can't stand very high temperature for a long period of  
18 time, assume this is true. Can we allow the length of  
19 time as a barrier, as a defense in-depth. These are  
20 some of the questions that we'll be tackling in the  
21 future.

22 MEMBER ROSEN: Well, before you get off  
23 that slide, there's one I -- the Generation 4 Program  
24 has pointed at that's not there, and that is the need  
25 for off-site evacuation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. ELTAWILA: It's in there.

2 MR. THADANI: It's coming.

3 MR. ELTAWILA: These additional policy  
4 issues -- I'm going to address the emergency planning  
5 as part of this.

6 CHAIRMAN APOSTOLAKIS: But these are  
7 related also to the others. If you bring up the issue  
8 of international standards, for example.

9 MR. ELTAWILA: Quickly, since these  
10 designs, or most of them, are done overseas, we really  
11 need to look at the senders overseas and see if we can  
12 capitalize --

13 CHAIRMAN APOSTOLAKIS: Yes, but for  
14 example, the Europeans don't really have safety goals;  
15 we do. So I don't know how you --

16 MR. THADANI: Well, I think if you go back  
17 and let me use EPR. If you go back and look at the  
18 EPR safety principles, they include probablistic  
19 considerations.

20 CHAIRMAN APOSTOLAKIS: Not the way that  
21 our Commission has -- I don't think they say this is  
22 a goal, do they?

23 MR. THADANI: Well, they establish some  
24 probablistic considerations --

25 CHAIRMAN APOSTOLAKIS: For what?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. THADANI: -- which then drive them to  
2 certain designs, for example, in terms of core damage  
3 severe accidents.

4 CHAIRMAN APOSTOLAKIS: But we have it at  
5 --

6 MR. THADANI: Ten to the minus X they  
7 have.

8 CHAIRMAN APOSTOLAKIS: Yes, but we have it  
9 at a level of individual risk.

10 MR. THADANI: Oh, yes, yes, they don't.

11 CHAIRMAN APOSTOLAKIS: They don't do that.

12 MR. THADANI: You're right. You're right.

13 MR. KRESS: With respect to this, Ashok,  
14 Farouk, I may be a maverick on this issue because I  
15 think it be well to understand what the safety  
16 requirements are in other countries and IAEA, their  
17 principles and stuff like that. But I find it  
18 perfectly reasonable to say different countries that  
19 have different have high-level risk acceptance  
20 criteria. That's because they have different citing  
21 characteristics, they have different values. They  
22 might value nuclear more than we do because it's the  
23 only option they have. So it's perfectly reasonable  
24 to me that we'd have a different set of safety  
25 standards than some of the countries.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN APOSTOLAKIS: At the health and  
2 safety level, yes, but the core damage or equivalent  
3 level, I'm not sure that's a wise way to go. Because  
4 one accident somewhere kills everybody.

5 MR. KRESS: Well, I don't think that's  
6 necessarily true either. I think that's a misnomer.

7 CHAIRMAN APOSTOLAKIS: I think we've used  
8 the argument that that design is different from ours  
9 to the limit. I don't think the American people will  
10 buy that.

11 MR. THADANI: I think that there's so many  
12 different variables that I think there are different  
13 forces that would push certainly western Europe in  
14 some directions that we may not want to go.

15 MR. KRESS: That's exactly my point. I  
16 don't think it's true that an accident anywhere is an  
17 accident everywhere, especially for some of the new  
18 plants.

19 CHAIRMAN APOSTOLAKIS: I think you're  
20 going to have a hard time convincing me --

21 MR. KRESS: Only philosophically.

22 MEMBER POWERS: But from a practical point  
23 of view, I think you're right, Tom, that we had a  
24 major accident in Russia with a plant design that was  
25 very different from ours. And it had a remarkably

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 little impact on the United States nuclear power  
2 program. Big impact on Europe's but remarkably little  
3 in Japan. So I think, yes, once the designs are  
4 distinct enough, you're probably right.

5 CHAIRMAN APOSTOLAKIS: But my argument is  
6 that -- the argument that the designs were distinct  
7 enough was accepted last time. I'm not sure how many  
8 times the American people will accept that.

9 MR. KRESS: They also didn't look very  
10 close either.

11 (Laughter.)

12 MEMBER SIEBER: A more important factor  
13 may have been the fact that they're far removed from  
14 us and people, when something happens thousands of  
15 miles away, don't see it as --

16 CHAIRMAN APOSTOLAKIS: I really don't want  
17 anybody to have a reactor with a core damage frequency  
18 of ten to the minus three or two. I don't care where  
19 it is, I don't care what their needs are.

20 MEMBER POWERS: There are a couple of  
21 them.

22 CHAIRMAN APOSTOLAKIS: They should --

23 MEMBER POWERS: Already.

24 CHAIRMAN APOSTOLAKIS: The West is doing  
25 something about the ones I know about.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: They would try to bomb  
2 them.

3 CHAIRMAN APOSTOLAKIS: Okay, Farouk.

4 MR. ELTAWILA: The first policy issue that  
5 we are putting in front of the Commission is the event  
6 selection and safety classification of system  
7 structure and the component. And as I mentioned  
8 earlier, that this passive system the traditional PRA  
9 will not work the same way --

10 CHAIRMAN APOSTOLAKIS: What do you mean by  
11 better selection? You mean design basis?

12 MR. ELTAWILA: Yes, the design basis and  
13 beyond design basis. So these are the -- yes, design  
14 basis selection. And the selection of these, for  
15 example, they will be generally low probability event,  
16 but they are going to be responding to different  
17 uncertainty. So assessing the reliability of this  
18 system and try to quantify the core damage frequency  
19 or LERF based on these phenomenological uncertainty  
20 will be extremely difficult. So sheds doubts about  
21 the usability of PRE.

22 That issue was raised in front of the  
23 Commission long time ago and in the 1993, and the  
24 staff at the time said that we are going to use a  
25 blend of deterministic and probablistic approach.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 We'll use the deterministic as it exists right now and  
2 supplement it with risk information. And the  
3 Commission found that to be acceptable at that time.

4 CHAIRMAN APOSTOLAKIS: Well, that was nine  
5 years ago, but I would say -- well, first of all, is  
6 your -- does your second bullet imply that maybe we  
7 will not have design basis accidents at all, that  
8 we'll have some other approach that maybe some people  
9 can come up with or a test to -- we have to have them?  
10 Maybe not in the --

11 MR. ELTAWILA: The approach that was  
12 proposed by the PBMR have some design basis approach,  
13 but, again, they are selected using PRA.

14 CHAIRMAN APOSTOLAKIS: Right.

15 MR. ELTAWILA: You know, that they were  
16 not really deterministic. They said that these are  
17 the design requirement that we are going to design the  
18 plants for.

19 CHAIRMAN APOSTOLAKIS: Because there is  
20 value to having specific accidents and accident  
21 sequences, because then it eases communication.  
22 There's no question about it. At the same time, you  
23 may not want to treat them the way what is in the  
24 LWRs.

25 MR. THADANI: If you go, for example, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 concept of frequency and consequences, if you go to  
2 that concept, consequences starting with nothing  
3 happening all the way to some significant releases, if  
4 you go to that, the point here would be you can do  
5 that in absence of a specific design, you can lay out  
6 some things. But then when you go to the specific  
7 design, you still need to -- maybe using that concept,  
8 you still need to, as you were saying in terms of  
9 communication, analysis and so on, need to identify  
10 what are those events that you need to --

11 MR. KRESS: You have a copy of my  
12 viewgraph that I gave to the Commission?

13 CHAIRMAN APOSTOLAKIS: Yes. I don't like  
14 the word, "supplemented," excuse me.

15 MEMBER WALLIS: I don't see how you can  
16 set deterministic requirements for a reactor concept  
17 which doesn't yet exist. You can always set  
18 probabilistic sort of requirements and safety goals,  
19 but you cannot set deterministic goals.

20 MR. KRESS: I was proposing an iterative  
21 process in my slides to the Commission in which you  
22 have some sort of -- you always are going to have a  
23 design concept. You don't have anything unless you  
24 start out with a design concept. And you can select  
25 initiating events for those concepts, and you can

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 establish some sort of initiating event frequency.  
2 Now, that's going to be the tough part, but the  
3 question is now which of these events and at what  
4 frequency level are you going to cut off and say these  
5 are design basis and these others aren't? Well, you  
6 could do it iteratively in the way that I proposed,  
7 and you would have to adjust the design, but you have  
8 to have a PRA to do this.

9 MEMBER WALLIS: That's right. You'll be  
10 --

11 MR. KRESS: And you have uncertainties in  
12 it, and you have to have high-level acceptance  
13 criteria.

14 MEMBER POWERS: Tom, the difficulty I have  
15 is that's great if I'm designing the reactor. But  
16 when I'm in the business of regulating the reactor,  
17 and you've gone through all that, do I care?

18 MR. KRESS: Once the design is fixed,  
19 that's the basis for certification.

20 MEMBER POWERS: No, no, no. Why should I  
21 care? Why shouldn't I say the basis of certification  
22 is this plant has an expectation value of the risk of  
23 such and such a value at such and such a confidence  
24 limit, and I really don't care what particular  
25 accidents the designer worked to try to knock down at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 very low levels?

2 MR. THADANI: If you take that in  
3 conjunction with other requirements like, for example,  
4 source term, containment fuel, quality and things like  
5 that, you can make that determination.

6 MEMBER POWERS: Yes.

7 MR. KRESS: Dana, I think this is back to  
8 my rationalist defense in-depth concept, and what it  
9 has to do with is you focus on individual sequences,  
10 and this is a way to do it. And you assure yourself  
11 that individual sequences meet two criteria: One,  
12 they don't contribute overly to the overall risk, and  
13 they don't contribute a huge amount to the  
14 uncertainty. That's why you do it in that manner.

15 MEMBER POWERS: Well, we've debated this  
16 before. I mean I don't care if my risk is ten to the  
17 minus eight and it's 99.9 percent due to one sequence,  
18 that's fine with me.

19 MR. KRESS: Yes. But you wouldn't want 99  
20 percent of your uncertainty be due to that sequence.  
21 That's my point.

22 MEMBER POWERS: If the uncertainty is only  
23 ten percent, I don't care.

24 MR. KRESS: Well, that's true too. That's  
25 a sliding scale.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 MR. ELTAWILA: The Commission actually  
2 addressed part of that issue in the '90s. For  
3 example, the air intrusion that was very low  
4 probability event, but the Commission said, "Don't  
5 have arbitrarily cut off at the exact frequency."  
6 Consider that issue, even though it's a very low  
7 probability, look at the consequence in that issue --

8 CHAIRMAN APOSTOLAKIS: Right.

9 MR. ELTAWILA: -- and incorporate it in  
10 the --

11 CHAIRMAN APOSTOLAKIS: The PRA.

12 MR. ELTAWILA: -- in your decision.

13 MR. KRESS: You have to look at all  
14 sequences.

15 VICE CHAIRMAN BONACA: In Option 2 right  
16 now we're struggling with the issue of having just one  
17 criterion, okay, to throw things into Risk 1, 2, 3 and  
18 4, and we have in fact discussed the possibility of  
19 having -- well, the FSAR has different criteria, has  
20 a set of criteria, generally. What are we going to  
21 use here? Are we going to intermediate criteria for  
22 the --

23 CHAIRMAN APOSTOLAKIS: I think it's  
24 covered by his earlier comment that -- what was it?

25 MR. THADANI: It was the issue of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 classification.

2 CHAIRMAN APOSTOLAKIS: The cornerstones,  
3 additional cornerstones. You may want to add  
4 additional. But I really don't like the word,  
5 "supplemented,"

6 VICE CHAIRMAN BONACA: But I think  
7 certainly we don't want to get into a situation, as we  
8 have right now, for Option 2 where --

9 MEMBER POWERS: I mean "supplemented" is  
10 what they said.

11 MR. ELTAWILA: That's what the Commission  
12 said. I think what we responded to Exelon we  
13 indicated there's going to be a blend of both real  
14 deterministic and probablistic analysis.

15 CHAIRMAN APOSTOLAKIS: Okay. That was in  
16 1993, wasn't it?

17 MR. ELTAWILA: Yes. It's just a  
18 statement.

19 CHAIRMAN APOSTOLAKIS: I think from the  
20 whole discussion here in my view there will have to be  
21 deterministic requirements at least for the ease of  
22 communication, but these should be based on  
23 probablistic arguments as much as possible.

24 MEMBER POWERS: George, we're all  
25 Bayesians now.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 (Laughter.)

2 CHAIRMAN APOSTOLAKIS: It's not this  
3 Committee that worries me.

4 MR. ELTAWILA: With probablistic  
5 arguments, with the robust consideration of  
6 uncertainties.

7 MEMBER POWERS: Yes, I'd like to see that  
8 happen.

9 MR. KRESS: That's our mantra now.

10 MR. THADANI: But you know, you've got to  
11 keep pushing. I think we cannot --

12 CHAIRMAN APOSTOLAKIS: But, you know,  
13 Ashok, it's very disappointing what's happening in  
14 real life. I mean the reactor safety study 25, 27  
15 years ago quantified parameter uncertainties. We  
16 ought to be discussing now model uncertainties. And  
17 what's happening? People are not even doing the  
18 parameters anymore. It's really very discouraging.

19 MR. THADANI: I know Mary's just itching  
20 to get and react to that statement, but I can tell you  
21 that there's really a fair amount of effort -- let me  
22 make sure. Maybe we have not been here talking to you  
23 as to what it is we're doing to move in that  
24 direction. I think your observation is reasonable  
25 that I've seen more studies recently over the last few

1 years which have had less discussion of uncertainty  
2 than I used to see many years ago.

3 CHAIRMAN APOSTOLAKIS: That's right.

4 MR. THADANI: So I think that --

5 CHAIRMAN APOSTOLAKIS: And you know why?  
6 I've talked to industry about these things. You know  
7 what the answer is? The NRC staff doesn't want them.  
8 I'm sorry, but that's what they told me: Why should  
9 we do it? Anyway, let's go on.

10 MR. ELTAWILA: The issue of fuel  
11 performance and qualification is one of the most  
12 important issues, and I think the policy decision that  
13 we would be seeking guidance from the Commission is  
14 regarding the test requirement. You know, we  
15 traditionally stopped at design basis requirements, so  
16 what is the role of beyond design basis? Should we  
17 stop -- they can demonstrate that the fuel will keep  
18 the temperature of 1600 degrees. We would like to  
19 require additional test that will go beyond that and  
20 look at the failure point and so on and when you can  
21 release the fission product.

22 MEMBER WALLIS: This is a deterministic  
23 thing which is thrown out in the air. It depends upon  
24 what the fuel is, what the accidents are, what the  
25 risks are. You can't just pick a number like 1600

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 degrees C.

2 MR. ELTAWILA: I did not pick that number.

3 MEMBER WALLIS: But you can't.

4 MR. ELTAWILA: I think because they have  
5 qualifications --

6 MEMBER WALLIS: You put it down there.  
7 Someone --

8 MEMBER POWERS: I think Graham is raising  
9 a general point here, and not just the fuel, but the  
10 general point is that why wouldn't you treat this just  
11 the way you treat many of the things now in looking at  
12 a safety analysis report? A guy has come to you and  
13 he's said, "Gee, I've got a reactor here. It's ten to  
14 the minus eighth reactor, and I proved it with this  
15 analyses." And you go through that analysis and you  
16 say, "Okay, one of your assumptions is that the fuel  
17 is good to 1600. It doesn't even hint at releasing  
18 fission products at 1600 for three and a half days.  
19 Prove that to me with test data and things like that."  
20 And you would just go through other things but  
21 following the assumptions that he made when he had  
22 done his analysis of the risk. I mean why focus just  
23 on fuel? I mean it would be all of the major  
24 assumptions. It may be up to some discretion and  
25 guidance from the staff on which ones they wanted to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 go after.

2 MR. ELTAWILA: Again, Dana, because as I  
3 indicated earlier, that the decision on any of these  
4 issues will affect the other decisions. So if you are  
5 going to say that there will be no fission product  
6 released ever, then you want to be sure that this  
7 decision is not at 1650. You're going to start seeing  
8 a release in fission product.

9 MEMBER POWERS: Everything comes out.

10 MR. ELTAWILA: So it's again because the  
11 importance that was given to the fuel as a prevention  
12 and mitigated feature that you want to have more  
13 assurance that we have done in the traditional fuel  
14 design.

15 MEMBER SIEBER; Okay. I guess when I see  
16 you said the burnups and temperature requirements in  
17 a deterministic way, you're really putting a box  
18 around what the fuel cycle will look like, which sets  
19 the cost.

20 MR. ELTAWILA: I apologize. This was  
21 Exelon proposal. I should have made that clear. This  
22 is the proposal that will be running at 80,000  
23 megawatt day per metric ton and is going to be with a  
24 stand temperature of 1600 degrees C. That's not our  
25 requirement.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER; Okay. I don't think we  
2 ever should make a requirement like that.

3 MR. KRESS: This may be an issue specific  
4 to gas cool reactors.

5 MEMBER ROSEN: Right. But I'm known to  
6 think about these things generically. Should you  
7 qualify for fuel's performance? Absolutely, but it  
8 may be different for different designs. Should fuel  
9 qualification testing be completed prior to granting  
10 a mine operating license? Excuse me? I wish we would  
11 just all rise at once and say, "Of course." I mean we  
12 didn't do that before but that was then, this is now.

13 MR. KRESS: Wait a minute. Suppose I told  
14 you that I have a fuel that I can't qualify?

15 MEMBER ROSEN: Well, I'd say you have a  
16 problem convincing me to license your reactor.

17 MR. ELTAWILA: What would you say that we  
18 have a fuel that was produced based on the same  
19 manufacture and process, like in Germany, but even you  
20 cannot prove to anybody that you are going to be  
21 following that process?

22 MR. KRESS: That's exactly --

23 MR. ELTAWILA: And there is a  
24 qualification, there are wealth of database on the  
25 Germany fuel, but the technology itself they have not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 produced that fuel using this process for a long  
2 period of time. So can you rely on this old data or  
3 you want the current processing of the fuel be tested  
4 to prove that this condition will be attained?

5 MEMBER POWERS: It's a cute question  
6 because you know what the answer is. They're not even  
7 close to reproducing the German fuel. I mean it's  
8 appalling how far away they are.

9 MR. KRESS: And not only --

10 CHAIRMAN APOSTOLAKIS: Just have the  
11 Germans do it then, make it?

12 MR. KRESS: But not only that if they do  
13 get the process down to where they've got the same  
14 quality fuel, and then you're going to take so many  
15 billion of those things and stick it in your reactor,  
16 to say that each one of those now has that quality  
17 based on the fact that I know how they made it,  
18 there's no way, in my mind, you can statistically  
19 prove that fuel has the quality that they said it has.  
20 And that's your issue here. You have to focus on  
21 process rather than product.

22 MEMBER POWERS: Well, don't worry, Tom,  
23 they're so far away now they can statistically prove  
24 they ain't there.

25 MR. KRESS: Well, right now, but they can

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 prove they're not there, but when they want to hit  
2 their target level they can't prove it. But I suggest  
3 that it's because you can't stick enough of this fuel  
4 and take it to that burnup level, at that temperature  
5 long enough in a test reactor, there's no way you can  
6 get the statistics out of that. What you have to do  
7 is test all the fuel at the same time.

8 MEMBER POWERS: And what's --

9 MR. KRESS: And the only way to do that is  
10 stick it in your reactor and, as installed, during  
11 startup and initial operations, you look to see how  
12 much fission products you get in your primary system.  
13 This should be a measure of at least how many faulty  
14 fuel elements you have. It's just like -- you know,  
15 we measure the quality of the fuel now by looking at  
16 how much activity is in the thing. You're going to  
17 have to develop that kind of concept for these, I  
18 think. And it ought to be part of the licensing  
19 provision.

20 CHAIRMAN APOSTOLAKIS: Isn't it completely  
21 inconceivable that I can have some damage to the fuel  
22 but then I have other means to contain it?

23 MEMBER SIEBER; Yes.

24 CHAIRMAN APOSTOLAKIS: Why?

25 MEMBER SIEBER; We usually put a reactor

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 pressure vessel around it.

2 CHAIRMAN APOSTOLAKIS: So then why do I  
3 need -- I mean I can provide other measures. Contain,  
4 let them clean it up.

5 MR. KRESS: Well, you can, you can.

6 MEMBER POWERS: We kind of do that right  
7 now.

8 CHAIRMAN APOSTOLAKIS: So, again, we're  
9 going back to the picture of the reactor as a whole,  
10 of the plant. It's not just --

11 MEMBER SIEBER; You've essentially removed  
12 one of the barriers of your risk --

13 CHAIRMAN APOSTOLAKIS: But I may have  
14 installed another one.

15 MEMBER SIEBER; Yes. You may just put  
16 more and more barriers.

17 MEMBER POWERS: Well, you're right,  
18 George, in the sense that we have much the same  
19 problem that we were discussing in connection with  
20 Yucca Mountain. We all agree that there are going to  
21 be multiple barriers. Now, the question is do we put  
22 our constraint on what the totality of those barriers  
23 are? Or do we go in and say, "Okay. The totality has  
24 to be hits," but no one barrier can be more than 30  
25 percent of this.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN APOSTOLAKIS: Absolutely,  
2 absolutely.

3 MEMBER POWERS: And that's a very  
4 interesting question to get into, and every time I  
5 persuade myself that I don't want to dictate what the  
6 barriers do, you come back with an argument on why I  
7 should.

8 CHAIRMAN APOSTOLAKIS: Farouk, you are  
9 going too slow here.

10 (Laughter.)

11 MR. ELTAWILA: I'll try. Okay. The issue  
12 of the source term is one of the -- traditionally, we  
13 use the TID 14844 or NUREG 1465 as a generic source  
14 term. The pebble bed and all advanced reactors try  
15 now to have a scenario-specific source term. And that  
16 I raise a question about the experimental database to  
17 support that, the fission product release and  
18 transport and the models and so on. We raised that  
19 issue in front of the Commission in '93, and they  
20 found there is no problem in using a mechanistic  
21 source term for the specific scenario, provided the  
22 database is adequate to address that issue. And as a  
23 matter of fact, in that regard, they said that we  
24 should be including their intrusion scenario.

25 The next issue is the containment

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 performance issue. I'm sorry?

2 CHAIRMAN APOSTOLAKIS: We discussed this  
3 already. Didn't we discuss this?

4 MR. ELTAWILA: I'm sorry.

5 CHAIRMAN APOSTOLAKIS: I thought we  
6 discussed most of this.

7 MR. ELTAWILA: That's true and so we can  
8 move on. Same issue with the --

9 MEMBER POWERS: Well, I think for our  
10 discussion purposes, sometime, just between us girls  
11 here, we're going to have to come down to some  
12 agreement on how we're going to handle the sabotage  
13 versus the more classical thing. Are we going to just  
14 set that aside and say we'll deal with sabotage and  
15 terrorist threats aside or are we going to continue to  
16 mesh is together? Because it really causes confusion,  
17 in my mind.

18 MR. ELTAWILA: It is an issue that --

19 MEMBER POWERS: I mean in the end you're  
20 going to have integrate it all together, but for  
21 discussions purposes --

22 MR. ELTAWILA: Yes. It is an issue that  
23 we're going to have to address, period.

24 MR. KRESS: That's another reason to  
25 change our thinking on the balance between prevention

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and mitigation. I think the more you put on the front  
2 end the less vulnerable it is to sabotage. That's a  
3 personal opinion. I think that, for instance, a  
4 pebble bed reactor is probably much less vulnerable to  
5 sabotage than an LWR.

6 MEMBER POWERS: Oh, I think it's much  
7 more.

8 MR. KRESS: Well, we'll have to debate it.

9 CHAIRMAN APOSTOLAKIS: Emergency.

10 MR. ELTAWILA: The next issue, Mr. Rosen,  
11 is the emergency evacuation, and the issue was  
12 addressed again in 1993 about reducing the EPZ and  
13 looking for it based on the small source term and so  
14 on. And the Commission at that time did not feel that  
15 we had enough information to reduce the EPZ, but at  
16 the same time told the staff to keep an open mind  
17 about this issue and come to us when you have  
18 additional information. We are keeping an open mind  
19 about this issue, and we're going to address it in  
20 totality with the rest of the other issues as part of  
21 the --

22 CHAIRMAN APOSTOLAKIS: Which may lead to  
23 an increase in EPZ --

24 MEMBER POWERS: Well, especially when you  
25 have --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN APOSTOLAKIS: -- depending on the  
2 reactor design, right? It's part now of the total  
3 risk profile.

4 MEMBER POWERS: I think you've got another  
5 thing to take into account. You've got a societal  
6 thing to take into account.

7 CHAIRMAN APOSTOLAKIS: That's exactly  
8 right.

9 MEMBER POWERS: Because you've got a bill  
10 in Congress right now that says make the EPZs 20  
11 miles.

12 MR. THADANI: Well, I don't think the bill  
13 says to make EPZ 20 miles. I think it talks about KI.

14 MR. KRESS: Yes. It's a planning and --

15 CHAIRMAN APOSTOLAKIS: But I don't think  
16 we should focus our discussion on reducing the EPZ.  
17 I think everything else we have discussed today is  
18 that we should look at the system as a whole --

19 MR. ELTAWILA: We should look at the whole  
20 thing as in development.

21 CHAIRMAN APOSTOLAKIS: If meeting the  
22 safety goals requires a larger EPZ, so be it.

23 MEMBER ROSEN: Right, but nobody's  
24 designing new reactors with a goal of having a much  
25 larger EPZ.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN APOSTOLAKIS: That's their  
2 business. We are regulators.

3 MEMBER ROSEN: The business end of the  
4 business is attempting to provide an attractive  
5 product, and one of the most attractive products is  
6 one where you can put a reactor someplace and say,  
7 "See," to the public, "this reactor is so safe we  
8 don't even have an off-site emergency plan."

9 MEMBER POWERS: But you can say that -- I  
10 mean I could say that right now. You've got to  
11 persuade the public that they agree with you.

12 CHAIRMAN APOSTOLAKIS: Yes.

13 MEMBER ROSEN: Because the next sentence  
14 is not that it's so safe that -- you don't stop with,  
15 "It's so safe that we don't need an off-site emergency  
16 evacuation plan." You say that, and you say,  
17 "Because," and then you give a cogent answer that  
18 people can understand.

19 MEMBER POWERS: I think I would believe  
20 you more if you said, "It's so safe that we don't need  
21 an EPZ, and it's so safe that we don't even want  
22 Price-Anderson indemnification."

23 CHAIRMAN APOSTOLAKIS: All we need today  
24 is a process for determining these things. We don't  
25 have to convince anybody. We have to convince people

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that our process is rationale and science-based.  
2 That's all.

3 MR. KRESS: Clearly, if you had high-level  
4 risk acceptance criteria and had appropriate PRA with  
5 uncertainties that showed that at particular  
6 confidence level you meet those without any emergency  
7 response at all, the question I would raise is that  
8 would be a nice goal to have but wouldn't you want an  
9 emergency plan anyway, even though you had that?

10 MEMBER POWERS: That's right, because you  
11 might be wrong.

12 MR. KRESS: Because I might be wrong. And  
13 there might be other considerations, like sabotage and  
14 things like that.

15 MR. THADANI: The Commission has -- we've  
16 had some requests, as you know, to reduce EPZ in some  
17 cases. I guess when EPRI came to us in the  
18 requirements development, ALWR document, that was one  
19 of the issues. They wanted to reduce the EPZ. And,  
20 basically, what we told them then, and I recognize  
21 this is several years ago, what we said was that  
22 emergency planning is considered yet another layer of  
23 defense in-depth outside of the design considerations.  
24 But as I think George was saying, these are all linked  
25 issues, and come out where it does and the Commission

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 -- we just need make sure we give Commission the  
2 relevant information.

3 VICE CHAIRMAN BONACA: Okay. That's it.  
4 Thank you.

5 MEMBER POWERS: The plan is that Mary is  
6 going to be the lead author on this document?

7 MR. ELTAWILA: I'm sorry?

8 MEMBER POWERS: May Drouin is going to be  
9 the lead author on this document?

10 MR. ELTAWILA: Which document? The policy  
11 paper is Tom King. And Mary has the policy paper --

12 MEMBER WALLIS: Tom King?

13 MR. ELTAWILA: Yes. He's --

14 MEMBER POWERS: You remember him.

15 MR. ELTAWILA: -- back.

16 MEMBER WALLIS: I have a comment on this  
17 whole thing.

18 MR. KRESS: We'll open the floor for  
19 comments at this point.

20 MEMBER WALLIS: What I see here is a whole  
21 series of questions, and I see very little in the way  
22 of confidence that you guys have the answers.

23 MR. ELTAWILA: We don't.

24 MEMBER WALLIS: The ACRS has been sitting  
25 here trying to get some answers, but that's just our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 game. I mean it's your job to come up with answers.

2 MR. KRESS: Their job right now is to  
3 define what the questions are.

4 MEMBER WALLIS: So I have a lot of doubt  
5 about you meeting anything like a deadline by fall  
6 2002.

7 MR. ELTAWILA: No. I think maybe we  
8 present you with the same Commission -- the same  
9 question that we asked in 1993. There was a decision  
10 taken by the Commission. The staff made the  
11 recommendation to the Commission. So we know the  
12 answers to most of these questions. All what we are  
13 doing right now revisiting this question to see if we  
14 are changing our mind because of information that we  
15 have or because of new policy change or something like  
16 that. But I think we feel very confident that all  
17 these questions will be addressed satisfactory by the  
18 --

19 MEMBER WALLIS: So all the questions have  
20 been answered before and you're just tweaking the  
21 answers? Is that what you're doing?

22 MR. ELTAWILA: Well, I don't think it's  
23 tweaking the answers. It's just looking at the  
24 additional information that we have, the experience  
25 that we gained in risk-informed regulation and see if

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 it changed any of these answers.

2 MR. THADANI: I think -- let me be careful  
3 because I want to make sure we're not missing each  
4 other's point here. What we're talking about is a set  
5 of issues. As you know, some of the technical issues  
6 it's going to take a long time before we get real  
7 information. But we want to make sure that the course  
8 of action that we lay out for us to follow is agreed  
9 to. I mean we're not going to be able to have risk-  
10 informed regulatory structure in three months. We're  
11 just not going to have that. But what we do need to  
12 be sure is that is there buy-in on the part of the  
13 Commission? This is a multiyear effort.

14 MEMBER WALLIS: Well, I'm not --

15 MR. THADANI: Here are the issues that we  
16 need to go forward with. We need to have some  
17 confidence.

18 MEMBER WALLIS: Let me be a member of the  
19 public here. I mean just because the Commission is  
20 going to make some decisions doesn't mean that they're  
21 right decisions. You've got to provide enough  
22 information to make darn sure that they make the right  
23 decisions. That's what I'm confused about.

24 MR. THADANI: That's fair. And I would  
25 like to think that we have already got some

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 information that obviously would be supplemented by  
2 what we learn over the next several months. But we're  
3 not going to go to Commission with no information.  
4 We're going to lay out what we know and what needs to  
5 be developed further, and that's part of the idea  
6 behind the research plan.

7 MR. KRESS: You're not going to them and  
8 asking for resolution of these issues at this time,  
9 are you?

10 MR. ELTAWILA: We need --

11 MR. KRESS: You're just going to say, "Are  
12 these the right questions?"

13 MR. ELTAWILA: Right. Are these the areas  
14 -- if the Commission says upfront that, "We just don't  
15 want you to pursue high-level safety principles  
16 approach," we'd like to know that.

17 CHAIRMAN APOSTOLAKIS: One of the things  
18 that I would appreciate if I were in their shoes is  
19 what lessons did we learn from the current regulatory  
20 system? Some of them are obvious, of course, but, for  
21 example, yesterday we had a marathon Subcommittee  
22 meeting of ten hours on CRDM cracking and Davis-Besse  
23 and so on. Let's say we license a reactor to 2030.  
24 Would there be a subcommittee in 2050 for ten hours  
25 looking at something unexpected and trying to fix it?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER WALLIS: Yes.

2 CHAIRMAN APOSTOLAKIS: There would be?

3 MEMBER WALLIS: Yes.

4 MEMBER WALLIS: Why? Why are you so  
5 confident that there will be?

6 MEMBER POWERS: Because no one has ever  
7 gone broke underestimating human capabilities.

8 CHAIRMAN APOSTOLAKIS: Well, but --

9 MEMBER POWERS: George, the world is far  
10 more complicated than the rationalists think it is.

11 CHAIRMAN APOSTOLAKIS: This was a major  
12 thing with that Voltaire stock, you know.

13 (Laughter.)

14 Well, but if that's the case, then the  
15 policy decisions that we're making now somehow we'll  
16 accommodate for that, which brings us back to the  
17 structure as defense in-depth. But how far can you  
18 push that? See, that's the real issue.

19 MR. SALSBERG: Well, I think there's  
20 another thing, though. I mean how far do you want to  
21 accommodate that in the design, and how far do you  
22 accommodate that in a kind of performance regulation?

23 CHAIRMAN APOSTOLAKIS: And I fully agree  
24 with that, but I tell you, before Three Mile Island I  
25 was a major player in the PRA we were doing for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 industry. If you dared say that the operators would  
2 do something wrong, you were out of the project,  
3 because the industry did not believe that the  
4 operators could make a mistake, period.

5 MR. SALSBERG: Your PRA is never going to  
6 postulate every error that --

7 CHAIRMAN APOSTOLAKIS: Nobody paid  
8 attention to the PRAs. As Rasmussen said, it was a  
9 status symbol. Everybody wanted to have the blue  
10 reactor safety study but nobody read it except him and  
11 Levin.

12 MEMBER POWERS: George, to think that --

13 CHAIRMAN APOSTOLAKIS: Well, you're not  
14 giving me a warm feeling here that we're going to have  
15 these Subcommittee meetings --

16 MEMBER WALLIS: You can't have a warm  
17 feeling, George, it's just the way it is.

18 MEMBER POWERS: And what you would hope  
19 for are one or two of them and not a marathon of  
20 marathons.

21 CHAIRMAN APOSTOLAKIS: Well, I didn't get  
22 the answer I wanted, but --

23 MR. SALSBERG: Let me just ask sort of a  
24 practical question, as a pragmatic sort of guy.

25 CHAIRMAN APOSTOLAKIS: Are you saying that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the questions so far have not been?

2 MR. SALSBERG: If I go with -- everything  
3 I hear is PRA and uncertainties. Now, you know, we  
4 talk about public acceptance. If I have to come in  
5 and defend a PRA down to whatever level I want to get  
6 down to, in a public litigation sort of situation, it  
7 seems to me that's an endless discussion. One of the  
8 things I like about a design basis is there's a very  
9 concrete acceptance kind of criteria with limits, and  
10 I just have a very difficult time in the sort of  
11 judicial approach in the litigation nature of  
12 Americans --

13 CHAIRMAN APOSTOLAKIS: But nobody's  
14 proposing that, Bill.

15 MR. SALSBERG: Well, I hear some things  
16 that sound a lot like that.

17 CHAIRMAN APOSTOLAKIS: No, no. It will be  
18 deterministic requirements based on probablistic  
19 arguments.

20 MR. KRESS: And even selection of design  
21 basis accident.

22 CHAIRMAN APOSTOLAKIS: Yes. But you will  
23 never go and argue probablistic, because you'll never  
24 finish.

25 MR. THADANI: In the end, that's what we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 meant here. Once you go -- if you go with frequency  
2 consequence approach, you still -- you can do that in  
3 the abstract even --

4 CHAIRMAN APOSTOLAKIS: Yes.

5 MR. THADANI: -- without knowing what  
6 number sequence. You can do these things. But you  
7 still, and Graham's point is valid, that you need  
8 design information, you need to -- if you're going to  
9 rely on PRA, you need to have some level of confidence  
10 in that. And what we're suggesting is once you lay  
11 out this plan and once you have confidence in the  
12 analysis, you can define certain events that sort of  
13 become part of the design base and that you make  
14 hopefully more rational decisions regarding the  
15 requirements for structure systems and components.  
16 That's the thinking. But it's got to go through a  
17 process, and I mean we're just sharing with you our  
18 early thoughts.

19 CHAIRMAN APOSTOLAKIS: Yes. Acceptance  
20 criteria will have to be deterministic. Otherwise  
21 there's no end to this.

22 MEMBER POWERS: Right. I'll just kick in,  
23 Farouk, I think you guys have really come up with a  
24 really nice set of questions.

25 MR. KRESS: Yes. That was my --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. ELTAWILA: Well, I really -- I don't  
2 want to leave you with that we only have questions and  
3 we don't -- I think we have the technical basis and  
4 the technical basis is going to be sharpened between  
5 now and October.

6 CHAIRMAN APOSTOLAKIS: We understand that.

7 MR. ELTAWILA: Okay. Thanks.

8 MR. KRESS: I think that's --

9 CHAIRMAN APOSTOLAKIS: Are there any other  
10 comments from members of the public or the staff?  
11 Thank you very much. Gentlemen, this was very, very  
12 informative. It was a little low-key, I would say,  
13 but thank you.

14 MR. THADANI: Farouk took too long.  
15 That's the only problem.

16 (Laughter.)

17 MEMBER POWERS: As usual.

18 CHAIRMAN APOSTOLAKIS: We'll recess for  
19 eight minutes and come back and give advice to our  
20 colleagues on the letters.

21 (Whereupon, the foregoing matter went off  
22 the record at 5:40 p.m.)

23

24

25

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

**CERTIFICATE**

This is to certify that the attached proceedings  
before the United States Nuclear Regulatory Commission  
in the matter of:

Name of Proceeding: 493<sup>rd</sup> Meeting of Advisory  
Committee on Reactor  
Safeguards

Docket Number: N/A

Location: Rockville, Maryland

were held as herein appears, and that this is the  
original transcript thereof for the file of the United  
States Nuclear Regulatory Commission taken by me and,  
thereafter reduced to typewriting by me or under the  
direction of the court reporting company, and that the  
transcript is a true and accurate record of the  
foregoing proceedings.

*Debra Wilensky*  
Debra Wilensky  
Official Reporter  
Neal R. Gross & Co., Inc.

**NEAL R. GROSS**  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
WASHINGTON, D. C. 20555

FOR  
0606  
Δ1

May 9, 2002

SCHEDULE AND OUTLINE FOR DISCUSSION  
493<sup>RD</sup> ACRS MEETING  
JUNE 6-8, 2002

THURSDAY, JUNE 6, 2002, CONFERENCE ROOM 2B3, TWO WHITE FLINT NORTH,  
ROCKVILLE, MARYLAND

- 1) 8:30 - 8:35 A.M. Opening Remarks by the ACRS Chairman (Open)  
1.1) Opening statement (GEA/JTL/SD)  
1.2) Items of current interest (GEA/SD)
- 2) 8:35 - 10:30 A.M. CRDM Cracking of Vessel Head Penetrations and Vessel Head Degradation (Open) (FPF/MWW)  
2.1) Remarks by the Subcommittee Chairman  
2.2) Briefing by and discussions with representatives of the NRC staff regarding issues related to the investigation of circumferential cracks in PWR control rod drive mechanism (CRDM) penetration nozzles and weldments, and reactor pressure vessel head degradation at the Davis-Besse Nuclear Power Plant.

Representatives of the nuclear industry may provide their views, as appropriate.

10:30 - 10:45 A.M. \*\*\*BREAK\*\*\*

- 3) 10:45 - 12:15 P.M. Technical Assessment Generic Safety Issue (GSI)-189, "Susceptibility of Ice Condenser and Mark III Containments to Early Failure from Hydrogen Combustion During a Severe Accident" (Open) (TSK/RBE/SD)  
3.1) Remarks by the Subcommittee Chairman  
3.2) Briefing by and discussions with representatives of the NRC staff regarding its technical basis and proposed recommendations for resolving GSI-189.

Representatives of the nuclear industry may provide their views, as appropriate.

12:15 - 1:15 P.M. \*\*\*LUNCH\*\*\*

- 4) 1:15 - 2:15 P.M. Technical Assessment of GSI-168, Environmental Qualification of Low-Voltage Instrumentation and Control Cables (Open) (GML/TJK/SD)  
4.1) Remarks by the Subcommittee Chairman  
4.2) Briefing by and discussions with representatives of the NRC staff regarding its technical basis and proposed recommendations for resolving GSI-168.

Representatives of the nuclear industry may provide their views, as appropriate.

- 5) 2:15 - 3:30 P.M. Development of Reliability/Availability Performance Indicators and Industry Trends (Open) (MVB/AWC/MWW)
- 5.1) Remarks by the Subcommittee Chairman
  - 5.2) Briefing by and discussions with representatives of the NRC staff regarding the staff's initiatives to integrate the NRC programs for risk-based analysis of reactor operating experience into the reactor oversight process, specifically the development of reliability/availability performance indicators and industry trends.

Representatives of the nuclear industry may provide their views, as appropriate.

**3:30 - 3:45 P.M. \*\*\*BREAK\*\*\***

- 6) 3:45 - 4:45 P.M. Technical and Policy Issues Related to Advanced Reactors (Open) (TSK/MME)
- 6.1) Remarks by the Subcommittee Chairman
  - 6.2) Briefing by and discussions with representatives of the NRC staff regarding technical and policy issues related to advanced reactors.

**4:45 - 5:00 P.M. \*\*\*BREAK\*\*\***

- 7) 5:00 - 7:15 P.M. Proposed ACRS Reports (Open)  
Discussion of proposed ACRS reports on:
- 7.1) CRDM Cracking of Vessel Head Penetrations and Vessel Head Degradation (FPF/MWW)
  - 7.2) Technical Assessment of GSI-189, "Susceptibility of Ice Condenser and Mark III Containments to Early Failure from Hydrogen Combustion During a Severe Accident" (TSK/RBE/SD)
  - 7.3) Technical Assessment of Generic Safety Issue-168, "Environmental Qualification of Low-Voltage I&C Cables" (GML/TJK/SD)
  - 7.4) Development of Reliability/Availability Performance Indicators and Industry Trends (MVB/AWC/MWW)
  - 7.5) Confirmatory Research Program on High Burnup Fuel (Tentative) (TSK/TJK/MME)
  - 7.6) Technical and Policy Issues Related to Advanced Reactors (Tentative) (TSK/MME)

**FRIDAY, JUNE 7, 2002, CONFERENCE ROOM 2B3, TWO WHITE FLINT NORTH, ROCKVILLE, MARYLAND**

- 8) 8:30 - 8:35 A.M. Opening Remarks by the ACRS Chairman (Open) (GEA/JTL/SD)
- 9) 8:35 - 10:00 A.M. Proposed Rulemaking to Endorse National Fire Protection Association (NFPA) 805, "Performance-Based Standard for Fire Protection for Light Water Reactor Electric Generating Plants" (Open) (SLR/RBE/SD)
- 9.1) Remarks by the Subcommittee Chairman
- 9.2) Briefing by and discussions with representatives of the NRC staff and the Nuclear Energy Institute regarding the proposed rulemaking to endorse NFPA 805 fire protection standard, and related matters.
- 10:00 - 10:15 A.M. **\*\*\*BREAK\*\*\***
- 10) 10:15 - 11:15 A.M. Generic Resolution of Voids in the Concrete Containment (Open) (MVB/RBE/SD)
- 10.1) Remarks by the Subcommittee Chairman
- 10.2) Briefing by and discussions with representatives of the NRC staff regarding the generic resolution of the issue of voids in the concrete containment walls.
- 11) 11:15 - 12:00 Noon. Future ACRS Activities/Report of the Planning and Procedures Subcommittee (Open) (GEA/JTL/SD)
- 11.1) Discussion of the recommendations of the Planning and Procedures Subcommittee regarding items proposed for consideration by the full Committee during future ACRS meetings.
- 11.2) Report of the Planning and Procedures Subcommittee on matters related to the conduct of ACRS business, and organizational and personnel matters relating to the ACRS.
- 12) 12:00 - 12:15 P.M. Reconciliation of ACRS Comments and Recommendations (Open) (GEA, et al./SD, et al.)
- Discussion of the responses from the NRC Executive Director for Operations to comments and recommendations included in recent ACRS reports and letters.
- 12:15 - 1:15 P.M. **\*\*\*LUNCH\*\*\***

- 13) 1:15 - 7:15 P.M. Proposed ACRS Reports (Open)  
 Discussion of proposed ACRS Reports on:
- 13.1) CRDM Cracking of Vessel Head Penetrations and Vessel Head Degradation (FPF/MWW)
  - 13.2) Technical Assessment of GSI-189, "Susceptibility of Ice Condenser and Mark III Containments to Early Failure from Hydrogen Combustion During a Severe Accident" (TSK/RBE/SD)
  - 13.3) Technical Assessment of GSI-168, "Environmental Qualification of Low-Voltage I&C Cables" (GML/TJK/SD)
  - 13.4) Development of Reliability/Availability Performance Indicators and Industry Trends (MVB/AWC/MWW)
  - 13.5) Proposed Rulemaking to Endorse NFPA 805 Fire Protection Standard (SLR/RBE/SD)
  - 13.6) Confirmatory Research Program on High Burnup Fuel (Tentative) (TSK/TJK/MME)
  - 13.7) Technical and Policy Issues Related to Advanced Reactors (Tentative) (TSK/MME)

**SATURDAY, JUNE 8, 2002, CONFERENCE ROOM 2B3, TWO WHITE FLINT NORTH, ROCKVILLE, MARYLAND**

- 14) 8:30 - 10:00 A.M. Proposed ACRS Reports (Open)  
 Continue discussion of proposed ACRS reports listed under Item 13.
- 10:00 - 10:15 A.M. **\*\*\*BREAK\*\*\***
- 15) 10:15 - 11:30 A.M. Discussion of Topics for Meeting with the NRC Commissioners (Open) (GEA, et al./JTTL, et al.)  
 Discussion of topics for meeting with the NRC Commissioners on July 10, 2002.
- 11:30 - 12:45 P.M. **\*\*\*WORKING LUNCH\*\*\***
- 16) 12:45 - 1:45 P.M. Format and Content of the 2003 ACRS Report on the NRC Safety Research Program (Open) (FPF/MME)  
 16.1) Remarks by the Subcommittee Chairman  
 16.2) Discussion of the format, content, schedule, and assignments for the 2003 ACRS report to the Commission on the NRC Safety Research Program.
- 17) 1:45 - 2:45 P.M. Proposed Papers for the Quadripartite Meeting (Open) (GEA, et al./JTTL, et al.)  
 Discussion of proposed papers on the following:
- 17.1) Safety Culture and Safety Management (MVB/DAP)
  - 17.2) Risk-Informed Regulation (GEA/TSK)
  - 17.3) Thermal-Hydraulic Analysis and Code Issues (GBW/VHR)
  - 17.4) Stress Corrosion Cracks in Pressure Retaining Components in Nuclear Power Plants (FPF/WJS)
  - 17.5) Risk Analysis of Spent Fuel Storage (TSK/DAP)

- 18) 2:45 - 3:00 P.M. Miscellaneous (Open) (GEA/JTL)  
Discussion of matters related to the conduct of Committee activities and matters and specific issues that were not completed during previous meetings, as time and availability of information permit.

**NOTE:**

- Presentation time should not exceed 50 percent of the total time allocated for a specific item. The remaining 50 percent of the time is reserved for discussion.
- Thirty-Five (35) copies of the presentation materials should be provided to the ACRS.

# **Ongoing NRC Regulatory Activities at Davis-Besse**

---

Davis-Besse Nuclear Power Station



# **Ongoing NRC Regulatory Activities at Davis-Besse**

---

## **Implementation of IMC 0350 at Davis-Besse**

- **Reactor Vessel Head Degradation represents a significant and complex technical and regulatory issue**
- **Plant is in an extended shutdown with a regulatory hold in effect (CAL)**
- **IMC 0350 enhances the agency's focus on clearly defining and addressing plant specific issues prior to restart**
- **IMC 0350 provides focused and coordinated regulatory oversight of Davis-Besse**

# **Ongoing NRC Regulatory Activities at Davis-Besse**

---

## **IMC 0350 Panel Goals**

- **Provide oversight and assessment of licensee performance during the shutdown and through restart**
- **Assure that restart issues are identified and resolved**
- **Integrate and prioritize agency resources to maximize agency effectiveness and minimize regulatory burden**
- **Provide a single focus to ensure consistent and effective communication with external stake holders**

# **Ongoing NRC Regulatory Activities at Davis-Besse**

---

## **IMC 0350 Panel Goals**

- **Continue oversight after plant restart until plant is returned to the routine Reactor Oversight Process**
- **Create a comprehensive public record of agency decisions and actions**

# **Ongoing NRC Regulatory Activities at Davis-Besse**

---

**License submitted Return to Service Plan - May 21, 2002**

- **Reactor Head Resolution Plan**
- **Containment Extent of Condition Plan**
- **System Health Assurance Plan**
- **Program Technical Compliance Plan**
- **Management and Human Performance Excellence Plan**
- **Restart and Post-Restart Test Plan**

# Ongoing NRC Regulatory Activities at Davis-Besse

---

## Current Inspections

- **AIT follow-up (May - June)**
- **Vessel Head Replacement (May - September)**
- **Extent of Condition - Boric Acid (May - August)**

June 6, 2002

Advisory Committee on Reactor Safeguards  
Nuclear Regulatory Commission

Chairman George Apostolakis

## Members of the Committee

My name is Ann Harris. I have traveled here today by my personal resources without benefit of taxpayer support or government payroll. I appeared before this committee in November, 1995, prior to your support to the Commission for the licensing of TVA's Watts Bar nuclear plant. I moved out of the evacuation zone to a nearby area.

The fact that we are all here again seven years later to hear staff's offering on the Generic Safety Issue 189 and NRC's recommendation is evidence of how things work with Staff and the industry. The Ice Condenser issue may be a generic issue to you, but you should be aware that it is real people's lives you are talking about. This is not a generic issue to me. It is about the nuclear reactors just down the road from where I live and where members of my family and friends live.

I hope that you are as worried about the time factor as I am. I take it as a positive sign that at least something is going to be done even if it is only talk this time. But do we need more talk? I was in this same room seven years ago arguing that Watts Bar was not ready for prime time. That didn't do any good since most of the problems were never fixed, just forgiven. Will we be back talking seven years from now when TVA and Staff admit that safety is still not a prime factor? I think not. TVA will be in the nuclear weapons production business at Watts Bar

and Sequoyah because Staff has never seen an industry license amendment request it did not like.

At the meeting in 1995, one of the subjects I heard about was whether the hydrogen igniters would work. My transcript of that meeting shows that committee member Ivan Catton tried to raise questions about hydrogen igniters and whether the igniters at Watts Bar were adequate to prevent the containment from leaking from hydrogen explosions. In fact, he was asking questions about whether the igniters were located in the right locations in the containment, and now here you are seven years later talking about the same thing. These meetings are like seven year locust visits. They just keep coming.

Committee Members, talking just isn't good enough anymore. Your talking has put lives at stake. It appeared at that 1995 meeting that Mr. Catton was truly interested in whether Watts Bar was safe enough but he was cut off and shut up by the chairman at that time.

What we did not know at that meeting was that the person at Watts Bar responsible for making sure the ice condenser was working correctly before startup had discovered that the screws holding the ice baskets up were defective. TVA devised a scheme to hide Curtis Overall's discovery, then get rid of him, therefore obtaining the Watts Bar license by lying to this Committee and the Commission. After years of investigations and court proceedings the NRC has been forced to levy a fine against TVA. TVA has had so many fines for employee abuse they shed them like water off a duck's back. No big deal!

The most troubling fact is that inspections of the ice baskets that Overall wanted (and was abused for) were never done. We still don't know if they'll stay put if there is an accident at the plant. I have never told anyone that I am an engineer. But I do have common sense. From what I understand, NRC seems to be finally facing up to the fact that ice condensers won't really work-----won't protect the public during an accident. Their idea to fix the problem is to get a little portable generator, from Home Depot or Lowe's, put it on a pick up truck, roll it up to containment, and plug it in. I worked in TVA's nuclear program for 16 years, fourteen at Watts Bar. I have seen some crazy, silly, childish and outlandish things done in the name of safety but I believe this one could take the blue ribbon! I keep having this cartoon run through my head of what would be going on if this generator is needed. There's a hurricane, a severe lighting storm, a terrorist attack, a flood, it is dark, no lights, and no backup power. The shift supervisor has just sent someone to the little shed outback containing the Honda generator with a copy of the combination to the padlock. People living down stream are depending upon this person to know the combination without hunting the paper it was written on. The rain is wetting the paper. His glasses are covered with water. The wind blows the paper away and he starts back inside for another copy. When he gets back, he unlocks the shed, rolls the generator to the containment building, plugs it in and proceeds to get it running. I think that our lives and our property values deserve a little more concern than this NRC proposal. Why are you only recommending this blue light special approach? I feel that the people who live near these plants are getting short-changed, run over and made expendable. The NRC recommendation seems to say the backup power doesn't have to



work if the accident is caused by a flood or an earthquake or a terrorist attack. How do you think this kind of accident is going to happen? Merlin conjuring?

Committee Members, the people living in these communities are real live people whose lives are being talked about here this morning, not just numbers and statistics. Those same people trust the NRC to protect their interests.

I wouldn't be surprised if NRC gets pressure from industry about making changes to the ice condensers to make them actually work. I imagine you will be pushed to pick numbers to re-do your calculations making it impossible to solve the problem that fixes the containment. I am speaking as much to licensing people in the audience as well as this committee and research staff, to keep in mind the interests of the real people living near these plants. Think twice about trying to make industry happy with analyses that say they don't have to fix anything. It is good that NRC has made a start, but so many times good starts end up as dead ends.


I think you should be careful about plans to fix the ice condenser plants depending upon the good will, and good intentions, of the plant owner. Some of the proposed changes, like the cheap portable generator idea, seem to be planning on not having the inspections that you have for other safety equipment. I don't know about other utilities but I know TVA well enough to know that if NRC leaves it all up to them, the generator will not have a motor or a receptacle for the plug. If there's neither inspection nor enforcement, that backup system is not going to be there when it's needed. You see the bigger danger is to have a lot of back and forth talk leading people to think that something's being done to fix the problem. But you and I know that's not

true. And there in lies the problem, misleading is worse than doing nothing.

I would ask that you recommend to the Commission that these ice condensers be fixed to protect the public NOW! You should advise the staff that they should be bending over backwards to protect the public's safety, not bending over to avoid trouble from the industry.

Thank you

Respectfully Submitted

A handwritten signature in cursive script, appearing to read "Ann P. Harris".

Ann P. Harris

341 Swing Loop

Rockwood, TN 37854

(865) 354-4559

By copy of this statement I request that my statement be made a part of the official record.

*Kenneth D. Bergeron, PhD  
17 Tierra Monte NE  
Albuquerque, NM 87122  
e-mail: kenberg@flash.net*

June 3, 2002

Advisory Commission on Reactor Safeguards  
ATTN: John T. Larkins, Executive Director  
U.S. Nuclear Regulatory Commission  
Mailstop T-2 E26  
Washington, DC 20555

Dear Members of the Committee,

Subject: ACRS Review of NRC/RES Proposal on Resolving Generic Issue 189

I have been involved, in one way or another, in the issue of the vulnerability of ice condenser PWRs to Station Blackout events (SBOs) for almost 20 years, beginning with work on NUREG-1150, followed by my managing Sandia's support to NRC's Containment Performance Improvement program in the late 1980s, and continuing with my involvement in the effort to resolve the Direct Containment Heating (DCH) issue for ice condensers in the late 1990s. In regard to this last effort, I was a co-author of "Assessment of the DCH Issue for Plants with Ice Condenser Containments," NUREG/CR-6427, and I carried out the CONTAIN code calculations for the final version of that report. Shortly thereafter, in 1999, I retired from Sandia (though I imply no cause and effect relationship there). Since then I have followed with interest NRC's efforts to deal with the remarkable vulnerability of ice condenser containments to SBOs.

In his transmittal of NUREG/CR-6427 to NRR, Ashok Thadani, NRC's research director, concluded that the study had, in effect, closed the DCH issue for ice condensers but had also brought to light the high vulnerability of these plants to containment failure (primarily from hydrogen combustion) in SBO sequences. He suggested at the time that this vulnerability be addressed through the ongoing efforts to risk-inform 10 CFR 50.44. I will admit to some skepticism about his suggestion at the time, since the vulnerability in question had been well known for at least fifteen years. But NRC's research effort on Generic Safety Issue 189 (GI-189), recently made public by Farouk Eltawila's May 13 memo to the ACRS, has impressed me and my skepticism has abated somewhat.

It has been less than a year since the NRC's Executive Director for Operations announced to the Commission in SECY-01-0162 the establishment of GI-189 to deal with the vulnerability of ice condensers and BWR Mark IIIs to SBOs, and less than six months since the Commission established a high priority on resolving it. The RES staff has

Members of the Committee

-2-

June 3, 2002

accomplished a great deal within these compressed timeframes and should be congratulated on their efforts (and those of the tireless contractors at ISL, BNL, and SNL). Their preliminary work has set the stage for an expeditious resolution of GI-189 and, hopefully, a timely implementation of the needed containment improvements to ice condenser PWRs.

I would very much have liked to attend the ACRS meeting at which GI-189 is to be discussed (June 6-8, 2002) and present my views on the ice condenser-related issues, but previous family commitments during that time frame make that impossible. In this letter, I will summarize some of my viewpoints. David Lochbaum of the Union of Concerned Scientists has offered to present some highlights of my assessment at the meeting, for which I am greatly appreciative, though I hasten to take responsibility for any errors in my review (political or otherwise).

My most important comment is that, while the contractor reports provide a basis for supporting a variety of the backfit options that were evaluated, Mr. Eltawila's letter appears to recommend only the low-cost portable electric generator to power only the igniters. I have long believed that a fix to ice condenser vulnerability must include, in addition, power to the air return fans. Nothing in the NRC's recent analyses has changed that belief. I will provide a detailed explanation of my views below, but I would first like to put that discussion in context by stepping back and looking at some overarching issues related to containment improvements.

#### Why are containment improvements so problematic for the NRC?

It has become apparent to me over the course of my many years of support to NRC that there is an asymmetry between what can be accomplished in the way of improved power plant safety in the 'front end' versus in the 'back end.' There has been no shortage of conflict between the regulator and the industry over improvements to the primary system and associated safety systems, but over time there have been many important safety upgrades as well. Compared to before TMI, we have better pump seals, better system reliability, better steam generators, better water chemistry, and the list can go on and on. By contrast, little has been done to improve containment performance, at least in the past decade or so.

Certainly there have been many changes related to the containment, and some have been based on risk analysis. But almost all such changes are some form or another of regulatory relief. Certainly there have also been innumerable cases of straight regulatory relief for the Nuclear Steam Supply System and its associated support systems, but in addition there have been many 'front end' changes that cost money but improve safety. And those changes continue. Not so for the containment system, in my belief. With very few (and minor) exceptions, risk-based changes to the containment and its operations have been strictly for relief, not improvement. It has become a one way street.

I believe the reason for this difference is simple. The plant owner has much more of a shared interest with the regulator in avoiding conditions that lead to severe accidents.

Members of the Committee

-3-

June 3, 2002

Doing so not only protects the public, but it also preserves the power plant as a source of revenue to the owner. As with TMI-2, a severe accident almost assuredly ends the life of the reactor as a productive capital asset regardless of whether the containment fails or not. This simple fact gives the licensee a double incentive to work with the regulator to reduce the core damage frequency. There is no such double incentive to reduce the conditional containment failure probability.

I think that at one time the NRC implicitly recognized this difference when it introduced the Containment Performance Improvement program in the 1980s. However, the virulence of industry's reaction to proposed improvements to BWR Mark I containments brought that program to an untimely end around 1990, and since then there has been no significant action, as far as I know, related to improvements in containment performance. That is, until Mr. Eltawila's May 13 memo.

I do not say this to put the industry in a bad light. I say it because it is important for NRC to take account of this asymmetry in its approach to containment improvements. It is inevitable, given the differences in industry's incentives, for it to be more difficult to gain industry consensus on containment improvements than on improvements to the front end. This doesn't mean the NRC should be satisfied with less progress. Defense in depth is important, and the meaning therefore is that NRC should work harder to accomplish such improvements, expect more resistance from licensees, and bring a firmer resolve to the deliberations.

Having now exercised my private citizen right to express my views, soapbox style, I will turn to the RES recommendations on GI-189.

**The low-cost backfit option recommended by RES is inadequate and possibly counterproductive.**

The Eltawila memo provides in its three attachments a preliminary technical basis for evaluating potential backfits to ice condenser containments (as well as Mark III containments, but I will have no comments on the Mark III issue). Attachment 1 is a brief cost study by Information Systems Laboratories, Inc. (ISL) of four basic options for adding equipment to provide backup power to containment safety systems during SBO conditions. Attachment 2 is an assessment by Brookhaven National Laboratory (BNL) of the averted costs (or benefits) that might accrue from implementation of a containment fix for the SBO vulnerability, which evaluates the dollar value of the benefits for a matrix of cases involving different plants and different analysis assumptions. Finally, Attachment 3 is a very preliminary report from Sandia National Laboratories (SNL) on MELCOR code calculations of the effectiveness of some of the backfit options.

Certainly one thing that is needed is a more integrated presentation of these disparate results, and I would hope that RES plans to prepare such a report in the future. However, given the time pressure for addressing GI-189 I can understand the decision to make available the research results in this fragmented form at this time.

Members of the Committee

-4-

June 3, 2002

By studying the BNL and ISL reports together, one can see that a number of the backfit options for ice condensers easily pass a cost benefit test for a range of analysis assumptions. For example, in Table 2-12 of Attachment 1 we see that the option involving pre-staged emergency backup power for igniters and air return fans has a total cost of \$313,300 for a single unit of a dual unit ice condenser plant. Table 6 of Attachment 2 gives lifetime benefits ranging from \$404,000 to \$6,730,000, depending on analysis assumptions. That it is cost beneficial to fix the ice condenser containments is not surprising to me, since the inadequacy of these plants in SBO conditions is notorious, and the risk significance of SBOs is high (at least for some plants). What is surprising is that Eltawila's memo, which is the only place any integration of the three reports occurs, seems to recommend only the low-cost option labeled "1b," which involves an off-the-shelf portable generator to provide backup power to the igniters only. Several other options that also have favorable cost/benefit numbers are not mentioned in the recommendations. Knowing that there will be resistance from industry to any of these proposals, I find it hard to understand why RES would choose to endorse only the 'el cheapo' option.

More important, I believe the low-cost option is inadequate to deal with ice condenser vulnerability to SBOs. In this, I agree with Duke Power's decision in their SAMA submittals on McGuire and Catawba to evaluate backup power to igniters only in conjunction with backup power to the air return fans. At a public meeting between the Nuclear Energy Institute and the NRC in September 2000,<sup>\*</sup> industry representatives criticized NRC's assertion that powering igniters only would be sufficient—they said you need to power *both* igniters *and* fans to control the hydrogen burn threat in ice condensers, and they were right.

Far too little importance has been attributed in the RES analysis to the possibility of detonations in the ice chest. What I am worried about is the possibility that in the absence of forced mixing via air return fans, a typical SBO scenario would lead to the following conditions: very high hydrogen concentrations (say, over 20%) throughout much of the ice chest; quite low concentrations (under 5%, say) in the upper plenum and containment dome because there has been little leakage through the upper deck doors until this point in time, and steam inerted conditions in the lower compartment. Then, when the concentration in the upper plenum finally becomes combustible, one or more burns occur there, resulting in upper deck doors opening and closing, perhaps in succession many times, which brings out a plume of much more combustible gas into the upper plenum from the ice chest. This plume would then ignite and carry the flame back to the ice chest, where the deflagration would transition to detonation because of the wide variety of channeling and reflecting surfaces there. A global detonation over most of the ice chest is something I don't even want to think about. Containment failure could occur either through missile generation or dynamic overloading of the containment structure.

---

<sup>\*</sup> "SUMMARY OF SEPTEMBER 28, 2000, PUBLIC MEETING WITH NUCLEAR ENERGY INSTITUTE (NEI) AND OTHER INTERESTED STAKEHOLDERS REGARDING RISK-INFORMED CHANGES TO 10 CFR 50.44", Memo from Alan S. Kuritzky, NRC/PRAB to Mark A. Cunningham, chief NRC/PRAB dated February 28, 2001.

Members of the Committee

-5-

June 3, 2002

I am not the first person to worry about this scenario, of course, but my point is that I don't think today's calculational tools can help NRC develop the confidence it needs to order a mandatory igniters-only backfit. I am glad NRC has commissioned Sandia to carry out a broad matrix of code calculations on hydrogen distribution, because they shed light on the overall issue, but there are some aspects of the problem that I believe defy accurate computational analysis. This means that even an expanded program of calculation will still leave substantial residual uncertainty about the potential for highly destructive detonations. The aspects that are problematic are the following:

1. Control volume codes like MELCOR and CONTAIN are not suitable for predictive modeling of natural convection in open regions that are larger than the characteristic dimensions of the circulation patterns. The governing equations ignore the convection of momentum, for example. Such codes are notoriously incapable of reliably modeling stable stratification, because they artificially diffuse mass in the absence of any driving force (an effect that some people call numerical diffusion). Results are highly sensitive to nodalization, far more so than with true Navier-Stokes solvers. For these reasons I have always been privately skeptical of NRC's use of control volume codes to address hot leg failure due to natural circulation in SBO-induced core meltdowns. It is true that skilled analysts can devise nodalizations that reproduce flow patterns resembling those seen in experiments, but I don't think that leads to *predictive* capabilities for shapes and scales far different from the tests.
2. The unique phenomena occurring in ice chests make such calculations even more uncertain. Hot air/hydrogen/steam mixtures will be affected dramatically and in numerous ways by the ice: first through condensation of steam, which creates a bulk flow towards the ice surface called Stefan flow; second through cooling, which affects buoyancy-related flow; and third through changes to the mean molecular weight of the gas mixture due to condensation of steam, which is intermediate in molecular weight between the lightest of the gases, hydrogen, and the heavier gases that are the principal components of air (nitrogen and oxygen). These various effects will either reinforce each other or oppose each other, depending on conditions. And the processes are occurring over a complex spatial distribution of ice surfaces, not just a simple boundary.
3. One might argue that these effects will serve to increase mixing compared to the corresponding hydrodynamic problem in the absence of ice, but it is also possible that under some conditions the effects might be to stabilize stratification, inhibit the formation of large convective loops, and in general reduce vertical mixing. Similarly, the pressure pulses originating from releases from the primary system are dampened by the effects of the ice chest to the extent that the upper deck doors do not open as often or as far as would be expected in the absence of ice. The result is increased isolation of the upper plenum (where the igniters are) from the ice chest (where most of the hydrogen is if the lower containment is steam inerted).
4. The problem is further complicated by the fact that the ice/gas boundaries are, over time, responsive to the gas flow, resulting in highly uncertain spatial

Members of the Committee

-6-

June 3, 2002

configurations of unmelted ice. The Finns have reported considerable unevenness of melting in their ice condenser test facilities when mixing processes are weak. The industry has long discussed 'channeling' and 'melt-through' as issues related to the design basis accident—one of the important roles of the air return fans is to insure relatively uniform melting.

These difficulties combine to create very large uncertainties in code predictions of hydrogen concentrations, with or without power to the igniters. With backup power to the air return fans, the NRC has a wonderful opportunity to reduce the uncertainty, and at a cost much cheaper than building a code that can accurately calculate the problem!

When I argue that there is residual uncertainty, I am not saying that there might be a 1% or 10% residual failure probability; I am saying that this fix might be ineffective 50% or 90% of the time. There is little way of knowing what its effectiveness will be *unless you ensure mixing*.

The low-cost option endorsed by RES might even make the accident worse, by causing a detonation-induced containment failure to occur many hours earlier than it might have in the absence of forced ignition. I would guess that the effect of this possibility on the risk picture would be modest, but I don't know. I suspect RES would not feel very comfortable asking one of its contractors to evaluate this downside of a mandated backfit—it could very possibly be used as an excuse to oppose the change. As with medicine, the first rule should be 'do no harm.'

The arguments in favor of providing power to the air return fans are compelling, I believe. The cost benefit numbers look good if reasonable assumptions are made about averted costs. The fans are already there, and they play the role of allowing the ice and the igniters to successfully accomplish their functions. Moreover the potential that the accident is exacerbated by the 'fix' is substantially eliminated.

I strongly encourage the ACRS to endorse the overall approach RES has initiated, but to insist on the additional assurance provided by backup power to the air return fans in ice condenser containments.

**The claim in the Eltawila memo that analyses in NUREG/CR-6427 are bounding is false.**

Page 3 of the Eltawila includes the statement "Note that in Attachment 2, the ice condenser averted cost estimates used relevant information from NUREG/CR-6427, and it appears to provide upper bound estimates as compared to plant-specific best estimates." This statement is untrue and misleading.

NUREG/CR-6427 was part of a long program (initiated around 1992) intended to resolve the DCH issue at U.S. nuclear power plants. Throughout that program the approach was best estimate and plant specific. Having been intensely involved in the ice condenser



Members of the Committee

-7-

June 3, 2002

DCH project for several years, and as a co-author of NUREG/CR-6427, I can say that there was a mix of assumptions used for the analyses that ranged from conservative to optimistic, and the end results can't be characterized as occupying any particular point in the spectrum.

For example, the plant-specific containment fragility curves (which dramatically affect the bottom line, of course) were taken from industry IPEs, which have never been audited by the NRC and which are almost certainly optimistic. (I say this because NRC's test program on containment failure has amply demonstrated the sensitivity of code results to nodalization details concerning penetrations, weldments, and other important locations for stress concentrations. It would not be expected that the industry's analysts would intentionally make assumptions that would exaggerate the potential for failure of their containments.)

In addition, certain assumptions about initial conditions in the core were also probably optimistic. Other assumptions, such as our treatment of steam spike, were probably pessimistic (or conservative), having been performed under severe time pressure. While I certainly wish that there had been time and funding to do more thorough analyses for the project, it is simply untrue to characterize the results as bounding or even conservative, regardless of how unpopular some of the results are with industry. The overall picture that emerged from NUREG/CR-6427 about ice condensers' vulnerability to SBO was qualitatively no different from the results of many earlier studies. It is because of that fact that GI-189 was established.

In the September 2000 meeting mentioned earlier, industry representatives complained that NUREG/CR-6427 was only a 'scoping study' and should not therefore be used as the sole basis for deciding on containment backfits. NRC responded that their recommendations were also based on other studies. Both sides were right. But it is inappropriate now for NRC to rewrite history by implying that the NUREG/CR-6427 was bounding in nature.

#### **Final Observation.**

While there is a clear need for additional study to support resolution of GI-189 (such as whether backfits that are not qualified for external event-induced SBOs would succeed anyway), I hope that the NRC proceeds into the implementation phase in a timely way. The RES staff has made a good start in establishing the technical basis for resolving this important issue. But I would like them to set aside their pre-conceived notions of what is the right answer and let the scientific facts speak for themselves. In this regard, I reiterate the following Observation from the 1998 ACRS review of the NRC Research program: "The Office of Nuclear Regulatory Research (RES) routinely relies on "assumed" solutions to address technical issues."<sup>1</sup>

---

<sup>1</sup>Advisory Committee on Reactor Safeguards, USNRC, "Review and Evaluation of the Nuclear Regulatory Commission Safety Research Program", NUREG-1635 vol. 1, p. 30 (June 1998).

Members of the Committee

-8-

June 3, 2002

There is an old saying, "if it's not broke, don't fix it." I'd like to propose a new version to the NRC: "if you're going to fix it, then *fix it!*"

I would be glad to discuss any questions the Committee or others at NRC might have in regard to these comments.

Sincerely,

A handwritten signature in cursive script, appearing to read "Kenneth Bergeron".

Kenneth D. Bergeron

# **Technical Assessment of GSI-189**



## **Advisory Committee on Reactor Safeguards**

**JUNE 6, 2002**

**Allen Notafrancesco, Task Manager  
Safety Margins and Systems Analysis Branch  
Division of Systems Analysis and Regulatory Effectiveness  
Office of Nuclear Regulatory Research**

# **GENERIC SAFETY ISSUE 189: “SUSCEPTIBILITY OF ICE CONDENSER AND MARK III CONTAINMENTS TO EARLY FAILURE FROM HYDROGEN COMBUSTION DURING A SEVERE ACCIDENT”**

- **Risk-Inform 10 CFR 50.44:**
  - “Status Report” in SECY-00-0198, September 14, 2000
  - “Staff Plans” in SECY-01-0162, August 23, 2001
  - SRM, December 31, 2001.....Resolve GSI-189 Expeditiously
- **GSI-189:**
  - MD 6.4, Passed GI Screening- February 2002
  - Generated Task Action Plan
  - Currently Completing Technical Assessment

## **AFFECTED DOMESTIC REACTORS**

- **PWR Reactors with Ice Condenser Containments:**

9 Reactors; four dual unit sites (McGuire, Catawba, D.C. Cook, and Sequoyah) and one single unit site (Watts Bar)

- **BWR Reactors with Mark III Containments:**

4 Reactors; four single unit sites (Grand Gulf, Perry, Clinton & River Bend)

- **Plants Retrofitted in 1980s with AC Powered Igniters to mitigate the consequences in which copious amounts of Hydrogen are produced (10CFR50.44)**



## **GSI-189 Technical Assessment**

**Objective:** For SBO events, determine whether an additional back-up power supply to igniters is justified.

- **Perform a Cost-Benefit Analysis guided by NRC prescribed methods**
  - **For Ice Condensers, perform an up-dated severe accident analysis to demonstrate that igniters alone are adequate**
- **Execute the Task Action Plan**
- **Brief ACRS**
- **Send findings to NRR**

## **GSI-189 TASK ACTION PLAN**

- **Approach for expeditious resolution:**
  - **Use Existing Studies**
  - **Assemble Support Team w/contractor assistance**
    - **Cost Analysis; REAHFB w/ISL**
    - **Benefits Analysis; PRAB w/BNL**
    - **Plant Analysis; SMSAB w/SNL**



## **COST ANALYSIS**

### **Back-up Power Supply Configurations Considered:**

- **Pre-Staged Design**
  - **Dedicated diesel generator (in its own protected enclosure) and its auxiliary equipment in place**
- **“Off-the-Shelf” Option (low cost)**
  - **Use of a portable diesel generator with minimal permanent plant modifications**

**Results: Low cost option is about 1/3 of pre-staged but may have slightly lower functional reliability, however low cost option may provide greater availability in response to external initiating events.**

# **RESPONSE TO EXTERNAL EVENTS**

- **PRE-STAGED DESIGN**

- If designed for external events, cost would double

- Expect survivability to be available for a reasonable subset of external events

- **LOW COST OPTION**

- No permanent structure and set-up would occur after the initial impact of the external event

- Portable diesel may come from multiple diverse locations

- These attributes should allow for increased likelihood of functionality in response to external events

## **COST BREAKDOWN (ISL Report):**

	<b>Low Cost</b>	<b>-----</b>	<b>Pre-Staged</b>	<b>-----</b>	<b>w/Ext-Qual.</b>	<b>-----</b>
<b>Attribute</b>	<b>Ice Cond. Unit</b>	<b>Mark III Unit</b>	<b>Ice Cond. Unit</b>	<b>Mark III Unit</b>	<b>Ice Cond. Unit</b>	<b>Mark III Unit</b>
<b>Industry *</b>	\$57-76K	\$78K	\$135-178K	\$193K	\$271-350K	\$385K
<b>NRC **</b>	\$13K	\$13K	\$13K	\$13K	\$13K	\$13K
<b>Total</b>	\$70-89K	\$91K	\$148-191K	\$206K	\$284-363K	\$398K

**\* Variability of ice condensers plants are mainly due to consideration of shared costs relevant to dual unit sites.**

**\*\* Assumed rulemaking is linked to on-going 10CFR50.44 effort.**

# BENEFIT ANALYSIS

## ICE CONDENSER CONTAINMENTS:

As part of license renewal, severe accident mitigation alternatives (SAMAs) are to be considered;(from NUREG-1437,Supplements 8 & 9)

- Benefits for Hydrogen Control in SBO events, all early failures are averted:

Plant	Based on most recent plant specific PRA*	Based on conditional containment failure probabilities from NUREG/CR-6427
McGuire	\$178 - 248K	\$678K
Catawba	\$236 - 329K	\$387K

\* Variation in costs due to sensitivities in discount rate (3-7%) and years of remaining life (20-40 years)

- BNL report confirmed that using NUREG/CR-6427, averted costs are somewhat greater

# **BENEFIT ANALYSIS**

## **MARK III CONTAINMENTS:**

- BNL used Grand Gulf for its analysis:
  - SBO CDF from IPE
  - Containment Performance from NUREG-1150
- Benefits for Hydrogen Control in SBO events, all early failures are averted = \$40-68K for Grand Gulf (40 yrs @ 3-7% discount rate)
  - Unique Risk Profile; high pressure SBO dominates

# BENEFIT ANALYSIS


## OTHER MARK III CONTAINMENTS:

Plant Name	SBO frequency ratio	2000 population ratio (estimated)	Product of ratios
Grand Gulf	1.00	1.00	1.00
Clinton	1.31	3.14	4.13
Perry	0.30	7.53	2.27
River Bend	1.81	3.14	5.68

Therefore, benefits for Hydrogen Control in SBO events, could exceed \$200K (40 yrs @ 7% discount rate)

# COST BENEFIT COMPARISON

## BENEFITS:



## COSTS:

## **COST BENEFIT SUMMARY**

(1) Focusing on the plant specific averted cost estimates for ice condenser plants, the low cost equipment option is clearly cost beneficial and provides for more overall flexibility in response to external events.

(2) For Mark III plants, the low cost back-up power supply option is marginally cost-beneficial.

(3) Since the proposed mitigative enhancement passes the back-fit cost beneficial test, we recommend that further regulatory action is warranted.



## ICE CONDENSER CONTAINMENT PERFORMANCE

- For non-SBO events, Igniters and Air Return Fan (ARF) functional and/or sprays
- For SBO events, need to investigate the feasibility of only igniters
- Performed MELCOR Scoping Study
  - Use new 10CFR50.44 H2 Source Terms
  - Pursuing key parametric sensitivities

## MELCOR SCOPING STUDY CONCLUSIONS

- Igniters alone are effective in controlling Hydrogen build-up
- Marginal improvement if one ARF is included, however fans accelerates time of ice melt-out
- Continuing ice condenser plant response uncertainty study, e.g., H<sub>2</sub> source terms, burn propagation, etc.

## **Response to Letter to ACRS Dated June 3, 2002**

### **Consideration of Adding Back-Up Power to ARF...Basis:**

- Arbitrary assumptions of limiting conditions & sequences of events are extreme
- Ease of DDT occurring in the ice chest is not demonstrated

### **Why Back-Up Power to Igniters Only are Sufficient....**

- 30+ igniters distributed through out containment will assure lean ignition and promote diffusive burning

- Direct lower compartment burning may occur; provides for propagation to the ice chest and enhances mixing due to deflagration induced turbulence
- More refined modeling (e.g., CFD) would reveal larger spatial gradients within a compartment than CV codes. Induce earlier lite-off than predicted in CV codes, effectively leading to leaner burns....
- Burning at leaner concentrations will promote gas circulation including the occurrence of diffusion flames in the ice chest
- Ice bed geometry is not conducive to create unconditional DDT; relatively open
- Downside to ARF
  - more rapid ice bed melt-out
  - more complicated and costly addition

# MRP Update to ACRS June 6, 2002


Larry Mathews  
Southern Nuclear  
Chairman, MRP Alloy 600 Issue Task  
Group


ACRS 6/6/02.1

EPRI



# Susceptibility Ranking





# Crack growth rate for thick-section Alloy 600 material exposed to PWR primary water

John Hickling, EPRI  
for the  
MRP Alloy 600 Issue Task Group

ACRS 6/6/02.3



# Derivation of MRP CGR Curve

Heat Rank		Material Supplier	Product Form	Number of Data Points	Log Mean Power-Law Constant $\alpha$ at 325°C (617°F)	
					SI Units <sup>1</sup>	English Units <sup>2</sup>
1		Creusot-Imphy	Forged Bar	21	6.01E-12	8.32E-03
2		B&WTP	Thick-wall Tube	4	5.16E-12	7.15E-03
3		French Supplier	CRDM Nozzle	9	5.08E-12	7.03E-03
4		Tecphy	Rolled Bar	7	4.96E-12	6.88E-03
5		B&WTP	Thick-wall Tube	4	4.71E-12	6.52E-03
6		VDM	Rolled Plate	2	3.92E-12	5.43E-03
7		Schneider-Creusot	Forged Bar	1	3.19E-12	4.42E-03
8		B&WTP	Thick-wall Tube	32	3.07E-12	4.25E-03
9		B&WTP	Thick-wall Tube	1	2.65E-12	3.68E-03
10		Arbed	CRDM Nozzle	3	2.01E-12	2.79E-03
11		Creusot-Imphy	Forged Plate	1	1.94E-12	2.69E-03
12		Schneider-Creusot	Forged Bar	1	1.62E-12	2.24E-03
13		Huntington	Thick-wall Tube	1	1.37E-12	1.90E-03
14		Huntington	Rolled Plate	14	1.29E-12	1.78E-03
15		<i>Not Listed</i>	Forged Bar	2	1.02E-12	1.41E-03
16		Sumitomo Metal	Thick-wall Tube	1	1.01E-12	1.40E-03
17		Sandvik	Thick-wall Tube	27	1.00E-12	1.39E-03
18		Standard Steel	Forged Bar	1	9.09E-13	1.26E-03
19		Huntington	Thick-wall Tube	12	7.21E-13	9.99E-04
20		<i>Not Listed</i>	Forged Bar	3	6.31E-13	8.74E-04
21		Tecphy	Rolled Bar	1	5.18E-13	7.18E-04
22		Huntington	Plate	1	4.97E-13	6.89E-04
23		Creusot-Ondaine	Forged Bar	4	4.44E-13	6.15E-04
24		Inco	Rolled Bar	1	2.51E-13	3.48E-04
25		Sandvik	Thick-wall Tube	2	2.18E-13	3.03E-04
26		Huntington	Thick-wall Tube	2	1.93E-13	2.67E-04
<i>Log-Mean for All Data Points</i>				158	1.96E-12	2.72E-03
<i>Log-Mean of Heat Log-Means</i>				26 Heats	1.34E-12	1.86E-03


ACRS 6/6/02.4

EPRI






# Derivation of MRP CGR Curve



# Derivation of MRP CGR Curve



# Application of MRP CGR Curve

- The MRP recommended curve is intended for disposition of detected PWSCC flaws in thick-walled Alloy 600 components exposed to normal PWR primary water
- Thus it is directly applicable to **axial ID flaws** detected in CRDM nozzle pressure boundary base material and to flaws below the J-groove weld
- Its use at low crack-tip stress intensity factors ( $< \text{approximately } 15 \text{ MPa}\sqrt{\text{m}}$ ) would involve assumptions not currently substantiated by actual CGR data for CRDM nozzle materials
- In practice, however, K values will already be above this


# **Probabilistic Fracture Mechanics Analysis of CRDM Nozzles**

**Presented at:  
ACRS Meeting  
Rockville, MD**

**From Presentation by:  
Dr. Peter C. Riccardella  
Structural Integrity Associates**

 ***Structural Integrity Associates, Inc.***

# Benchmarking of PFM Results with respect to B&W Plants



ACRS 6/6/02.9




# Technical Basis for Inspection Plan

## - Basic Concept -

- Start with “benchmarked” analysis parameters from B&W plant analysis
- Analyze plants at various head temperatures
- Set risk categories based on probability of Net Section Collapse (per year) and cumulative leakage probability
- Set inspection intervals based on effect of various inspections on probability of Net Section Collapse (per year)

# Correspondence of Susceptibility Categories to EDYs




# Inspection Frequency Runs: Probabilities of Detection

- Bare Metal Visual Inspections (BMV)
  - Initial POD = 0.6
  - POD for Subsequent Exams =  $0.2 \times \text{Initial POD}$  (when Leakage missed)
- Non-Destructive Examinations (NDE)
  - POD =  $f(\text{crack depth})$  per EPRI-TR-102074<sup>1</sup>
  - 80% Coverage Assumed

<sup>1</sup>Dimitrijevic, V. and Ammirato, F., "Use of Nondestructive Evaluation Data to Improve Analysis of Reactor Pressure Vessel Integrity, " EPRI Report TR-102074, Yankee Atomic Electric Co. March 1993



# Effect of Inspections Upon Entering Moderate Category



ACRS 6/6/02.13

EPRI



# Technical Assessment of Davis-Besse Degradation

Prepared by:

G. White

C. Marks

S. Hunt

Dominion Engineering, Inc.

ACRS 6/6/02.14

EPRI



# Purpose

- The purpose of the technical assessments is to complement plant experience in answering the following questions:
  - If a significant amount of RPV head material loss occurs, will it be detectable visually from above the head (either directly or through the presence of deposits)?
  - Is there a period of time following initiation of a through-wall leak for which there is assurance that no unacceptable reactor vessel head corrosion will occur?
- In addition, the technical assessments also address current questions regarding the progression of material loss mechanisms (i.e., understanding of degradation progression)

# Approach

- The basic approach is to examine how the various potential material loss mechanisms vary as the leak rate is increased from  $10^{-6}$  to 1.0 gpm and the initial tight nozzle annulus becomes a large cavity through material loss. Evaluations focus on:
  - Thermal-hydraulic environment
  - Chemical environment
  - Properties of boric acid and boron compounds
  - Relevant experimental results and plant experience
- The leak rate is expected to be the key parameter:
  - Expansion cooling increases with leak rate, potentially permitting a liquid film to reach the top head surface
  - Increasing leak rates result in higher velocities and potentially erosion or flow accelerated corrosion


# Approach (continued)

- The leak rate also determines the amount of boric acid deposits that exit the pressure boundary
- The results of corrosion and erosion rate evaluations are used to bound:
  - The timeframe for significant degradation
  - The volume of low alloy steel material loss versus the volume of deposits produced

# Degradation Progression

## Leak Rate is Main Controlling Parameter

PRELIMINARY



# Inspection Plan

## PWR Reactor Pressure Vessel Head Penetrations

ACRS 6/6/02.19

EPRI





# Status of Inspection Plan

- Inspection Plan and technical bases were presented to NRC staff on May 22
  - Technical Bases documents will be provided to NRC in June 2002.
- Comments received in following areas
  - Plan should address inspections for both wastage and nozzle ejection issues
  - Timeframe for wastage development
  - Leakage past tight interferences
  - Policy issue of detecting degradation through leakage
  - Address replacement head



PWR RPV Head Penetrations Inspection Flowchart





**\*\*** 100% of the CRDM/CEDM penetrations and associated J-groove welds or portions thereof that can be examined without incurring undue hardship


*Advisory Committee on Reactor Safeguards*  
*Update of the*  
*Davis-Besse Nuclear Power Station*  
*Reactor Pressure Vessel Closure Head*  
*Activities*

*June 6, 2002*

1



# Agenda



## Introduction

- Jim Powers

## Update of RPV Closure Head

### Field Activities

- Mark McLaughlin

## RPV Closure Head Replacement

- Bob Schrauder

## Root Cause Analysis

- Steve Loehlein

## Concluding Remarks

- Jim Powers



*Update  
of RPV Closure Head  
Field Activities*


*Mark McLaughlin  
Field Activities Team Leader*



**FENOC**  
Field Nuclear Closure Company

*Davis-Besse Nuclear Power Station*

# *Abrasive Water Jet*




2002. 5. 7/12:26

4

**FENOC**  
Fine Erosion Non-Contact



*Davis-Besse Nuclear Power Station*

# *Area Removed from RPV Closure Head*





# Underneath RPV Closure Head




**FENOC**  
First Energy Nuclear Operating Company

*Davis-Besse Nuclear Power Station*



# *RPV Closure Head Cutout*




7



# *Sample Plan*

- Phase 1
  - Corrosion products/boric acid deposits from top of head
  - Deposits scraped from CRD nozzle 3 below the flange
  - Draft report issued for Davis-Besse review
- Phase 2
  - Corrosion products/boric acid deposits from nozzle 2 removal
- Phase 3
  - Nozzle 3 and nozzle 3 corrosion area
  - Nozzle 2



# *RPV Closure Head Cutout*




9



# *Nozzle 3 Cutout Cladding Interface*



10






*Reactor Pressure Vessel Closure Head  
(RVPCH)  
Replacement*


*Bob Schrauder  
Engineering Services*



# *RPVCH Replacement Considerations*




- The Midland RPVCH is
  - Similar in design to the Davis-Besse RPVCH
  - Readily available
  - Not contaminated



# *Replacement RPVCH*

- Midland RPVCH was fabricated by Babcock and Wilcox
  - Manufactured to ASME Boiler & Pressure Vessel Code Section III, Code Class A, 1968 Edition, Summer 1968 Addenda
  - Accepted by Consumers Power and an Authorized Nuclear Inspector as an acceptable ASME component
  - Hydrostatically tested at 3125 psig per ASME Code Requirements



# *Replacement RPVCH*


- Framatome-Advanced Nuclear Power (FRA-ANP) has purchased Midland RPVCH and is compiling/validating the ASME Code Data Package
- FRA-ANP is reconciling the Midland RPVCH against Davis-Besse design requirements
- FRA-ANP activities are governed by their safety-related Quality Assurance program, including 10CFR21 reporting






*Replacement RPVCH Comparison  
to Davis-Besse RPVCH*

	<u>Davis-Besse</u>	<u>Midland</u>
<i>Material of Construction</i>		
Closure Head	SA-533, GR B Cl 1	Same
Closure Head Flange	SA-508, Cl 2	SA-508-64, Cl 2
CRDM Nozzle	Inconel SB-167	Same
CRDM Flange	SA-182, F-304	Same
<i>Design</i>		
Pressure	2500 psig	Same
Temperature	650 degree F	Same




# *Replacement RPVCH CRD Nozzles*


- Midland's Control Rod Drive (CRD) nozzles are similar to Davis-Besse
  - 68 Nozzles: Material Heat M7929
  - 1 Nozzle: Material Heat M6623
- Alignment of control rods to RPVCH nozzles is consistent with original Davis-Besse design



# *Replacement RPVCH*




- Minor machining of 4 out of 8 vessel-to-head keyway surfaces is required
- The Midland CRDM flange indexing pin hole locations will be modified to match the proper Davis-Besse azimuth-orientation




## Replacement RPVCH

- Minor differences in RPVCH O-ring design
  - O-ring grooves are slightly different requiring the use of smaller diameter O-rings (0.455 in. vs 0.500 in.)
  - New O-rings will be installed



# Examinations of Replacement RPVCH




# *Examinations of Replacement RPVCH*

- Examinations to supplement ASME Code Data Package:
  - Visual examinations
  - Radiography (RT) of flange-to-dome weld
    - Lifting attachments prevented full coverage
  - RT of nozzle-to-flange welds
  - PT examination of the CRDM nozzle J-groove welds




# *Examinations of Replacement RPVCH*

- Preservice Inspections
  - Magnetic Particle (MT) examination of flange-to-dome weld
  - Ultrasonic (UT) examination of flange-to-dome weld
  - Liquid Penetrant (PT) examination of peripheral CRDM nozzle-to-flange welds



# *Examinations of Replacement RPVCH*


- Additional Non-Destructive Examinations
  - Chemical smears
  - Baseline UT of CRD nozzles
  - Eddy Current Testing (ET) of CRD nozzles






# *Installation of the Replacement RPVCH at Davis-Besse*

- Davis-Besse Containment Building will require temporary access opening
- Original RPVCH will be moved outside Containment Building for storage and/or disposal
- Davis-Besse Service Structure will be used
- Inspection ports will be installed on replacement support skirt



# *Installation of the Replacement RPVCH at Davis-Besse (continued)*


- Original Davis-Besse control rod location and core configuration will be used
  - Existing CRD Mechanisms will be used
  - CRD Mechanisms nozzle flange split nut ring modification will be performed
  - Upgraded gasket design will be incorporated



# *Root Cause Investigation*


*Steve Loehlein*

*Root Cause Investigation Team Leader*



# *Key Questions*


- Was there a new mechanism that caused this degradation?
- Was there adequate guidance/knowledge available to have prevented the degradation to the RPV closure head?



## *Key Conclusions*

- The degradation to the RPV closure head was caused by Primary Water Stress Corrosion Cracking (PWSCC) of the Control Rod Drive (CRD) nozzle which led to leaks that were undetected allowing boric acid corrosion to occur
- The existing guidance/knowledge was adequate for preventing unacceptable RPV closure head degradation from CRD nozzle leaks

# Timeline of Key Events



# *Concluding Remarks*

# **NRC Staff Activities on Vessel Head Penetration Nozzle Cracking and Vessel Head Degradation**



Bill Bateman, Branch Chief  
Materials & Chemical Engineering Branch  
301-415-2795

ACRS Full Committee Presentation  
June 6, 2002



# NRC Staff Activities

- Assess Current Status of PWRs
  - Bulletins 2001-01 and 2002-01
  - Information Notice 2002-13
- Effective “Future” Management
  - Proposed New Generic Communication - Interim Inspection Guidance
  - Long-term Inspection Requirements - Technical Basis
- Davis-Besse Specific
  - Manual Chapter 0350 Panel
  - Lessons Learned Task Force





**United States Nuclear Regulatory Commission**

# **Technical Assessment of GSI-168 Environmental Qualification of Low- Voltage I&C Cables**

**Presentation to Advisory Committee on Reactor  
Safeguards**

**Office of Nuclear Regulatory Research  
N. Chokshi and S. Aggarwal, Division of Engineering Technology  
June 6, 2002**



## **United States Nuclear Regulatory Commission**

### **Purpose:**

- **To presents to the ACRS the technical assessment of GSI 168 and request a letter from the Committee.**

### **Process**

- **Technical Assessment is complete.**
- **RES plans to incorporate the ACRS comments.**
- **Forward the Technical assessment to Director, NRR by June 30, 2002 (copy to EDO).**



**United States Nuclear Regulatory Commission**

# **Overview of the Technical Assessment:**

## **Technical Assessment Based On:**

- 1. EQ Literature Review**
- 2. LOCA Tests**
- 3. Condition Monitoring Tests**
- 4. Interaction with the Nuclear Industry**
- 5. Risk Insights**

**Test Results (Items 1- 3) were presented to the ACRS on October 6, 2000.**

- The qualification criterion is “zero” failures based on testing of a single prototype.**



## United States Nuclear Regulatory Commission

# STEPS IN LOCA TESTS

- **Preaging: Thermal & Radiation-** to simulate end of life conditions.
- **LOCA Exposure:** To simulate postulated DBE.
- **Post LOCA Simulation Test:** To demonstrate an adequate margin of safety by requiring mechanical durability.



## **United States Nuclear Regulatory Commission**

### **Research Results:**

- **Failures of certain I&C cables in NRC tests.**
- **Failures of single conductor bonded Okonite cables.**
- **No single condition monitoring technique is effective to detect degradation- combination of techniques could be used.**
- **Visual Inspections proven to be useful.**



# United States Nuclear Regulatory Commission

## RISK

- **Results indicate that benefits from reducing the cable failure probabilities to zero are modest.**
- **The state- of- the art of incorporating cable failures into PRA is still evolving.**
- **KEY ASSUMPTION: Operating environments are lower than or equal to those assumed during qualification.**
- **Uncertainties arise from sparse data, uncertainty of applicability of experiments, and human error probabilities.**
- **Complete coupling between redundant trains was assumed.**



## **United States Nuclear Regulatory Commission**

# **Interaction with Nuclear Industry**

- **I&C cables have not experienced any significant aging. In limited cases of hot spots, several options are exercised (early replacements, modification of environments, or some kind of condition monitoring).**
- **Aging evaluation are ongoing throughout the plant life.**





## **United States Nuclear Regulatory Commission**

### **60 Years Aging Assessment**

- **In NRC tests 8 out of 12 cables failed the Post LOCA Simulation Test.**
- **Some of these cables may not have sufficient margins beyond the 40 years of qualified life.**
- **If the operating conditions are less severe than the qualification parameters, the margins could be used to extend the life.**
- **Knowledge of the environment for cables continues to be essential.**



## United States Nuclear Regulatory Commission

### Summary of RES Findings:

- **Qualification test programs include numerous conservative practices.**
- **Failures in NRC tests indicate that some cables did not meet qualification criteria and the margins are reduced.**
- **Knowledge of the operating environment for cables is essential.**



---

## United States Nuclear Regulatory Commission

---

### **Summary of RES Findings (Cont'd):**

- **Industry good practices, as described by NEI, seems to be adequate.**
  - **Plant specific practices are not known.**
- **Walkdowns to look for any visible signs of anomalies attributable to cable degradation have proven to be effective and useful.**



## **United States Nuclear Regulatory Commission**

# **RES RECOMMENDATION**

- **Dissemination of research results and other information consistent with the generic communication process, to include:**
  - **Results of Tests conducted on cables for service life of 40 & 60 years.**
  - **Summary of Okonite test results and subsequent NRC actions.**
  - **Summary of research findings on condition monitoring techniques.**
  - **Summary of the industry good practices for condition monitoring.**
  - **Importance of knowledge of operating environments for cables.**

# **Revised Oversight Process Performance Indicator Pilot Program Mitigating System Performance Index**



**Patrick Baranowsky (415-7493)**  
Office of Nuclear Regulatory Research

June 6, 2002

June 6, 2002

MSPI ACRS Presentation

1

## **Purpose/Outline**

- The purpose of this presentation is provide an overview of the reliability/availability performance indicator pilot program for the revised reactor oversight process (ROP).
- Presentation outline
  - Background
  - Problems with current ROP PIs and how they are addressed by pilot program PIs
  - Insights from the phase 1 risk-based performance indicator (RBPI) study
  - Overview of technical approach and its limitations
  - Summary of issues raised by ACRS subcommittee on PRA
  - Conclusions/implementation schedule

June 6, 2002

MSPI ACRS Presentation

2

## Background

- SECY 99-007 stated the need to further refine reactor oversight process (ROP) performance indicators (PIs)
- During first two years of initial ROP implementation, staff and industry identified problems with current ROP PIs and made several changes
- It was decided to form a working group to address these problems and develop new/revised PIs
- Reliability and availability performance monitoring of selected mitigating systems is one aspect of the ROP refinement

June 6, 2002

MSPI ACRS Presentation

3

## Problems with Current ROP PIs

- Current ROP PIs include design-basis functions along with risk-significant functions
- ROP PI thresholds are generic
- Demand failures are not properly accounted for
  - Demand failures are treated in unavailability using fault exposure hours
  - Use of fault exposure hours can overestimate the risk significance of equipment performance degradation
- There are no PIs for support systems
  - Unavailabilities of support systems are cascaded onto the unavailabilities of monitored systems
  - Cascading support system unavailability results in overestimating the unavailability attributed to the performance of the monitored system

June 6, 2002

MSPI ACRS Presentation

4

## How are These Problems Addressed by PIs in the Pilot Program?

- Pilot Program PIs are based on risk-significant functions
- Pilot Program PIs account for plant-specific design/operating characteristics through use of available risk models and data
- Demand failures are accounted for in unreliability portion of PIs
- New PIs are developed for risk-significant support systems
  - Component cooling water and service water systems (or their equivalent cooling water systems)
- Pilot Program PIs address the recommendations made by ACRS on ROP PIs
  - PI thresholds should be plant-specific
  - Technical basis for choice of sampling intervals should be explained
  - Action levels should be related explicitly to risk metrics such as CDF and LERF, where possible

June 6, 2002

MSPI ACRS Presentation

5

## Insights from Phase 1 RBPI Study

- There were enough risk-significant differences among different plants that necessitated the development of plant-specific thresholds for unavailability and unreliability PIs
  - MSPI accounts for plant-specific differences
- Unavailability and unreliability indicators were found to provide objective and risk-informed indications of plant performance. They also provide broader risk coverage
  - They were tested by evaluating plant-specific data for 44 plants over three-year period (1997-1999)
- Performance indicators for CCW and SSW (or their equivalent support systems) were found to be difficult to develop due to the wide variation of plant-specific design features
  - Based on the technical analyses performed by NRC/industry, an approach has been developed for the Pilot
- Use of Bayesian update for estimating component unreliability was found to minimize the likelihood of false-positive/false-negative indications

June 6, 2002

MSPI ACRS Presentation

6

## Overview of Technical Approach

- Mitigating System Performance Index (MSPI) monitors risk impact (i.e., change in CDF) of changes in performance of selected mitigating systems, which accounts for plant-specific design and performance data
- MSPI includes Level I, internal events for at-power mode, which is consistent with the scope of the current ROP PIs
- MSPI consists of two elements, system unavailability and system reliability. MSPI is the sum of changes in a simplified CDF evaluation resulting from changes in system unavailability and system unreliability relative to baseline values
  - Baseline values are based on SECY-99-007 concepts

June 6, 2002

MSPI ACRS Presentation

7

## Overview of Technical Approach (cont.)

- The risk impact of changes in mitigating system performance on plant-specific CDF is estimated using plant-specific performance data and Fussell-Vesely importance measure
- MSPI for each monitored system is calculated as follows:

$$\text{MSPI} = \text{UAI} + \text{URI}$$

- UAI is the system unavailability index due to changes in train unavailability
- URI is the system unreliability index due to changes in component unreliability

June 6, 2002

MSPI ACRS Presentation

8



## List of Monitored Systems

- BWR Systems
  - HPCI/HPCS (high pressure core injection/spray)
  - RCIC (reactor core isolation cooling)
  - RHR (residual heat removal)
  - EDGs (emergency AC power)
  - Cooling water support systems (ESW+ RBCCW+TBCCW)
- PWR Systems
  - HPSI (high pressure safety injection)
  - AFW (auxiliary feedwater or equivalent)
  - RHR (residual heat removal)
  - EDGs (emergency AC power)
  - Cooling water support system (ESW + CCW or equivalent)

June 6, 2002

MSPI ACRS Presentation

9

## Limitations of Pilot Program Pls

- Inspection/SDP will be used for performance areas outside the scope of MSPI
  - CCFs
  - Concurrent failures of multiple components
  - Passive components
  - Demand failures not capable of being discovered during normal surveillance tests
- During the pilot, various approaches will be evaluated as well as other technical issues as summarized below:
  - Acceptable level of false-positive/false-negative indication
    - P(W/baseline)
    - P(G/W-Y)
    - P(G/Y-R)
  - Issues related to data that were used to set baseline unavailability and unreliability values
  - Independent calculations using SPAR models versus licensees PRA models
  - Evaluations of potential differences between MSPI and SDP results
  - Others

June 6, 2002

MSPI ACRS Presentation

10

## Summary of Questions Raised by ACRS Subcommittee on PRA

- Summary of questions raised by ACRS subcommittee on PRA during the presentation on May 30, 2002 are:
  - What are the reasons/justifications for selection of baseline values used for calculating changes in unavailability and unreliability elements of the PIs?
  - Should the pilot program PIs be based on SECY-99-007 thresholds (i.e.,  $1.0 \times 10^{-6}$ ,  $1.0 \times 10^{-5}$ ,  $1.0 \times 10^{-4}$ )?
  - Background information on the technical approach/equations should be provided
- We will provide a white paper explaining the technical aspects of the pilot program PIs to ACRS members in time for the next ACRS subcommittee meeting
- We will hold at least two more ACRS subcommittee briefings during the course of the pilot program to discuss these and other technical issues

June 6, 2002

MSPI ACRS Presentation

11

## Conclusions

- The MSPI approach is based on risk insights. It accounts for plant-specific design/operating characteristics through the use of available risk models and data
  - Use of F-V importance measure to account for plant-specific features
  - Treatment of demand failures in unreliability indicators
  - Use of Bayesian update for unreliability indicators
  - Use of risk-significant functions rather than design-basis functions
  - Use of a new indicator for cooling water support systems
- The MSPI approach allows for balancing between component unreliability and unavailability consistent with the Maintenance Rule
- The MSPI provides more objective indication of plant performance and will provide broader risk coverage
- The limitations of the MSPI have been clearly identified and will be covered through inspection/SDP
- The MSPI provides appropriate risk-categorization of performance degradations that are covered by PIs

June 6, 2002

MSPI ACRS Presentation

12

## Implementation Schedule

July 23-25, 2002	Public workshop to prepare for start of the MSPI pilot
August 1, 2002	Start of MSPI pilot
November 2002	Briefing to ACRS subcommittee on pilot progress
February 2003	End of MSPI pilot data collection and start of the analysis period to analyze collected data
March 2003	Briefing to ACRS subcommittee on pilot progress
July 2003	End of pilot program

June 6, 2002

MSPI ACRS Presentation

13

## Plants Participating in the Pilot MSPI

Region I	Limerick 1/2 Millstone 2/3 Hope Creek Salem 1/2
Region II	Surry 1/2
Region III	Braidwood 1/2 Prairie Island 1/2
Region IV	Palo Verde 1/2/3 San Onofre 2/3 South Texas 1/2

June 6, 2002

MSPI ACRS Presentation

14

# Industry Trends Program



Thomas Boyce  
Division of Inspection Program Management  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission

June 6, 2002

## Industry Trends

- Background
- Communications
- Process
- FY 2001 Results
- Future Development

June 3, 2002

Industry Trends Program

2

## Background

- NRC performance goal measure
- Purposes
- Relationship to NRC processes

June 3, 2002

Industry Trends Program

3

## Communications

- Industry indicators are published on the external NRC web site
- Annual report to Commission
- Annual report to Congress in NRC Performance and Accountability Report
- Conferences with Industry

June 3, 2002

Industry Trends Program

4

## Process

- Identify any statistically significant adverse industry trends
- Evaluate underlying issues and assess safety significance
- Agency response in accordance with existing NRC processes for generic communications
- Review at annual agency review meeting

June 3, 2002

Industry Trends Program

5

## FY2001 Results

- No statistically significant adverse industry trends in safety performance
- Insufficient data on ROP indicators (<4 years)

June 3, 2002

Industry Trends Program

6

## Future Development

- SRM of 8/2001 – Develop risk-informed thresholds “as soon as practicable”
- Enhanced performance goal measure
- Potential additional indicators

June 3, 2002

Industry Trends Program

7

## Industry Trend Thresholds

- RES is developing industry trend thresholds for use in a risk-informed regulatory framework.
- Industry thresholds differ from plant-specific thresholds.

June 3, 2002

Industry Trends Program

8

## Kinds of Thresholds

- Action Threshold
  - Used to measure industry performance, similar to thresholds used in ROP process
  - Report to Congress
- Early-Warning Threshold
  - Used to alert NRC to a change in industry trends that may indicate a change in industry safety performance

June 3, 2002

Industry Trends Program

9

## Threshold Characteristics

- Rational basis that is well documented
- Practical and simple
- Consistent with the existing regulatory framework
- Reflect risk (including associated uncertainties), safety, and regulatory perspectives

June 3, 2002

Industry Trends Program

10



## Protocol for Setting Thresholds

- Develop risk and statistical information related to trends for input to an expert panel
- Provide associated safety and regulatory information for expert panel
- Expert panel sets thresholds based upon input and expert judgment

June 3, 2002

Industry Trends Program

11

## Technical Approaches to Estimating Trend Thresholds

- Prediction Limits
- Bayesian Predictive Distribution
- Percentiles from Industry Distributions
- Insights from PRAs
- Rate-of-Change of Trend
- Expert Panel Input
- Modification of Current ROP PI Thresholds
- Combine Plant-specific Thresholds
- Integrated risk measure concept being developed for the enhanced PIs
- Combination of the above

June 3, 2002

Industry Trends Program

12

## Technical Questions

- How many years should be included in the estimation of a trend?
- What level is appropriate for reporting to Congress?
- What level is appropriate for agency action to an adverse trend?
- Should some of the PIs be grouped?
- How does the safety goal influence setting thresholds?
- Should concepts in Reg. Guide 1.174 be used in setting thresholds?

June 3, 2002

Industry Trends Program

13

## Schedule

- Initial thresholds for initiating events and mitigating systems – July 02
- Thresholds for other cornerstones – Sep. 02
- Change to performance goal measure – Fall 02
- Annual Commission paper – Mar. 03
- Final thresholds – FY03

June 3, 2002

Industry Trends Program

14



**United States Nuclear Regulatory Commission**

## **Presentation to the ACRS Full Committee**

---

### **Potential Policy Issues for Advanced Reactors**

Ashok Thadani, Director

*Office of Nuclear Regulatory Research*

Farouk Eltawila, Director

*Division of Systems Analysis and Regulatory Effectiveness*

*Office of Nuclear Regulatory Research*



# Outline

---

- ❑ *Purpose of the Briefing*
- ❑ *Background*
- ❑ *Enhanced Margin of Safety*
- ❑ *Relationship to International Standards*
- ❑ *Five Potential Policy Issues*
  - ❖ *Event Selection*
  - ❖ *Fuel Performance*
  - ❖ *Source Term*
  - ❖ *Containment Performance*
  - ❖ *Emergency Evacuation*
- ❑ *Future Plan*



# Purpose of the Briefing

---

- ❑ Summarize Technical Issues With Generic Policy Implications For Advanced Reactors Resulting From Technical Portion of Preapplication Reviews
- ❑ Summarize Staff Previous Resolution of These Issues
  - ❖ SECY-93-092, July 30, 1993, SRM
- ❑ Solicit ACRS Feedback On Scope and Nature of Issues:
  - ❖ Is the List the of Key Issues Complete?
  - ❖ Are They Stated Clearly and Correctly?
  - ❖ What Are the Important Considerations in Their Resolution?
- ❑ Develop Risk-Informed Performance-Based Criteria for Advanced Reactors
  - ❖ Risk-Informed Regulation Implementation Plan Update, June 2002
- ❑ ACRS Letter



## *Background*

---

- ❑ Preapplication Reviews For AP-1000 Complete
- ❑ PBMR Preapplication Activities in Closeout
- ❑ GT-MHR Preapplication Activities Planned
- ❑ Other Preapplication Activities Possible (E.G., GE-ESBWR, Framatome SWR1000, NG-CANDU)
- ❑ Many Issues Developed in the Course of the Review Have Generic Policy Implications:
  - ❖ Legal/Financial (SECY-01-207)
  - ❖ Technical (Memorandum to the Commission in Preparation)
- ❑ NEI White Paper On Risk-Informed Regulatory Framework For All Reactor Types
- ❑ Continued Work On Generic Policy Issues Can Facilitate Future Regulatory Work On Advanced Reactors



# Enhanced Margins of Safety

---

- ❑ Advanced Reactor Policy Statement Expectations:
  - ❖ Enhanced Margins of Safety
  - ❖ Use of Simplified, Inherent, Passive or Other Innovative Means to Accomplish Safety Functions
- ❑ The Severe Accident Policy Statement Expectations:
  - ❖ Expectation for Advanced Reactors--Should Safer than Current reactors, as a minimum Provide the Same Degree of Protection As Current Plants
  - ❖ Completion of PRA and Consideration of Severe Accidents Vulnerabilities
  - ❖ Containment Equivalent to a Large, Dry Containment Capable of Mitigating a Core Melt
- ❑ Key Fundamental Policy Issues For Commission Consideration (RIRIP)
  - ❖ Current Metrics (CDF and LERF) Insufficient
  - ❖ Should Additional Cornerstones Be Included?
  - ❖ Should Environmental Risk Metrics Be Considered?
  - ❖ Should a Higher Level of Safety Be Required For New Plant Designs?
  - ❖ How Should Defense-In-Depth Be Applied to New Plant Designs?
  - ❖ Should Criteria Apply to Single Unit or Entire Site?



# Relationship to International Safety Requirements

---

- ❑ Future Plant R&D Design and Marketing Are Becoming International Efforts
  - ❖ Designers
  - ❖ Suppliers
- ❑ Issue For Commission Consideration:
  - ❖ What Should Be the Relationship of NRC Safety Requirements to International Safety Requirements?
- ❑ Could Be Useful in Bringing in Expertise in Areas Where NRC Lacks Infrastructure





# Event Selection and Safety Classification

---

- ❑ To What Extent Should a Probabilistic Approach Be Used to Establish the Licensing Basis For New Plant Designs, Considering:
  - ❖ Less Experience, Data, Methods
  - ❖ PRA Quality, Completeness and Documentation
- ❑ What Should Be the Criteria For Event Selection and Safety Classification, Considering
  - ❖ Role of Engineering Judgment
  - ❖ Risk Metrics, Criteria
  - ❖ Treatment of Uncertainties
  - ❖ Desired Confidence Level
- ❑ *In SECY-93-092, the Staff Recommended an Approach That Is Deterministically Based Supplemented With Probabilistic Information. In the July 30, 1993 SRM, the Commission Approved the Staff Recommendation.*



# Fuel Performance and Qualification

---

- ☐ Fuel Performance and Qualification
  - ❖ Designed to Achieve Burnup of 80,000 MWd/t
  - ❖ Withstand High Temperature (1600<sup>0</sup> C) Without Release of Fission Products
- ☐ Should Fuel Qualification Testing Be Completed Prior to Granting A COL?
- ☐ Should Applicants Be Required to Test Fuel to Beyond Design Basis Event Conditions?
- ☐ What Independent Fuel Testing Should NRC Perform?
- ☐ Under What Conditions Can Fuel Manufactured Outside the U.S. Be Accepted For Use in a U.S. Plant?
- ☐ What Conditions Should NRC Employ to Ensure Fuel Quality Over the Life of the Plant?



# Source Term

---

- ❑ Licensing Source Term –TID-14844, NUREG-1465 Are Used to Determine LWR Containment Effectiveness and Site Suitability
- ❑ Questions
  - ❖ Under What Conditions, If Any, Should the Commission Accept the Use of Scenario Specific Source Terms For Licensing Decisions Regarding Containment and Site Suitability?
  - ❖ What Codes and Model Validation Should Be Used?
  - ❖ How to Account For Uncertainties?
- ❑ *The Commission July 30, 1993, SRM Approved the Staff Recommendation in SECY-93-092, Which Recommended That Scenario Specific (Mechanistic) Source Terms Be Allowed Provided There Was a Sufficient Understanding of Fuel Performance, Fission Product Behavior and Accident Selection to Bound Uncertainties.*



# Containment Performance

---

- ❑ Criteria For Containment/ Confinement Performance
  - ❖ Limit Fission Product Release
  - ❖ Barrier to Release
- ❑ Question
  - ❖ Under What Conditions, If Any, Should the Commission Accept the Use of Non-pressure Retaining Containment Building?
  - ❖ The Role of Containment Vs. Confinement In Protecting the Plant From External Threats, Sabotage, and Maintaining Public Confidence?
- ❑ *In SECY-93-092, the Staff Had Proposed an Approach for Containment That Focused on Functional Performance, Rather Than Prescriptive Design Criteria. The Commission July 30, 1993, SRM Approved the Staff Proposal, With the Addition of an Air Ingress Event to the MHTGR Proposed Accidents to Be Considered.*



# Emergency Evacuation

---

- ❑ Under What Conditions, If Any, Would the Commission Approve Reducing the EPZ, Including a Reduction to the Site Exclusion Area Boundary?
  - ❖ Criteria For Evacuation Planning
    - Timing For Release
  - ❖ Source Term and Probability
  - ❖ Margin (Defense - In - Depth)
  - ❖ Evacuation Planning Zone
  - ❖ Infrastructure Requirements
  - ❖ Exercises
- ❑ *The Commission July 30, 1993 SRM Stated That It Was Premature to Reach a Conclusion on Emergency Planning for Advanced Reactors, but Requested the Staff Remain Open to Suggestions to Simplify EP Requirements for Reactors With Greater Safety Margins.*



# Future Plan

---

- ❑ Develop Draft Staff Positions on Each Issue
- ❑ Solicit Stakeholder Feedback:
  - ❖ Public Workshop
  - ❖ ACRS Meetings
- ❑ Final Paper Requesting Commission Guidance - Fall 2002