

September 21, 1994

Docket Nos. STN 50-528, STN 50-529
and STN 50-530

Mr. William L. Stewart
Executive Vice President, Nuclear
Arizona Public Service Company
Post Office Box 53999
Phoenix, Arizona 85072-3999

Dear Mr. Stewart:

SUBJECT: ISSUANCE OF AMENDMENTS FOR THE PALO VERDE NUCLEAR GENERATING STATION
UNIT NO. 1 (TAC NO. M87244), UNIT NO. 2 (TAC NO. M87245), AND UNIT
NO. 3 (TAC NO. M87246)

The Commission has issued the enclosed Amendment No. 81 to Facility Operating License No. NPF-41, Amendment No. 68 to Facility Operating License No. NPF-51, and Amendment No. 53 to Facility Operating License No. NPF-74 for the Palo Verde Nuclear Generating Station, Unit Nos. 1, 2, and 3, respectively. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated August 5, 1993.

The amendments change the phrase "Pressurizer Pressure - Wide Range" to "Reactor Coolant System Pressure - Wide Range" in item 4 of TS Table 3.3-10 and item 4 of Table 4.3-7. These amendments will clarify the instrumentation required and eliminate potential confusion between the reactor coolant system pressure instruments and the pressurizer pressure instruments.

A copy of the related Safety Evaluation is also enclosed. A notice of issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,
Original signed by:
Linh N. Tran, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 81 to NPF-41
2. Amendment No. 68 to NPF-51
3. Amendment No. 53 to NPF-74
4. Safety Evaluation

cc w/enclosures:
See next page

9409280130 940921
PDR ADDCK 05000528
PDR

DISTRIBUTION

Docket File, T5C3 NRC & Local PDRs
EAdensam DFoster-Curseen
DHagan, T-4A43 GHill (6), T-5C3
OPA, T-2G5 OC/LFDCB
JRoe PDIV-2/RF
TQuay OGC, 0-15B18
CGrimes, 0-11E22 ACRS (10), T-2E26
Region IV BHolian
LTran KPerkins, WCFO

OFC	DRPW/LA <i>J-C</i>	PDIV-2/PM	PDIV-2/PM	OGC <i>CRS</i>	PDIV-2/D
NAME	DFoster-Curseen	LTran <i>pk</i>	BHolian <i>pk</i>	<i>R. Buchmann</i>	TQuay <i>TRQ</i>
DATE	8/25/94	8/25/94	8/25/94	8/30/94	9/21/94

OFFICIAL RECORD COPY

DOCUMENT NAME: PV87244.AMD

270068

NRC FILE CENTER COPY

DFC



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

September 21, 1994

Docket Nos. STN 50-528, STN 50-529
and STN 50-530

Mr. William L. Stewart
Executive Vice President, Nuclear
Arizona Public Service Company
Post Office Box 53999
Phoenix, Arizona 85072-3999

Dear Mr. Stewart:

SUBJECT: ISSUANCE OF AMENDMENTS FOR THE PALO VERDE NUCLEAR GENERATING STATION
UNIT NO. 1 (TAC NO. M87244), UNIT NO. 2 (TAC NO. M87245), AND UNIT
NO. 3 (TAC NO. M87246)

The Commission has issued the enclosed Amendment No. 81 to Facility Operating License No. NPF-41, Amendment No. 68 to Facility Operating License No. NPF-51, and Amendment No. 53 to Facility Operating License No. NPF-74 for the Palo Verde Nuclear Generating Station, Unit Nos. 1, 2, and 3, respectively. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated August 5, 1993.

The amendments change the phrase "Pressurizer Pressure - Wide Range" to "Reactor Coolant System Pressure - Wide Range" in item 4 of TS Table 3.3-10 and item 4 of Table 4.3-7. These amendments will clarify the instrumentation required and eliminate potential confusion between the reactor coolant system pressure instruments and the pressurizer pressure instruments.

A copy of the related Safety Evaluation is also enclosed. A notice of issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

A handwritten signature in dark ink, appearing to read "Linh N. Tran", is written over a horizontal line.

Linh N. Tran, Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 81 to NPF-41
2. Amendment No. 68 to NPF-51
3. Amendment No. 53 to NPF-74
4. Safety Evaluation

cc w/enclosures:
See next page



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

ARIZONA PUBLIC SERVICE COMPANY, ET AL.

DOCKET NO. STN 50-528

PALO VERDE NUCLEAR GENERATING STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 81
License No. NPF-41

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Arizona Public Service Company (APS or the licensee) on behalf of itself and the Salt River Project Agricultural Improvement and Power District, El Paso Electric Company, Southern California Edison Company, Public Service Company of New Mexico, Los Angeles Department of Water and Power, and Southern California Public Power Authority dated August 5, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-41 is hereby amended to read as follows:

9409280136 940921
PDR ADOCK 05000528
P PDR

Mr. William L. Stewart
Arizona Public Service Company

Palo Verde

cc:

Mr. Steve Olea
Arizona Corporation Commission
1200 W. Washington Street
Phoenix, Arizona 85007

Jack R. Newman, Esq.
Newman & Holtzinger, P.C.
1615 L Street, N.W., Suite 1000
Washington, D.C. 20036

T. E. Oubre, Esq.
Southern California Edison Company
P. O. Box 800
Rosemead, California 91770

Mr. Curtis Hoskins
Executive Vice President and
Chief Operating Officer
Palo Verde Services
2025 N. 3rd Street, Suite 220
Phoenix, Arizona 85004

Senior Resident Inspector
Palo Verde Nuclear Generating Station
5951 S. Wintersburg Road
Tonopah, Arizona 85354-7537

Roy P. Lessey, Jr., Esq.
Akin, Gump, Strauss, Hauer and Feld
El Paso Electric Company
1333 New Hampshire Avenue, Suite 400
Washington, DC. 20036

Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
Harris Tower & Pavillion
611 Ryan Plaza Drive, Suite 400
Arlington, Texas 76011-8064

Ms. Angela K. Krainik, Manager
Nuclear Licensing
Arizona Public Service Company
P. O. Box 52034
Phoenix, Arizona 85072-2034

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
ABB Combustion Engineering Nuclear Power
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Chairman, Maricopa County Board
of Supervisors
111 South Third Avenue
Phoenix, Arizona 85003


Mr. Aubrey V. Godwin, Director
Arizona Radiation Regulatory Agency
4814 South 40 Street
Phoenix, Arizona 85040

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 81, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. APS shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of the date of issuance and must be fully implemented no later than 45 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Theodore R. Quay, Director
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 21, 1994

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 81 TO FACILITY OPERATING LICENSE NO. NPF-41

DOCKET NO. STN 50-528

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove

3/4 3-58
3/4 3-60

Insert

3/4 3-58
3/4 3-60

INSTRUMENTATION

POST-ACCIDENT MONITORING INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.3.6 The post-accident monitoring instrumentation channels shown in Table 3.3-10 shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With one or more accident monitoring instrumentation channels inoperable, take the action shown in Table 3.3-10.
- b. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.3.3.6 Each post-accident monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3-7.

TABLE 3.3-10
POST-ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>REQUIRED NUMBER OF CHANNELS</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>ACTION</u>
1. Containment Pressure	2	1	29,30
2. Reactor Coolant Outlet Temperature - T_{hot} (Wide Range)	2	1/loop	29,30
3. Reactor Coolant Inlet Temperature - T_{cold} (Wide Range)	2	1/loop	29,30
4. Reactor Coolant System Pressure - Wide Range	2	1	29,30
5. Pressurizer Water Level	2	1	29,30
6. Steam Generator Pressure	2/steam generator	1/steam generator	29,30
7. Steam Generator Water Level - Wide Range	2/steam generator	1/steam generator	29,30
8. Refueling Water Storage Tank Water Level	2	1	29,30
9. Auxiliary Feedwater Flow Rate	2	1	29,30
10. Reactor Cooling System Subcooling Margin Monitor	2	1	29,30
11. Pressurizer Safety Valve Position Indicator	1/valve	1/valve	29,30
12. Containment Water Level (Narrow Range)	2	1	29,30
13. Containment Water Level (Wide Range)	2	1	29,30
14. Core Exit Thermocouples	4/core quadrant	2/core quadrant	29,30
15. Reactor Vessel Water Level	2*	1*	31,32
16. Neutron Flux Monitor (Power Range)	2	1	29,30

*A channel is eight sensors in a probe. A channel is OPERABLE if four or more sensors, two or more in the upper four and two or more in the lower four, are OPERABLE.

TABLE 3.3-10
ACTION STATEMENTS

- ACTION 29 - With the number of OPERABLE Channels one less than the Required Number of Channels in Table 3.3-10, either restore the Inoperable Channel(s) to OPERABLE status within 7 days, or be in HOT SHUTDOWN within the next 12 hours.
- ACTION 30 - With the number of OPERABLE Channels one less than the Minimum Channels OPERABLE in Table 3.3-10, either restore the Inoperable Channel(s) to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 12 hours.
- ACTION 31 - With the number of OPERABLE Channels one less than the Required Number of Channels, either restore the system to OPERABLE status within 7 days if repairs are feasible without shutting down or prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 30 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.
- ACTION 32 - With the number of OPERABLE Channels one less than the Minimum Channels OPERABLE in Table 3.3-10, either restore the inoperable channel(s) to OPERABLE status within 48 hours if repairs are feasible without shutting down or:
1. Initiate an alternate method of monitoring the reactor vessel inventory;
 2. Prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 30 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status; and
 3. Restore the system to OPERABLE status at the next scheduled refueling.

TABLE 4.3-7

POST-ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. Containment Pressure	M	R
2. Reactor Coolant Outlet Temperature - T_{hot} (Wide Range)	M	R
3. Reactor Coolant Inlet Temperature - T_{cold} (Wide Range)	M	R
4. Reactor Coolant System Pressure - Wide Range	M	R
5. Pressurizer Water Level	M	R
6. Steam Generator Pressure	M	R
7. Steam Generator Water Level - Wide Range	M	R
8. Refueling Water Storage Tank Water Level	M	R
9. Auxiliary Feedwater Flow Rate	M	R
10. Reactor Coolant System Subcooling Margin Monitor	M	R
11. Pressurizer Safety Valve Position Indicator	M	R
12. Containment Water Level (Narrow Range)	M	R
13. Containment Water Level (Wide Range)	M	R
14. Core Exit Thermocouples	M	R
15. Reactor Vessel Water Level	M	R
16. Neutron Flux Monitor (Power Range)	M	R



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

ARIZONA PUBLIC SERVICE COMPANY, ET AL.

DOCKET NO. STN 50-529

PALO VERDE NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 68
License No. NPF-51


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Arizona Public Service Company (APS or the licensee) on behalf of itself and the Salt River Project Agricultural Improvement and Power District, El Paso Electric Company, Southern California Edison Company, Public Service Company of New Mexico, Los Angeles Department of Water and Power, and Southern California Public Power Authority dated August 5, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations set forth in 10 CFR Part I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-51 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No.68 , and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. APS shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of the date of issuance and must be fully implemented no later than 45 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Theodore R. Quay, Director
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 21, 1994

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 68 TO FACILITY OPERATING LICENSE NO. NPF-51

DOCKET NO. STN 50-529

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove

3/4 3-58
3/4 3-60

Insert

3/4 3-58
3/4 3-60

TABLE 3.3-10
POST-ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>REQUIRED NUMBER OF CHANNELS</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>ACTION</u>
1. Containment Pressure	2	1	29,30
2. Reactor Coolant Outlet Temperature - T_{hot} (Wide Range)	2	1/loop	29,30
3. Reactor Coolant Inlet Temperature - T_{cold} (Wide Range)	2	1/loop	29,30
4. Reactor Coolant system Pressure - Wide Range	2	1	29,30
5. Pressurizer Water Level	2	1	29,30
6. Steam Generator Pressure	2/steam generator	1/steam generator	29,30
7. Steam Generator Water Level - Wide Range	2/steam generator	1/steam generator	29,30
8. Refueling Water Storage Tank Water Level	2	1	29,30
9. Auxiliary Feedwater Flow Rate	2	1	29,30
10. Reactor Cooling System Subcooling Margin Monitor	2	1	29,30
11. Pressurizer Safety Valve Position Indicator	1/valve	1/valve	29,30
12. Containment Water Level (Narrow Range)	2	1	29,30
13. Containment Water Level (Wide Range)	2	1	29,30
14. Core Exit Thermocouples	4/core quadrant	2/core quadrant	29,30
15. Reactor Vessel Water Level	2*	1*	31,32
16. Neutron Flux Monitor (Power Range)	2	1	29,30

*A channel is eight sensors in a probe. A channel is OPERABLE if four or more sensors, two or more in the upper four and two or more in the lower four, are OPERABLE.

INSTRUMENTATION

POST-ACCIDENT MONITORING INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.3.6 The post-accident monitoring instrumentation channels shown in Table 3.3-10 shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With one or more accident monitoring instrumentation channels inoperable, take the action shown in Table 3.3-10.
- b. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.3.3.6 Each post-accident monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3-7.

TABLE 3.3-10 (Continued)

ACTION STATEMENTS

- ACTION 29 - With the number of OPERABLE Channels one less than the Required Number of Channels in Table 3.3-10, either restore the Inoperable Channel(s) to OPERABLE status within 7 days, or be in HOT SHUTDOWN within the next 12 hours.
- ACTION 30 - With the number of OPERABLE Channels one less than the Minimum Channels OPERABLE in Table 3.3-10, either restore the Inoperable Channel(s) to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 12 hours.
- ACTION 31 - With the number of OPERABLE Channels one less than the Required Number of Channels either restore the system to OPERABLE status within 7 days if repairs are feasible without shutting down or prepare and submit a Special Report to the Commission Pursuant to Specification 6.9.2 within 30 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.
- ACTION 32 - With the number of OPERABLE Channels one less than the Minimum Channels OPERABLE in Table 3.3-10, either restore the inoperable channel(s) to OPERABLE status within 48 hours if repairs are feasible without shutting down or:
1. Initiate an alternative method of monitoring the reactor vessel inventory:
 2. Prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 30 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status; and
 3. Restore the system to OPERABLE status at the next scheduled refueling.

TABLE 4.3-7

POST-ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. Containment Pressure	M	R
2. Reactor Coolant Outlet Temperature - T_{hot} (Wide Range)	M	R
3. Reactor Coolant Inlet Temperature - T_{cold} (Wide Range)	M	R
4. Reactor Coolant System Pressure - Wide Range	M	R
5. Pressurizer Water Level	M	R
6. Steam Generator Pressure	M	R
7. Steam Generator Water Level - Wide Range	M	R
8. Refueling Water Storage Tank Water Level	M	R
9. Auxiliary Feedwater Flow Rate	M	R
10. Reactor Coolant System Subcooling Margin Monitor	M	R
11. Pressurizer Safety Valve Position Indicator	M	R
12. Containment Water Level (Narrow Range)	M	R
13. Containment Water Level (Wide Range)	M	R
14. Core Exit Thermocouples	M	R
15. Reactor Vessel Water Level	M	R
16. Neutron Flux Monitor (Power Range)	M	R



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

ARIZONA PUBLIC SERVICE COMPANY, ET AL.

DOCKET NO. STN 50-530

PALO VERDE NUCLEAR GENERATING STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 53
License No. NPF-74


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Arizona Public Service Company (APS or the licensee) on behalf of itself and the Salt River Project Agricultural Improvement and Power District, El Paso Electric Company, Southern California Edison Company, Public Service Company of New Mexico, Los Angeles Department of Water and Power, and Southern California Public Power Authority dated August 5, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-74 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 53, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. APS shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of the date of issuance and must be fully implemented no later than 45 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Theodore R. Quay, Director
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 21, 1994

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 53 TO FACILITY OPERATING LICENSE NO. NPF-74

DOCKET NO. STN 50-530

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove

3/4 3-58
3/4 3-60

Insert

3/4 3-58
3/4 3-60

INSTRUMENTATION

POST-ACCIDENT MONITORING INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.3.6 The post-accident monitoring instrumentation channels shown in Table 3.3-10 shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With one or more accident monitoring instrumentation channels inoperable, take the action shown in Table 3.3-10.
- b. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.3.3.6 Each post-accident monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK and CHANNEL CALIBRATION operations at the frequencies shown in Table 4.3-7.

TABLE 3.3-10

POST-ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>REQUIRED NUMBER OF CHANNELS</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>ACTION</u>
1. Containment Pressure	2	1	29,30
2. Reactor Coolant Outlet Temperature - T_{hot} (Wide Range)	2	1/loop	29,30
3. Reactor Coolant Inlet Temperature - T_{cold} (Wide Range)	2	1/loop	29,30
4. Reactor Coolant System Pressure - Wide Range	2	1	29,30
5. Pressurizer Water Level	2	1	29,30
6. Steam Generator Pressure	2/steam generator	1/steam generator	29,30
7. Steam Generator Water Level - Wide Range	2/steam generator	1/steam generator	29,30
8. Refueling Water Storage Tank Water Level	2	1	29,30
9. Auxiliary Feedwater Flow Rate	2	1	29,30
10. Reactor Cooling System Subcooling Margin Monitor	2	1	29,30
11. Pressurizer Safety Valve Position Indicator	1/valve	1/valve	29,30
12. Containment Water Level (Narrow Range)	2	1	29,30
13. Containment Water Level (Wide Range)	2	1	29,30
14. Core Exit Thermocouples	4/core quadrant	2/core quadrant	29,30
15. Reactor Vessel Water Level	2*	1*	31,32
16. Neutron Flux Monitor (Power Range)	2	1	29,30

*A channel is eight sensors in a probe. A channel is OPERABLE if four or more sensors, two or more in the upper four and two or more in the lower four, are OPERABLE.

TABLE 3.3-10 (Continued)

ACTION STATEMENTS

- ACTION 29 - With the number of OPERABLE Channels one less than the Required Number of Channels in Table 3.3-10, either restore the Inoperable Channel(s) to OPERABLE status within 7 days, or be in HOT SHUTDOWN within the next 12 hours.
- ACTION 30 - With the number of OPERABLE Channels one less than the Minimum Channels OPERABLE in Table 3.3-10, either restore the Inoperable Channel(s) to OPERABLE status within 48 hours or be in at least HOT SHUTDOWN within the next 12 hours.
- ACTION 31 - With the number of OPERABLE Channels one less than the Required Number of Channels either restore the system to OPERABLE status within 7 days if repairs are feasible without shutting down or prepare and submit a Special Report to the Commission Pursuant to Specification 6.9.2 within 30 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status.
- ACTION 32 - With the number of OPERABLE Channels one less than the Minimum Channels OPERABLE in Table 3.3-10, either restore the inoperable channel(s) to OPERABLE status within 48 hours if repairs are feasible without shutting down or:
1. Initiate an alternative method of monitoring the reactor vessel inventory:
 2. Prepare and submit a Special Report to the Commission pursuant to Specification 6.9.2 within 30 days following the event outlining the action taken, the cause of the inoperability and the plans and schedule for restoring the system to OPERABLE status; and
 3. Restore the system to OPERABLE status at the next scheduled refueling.

TABLE 4.3-7

POST-ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. Containment Pressure	M	R
2. Reactor Coolant Outlet Temperature - T_{hot} (Wide Range)	M	R
3. Reactor Coolant Inlet Temperature - T_{cold} (Wide Range)	M	R
4. Reactor Coolant System Pressure - Wide Range	M	R
5. Pressurizer Water Level	M	R
6. Steam Generator Pressure	M	R
7. Steam Generator Water Level - Wide Range	M	R
8. Refueling Water Storage Tank Water Level	M	R
9. Auxiliary Feedwater Flow Rate	M	R
10. Reactor Coolant System Subcooling Margin Monitor	M	R
11. Pressurizer Safety Valve Position Indicator	M	R
12. Containment Water Level (Narrow Range)	M	R
13. Containment Water Level (Wide Range)	M	R
14. Core Exit Thermocouples	M	R
15. Reactor Vessel Water Level	M	R
16. Neutron Flux Monitor (Power Range)	M	R



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 81 TO FACILITY OPERATING LICENSE NO. NPF-41,
AMENDMENT NO. 68 TO FACILITY OPERATING LICENSE NO. NPF-51,
AND AMENDMENT NO. 53 TO FACILITY OPERATING LICENSE NO. NPF-74
ARIZONA PUBLIC SERVICE COMPANY, ET AL.
PALO VERDE NUCLEAR GENERATING STATION, UNIT NOS. 1, 2, AND 3
DOCKET NOS. STN 50-528, STN 50-529, AND STN 50-530

1.0 INTRODUCTION

By letter dated August 5, 1993, the Arizona Public Service Company (APS or the licensee) submitted a request for changes to the Technical Specifications (TS) for the Palo Verde Nuclear Generating Station, Units 1, 2, and 3 (Appendix A to Facility Operating License Nos. NPF-41, NPF-51, and NPF-74, respectively). The Arizona Public Service Company submitted this request on behalf of itself, the Salt River Project Agricultural Improvement and Power District, Southern California Edison Company, El Paso Electric Company, Public Service Company of New Mexico, Los Angeles Department of Water and Power, and Southern California Public Power Authority. The proposed amendments change the phrase "Pressurizer Pressure - Wide Range" to "Reactor Coolant System Pressure - Wide Range" in item 4 of TS Table 3.3-10 and item 4 of Table 4.3-7. These amendments will clarify the instrumentation required and eliminate potential confusion between the reactor coolant system pressure instruments and the pressurizer pressure instruments.

2.0 DISCUSSION AND EVALUATION

The purpose of TS 3/4 3.3.6, "Post-Accident Monitoring Instrumentation," is to ensure that sufficient information is available about selected plant parameters following an accident. Currently, item 4 of Table 3.3-10, "Post-Accident Monitoring Instrumentation," and item 4 of Table 4.3-7, "Post-Accident Monitoring Instrumentation Surveillance Requirements," use the phrase "Pressurizer Pressure" to designate the wide-range pressure instrumentation required for post-accident monitoring. The licensee proposes to change the phrase "Pressurizer Pressure" to "Reactor Coolant System Pressure" to be consistent with Regulatory Guide (RG) 1.97, "Instrumentation for Light-Water-Cooled Nuclear Plants to Assess Plant Conditions During and Following an Accident," and to agree with the as-built configuration and the field equipment identification. The licensee stated that this change is administrative in nature because it only corrects the nomenclature of the instrumentation and does not change equipment, configuration, or operation.

This amendment will clarify the instrumentation required and eliminate potential confusion between the reactor coolant system pressure instruments and the pressurizer pressure instruments and is, therefore, acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Arizona State official was notified of the proposed issuance of the amendments. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and change surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (58 FR 50962). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: L. Tran

Date: September 21, 1994