Docket Nos. STN 50-528, STN 50-529 and STN 50-530

Mr. William F. Conway Executive Vice President, Nuclear Arizona Public Service Company Post Office Box 53999 Phoenix. Arizona 85072-3999

Dear Mr. Conway:

DATE

OFFICIAL

6 /94

RECORD COPY

ISSUANCE OF AMENDMENTS FOR THE PALO VERDE NUCLEAR GENERATING SUBJECT: STATION UNIT NO. 1 (TAC NO. M88679), UNIT NO. 2 (TAC NO. M88680), AND UNIT NO. 3 (TAC NO. M88681)

The Commission has issued the enclosed Amendment No.76 to Facility Operating License No. NPF-41, Amendment No. 62 to Facility Operating License No. NPF-51, and Amendment No. 48 to Facility Operating License No. NPF-74 for the Palo Verde Nuclear Generating Station, Unit Nos. 1, 2, and 3, respectively. The amendments consist of changes to the Technical Specifications in response to your application dated January 20, 1994.

These amendments would increase the DNBR limit from 1.24 to 1.30 to accommodate the uncertainties in core inlet flow distribution. The amendments also add the analytical method supplement entitled "System 80^{TM} Inlet Flow Distribution" to the list of methods used to determine core operating limits.

A copy of the related Safety Evaluation is also enclosed. A notice of issuance will be included in the Commission's next regular biweekly Federal Register notice.

Sincerely,

Original signed by:

Brian E. Holian, Project Manager Wills I Have WHICH & LEH WHEN Project Directorate IV-3 Division of Reactor Projects III/IV Office of Nuclear Reactor Regulation DISTRIBUTION Enclosures: Amendment No. ⁷⁶ to NPF-41 Docket File NRC & Local PDRs 1 Amendment No. 62 to NPF-51 **DFoster-Curseen** 2. EAdensam Amendment No. 48 to NPF-74 3. DHagan, 3206 GHill (6), P1-37 Safety Evaluation OPA, 2G5 OC/LFDCB, 4503 4. PDIV-3/RF JRoe OGC, 15B18 ACRS (10), P-315 cc w/enclosures: TOuav See next page CGrimes, 11E22 9406080177 940526 PDR ADDCK 05000528 Region IV (12) BHolian LTran KPerkins, WCFO PDR GSchwenk OFFICE PDIV-3/PM PDIV-3/LA PDIV-3/PM 0G(PDIV-3/D BHolian:mk NAME **DFoster-Curseen** LTran UT TOuav

B /94

FILENAME:

5/13/94

A:\PVM88679.AMD

1.1-1

₽£#<u>}</u>

/94

Docket Nos. STN 50-528, STN 50-529 and STN 50-530

Mr. William F. Conway Executive Vice President, Nuclear Arizona Public Service Company Post Office Box 53999 Phoenix, Arizona 85072-3999

Dear Mr. Conway:

SUBJECT: ISSUANCE OF AMENDMENTS FOR THE PALO VERDE NUCLEAR GENERATING STATION UNIT NO. 1 (TAC NO. M88679), UNIT NO. 2 (TAC NO. M88680), AND UNIT NO. 3 (TAC NO. M88681)

The Commission has issued the enclosed Amendment No.76 to Facility Operating License No. NPF-41, Amendment No. 62 to Facility Operating License No. NPF-51, and Amendment No. 48 to Facility Operating License No. NPF-74 for the Palo Verde Nuclear Generating Station, Unit Nos. 1, 2, and 3, respectively. The amendments consist of changes to the Technical Specifications in response to your application dated January 20, 1994.

These amendments would increase the DNBR limit from 1.24 to 1.30 to accommodate the uncertainties in core inlet flow distribution. The amendments also add the analytical method supplement entitled "System 80^{TM} Inlet Flow Distribution" to the list of methods used to determine core operating limits.

A copy of the related Safety Evaluation is also enclosed. A notice of issuance will be included in the Commission's next regular biweekly <u>Federal</u> <u>Register</u> notice.

Sincerely,

Original signed by:

Brian E. Holian, Project Manager Project Directorate IV-3 Division of Reactor Projects III/IV Office of Nuclear Reactor Regulation

Enclosures: 1. Amendment No. 76 to NPF-41 2. Amendment No. 62 to NPF-51

- 3. Amendment No. 48 to NPF-74
- 4. Safety Evaluation

cc w/enclosures:

See next page

DISTRIBUTION	
Docket File	NRC & Local PDRs
EAdensam	DFoster-Curseen
DHagan, 3206	GHill (6), P1-37
OPA, 2G5	OC/LFDCB, 4503
JRoe	PDIV-3/RF
TQuay	- OGC, 15B18
CGrimes, 11E22	ACRS (10), P-315
Region IV (12)	BHolian
LTran	KPerkins, WCFO

		GSc	hwenk		
OFFICE	PDIV-3/LA JCU	PDIV-3/PM	PDIV-3/PM	OGC.A.)	PDIV-3/D
NAME	DFoster-Curseen	BHolian:mk	LTran UT	1 OPW	TQuay BEthen
DATE	5/13/94	5 / B/94	5/13/94	5/1/94	5/76/94
OFFICIA	L DECODD CODY / ETL				

OFFICIAL RECORD COPY/ FILENAME: A:\PVM88679.AMD



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

May 26, 1994

Docket Nos. STN 50-528, STN 50-529 and STN 50-530

Mr. William F. Conway Executive Vice President, Nuclear Arizona Public Service Company Post Office Box 53999 Phoenix, Arizona 85072-3999

Dear Mr. Conway:

SUBJECT: ISSUANCE OF AMENDMENTS FOR THE PALO VERDE NUCLEAR GENERATING STATION UNIT NO. 1 (TAC NO. M88679), UNIT NO. 2 (TAC NO. M88680), AND UNIT NO. 3 (TAC NO. M88681)

The Commission has issued the enclosed Amendment No. 76 to Facility Operating License No. NPF-41, Amendment No. 62 to Facility Operating License No. NPF-51, and Amendment No. 48 to Facility Operating License No. NPF-74 for the Palo Verde Nuclear Generating Station, Unit Nos. 1, 2, and 3, respectively. The amendments consist of changes to the Technical Specifications in response to your application dated January 20, 1994.

These amendments would increase the DNBR limit from 1.24 to 1.30 to accommodate the uncertainties in core inlet flow distribution. The amendments also add the analytical method supplement entitled "System 80^{TM} Inlet Flow Distribution" to the list of methods used to determine core operating limits.

A copy of the related Safety Evaluation is also enclosed. A notice of issuance will be included in the Commission's next regular biweekly <u>Federal</u> <u>Register</u> notice.

Sincerely,

BERR

Brian E. Holian, Project Manager Project Directorate IV-3 Division of Reactor Projects III/IV Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 76 to NPF-41
- 2. Amendment No. 62 to NPF-51
- 3. Amendment No. 48 to NPF-74
- 4. Safety Evaluation

cc w/enclosures: See next page Mr. William F. Conway Arizona Public Service Company

cc: Mr. Steve Olea Arizona Corporation Commission 1200 W. Washington Street Phoenix, Arizona 85007

James A. Beoletto, Esq. Southern California Edison Company P. O. Box 800 Rosemead, California 91770

Senior Resident Inspector Palo Verde Nuclear Generating Station 5951 S. Wintersburg Road Tonopah, Arizona 85354-7537

Regional Administrator, Region IV U. S. Nuclear Regulatory Commission Harris Tower & Pavillion 611 Ryan Plaza Drive, Suite 400 Arlington, Texas 76011-8064

Mr. Charles B. Brinkman, Manager Washington Nuclear Operations ABB Combustion Engineering Nuclear Power 12300 Twinbrook Parkway, Suite 330 Rockville, Maryland 20852

Mr. Aubrey V. Godwin, Director Arizona Radiation Regulatory Agency 4814 South 40 Street Phoenix, Arizona 85040

Chairman Maricopa County Board of Supervisors 111 South Third Avenue Phoenix, Arizona 85003 Palo Verde

Jack R. Newman, Esq. Newman & Holtzinger, P.C. 1615 L Street, N.W., Suite 1000 Washington, D.C. 20036

Mr. Curtis Hoskins Executive Vice President and Chief Operating Officer Palo Verde Services 2025 N. 3rd Street, Suite 220 Phoenix, Arizona 85004

Roy P. Lessey. Jr., Esq. Akin, Gump, Strauss, Hauer and Feld El Paso Electric Company 1333 New Hampshire Avenue, Suite 400 Washington, DC. 20036

Ms. Angela K. Krainik, Manager Nuclear Licensing Arizona Public Service Company P. O. Box 52034 Phoenix, Arizona 85072-2034



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

ARIZONA PUBLIC SERVICE COMPANY, ET AL.

DOCKET NO. STN 50-528

PALO VERDE NUCLEAR GENERATING STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 76 License No. NPF-41

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Arizona Public Service Company (APS or the licensee) on behalf of itself and the Salt River Project Agricultural Improvement and Power District, El Paso Electric Company, Southern California Edison Company, Public Service Company of New Mexico, Los Angeles Department of Water and Power, and Southern California Public Power Authority dated January 20, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-41 is hereby amended to read as follows:

9406080186 940526 PDR ADOCK 05000528 P PDR

2.

(2) <u>Technical Specifications and Environmental Protection Plan</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. ⁷⁶, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. APS shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of the date of issuance and must be fully implemented prior to the startup from Cycle 5 Refueling Outage.

FOR THE NUCLEAR REGULATORY COMMISSION

EHL - For

Theodore R. Quay, Director Project Directorate IV-3 Division of Reactor Projects III/IV Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: May 26, 1994

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 76 TO FACILITY OPERATING LICENSE NO. NPF-41

DOCKET NO. STN 50-528

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Insert
2-1
2-3
B 2-1
B 2-2
B 2-6
6-20a

ł

2.0 SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.1 SAFETY LIMITS

2.1.1 REACTOR CORE

DNBR

2.1.1.1 The calculated DNBR of the reactor core shall be maintained greater than or equal to 1.30.

APPLICABILITY: MODES 1 and 2.

ACTION:

Whenever the calculated DNBR of the reactor has decreased to less than 1.30, be in HOT STANDBY within 1 hour, and comply with the requirements of Specification 6.7.1.

PEAK LINEAR HEAT RATE

2.1.1.2 The peak linear heat rate (adjusted for fuel rod dynamics) of the fuel shall be maintained less than or equal to 21 kW/ft.

APPLICABILITY: MODES 1 and 2.

ACTION:

Whenever the peak linear heat rate (adjusted for fuel rod dynamics) of the fuel has exceeded 21 kW/ft, be in HOT STANDBY within 1 hour, and comply with the requirements of Specification 6.7.1.

REACTOR COOLANT SYSTEM PRESSURE

2.1.2 The Reactor Coolant System pressure shall not exceed 2750 psia.

APPLICABILITY: MODES 1, 2, 3, 4, and 5.

ACTION:

MODES 1 and 2:

Whenever the Reactor Coolant System pressure has exceeded 2750 psia, be in HOT STANDBY with the Reactor Coolant System pressure within its limit within 1 hour, and comply with the requirements of Specification 6.7.1.

MODES 3, 4, and 5:

Whenever the Reactor Coolant System pressure has exceeded 2750 psia, reduce the Reactor Coolant System pressure to within its limit within 5 minutes, and comply with the requirements of Specification 6.7.1.

SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.2 LIMITING SAFETY SYSTEM SETTINGS

REACTOR TRIP SETPOINTS

2.2.1 The reactor protective instrumentation setpoints shall be set consistent with the Trip Setpoint values shown in Table 2.2-1.

APPLICABILITY: As shown for each channel in Table 3.3-1.

ACTION:

With a reactor protective instrumentation setppint less conservative than the value shown in the Allowable Values column of Table 2.2-1, declare the channel inoperable and apply the applicable ACTION statement requirement of Specification 3.3.1 until the channel is restored to OPERABLE status with its trip setpoint adjusted consistent with the Trip Setpoint value.

	:	<u>TABLE 2.2-1</u>	
	REACTOR PROTECTIVE IN	STRUMENTATION TRIP SETPOINT	LIMITS
<u>FU</u>	NCTIONAL UNIT	TRIP SETPOINT	ALLOWABLE VALUES
1. TR	IP GENERATION		
Α.	Process		
	1. Pressurizer Pressure - High	≤ 2383 psia	≤ 2388 psia
	2. Pressurizer Pressure - Low	≥ 1837 psia (2)	≥ 1821 psia (2)
	3. Steam Generator Level - Low	≥ 44.2% (4)	≥ 43.7% (4)
	4. Steam Generator Level - High	≤ 91.0% (9)	≤ 91.5% (9)
	5. Steam Generator Pressure - Low	≥ 919 psia (3)	≥ 911 psia (3)
	6. Containment Pressure - High	≤ 3.0 psig	≤ 3.2 psig
	7. Reactor Coolant Flow - Low		
•	a. Rate	≤ 0.115 psi/sec (6)(7)	≤ 0.118 psi/sec (6)(7)
	b. Floor	≥ 11.9 psid (6)(7)	≥ 11.7 psid(6)(7)
	c. Band	≤ 10.0 psid (6)(7)	≤ 10.2 psid (6)(7)
i ¢	8. Local Power Density - High	≤ 21.0 kW/ft (5)	≤ 21.0 kW/ft (5)
	9. DNBR - Low	≥ 1.30 (5)	≥ 1.30 (5)
· B.	Excore Neutron Flux		\$
	1. Variable Overpower Trip		
	a. Rate	≤10.6 %/min of RATED THERMAL POWER (8)	≤11.0%/min of RATED THERMAL POWER (8)
	b. Ceiling	≤110.0% of RATED THERMAL POWER (8)	≤111.0% of RATED THERMAL POWER (8)
	c. Band	≤9.7% of RATED THERMAL POWER (8)	≤9.9% of RATED THERMAL POWER (8)

.

٠

PALO VERDE - UNIT 1

2-3

AMENDMENT NO. -24, 76

TABLE 2.2-1 (Continued)

REACTOR PROTECTIVE INSTRUMENTATION TRIP SETPOINT LIMITS

	<u>FUNCTIONAL UNIT</u> 2. Logarithmic Power Level - High (1) a. Startup and Operating		TRIP SETPOINT	ALLOWABLE VALUES
			< 0.010% of RATED THERMAL POWER	< 0.011% of RATED THERMAL POWER
		b. Shutdown	< 0.010% of RATED THERMAL POWER	< 0.011% of RATED THERMAL POWER
	C.	Core Protection Calculator System		•
	•	1. CEA Calculators	Not Applicable	Not Applicable
		2. Core Protection Calculators	Not Applicable	Not Applicable
	D.	Supplementary Protection System		
		Pressurizer Pressure - High	<u><</u> 2409 psia	< 2414 psia
11.	RPS	LOGIC	······································	······································
	A:	Matrix Logic	Not Applicable	Not Applicable
	8.	Initiation Logic	Not Applicable	Not Applicable
111.	RPS	ACTUATION DEVICES		
	A.	Reactor Trip Breakers	Not Applicable	Not Applicable
	B.	Manuậi ¦Trip	Not Applicable	Not Applicable

2-4

2.1 and 2.2 SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

BASES

2.1.1 REACTOR CORE

The restrictions of these safety limits prevent overheating of the fuel cladding and possible cladding perforation which would result in the release of fission products to the reactor coolant. Overheating of the fuel cladding is prevented by (1) restricting fuel operation to within the nucleate boiling regime where the heat transfer coefficient is large and the cladding surface temperature is slightly above the coolant saturation temperature, and (2) maintaining the dynamically adjusted peak linear heat rate of the fuel at or less than 21 kW/ft which will not cause fuel centerline melting in any fuel rod.

First, by operating within the nucleate boiling regime of heat transfer, the heat transfer coefficient is large enough so that the maximum clad surface temperature is only slightly greater than the coolant saturation temperature. The upper boundary of the nucleate boiling regime is termed "departure from nucleate boiling" (DNB). At this point, there is a sharp reduction of the heat transfer coefficient, which would result in higher cladding temperatures and the possibility of cladding failure.

Correlations predict DNB and the location of DNB for axially uniform and non-uniform heat flux distributions. The local DNB ratio (DNBR), defined as the ratio of the predicted DNB heat flux at a particular core location to the actual heat flux at that location, is indicative of the margin to DNB. The minimum value of DNBR during normal operation and design basis anticipated operational occurrences is limited to 1.30 based upon a statistical combination of CE-1 CHF correlation and engineering factor uncertainties and is established as a Safety Limit. The DNBR limit of 1.30 includes a rod bow compensation of 1.75% on DNBR.

Second, operation with a peak linear heat rate below that which would cause fuel centerline melting maintains fuel rod and cladding integrity. Above this peak linear heat rate level (i.e., with some melting in the center), fuel rod integrity would be maintained only if the design and operating conditions are appropriate throughout the life of the fuel rods. Volume changes which accompany the solid to liquid phase change are significant and require accommodation. Another consideration involves the redistribution of the fuel which depends on the extent of the melting and the physical state of the fuel rod at the time of melting. Because of the above factors, the steady state value of the peak linear heat rate which would not cause fuel centerline melting is established as a Safety Limit. To account for fuel rod dynamics (lags), the directly indicated linear heat rate is dynamically adjusted by the CPC program.

.....

PALO VERDE - UNIT 1

SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

BASES

Limiting Safety System Settings for the Low DNBR, High Local Power Density, High Logarithmic Power Level, Low Pressurizer Pressure and High Linear Power Level trips, and Limiting Conditions for Operation on DNBR and kW/ftmargin are specified such that there is a high degree of confidence that the specified acceptable fuel design limits are not exceeded during normal operation and design basis anticipated operational occurrences.

2.1.2 REACTOR COOLANT SYSTEM PRESSURE

The restriction of this Safety Limit protects the integrity of the Reactor Coolant System from overpressurization and thereby prevents the release of radionuclides contained in the reactor coolant from reaching the containment atmosphere.

The Reactor Coolant System components are designed to Section III, 1974 Edition, Summer 1975 Addendum, of the ASME Code for Nuclear Power Plant Components which permits a maximum transient pressure of 110% (2750 psia) of design pressure. The Safety Limit of 2750 psia is therefore consistent with the design criteria and associated code requirements.

The entire Reactor Coolant System is hydrotested at 3125 psia to demonstrate integrity prior to initial operation.

2.2.1 REACTOR TRIP SETPOINTS

The Reactor Trip Setpoints specified in Table 2.2-1 are the values at which the Reactor Trips are set for each functional unit. The Trip Setpoints have been selected to ensure that the reactor core and Reactor Coolant System are prevented from exceeding their Safety Limits during normal operation and design basis anticipated operational occurrences and to assist the Engineered Safety Features Actuation System in mitigating the consequences of accidents. Operation with a trip set less conservative than its Trip Setpoint but within its specified Allowable Value is acceptable on the basis that the difference between each Trip Setpoint and the Allowable Value is equal to or less than the drift allowance assumed for each trip in the safety analyses.

The DNBR - Low and Local Power Density - High are digitally generated trip setpoints based on Safety Limits of 1.30 and 21 kW/ft, respectively. Since these trips are digitally generated by the Core Protection Calculators, the trip values are not subject to drifts common to trips generated by analog type - equipment. The Allowable Values for these trips are therefore the same as the Trip Setpoints.

To maintain the margins of safety assumed in the safety analyses, the calculations of the trip variables for the DNBR - Low and Local Power Density - High trips include the measurement, calculational and processor uncertainties and dynamic allowances as defined in the latest applicable revision of CEN-305-P, "Functional Design Requirements for a Core Protection Calculator," and CEN-304-P, "Functional Design Requirements for a Control Element Assembly Calculator."

BASES

٠.:,

Local Power Density - High (Continued)

- a. Nuclear flux power and axial power distribution from the excore flux monitoring system;
- b. Radial peaking factors from the position measurement for the CEAs;
- c. Delta T power from reactor coolant temperatures and coolant flow measurements.

The local power density (LPD), the trip variable, calculated by the CPC incorporates uncertainties and dynamic compensation routines. These uncertainties and dynamic compensation routines ensure that a reactor trip occurs when the actual core peak LPD is sufficiently less than the fuel design limit such that the increase in actual core peak LPD after the trip will not result in a violation of the Peak Linear Heat Rate Safety Limit. CPC uncertainties related to peak LPD are the same types used for DNBR calculation. Dynamic compensation for peak LPD is provided for the effects of core fuel centerline temperature delays (relative to changes in power density), sensor time delays, and protection system equipment time delays.

DNBR - Low

•••

The DNBR - Low trip is provided to prevent the DNBR in the limiting coolant channel in the core from exceeding the fuel design limit in the event of design bases anticipated operational occurrences. The DNBR - Low trip incorporates a low pressurizer pressure floor of 1860 psia. At this pressure a DNBR - Low trip will automatically occur. The DNBR is calculated in the CPC utilizing the following information:

- a. Nuclear flux power and axial power distribution from the excore neutron flux monitoring system;
- b. Reactor Coolant System pressure from pressurizer pressure measurement;
- c. Differential temperature (Delta T) power from reactor coolant temperature and coolant flow measurements;
- d. Radial peaking factors from the position measurement for the CEAs;
- e. Reactor coolant mass flow rate from reactor coolant pump speed;
- f. Core inlet temperature from reactor coolant cold leg temperature measurements.

SAFETY LIMITS AND LIMITING SAFETY SYSTEMS SETTINGS

- 2

BASES

DNBR - Low (Continued)

The DNBR, the trip variable, calculated by the CPC incorporates various uncertainties and dynamic compensation routines to assure a trip is initiated prior to violation of fuel design limits. These uncertainties and dynamic compensation routines ensure that a reactor trip occurs when the calculated core DNBR is sufficiently greater than 1.30 such that the decrease in calculated core DNBR-after the trip will not result in a violation of the DNBR Safety Limit. CPC uncertainties related to DNBR cover CPC input measurement uncertainties, algorithm modelling uncertainties, and computer equipment processing uncertainties. Dynamic compensation is provided in the CPC calculations for the effects of coolant transport delays, core heat flux delays (relative to changes in core power), sensor time delays, and protection system equipment time

The DNBR algorithm used in the CPC is valid only within the limits indicated below and operation outside of these limits will result in a CPC initiated trip.

.

Parameter

	raralleter	Limiting Value
a. b. c.	RCS Cold Leg Temperature-Low RCS Cold Leg Temperature-High Axial Shape Index-Positive Axial Shape Index-Norative	≥ 470°F ≤ 610°F Not more positive than + 0.5
e.	Pressurizer Pressure-Low	Not more negative than - 0.5
f.	Pressurizer Pressure-High	\geq 1000 psta < 2388 psta
g.	Integrated Radial Peaking	7 1000 bold
	Factor-Low	≥ 1.28
h.	Integrated Radial Peaking Factor-High	- < 7 00
i.	Quality Margin-Low	> 0

Steam Generator Level - High

The Steam Generator Level - High trip is provided to protect the turbine from excessive moisture carry over. Since the turbine is automatically tripped when the reactor is tripped, this trip provides a reliable means for providing protection to the turbine from excesssive moisture carryover. This trip's setpoint does not correspond to a safety limit, and provides protection in the event of excess feedwater flow. The setpoint is identical to the main steam isolation setpoint. Its functional capability at the specified trip setting enhances the overall reliability of the reactor protection system.

ADMINISTRATIVE CONTROLS

CORE OPERATING LIMITS REPORT

6.9.1.9 Core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT before each reload cycle or any remaining part of a reload cycle for the following:

- Shutdown Margin $K_{N,1}$ Any CEA Withdrawn for Specification 3.1.1.2 а.
- Moderator Temperature Coefficient BOL and EOL limits for b. Specification 3.1.1.3
- Boron Dilution Alarms for Specification 3.1.2.7 с.
- Movable Control Assemblies CEA Position for Specification 3.1.3.1 d.
- Regulating CEA Insertion Limits for Specification 3.1.3.6 e.
- f. Part Length CEA Insertion Limits for Specification 3.1.3.7
- Linear Heat Rate for Specification 3.2.1 q.
- Azimuthal Power Tilt T_q for Specification 3.2.3 DNBR Margin for Specification 3.2.4 ĥ.
- i.
- j. Axial Shape Index for Specification 3.2.7
- The analytical methods used to determine the core operating limits 6.9.1.10 shall be those previously reviewed and approved by the NRC in:
 - "CE Method for Control Element Assembly Ejection Analysis, "CENPDa. 0190-A, January 1976 (Methodology for Specification 3.1.3.6, Regulating CEA Insertion Limits).
 - "The ROCS and DIT Computer Codes for Nuclear Design," CENPD-266-P-A, b. April 1983 (Methodology for Specifications 3.1.1.2, Shutdown Margin K_{N-1} - Any CEA Withdrawn; 3.1.1.3, Moderator Temperature Coefficient BOL and EOL limits and 3.1.3.6, Regulating CEA Insertion Limits).
 - "Safety Evaluation Report related to the Final Design of the Standard с. Nuclear Steam Supply Reference Systems CESSAR System 80, Docket No. STN 50-470, "NUREG-0852 (Novenber 1981), Supplements No. 1 (March 1983), No. 2 (September 1983), No. 3 (December 1987) (Methodology for Specifications 3.1.1.2, Shutdown Margin K_{N-1} - Any CÉA Withdrawn; 3.1.1.3, Moderator Temperature Coefficient BOL and EOL limits; 3.1.2.7, Boron Dilution Alarms; 3.1.3.1, Movable Control Assemblies -CEA Position; 3.1.3.6, Regulating CEA Insertion Limits; 3.1.3.7, Part Length CEA Insertion Limits and 3.2.3 Azimuthal Power Tilt - T_n).

"Modified Statistical Combination of Uncertainties," CEN-356(V)-P-A **d**. Revision 01-P-A, May 1988 and "System 80™ Inlet Flow Distribution," Supplement 1-P to Enclosure 1-P to LD-82-054, February 1993 (Methodology for Specification 3.2.4, DNBR Margin and 3.2.7 Axial -Shape Index).

ADMINISTRATIVE CONTROLS

CORE OPERATING LIMITS REPORT (Continued)

- e. "Calculational Methods for the CE Large Break LOCA Evaluation Model," CENPD-132-P, August 1974 (Methodology for Specification 3.2.1, Linear Heat Rate).
- f. "Calculational Methods for the CE Large Break LOCA Evaluation Model," CENPD-132-P, Supplement 1, February 1975 (Methodology for Specification 3.2.1, Linear Heat Rate).
- g. "Calculational Methods for the CE Large Break LOCA Evaluation Model," CENPD-132-P, Supplement 2-P, July 1975 (Methodology for Specification 3.2.1, Linear Heat Rate).
- h. "Calculative Methods for the CE Small Break LOCA Evaluation Model," CENPD-137-P, August 1974 (Methodology for Specification 3.2.1, Linear Heat Rate).
- i. "Calculative Methods for the CE Small Break LOCA Evaluation Model," CENPD-137-P, Supplement 1P, January 1977 (Methodology for Specification 3.2.1, Linear Heat Rate).
- j. Letter: O. D. Parr (NRC) to F. M. Stern (CE), dated June 13, 1975 (NRC Staff Review of the Combustion Engineering ECCS Evaluation Model). NRC approval for: 6.9.1.10e, 6.9.1.10f, 6.9.1.10h.
- k. Letter: D. D. Parr (NRC) to A. E. Scherer (CE), dated December 9, 1975 (NRC Staff Review of the Proposed Combustion Engineering ECCS Evaluation Model Changes). NRC approval for: 6.9.1.10g.
- 1. Letter: K. Kniel (NRC) to A. E. Scherer (CE), dated September 27, 1977 (Evaluation of Topical Reports CENPD-133, Supplement 3-P and CENPD-137, Supplement 1-P). NRC approval for 6.9.1.10.1.

The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and analysis limits) of the safety analysis are met.

The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

PALD VERDE - UNIT 1



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

ARIZONA PUBLIC SERVICE COMPANY, ET AL.

DOCKET NO. STN 50-529

PALO VERDE NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 62 License No. NPF-51

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Arizona Public Service Company (APS or the licensee) on behalf of itself and the Salt River Project Agricultural Improvement and Power District, El Paso Electric Company, Southern California Edison Company, Public Service Company of New Mexico, Los Angeles Department of Water and Power, and Southern California Public Power Authority dated January 20, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations set forth in 10 CFR Part I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- 2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-51 is hereby amended to read as follows:

(2) <u>Technical Specifications and Environmental Protection Plan</u>

The Technical Specifications contained in Appendix A, as revised through Amendment $No.6^2$, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. APS shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of the date of issuance and must be fully implemented prior to the startup from Cycle 5 Refueling Outage.

FOR THE NUCLEAR REGULATORY COMMISSION

B_FZ AD For

Theodore R. Quay, Director Project Directorate IV-3 Division of Reactor Projects III/IV Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: May 26, 1994

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 62 TO FACILITY OPERATING LICENSE NO. NPF-51

DOCKET NO. STN 50-529

.

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove	<u>Insert</u>
2-1	2-1
2-3	2-3
B 2-1	B 2-1
B 2-2	B 2-2
B 2-6	B 2-6
6-20a	6-20a

2.0 SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.1 SAFETY LIMITS

2.1.1 <u>REACTOR_CORE</u>

DNBR

2.1.1.1 The calculated DNBR of the reactor core shall be maintained greater than or equal to 1.30.

APPLICABILITY: MODES 1 and 2.

ACTION:

Whenever the calculated DNBR of the reactor has decreased to less than 1.30, be in HOT STANDBY within 1 hour, and comply with the requirements of Specification 6.7.1.

PEAK LINEAR HEAT RATE

2.1.1.2 The peak linear heat rate (adjusted for fuel rod dynamics) of the fuel shall be maintained less than or equal to 21 kW/ft.

APPLICABILITY: MODES 1 and 2.

ACTION:

Whenever the peak linear heat rate (adjusted for fuel rod dynamics) of the fuel has exceeded 21 kW/ft, be in HOT STANDBY within 1 hour, and comply with the requirements of Specification 6.7.1.

REACTOR COOLANT SYSTEM PRESSURE

2.1.2 The Reactor Coolant System pressure shall not exceed 2750 psia.

APPLICABILITY: MODES 1, 2, 3, 4, and 5.

ACTION:

MODES 1 and 2:

Whenever the Reactor Coolant System pressure has exceeded 2750 psia, be in HOT STANDBY with the Reactor Coolant System pressure within its limit within 1 hour, and comply with the requirements of Specification 6.7.1.

MODES 3, 4, and 5:

Whenever the Reactor Coolant System pressure has exceeded 2750 psia, reduce the Reactor Coolant System pressure to within its limit within 5 minutes, and comply with the requirements of Specification 6.7.1.

SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.2 LIMITING SAFETY SYSTEM SETTINGS

REACTOR TRIP SETPOINTS

2.2.1 The reactor protective instrumentation setpoints shall be set consistent with the Trip Setpoint values shown in Table 2.2-1.

APPLICABILITY: As shown for each channel in Table 3.3-1.

ACTION:

With a reactor protective instrumentation setpoint less conservative than the value shown in the Allowable Values column of Table 2.2-1, declare the channel inoperable and apply the applicable ACTION statement requirement of Specification 3.3.1 until the channel is restored to OPERABLE status with its trip setpoint adjusted consistent with the Trip Setpoint value.

<u>TABLE 2.2-1</u>

REACTOR PROTECTIVE INSTRUMENTATION TRIP SETPOINT LIMITS

	FUN	CTION	AL_UNIT	TRIP SETPOINT	ALLOWABLE VALUES
1.	L. TRIP GENERATION		ERATION		
	Α.	Proc	ess		
		1.	Pressurizer Pressure – High	≤ 2383 psia	≤ 2388 psia
		2.	Pressurizer Pressure - Low	≥ 1837 psia (2)	≥ 1821 psia (2)
		3.	Steam Generator Level - Low	≥ 44.2% (4)	≥ 43.7% (4)
		4.	Steam Generator Level - High	≤ 91.0% (9)	≤ 91.5% (9)
		5.	Steam Generator Pressure - Low	≥ 919 psia (3)	≥ 911 psia (3)
		6.	Containment Pressure - High	≤ 3.0 psig	≤ 3.2 psig
		7.	Reactor Coolant Flow - Low		
			a. Rate	≤ 0.115 psi/sec (6)(7)	≤ 0.118 psi/sec (6)(7)
			b. Floor	≥ 11.9 psid (6)(7)	≥ 11.7 psid(6)(7)
			c. Band	≤ 10.0 psid (6)(7)	≤ 10.2 psid (6)(7)
		8.	Local Power Density - High	≤ 21.0 kW/ft (5)	≤ 21.0 kW/ft (5)
•		9.	DNBR - Low	≥ 1.30 (5)	≥ 1.30 (5)
	Β.	Exco	re Neutron Flux		
		1.	Variable Overpower Trip		
			a. Rate	≤10.6%/min of RATED THERMAL POWER (8)	≤11.0%/min of RATED THERMAL POWER (8)
			b. Ceiling	≤110.0% of RATED THERMAL POWER (8)	≤111.0% of RATED THERMAL POWER (8)
			c. Band	≤9.7% of RATED THERMAL POWER (8)	≤9.9% of RATED THERMAL POWER (8)

PALO VERDE - UNIT 2

2-3

AMENDMENT NO. 19, 62

TABLE 2.2-1 (Continued)

REACTOR PROTECTIVE INSTRUMENTATION TRIP SETPOINT LIMITS

	<u>FUNCTIONAL_UNIT</u> 2. Logarithmic Power Level - High (1)		TRIP SETPOINT	ALLOWABLE VALUES	
		a. Startup and Operating	< 0.010% of RATED THERMAL POWER	< 0.011% of RATED THERMAL POWER	
		b. Shutdown	< 0.010% of RATED THERMAL POWER	< 0.011% of RATED THERMAL POWER	
	C.	Core Protection Calculator System			
ł		1. CEA Calculators	Not Applicable	Not Applicable	
	•	2. Core Protection Calculators	Not Applicable	Not Applicable	
•	D.	Supplementary Protection System		•	
		Pressurizer Pressure – High	<u><</u> 2409 psia	<u><</u> 2414 psia	
11.	RPS	LOGIC			
	۸.	Matrix Logic	Not Applicable	Not Applicable	
	8.	Initiation Logic	Not.Applicable	Not Applicable	
111.	RPS	ACTUATION DEVICES			
	۸.	Reactor Trip Breakers	Not Applicable	Not Applicable	
	B.	Manual!Trip	Not Applicable	Not Applicable	

2.1 and 2.2 SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

BASES

2.1.1 REACTOR CORE

The restrictions of these safety limits prevent overheating of the fuel cladding and possible cladding perforation which would result in the release of fission products to the reactor coolant. Overheating of the fuel cladding is prevented by (1) restricting fuel operation to within the nucleate toiling regime where the heat transfer coefficient is large and the cladding surface temperature is slightly above the coolant saturation temperature, and (2) maintaining the dynamically adjusted peak linear heat rate of the fuel at or less than 21 kW/ft which will not cause fuel centerline melting in any fuel rod.

First, by operating within the nucleate boiling regime of heat transfer, the heat transfer coefficient is large enough so that the maximum clad surface temperature is only slightly greater than the coolant saturation temperature. The upper boundary of the nucleate boiling regime is termed "departure from nucleate boiling" (DNB). At this point, there is a sharp reduction of the heat transfer coefficient, which would result in higher cladding temperatures and the possibility of cladding failure.

Correlations predict DNB and the location of DNB for axially uniform and non-uniform heat flux distributions. The local DNB ratio (DNBR), defined as the ratio of the predicted DNB heat flux at a particular core location to the actual heat flux at that location, is indicative of the margin to DNB. The minimum value of DNBR during normal operation and design basis anticipated operational occurrences is limited to 1.30 based upon a statistical combination of CE-1 CHF correlation and engineering factor uncertainties and is established as a Safety Limit. The DNBR limit of 1.30 includes a rod bow compensation of 1.75% on DNBR.

Second, operation with a peak linear heat rate below that which would cause fuel centerline melting maintains fuel rod and cladding integrity. Above this peak linear heat rate level (i.e., with some melting in the center), fuel rod integrity would be maintained only if the design and operating conditions are appropriate throughout the life of the fuel rods. Volume changes which accompany the solid to liquid phase change are significant and require accommodation. Another consideration involves the redistribution of the fuel which depends on the extent of the melting and the physical state of the fuel rod at the time of melting. Because of the above factors, the steady state value of the peak linear heat rate which would not cause fuel centerline melting is established as a Safety Limit. To account for fuel rod dynamics (lags), the directly indicated linear heat rate is dynamically adjusted by the CPC program.

BASES

Limiting Safety System Settings for the Low DNBR, High Local Power Density, High Logarithmic Power Level, Low Pressurizer Pressure and High Linear Power Level trips, and Limiting Conditions for Operation on DNBR and kW/ftmargin are specified such that there is a high degree of confidence that the specified acceptable fuel design limits are not exceeded during normal operation and design basis anticipated operational occurrences.

2.1.2 REACTOR COOLANT SYSTEM PRESSURE

The restriction of this Safety Limit protects the integrity of the Reactor Coolant System from overpressurization and thereby prevents the release of radionuclides contained in the reactor coolant from reaching the containment atmosphere.

The Reactor Coolant System components are designed to Section III, 1974 Edition, Summer 1975 Addendum, of the ASME Code for Nuclear Power Plant Components which permits a maximum transient pressure of 110% (2750 psia) of design pressure. The Safety Limit of 2750 psia is therefore consistent with the design criteria and associated code requirements.

The entire Reactor Coolant System is hydrotested at 3125 psia to demonstrate integrity prior to initial operation.

2.2.1 REACTOR TRIP SETPOINTS

The Reactor Trip Setpoints specified in Table 2.2-1 are the values at which the Reactor Trips are set for each functional unit. The Trip Setpoints have been selected to ensure that the reactor core and Reactor Coolant System are prevented from exceeding their Safety Limits during normal operation and design basis anticipated operational occurrences and to assist the Engineered Safety Features Actuation System in mitigating the consequences of accidents. Operation with a trip set less conservative than its Trip Setpoint but within its specified Allowable Value is acceptable on the basis that the difference between each Trip Setpoint and the Allowable Value is equal to or less than the drift allowance assumed for each trip in the safety analyses.

The DNBR - Low and Local Power Density - High are digitally generated trip setpoints based on Safety Limits of 1.30 and 21 kW/ft, respectively. Since these trips are digitally generated by the Core Protection Calculators, the trip values are not subject to drifts common to trips generated by analog type equipment. The Allowable Values for these trips are therefore the same as the Trip Setpoints.

To maintain the margins of safety assumed in the safety analyses, the calculations of the trip variables for the DNBR - Low and Local Power Density - High trips include the measurement, calculational and processor uncertainties and dynamic allowances as defined in the latest applicable revision of CEN-305-P, "Functional Design Requirements for a Core Protection Calculator," and CEN-304-P, "Functional Design Requirements for a Control Element Assembly Calculator."

BASES

Local Power Density - High (Continued)

- a. Nuclear flux power and axial power distribution from the excore flux monitoring system;
- b. Radial peaking factors from the position measurement for the CEAs;
 - c. Delta T power from reactor coolant temperatures and coolant flow measurements.

The local power density (LPD), the trip variable, calculated by the CPC incorporates uncertainties and dynamic compensation routines. These uncertainties and dynamic compensation routines ensure that a reactor trip occurs when the actual core peak LPD is sufficiently less than the fuel design limit such that the increase in actual core peak LPD after the trip will not result in a violation of the Peak Linear Heat Rate Safety Limit. CPC uncertainties related to peak LPD are the same types used for DNBR calculation. Dynamic compensation for peak LPD is provided for the effects of core fuel centerline temperature delays (relative to changes in power density), sensor time delays, and protection system equipment time delays.

DNBR - Low

The DNBR - Low trip is provided to prevent the DNBR in the limiting coolant channel in the core from exceeding the fuel design limit in the event of design bases anticipated operational occurrences. The DNBR - Low trip incorporates a low pressurizer pressure floor of 1860 psia. At this pressure a DNBR - Low trip will automatically occur. The DNBR is calculated in the CPC utilizing the following information:

- a. Nuclear flux power and axial power distribution from the excore neutron flux monitoring system;
- b. Reactor Coolant System pressure from pressurizer pressure measurement;
- c. Differential temperature (Delta T) power from reactor coolant temperature and coolant flow measurements;
- d. Radial peaking factors from the position measurement for the CEAs;
- e. Reactor coolant mass flow rate from reactor coolant pump speed;
- f. Core inlet temperature from reactor coolant cold leg temperature measurements.

SAFETY LIMITS AND LIMITING SAFETY SYSTEMS SETTINGS

BASES

DNBR - Low (Continued)

The DNBR, the trip variable, calculated by the CPC incorporates various uncertainties and dynamic compensation routines to assure a trip is initiated prior to violation of fuel design limits. These uncertainties and dynamic compensation routines ensure that a reactor trip occurs when the calculated core DNBR is sufficiently greater than 1.30 such that the decrease in calculated core DNBR after the trip will not result in a violation of the DNBR Safety Limit. CPC uncertainties related to DNBR cover CPC input measurement uncertainties, algorithm modelling uncertainties, and computer equipment processing uncertainties. Dynamic compensation is provided in the CPC calculations for the effects of coolant transport delays, core heat flux delays (relative to changes in core power), sensor time delays, and protection system equipment time delays.

The DNBR algorithm used in the CPC is valid only within the limits indicated below and operation outside of these limits will result in a CPC initiated trip.

<u>Paramet**er**</u>

<u>Limiting Value</u>

a. b. c.	RCS Cold Leg Temperature-Low RCS Cold Leg Temperature-High Axial Shape Index-Positive	\geq 470°F \leq 610°F Not more positive than + 0 F
d.	Axial Shape Index-Negative	Not more negative than -0.5
e.	Pressurizer Pressure-Low	> 1860 psia
f.	Pressurizer Pressure-High	<u><</u> 2388 psia
g.	Integrated Radial Peaking	
	Factor-Low	≥ 1.28
h.	Integrated Radial Peaking	
	Factor-High	≤ 7.00
i.	Quality Margin-Low	> 0

<u>Steam Generator Level - High</u>

The Steam Generator Level - High trip is provided to protect the turbine from excessive moisture carry over. Since the turbine is automatically tripped when the reactor is tripped, this trip provides a reliable means for providing protection to the turbine from excessive moisture carryover. This trip's setpoint does not correspond to a safety limit, and provides protection in the event of excess feedwater flow. The setpoint is identical to the main steam isolation setpoint. Its functional capability at the specified trip setting enhances the overall reliability of the reactor protection system.

ADMINISTRATIVE CONTROLS

CORE OPERATING LIMITS REPORT

6.9.1.9 Core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT before each reload cycle or any remaining part of a reload cycle for the following:

- a. Shutdown Margin K_{N-1} Any CEA Withdrawn for Specification 3.1.1.2
- b. Moderator Temperature Coefficient BOL and EOL limits for Specification 3.1.1.3
- -c. Boron Dilution Alarms for Specification 3.1.2.7
- d. Movable Control Assemblies CEA Position for Specification 3.1.3.1
- e. Regulating CEA Insertion Limits for Specification 3.1.3.6
- f. Part Length CEA Insertion Limits for Specification 3.1.3.7
- g. Linear Heat Rate for Specification 3.2.1
- h. Azimuthal Power Tilt T_q for Specification 3.2.3
- i. DNBR Margin for Specification 3.2.4
- j. Axial Shape Index for Specification 3.2.7
- 6.9.1.10 The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC in:
 - a. "CE Method for Control Element Assembly Ejection Analysis," CENPD-0190-A, January 1976 (Methodology for Specification 3.1.3.6, Regulating CEA Insertion Limits).
 - b. "The ROCS and DIT Computer Codes for Nuclear Design," CENPD-266-P-A, April 1983 (Methodology for Specifications 3.1.1.2, Shutdown Margin K_{N-1} - Any CEA Withdrawn; 3.1.1.3, Moderator Temperature Coefficient BOL and EOL limits and 3.1.3.6, Regulating CEA Insertion Limits).
 - c. "Safety Evaluation Report related to the Final Design of the Standard Nuclear Steam Supply Reference Systems CESSAR System 80, Docket No. STN 50-470, "NUREG-0852 (Novenber 1981), Supplements No. 1 (March 1983), No. 2 (September 1983), No. 3 (December 1987) (Methodology for Specifications 3.1.1.2, Shutdown Margin K_{N-1} - Any CEA Withdrawn; 3.1.1.3, Moderator Temperature Coefficient BOL and EOL limits; 3.1.2.7, Boron Dilution Alarms; 3.1.3.1, Movable Control Assemblies -CEA Position; 3.1.3.6, Regulating CEA Insertion Limits; 3.1.3.7, Part Length CEA Insertion Limits and 3.2.3 Azimuthal Power Tilt - T_o).
 - d. "Modified Statistical Combination of Uncertainties," CEN-356(V)-P-A Revision 01-P-A, May 1988 and "System 80™ Inlet Flow Distribution," Supplement 1-P to Enclosure 1-P to LD-82-054, February 1993 (Methodology for Specification 3.2.4, DNBR Margin and 3.2.7 Axial Shape Index).

ADMINISTRATIVE CONTROLS

CORE OPERATING LIMITS REPORT (Continued)

- e. "Calculational Methods for the CE Large Break LOCA Evaluation Model," CENPD-132-P, August 1974 (Methodology for Specification 3.2.1, Linear Heat Rate).
- f. "Calculational Methods for the CE Large Break LOCA Evaluation Model," CENPD-132-P, Supplement 1, February 1975 (Methodology for Specification 3.2.1, Linear Heat Rate).
- g. "Calculational Methods for the CE Large Break LOCA Evaluation Model," CENPD-132-P, Supplement 2-P, July 1975 (Methodology for Specification 3.2.1, Linear Heat Rate).
- h. "Calculative Methods for the CE Small Break LOCA Evaluation Model," CENPD-137-P, August 1974 (Methodology for Specification 3.2.1, Linear Heat Rate).
- i. "Calculative Methods for the CE Small Break LOCA Evaluation Model," CENPD-137-P, Supplement 1P, January 1977 (Methodology for Specification 3.2.1, Linear Heat Rate).
- j. Letter: O. D. Parr (NRC) to F. M. Stern (CE), dated June 13, 1975 (NRC Staff Review of the Combustion Engineering ECCS Evaluation Model). NRC approval for: 6.9.1.10e, 6.9.1.10f, 6.9.1.10h.
- k. Letter: O. D. Parr (NRC) to A. E. Scherer (CE), dated December 9, 1975 (NRC Staff Review of the Proposed Combustion Engineering ECCS Evaluation Model Changes). NRC approval for: 6.9.1.10g.
- Letter: K. Kniel (NRC) to A. E. Scherer (CE), dated September 27, 1977 (Evaluation of Topical Reports CENPD-133, Supplement 3-P and CENPD-137, Supplement 1-P). NRC approval for 6.9.1.10.i.

The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and analysis limits) of the safety analysis are met.

The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.

.



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

ARIZONA PUBLIC SERVICE COMPANY, ET AL.

DOCKET NO. STN 50-530

PALO VERDE NUCLEAR GENERATING STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 48 License No. NPF-74

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Arizona Public Service Company (APS or the licensee) on behalf of itself and the Salt River Project Agricultural Improvement and Power District, El Paso Electric Company, Southern California Edison Company, Public Service Company of New Mexico, Los Angeles Department of Water and Power, and Southern California Public Power Authority dated January 20, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-74 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 48, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated into this license. APS shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

3. This license amendment is effective as of the date of issuance and must be fully implemented prior to the startup from Cycle 4 Refueling Outage.

FOR THE NUCLEAR REGULATORY COMMISSION

Br E. Hol For

Theodore R. Quay, Director Project Directorate IV-3 Division of Reactor Projects III/IV Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: May 26, 1994

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 48 TO FACILITY OPERATING LICENSE NO. NPF-74

DOCKET NO. STN 50-530

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change.

Remove	<u>Insert</u>
2-1	2-1
2-3	2-3
B 2-1	B 2-1
B 2-2	B 2-2
B 2-6	B 2-6
6-20a	6-20a

2.0 SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.1 SAFETY LIMITS

2.1.1 <u>REACTOR CORE</u>

<u>DNBR</u>

2.1.1.1 The calculated DNBR of the reactor core shall be maintained greater than or equal to 1.30.

APPLICABILITY: MODES 1 and 2.

ACTION:

Whenever the calculated DNBR of the reactor has decreased to less than 1.30, be in HOT STANDBY within 1 hour, and comply with the requirements of Specification 6.7.1.

PEAK LINEAR HEAT RATE

2.1.1.2 The peak linear heat rate (adjusted for fuel rod dynamics) of the fuel shall be maintained less than or equal to 21 kW/ft.

APPLICABILITY: MODES 1 and 2.

ACTION:

Whenever the peak linear heat rate (adjusted for fuel rod dynamics) of the fuel has exceeded 21 kW/ft, be in HOT STANDBY within 1 hour, and comply with the requirements of Specification 6.7.1.

REACTOR COOLANT SYSTEM PRESSURE

2.1.2 The Reactor Coolant System pressure shall not exceed 2750 psia.

APPLICABILITY: MODES 1, 2, 3, 4, and 5.

<u>ACTION:</u>

MODES 1 and 2:

Whenever the Reactor Coolant System pressure has exceeded 2750 psia, be in HOT STANDBY with the Reactor Coolant System pressure within its limit within 1 hour, and comply with the requirements of Specification 6.7.1.

MODES 3, 4, and 5:

Whenever the Reactor Coolant System pressure has exceeded 2750 psia, reduce the Reactor Coolant System pressure to within its limit within 5 minutes, and comply with the requirements of Specification 6.7.1.

SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

2.2 LIMITING SAFETY SYSTEM SETTINGS

REACTOR TRIP SETPOINTS

2.2.1 The reactor protective instrumentation setpoints shall be set consistent with the Trip Setpoint limits shown in Table 2.2-1.

APPLICABILITY: As shown for each channel in Table 3.3-1.

ACTION:

With a reactor protective instrumentation setpoint less conservative than the value shown in the Allowable Values column of Table 2.2-1, declare the channel inoperable and apply the applicable ACTION statement requirement of Specification 3.3.1 until the channel is restored to OPERABLE status with its trip setpoint adjusted consistent with the Trip Setpoint value.

١

TABLE 2.2-1

• • ...

REACTOR PROTECTIVE INSTRUMENTATION TRIP SETPOINT LIMITS

	FUNCTIONAL UNIT		AL UNIT	TRIP_SETPOINT	ALLOWABLE VALUES	
1.	TRIP GENERATION					
	Α.	Proc	ess			
		1.	Pressurizer Pressure - High	≤ 2383 psia	≤ 2388 psia	
		2.	Pressurizer Pressure - Low	≥ 1837 psia (2)	≥ 1821 psia (2)	
		3.	Steam Generator Level - Low	≥ 44.2% (4)	≥ 43.7% (4)	
		4.	Steam Generator Level - High	≤ 91.0% (9)	≤ 91.5% (9)	
		5.	Steam Generator Pressure - Low	≥ 919 psia (3)	≥ 912 psia (3)	
		6.	Containment Pressure - High	≤ 3.0 psig	≤ 3.2 psig	
		7.	Reactor Coolant Flow - Low			
			a. Rate	≤ 0.115 psi/sec (6)(7)	≤ 0.118 psi/sec (6)(7)	
			b. Floor	≥ 11.9 psid (6)(7)	≥ 11.7 psid(6)(7)	
		1	c. Band	≤ 10.0 psid (6)(7)	≤ 10.2 psid (6)(7)	
		8.	Local Power Density - High	≤ 21.0 kW/ft (5)	≤ 21.0 kW/ft (5)	
		9.	DNBR - Low	≥ 1.30 (5)	≥ 1.30 (5)	
	Β.	Exco	re Neutron Flux			
		1.	Variable Overpower Trip			
			a. Rate	≤10.6%/min of RATED THERMAL POWER (8)	≤11.0%/min of RATED THERMAL POWER (8)	
			b. Ceiling	≤110.0% of RATED THERMAL POWER (8)	≤111.0% of RATED THERMAL POWER (8)	
		ſ	c. Band	≤9.8% of RATED THERMAL POWER (8)	≤10.0% of RATED THERMAL POWER (8)	

2-3

TABLE 2.2-1 (Continued)

REACTOR PROTECTIVE INSTRUMENTATION TRIP SETPOINT LIMITS

	FUN	ICTIONAL L	INIT	TRIP SETPOINT	ALLOWABLE VALUES
		2. Loga	rithmic Power Level - High (1)		
		a.	Startup and Operating	< 0.010% of RATED Thermal Power	< 0.011% of RATED THERMAL POWER
		b.	Shutdown	< 0.010% of RATED Thermal Power	< 0.011% of RATED THERMAL POWER
	C.	Core Pro	tection Calculator System		
		1. CEA	Calculators	Not Applicable	Not Applicable
		2. Core	Protection Calculators	Not Applicable	Not Applicable
	D.	Suppleme	ntary Protection System		
		Pressuri	zer Pressure - High	<u><</u> 2409 psia	<u>≤</u> 2414 psia
II.	RPS	LOGIC			
	A .	Matrix L	ogic	Not Applicable	Not Applicable
	B.	Initiati	on Logic	Not Applicable	Not Applicable
III.	RPS	ACTUATIO	N DEVICES		
	۸.	Reactor	Trip Breakers	Not Applicable	Not Applicable
	B.	Manual Tr	rip	Not Applicable	Not Applicable

2.1 and 2.2 SAFETY LIMITS AND LIMITING SAFETY SYSTEM SETTINGS

BASES

2.1.1 REACTOR CORE

The restrictions of these safety limits prevent overheating of the fuel cladding and possible cladding perforation which would result in the release of fission products to the reactor coolant. Overheating of the fuel cladding is prevented by (1) restricting fuel operation to within the nucleate boiling regime where the heat transfer coefficient is large and the cladding surface temperature is slightly above the coolant saturation temperature, and (2) maintaining the dynamically adjusted peak linear heat rate of the fuel at or less than 21 kW/ft which will not cause fuel centerline melting in any fuel rod.

First, by operating within the nucleate boiling regime of heat transfer, the heat transfer coefficient is large enough so that the maximum clad surface temperature is only slightly greater than the coolant saturation temperature. The upper boundary of the nucleate boiling regime is termed "departure from nucleate boiling" (DNB). At this point, there is a sharp reduction of the heat transfer coefficient, which would result in higher cladding temperatures and the possibility of cladding failure.

Correlations predict DNB and the location of DNB for axially uniform and non-uniform heat flux distributions. The local DNB ratio (DNBR), defined as the ratio of the predicted DNB heat flux at a particular core location to the actual heat flux at that location, is indicative of the margin to DNB. The minimum value of DNBR during normal operation and design basis anticipated operational occurrences is limited to 1.30 based upon a statistical combination of CE-1 CHF correlation and engineering factor uncertainties and is established as a Safety Limit. The DNBR limit of 1.30 includes a rod bow compensation of 1.75% on DNBR.

Second, operation with a peak linear heat rate below that which would cause fuel centerline melting maintains fuel rod and cladding integrity. Above this peak linear heat rate level (i.e., with some melting in the center), fuel rod integrity would be maintained only if the design and operating conditions are appropriate throughout the life of the fuel rods. Volume changes which accompany the solid to liquid phase change are significant and require accommodation. Another consideration involves the redistribution of the fuel which depends on the extent of the melting and the physical state of the fuel rod at the time of melting. Because of the above factors, the steady state value of the peak linear heat rate which would not cause fuel centerline melting is established as a Safety Limit. To account for fuel rod dynamics (lags), the directly indicated linear heat rate is dynamically adjusted by the CPC program.

BASES

Limiting Safety System Settings for the Low DNBR, High Local Power Density, High Logarithmic Power Level, Low Pressurizer Pressure and High Linear Power Level trips, and Limiting Conditions for Operation on DNBR and kW/ftmargin are specified such that there is a high degree of confidence that the specified acceptable fuel design limits are not exceeded during normal operation and design basis anticipated operational occurrences.

2.1.2 REACTOR COOLANT SYSTEM PRESSURE

The restriction of this Safety Limit protects the integrity of the Reactor Coolant System from overpressurization and thereby prevents the release of radionuclides contained in the reactor coolant from reaching the containment atmosphere.

The Reactor Coolant System components are designed to Section III, 1974 Edition, Summer 1975 Addendum, of the ASME Code for Nuclear Power Plant Components which permits a maximum transient pressure of 110% (2750 psia) of design pressure. The Safety Limit of 2750 psia is therefore consistent with the design criteria and associated code requirements.

The entire Reactor Coolant System is hydrotested at 3125 psia to demonstrate integrity prior to initial operation.

2.2.1 REACTOR TRIP SETPOINTS

The Reactor Trip Setpoints specified in Table 2.2-1 are the values at which the Reactor Trips are set for each functional unit. The Trip Setpoints have been selected to ensure that the reactor core and Reactor Coolant System are prevented from exceeding their Safety Limits during normal operation and design basis anticipated operational occurrences and to assist the Engineered Safety Features Actuation System in mitigating the consequences of accidents. Operation with a trip set less conservative than its Trip Setpoint but within its specified Allowable Value is acceptable on the basis that the difference between each Trip Setpoint and the Allowable Value is equal to or less than the drift allowance assumed for each trip in the safety analyses.

The DNBR - Low and Local Power Density - High are digitally generated trip setpoints based on Safety Limits of 1.30 and 21 kW/ft, respectively. Since these trips are digitally generated by the Core Protection Calculators, the trip values are not subject to drifts common to trips generated by analog type equipment. The Allowable Values for these trips are therefore the same as the Trip Setpoints.

To maintain the margins of safety assumed in the safety analyses, the calculations of the trip variables for the DNBR - Low and Local Power Density - High trips include the measurement, calculational and processor uncertainties and dynamic allowances as defined in the latest applicable revision of CEN-305-P, "Functional Design Requirements for a Core Protection Calculator" and CEN-304-P, "Functional Design Requirements for a Control Element Assembly Calculator."

BASES

Local Power Density - High (Continued)

- a. Nuclear flux power and axial power distribution from the excore flux monitoring system;
- b. Radial peaking factors from the position measurement for the CEAs;
- c. Delta T power from reactor coolant temperatures and coolant flow measurements.

The local power density (LPD), the trip variable, calculated by the CPC incorporates uncertainties and dynamic compensation routines. These uncertainties and dynamic compensation routines ensure that a reactor trip occurs when the actual core peak LPD is sufficiently less than the fuel design limit such that the increase in actual core peak LPD after the trip will not result in a violation of the Peak Linear Heat Rate Safety Limit. CPC uncertainties compensation for peak LPD is provided for the effects of core fuel centerline temperature delays (relative to changes in power density), sensor time delays, and protection system equipment time delays.

DNBR - Low

The DNBR - Low trip is provided to prevent the DNBR in the limiting coolant channel in the core from exceeding the fuel design limit in the event of design bases anticipated operational occurrences. The DNBR - Low trip incorporates a low pressurizer pressure floor of 1860 psia. At this pressure a DNBR - Low trip will automatically occur. The DNBR is calculated in the CPC utilizing the following information:

- a. Nuclear flux power and axial power distribution from the excore neutron flux monitoring system;
- b. Reactor Coolant System pressure from pressurizer pressure measurement;
- Differential temperature (Delta T) power from reactor coolant temperature and coolant flow measurements;
- d. Radial peaking factors from the position measurement for the CEAs;
- e. Reactor coolant mass flow rate from reactor coolant pump speed;
- f. Core inlet temperature from reactor coolant cold leg temperature measurements.

SAFETY LIMITS AND LIMITING SAFETY SYSTEMS SETTINGS

BASES

<u>DNBR - Low</u> (Continued)

The DNBR, the trip variable, calculated by the CPC incorporates various uncertainties and dynamic compensation routines to assure a trip is initiated prior to violation of fuel design limits. These uncertainties and dynamic compensation routines ensure that a reactor trip occurs when the calculated core DNBR is sufficiently greater than 1.30 such that the decrease in calculated core DNBR after the trip will not result in a violation of the DNBR Safety Limit. CPC uncertainties related to DNBR cover CPC input measurement uncertainties, algorithm modelling uncertainties, and computer equipment processing uncertainties. Dynamic compensation is provided in the CPC calculations for the effects of coolant transport delays, core heat flux delays (relative to changes in core power), sensor time delays, and protection system equipment time delays.

The DNBR algorithm used in the CPC is valid only within the limits indicated below and operation outside of these limits will result in a CPC initiated trip.

Parameter

Limiting Value

a. b. c. d. e. f. g.	RCS Cold Leg Temperature-Low RCS Cold Leg Temperature-High Axial Shape Index-Positive Axial Shape Index-Negative Pressurizer Pressure-Low Pressurizer Pressure-High Integrated Radial Peaking Factor-Low	\geq 470°F \leq 610°F Not more positive than + 0.5 Not more negative than - 0.5 \geq 1860 psia \leq 2388 psia \geq 1.28
h.	Integrated Radial Peaking Factor-High	< 7.00
i.	Quality Margin-Low	> 0

<u>Steam Generator Level - High</u>

The Steam Generator Level - High trip is provided to protect the turbine from excessive moisture carry over. Since the turbine is automatically tripped when the reactor is tripped, this trip provides a reliable means for providing protection to the turbine from excesssive moisture carryover. This trip's setpoint does not correspond to a safety limit, and provides protection in the event of excess feedwater flow. The setpoint is identical to the main steam isolation setpoint. Its functional capability at the specified trip setting enhances the overall reliability of the reactor protection system.

ADMINISTRATIVE CONTROLS

CORE OPERATING LIMITS REPORT

6.9.1.9 Core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT before each reload cycle or any remaining part of a reload cycle for the following:

- a. Shutdown Margin K_{N-1} - Any CEA Withdrawn for Specification 3.1.1.2
- b. Moderator Temperature Coefficient BOL and EOL limits for Specification 3.1.1.3
- Boron Dilution Alarms for Specification 3.1.2.7 с.
- Movable Control Assemblies CEA Position for Specification 3.1.3.1 d.
- Regulating CEA Insertion Limits for Specification 3.1.3.6 e.
- f. Part Length CEA Insertion Limits for Specification 3.1.3.7
- Linear Heat Rate for Specification 3.2.1 g.
- Azimuthal Power Tilt T_q for Specification 3.2.3 DNBR Margin for Specification 3.2.4 h.
- i.
- j. Axial Shape Index for Specification 3.2.7
- 6.9.1.10 The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC in:
 - "CE Method for Control Element Assembly Ejection Analysis," а. CENPD-0190-A, January 1976 (Methodology for Specification 3.1.3.6, Regulating CEA Insertion Limits).
 - b. "The ROCS and DIT Computer Codes for Nuclear Design," CENPD-266-P-A, April 1983 (Methodology for Specifications 3.1.1.2, Shutdown Margin K_{N-1} - Any CEA Withdrawn; 3.1.1.3, Moderator Temperature Coefficient BOL and EOL limits and 3.1.3.6, Regulating CEA Insertion Limits).
 - "Safety Evaluation Report related to the Final Design of the Standard с. Nuclear Steam Supply Reference Systems CESSAR System 80, Docket No. STN 50-470, "NUREG-0852 (November 1981), Supplements No. 1 (March 1983), No. 2 (September 1983), No. 3 (December 1987) (Methodology for Specifications 3.1.1.2, Shutdown Margin K_{N-1} - Any CÉA Withdrawn; 3.1.1.3, Moderator Temperature Coefficient BOL and EOL limits; 3.1.2.7, Boron Dilution Alarms; 3.1.3.1, Movable Control Assemblies -CEA Position; 3.1.3.6, Regulating CEA Insertion Limits; 3.1.3.7, Part Length CEA Insertion Limits and 3.2.3 Azimuthal Power Tilt $-T_{a}$).
 - d. "Modified Statistical Combination of Uncertainties," CEN-356(V)-P-A Revision 01-P-A, May 1988 and "System 80™ Inlet Flow Distribution," Supplement 1-P to Enclosure 1-P to LD-82-054, February 1993 (Methodology for Specification 3.2.4, DNBR Margin and 3.2.7 Axial Shape Index).

ADMINISTRATIVE CONTROLS

CORE OPERATING LIMITS REPORT (Continued)

- e. "Calculational Methods for the CE Large Break LOCA Evaluation Model," CENPD-132-P, August 1974 (Methodology for Specification 3.2.1, Linear Heat Rate).
- f. "Calculational Methods for the CE Large Break LOCA Evaluation Model," CENPD-132-P, Supplement 1, February 1975 (Methodology for Specification 3.2.1, Linear Heat Rate).
- g. "Calculational Methods for the CE Large Break LOCA Evaluation Model," CENPD-132-P, Supplement 2-P, July 1975 (Methodology for Specification 3.2.1, Linear Heat Rate).
- h. "Calculative Methods for the CE Small Break LOCA Evaluation Model," CENPD-137-P, August 1974 (Methodology for Specification 3.2.1, Linear Heat Rate).
- i. "Calculative Methods for the CE Small Break LOCA Evaluation Model," CENPD-137-P, Supplement 1P, January 1977 (Methodology for Specification 3.2.1, Linear Heat Rate).
- j. Letter: O. D. Parr (NRC) to F. M. Stern (CE), dated June 13, 1975 (NRC Staff Review of the Combustion Engineering ECCS Evaluation Model). NRC approval for: 6.9.1.10e, 6.9.1.10f, 6.9.1.10h.
- k. Letter: O. D. Parr (NRC) to A. E. Scherer (CE), dated December 9, 1975 (NRC Staff Review of the Proposed Combustion Engineering ECCS Evaluation Model Changes). NRC approval for: 6.9.1.10g
- Letter: K. Kniel (NRC) to A. E. Scherer (CE), dated September 27, 1977 (Evaluation of Topical Reports CENPD-133, Supplement 3-P and CENPD-137, Supplement 1-P). NRC approval for 6.9.1.10.i.

The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as shutdown margin, and transient and analysis limits) of the safety analysis are met.

The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector.



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION RELATED TO AMENDMENT NO. 76 TO FACILITY OPERATING LICENSE NO. NPF-41.

AMENDMENT NO. 62 TO FACILITY OPERATING LICENSE NO. NPF-51.

AND AMENDMENT NO. 48 TO FACILITY OPERATING LICENSE NO. NPF-74

ARIZONA PUBLIC SERVICE COMPANY, ET AL.

PALO VERDE NUCLEAR GENERATING STATION, UNIT NOS. 1, 2, AND 3

DOCKET NOS. STN 50-528, STN 50-529, AND STN 50-530

1.0 BACKGROUND

In a letter of March 30, 1993 (Ref. 1), Arizona Public Service Company (APS) requested U.S. Nuclear Regulatory Commission (NRC) review of Supplement 1-P to Enclosure 1-P to LD-82-054, "System 80^{TM} Inlet Flow Distribution." Enclosure 1P to LD-82-054, "Statistical Combination of Uncertainties - of System Parameter Uncertainties in Thermal Margin Analyses for System 80^{TM} ," is used to calculate the departure from nucleate boiling ratio (DNBR) for Palo Verde Nuclear Generating Station (PVNGS) units. This method has been reviewed and approved by the NRC.

Supplement 1-P to Enclosure 1P to LD-82-054 describes a revised System 80^{TM} core inlet flow distribution for use with ABB-CE Statistical Combination of Uncertainties (SCU) methodology for assessing core thermal margin. The revised core inlet flow distribution and the associated uncertainties are the result of re-evaluating the System 80^{TM} reactor flow model data. The re-evaluation treats the core inlet flow distribution data in a statistical manner, as opposed to the deterministic method currently used. The objective of the revised methodology is to reduce conservatism in the current deterministic approach to gain additional calculated core thermal margin.

The report summarizes the current deterministic method of treating the core inlet flow data as an introduction to the revised methodology. The geometric features of the core lower support structure are described in relation to their possible impacts on core inlet flow distribution. Based on these features, the core inlet plane is regionalized to account for potential differences in inlet flow rates. The System 80^{TM} flow model data is then used to determine the core inlet flow factors and their uncertainties for the core inlet regions. A statistical test is applied to the resulting core inlet flow factors to support the hypothesis that the selected regions have separate, distinct core inlet flow factors.

9406080192 940526 PDR ADOCK 05000528 PDR PDR

2.0 INTRODUCTION

· -

By letter dated January 20, 1994 (Ref. 2), the Arizona Public Service Company (APS or the licensee) submitted a request for changes to the Technical Specifications (TS) for the Palo Verde Nuclear Generating Station, Units 1, 2, and 3 (Appendix A to Facility Operating License Nos. NPF-41, NPF-51, and NPF-74, respectively). The Arizona Public Service Company submitted this request on behalf of itself, the Salt River Project Agricultural Improvement and Power District, Southern California Edison Company, El Paso Electric Company, Public Service Company of New Mexico, Los Angeles Department of Water and Power, and Southern California Public Power Authority. The proposed changes would increase the DNBR limit from 1.24 to 1.30 to accommodate the uncertainties in core inlet flow distribution. The proposed amendment also adds the analytical method supplement entitled "System 80TM Inlet Flow Distribution" to the list of methods used to determine core operating limits.

3.0 EVALUATION

APS currently uses a deterministic method to account for the inlet flow distribution and associated uncertainties in thermal margin analysis. The revised approach applied to determine the System 80^{TM} core inlet flow distribution is to identify regional flow factors based on the assumption that the inlet flow for groups of assemblies is determined by some common relationship to the upstream flow geometry. It consists of the following steps:

- Define geometric features in the reactor vessel which influence the core inlet flow distribution.
- Examine the core inlet flow distribution data to identify regions which have similar inlet flow factors, and categorize those regions.
- Determine the mean inlet flow factor and standard deviation of the flow factors for each region.
- Test the null hypothesis that the mean inlet flow factor values for two regions are from the same population. If that hypothesis can be rejected at a significance level of 5% for an equal-tails test, assume that the mean flow factors for the two regions are distinct values.
- Repeat the test pairwise for each of the regions that have been identified.

Using this approach, six different regions each with its own mean value and standard deviation for inlet flow factors are identified in Table 3-2 (Ref. 1). The licensee's report concludes that these revised flow factors along with the sample standard deviations of the flow factors are a valid set to be used for future System 80^{TM} thermal margin licensing analyses.

For the System 80^{TM} plants, the current SCU methodology treats the core inlet flow distribution in a deterministic manner. As a result of the reassessment of the System 80^{TM} core inlet flow distribution, the core inlet flow distribution and its associated uncertainties will be treated in a statistical manner.

The system parameter SCU methodology consists of developing a minimum departure from nucleate boiling ratio (MDNBR) response surface which provides the functional relationship between the dependent variable, MDNBR, and the independent system parameter variable. The response surface is used to combine the probability density functions (PDFs) or the uncertainties associated with each of the independent variables into a resultant DNB PDF. The DNB PDF is then used to determine the MDNBR value at the 95% probability and 95% confidence levels.

The 95/95 SCU MDNBR limit is used in conjunction with a best estimate thermal margin model to assess margin to the DNBR limit.

With respect to the System 80^{TM} SCU methodology described in NUREG-0852, Supplement 2 (Ref. 3), the revised core inlet flow distribution approach will involve the following changes:

- The sensitivity of DNBR with respect to inlet flow factor will be determined for the limiting assembly and adjacent assemblies. These sensitivities will then be used with the appropriate inlet flow factor uncertainties to calculate an overall root-sum-square system parameter uncertainty, using the method presented in Section 5.3 of "Statistical Combination of Uncertainties, Combination of System Parameter Uncertainties in Thermal Margin Analyses for Arkansas Nuclear One Unit 2" (Ref. 4).
- This approach will yield an increased MDNBR limit which will include allowances for uncertainties in hot assembly and adjacent assembly inlet flow. The increase in MDNBR limit can be accommodated directly by increasing the limit, or by applying a thermal margin penalty.

APS has proposed (Ref. 2) to increase the MDNBR limit from 1.24 to 1.30 to accommodate the uncertainties in the core inlet flow distribution.

Reference 1 has proposed a set of factors to construct a best estimate core thermal margin model. Uncertainties in inlet flow to the hot assembly and adjacent assemblies can be accounted for statistically by either increasing DNBR or applying a thermal margin penalty using approved SCU methods. Uncertainties in inlet flow have been treated statistically, using these methods (Ref. 4) and have been previously approved by the staff for other Combustion Engineering plants.

The licensee has proposed to implement the uncertainties associated with core inlet flow distribution by increasing the MDNBR from 1.24 to 1.30. The basis for this increase is provided in References 2 and 5. This has been reviewed

•

÷ .

by the staff and is acceptable for use in Palo Verde Units 1, 2, and 3. The staff finds the technical specification changes proposed in Reference 2 to be acceptable.

4.0 <u>STATE CONSULTATION</u>

In accordance with the Commission's regulations, the Arizona State official was notified of the proposed issuance of the amendments. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and change surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (59 FR 12358). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

7.0 <u>REFERENCES</u>

- Letter from W. F. Conway (APS) to Document Control Desk (NRC), "Supplement 1-P to Enclosure 1-P to LD-82-054," March 30, 1993.
- Letter from W. F. Conway (APS) to Document Control Desk (NRC), "Proposed Amendment to Technical Specification Sections 2.1.1.1, 2.2.1, and 6.9.1.10," January 20, 1994.
- 3. NUREG-0852, Supplement 2, CESSAR System 80[™] SSER 2, September 1983.
- 4. "Statistical Combination of Uncertainties, Combination of System Parameter Uncertainties in Thermal Margin Analyses for Arkansas Nuclear One Unit 2," CEN-139(P), November 1980.

5. "Presentation to NRC on Impact of Improved Inlet Flow Distribution on the CPCS," CEN-424(v)-P, October 1993.

Principal Contributor: G. Schwenk B. Holian

Date: May 26, 1994

- Č