



JUN 10 2002

L-2002-107
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report – May 2002

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the May 2002 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

John P. McElwain
Vice President
Turkey Point Plant

SM

Attachments

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC.

IE24

DOCKET NO.: 50-250
UNIT: Turkey Point Unit 3
DATE: 6/4/2002
COMPLETED BY: Stavroula Mihalakea
TELEPHONE: (305) 246-6454

Reporting Period **May, 2002**

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	744	3623	189402.8
No. of hours generator was on line (service hours)	744	3623	187071.5
Unit reserve shutdown hours	0	0	121.8
Net Electrical Energy (MWH)	530248	2582137	121725784

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) Reason

A - Equipment Failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction
E - Operator Training/License Examination
F - Administrative
G - Operational Error (Explain)
H - Other

(2) Method

1 - Manual
2 - Manual Trip/Scram
3 - Automatic Trip/Scram
4 - Continuation
5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 3 operated at essentially 100% for the month of May 2002.

DOCKET NO.: 50-251
 UNIT: Turkey Point Unit 4
 DATE: 6/4/2002
 COMPLETED BY: Stavroula Mihalakea
 TELEPHONE: (305) 246-6454

Reporting Period May, 2002

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	744	3256.2	186225.7
No. of hours generator was on line (service hours)	744	3247.5	181822.6
Unit reserve shutdown hours	0	0	577.2
Net Electrical Energy (MWH)	512399	2259525	119364536

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 4 operated at essentially 100% for the month until May 17, 2002 when power was reduced to 20% to repair the 4B CRDM cooling fan. Power was subsequently returned to 100% on May 19, 2002 and remained at essentially 100% for the rest of the month.