



444 South 16th Street Mall
Omaha NE 68102-2247

June 11, 2002
LIC-02-0071

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Reference: Docket No. 50-285

SUBJECT: May 2002 Monthly Operating Report (MOR)

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for May 2002.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,

D. J. Bannister
Manager
Fort Calhoun Station

DJB/EPM/epm

Attachments

- c: E. W. Merschoff, NRC Regional Administrator, Region IV
- A. B. Wang, NRC Project Manager
- J. G. Kramer, NRC Senior Resident Inspector
- INPO Records Center
- Winston & Strawn

IE24

**ATTACHMENT 1
OPERATING DATA REPORT**

DOCKET NO.	<u>50-285</u>
UNIT NAME	<u>Fort Calhoun Station</u>
DATE	<u>June 01, 2002</u>
COMPLETED BY	<u>E. P. Matzke</u>
TELEPHONE	<u>(402) 533-6855</u>

REPORT PERIOD: May 2002

1. Design Electrical Rating	<u>(MWe-Net):</u>	<u>478</u>
2. Maximum Dependable Capacity	<u>(MWe-Net):</u>	<u>478</u>

OPERATING STATUS

	MONTH	YEAR TO DATE	CUMULATIVE
3. Number of Hours Reactor was Critical:	72	2,951	202,831
4. Number of Hours Generator was On-line:	69	2,948	200,815
5. Unit Reserve Shutdown Hours:	0		
6. Net Electrical Energy Generated (MWh):	6,997	1,378,793	86,586,304

**ATTACHMENT 2
 UNIT SHUTDOWNS**

REPORT MONTH May 2002

DOCKET NO. 50-285
 UNIT NAME Fort Calhoun Station
 DATE June 1, 2002
 COMPLETED BY E. P. Matzke
 TELEPHONE (402) 533-6855

No.	Date (YY/MM/DD)	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action to Prevent Recurrence
1	02/05/03	S	675	C	1	Scheduled refueling shutdown.

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

OPERATIONS SUMMARY

The Fort Calhoun Station (FCS) was operated at a nominal 30% power until May 3, when the plant was taken off-line for the refueling outage. During the outage, the seals for all Reactor Coolant Pumps (RCPs) were replaced with a newer design. All RCP seals are operating as expected. During the outage all fuel bundles suspected of leakage were replaced. There is no fuel reliability concern at this time. The refueling outage was completed on June 2, 2002.

SAFETY VALVE OR PORV CHALLENGES/FAILURES

No failures or challenges to safety valves or PORVs occurred during the month.