

# **ESBWR Plant Performance**

**Y.K. Cheung**

**NRC Staff - GE Meeting  
June 20 and 21, 2002  
Rockville, Maryland**



# Outline


---

- **Normal Operation**
- **Transients**
- **LOCA and Containment**
- **Comparison to operating plants and ABWR**
- **Summary**

# ESBWR Normal Operation

---

- **No recirculation pumps – total reliance on natural circulation**
- **Significant natural circulation flow exists in all BWR's**
- **For a given core power, there is a corresponding natural circulation flow**
- **ESBWR uses enhanced design features to increase the flow compared to standard BWR's**




# Performance and Core Flow

---

- **Parametric studies show that**
  - Minimum Critical Power Ratio (MCPR) and Stability Ratio are strong functions of core flow
- **Design was enhanced to increase core flow for improved plant performance**

# Key Design Parameters Affecting Natural Circulation

- **Core flow depends on**
  - driving head
  - losses through the loop
- **Driving head**
  - proportion to chimney height
    - **Void Fraction**
- **Loop losses**
  - downcomer
    - **Single-phase pressure drop, handbook loss coefficient**
  - core (fuel bundle)
    - **Two-phase pressure drop, data/correlation**
  - chimney ~ very small
  - Separator
    - **Two-phase pressure drop, data/correlation**



**Schematic of Flow and Pressure Drops  
in a Reactor**


# **Downcomer Losses Depend on the Plant Design**

- **Jet pump plant**
  - Large loss at the jet pump suction ( $\sim 0.034$  sq.m. per jet pump)
- **Internal pump plant**
  - Very large loss at the internal pump minimum flow area
- **Natural circulation plant (ESBWR)**
  - insignificant loss

# Comparison of ESBWR and ABWR


	ESBWR	ABWR
Fuel Length	3.05 m	3.66 m
Chimney/upper plenum	tall	short
Downcomer flow area	open	restricted

- **Key parameters that increase core flow in ESBWR**
  - Shorter fuel
  - Tall chimney
  - Un-restricted downcomer



# Effect of Downcomer Flow Area on Total Core Flow


---






# Effects of ESBWR Design Features on Natural Circulation Flow

---



# Comparison of Natural Circulation Flow for BWRs




POWFLO-2.xls chart 9(3)

**ESBWR has 2 to 3 times more natural circulation flow; power/flow ratio same as pumped plants at rated condition**

# Minimum Critical Power Ratio (MCPR)

- Assures no boiling transition will occur during normal plant operational transients
- MCPR is the ratio of the critical bundle power, at which boiling transition is calculated to occur, to the operating bundle power
- Operating limit MCPR = Safety limiting MCPR +  $\Delta$ CPR



# ESBWR $\Delta$ CPR

---

- **ESBWR Transient Analyses --  $\Delta$ CPR**

<b>Case</b>	<b>Event and condition</b>	<b><math>\Delta</math>CPR</b>
<b>1</b>	<b>Generator load rejection with failure of all bypass valves (Stop valve position scram, similar to ABWR – K6/7)</b>	<b>0.095</b>
<b>2</b>	<b>Feedwater controller failure, (maximum demand at 150%)</b>	<b>0.101</b>

- **For 33% Bypass capacity, limiting  $\Delta$ CPR is 0.1**

# Margins to Operating Limit MCPR

**ESBWR Design Target**                      **1.38**

**Bypass Capacity**                      **33%**

Scram signal                                      Valve  
Position

Safety Limit MCPR for GE12                      1.09

Target  $\Delta$ CPR                                      0.1

**Operating Limit MCPR**                      **1.19**

Margin to Operating Limit                      16%

# **LOCA and Containment Responses**

---

- **TRACG used to perform both the LOCA and containment analyses**
- **For LOCA (0 to 1 hours)**
  - Fine nodalization in RPV, coarse nodalization in containment to provide system responses to the RPV
  - Key output: mixture level inside shroud and Peak Cladding Temperature (PCT)
- **For containment (0 to 72 hours)**
  - Fine nodalization in containment, coarse nodalization in RPV to provide system responses to the containment
  - Key output: Long term containment pressure

# Main Steam Line Break – Largest Pipe Break

- **Objective**

- To demonstrate the LOCA and Containment responses after a postulated pipe break
- To show the design margins in the ESBWR


- **Key assumptions**

- 4 PCCs with a total capacity of 54 MW
- No credit for the ICs
- For long term containment calculation, leakage flow between DW and WW included as

$$\frac{A}{\sqrt{k}} = 1.0\text{cm}^2$$

# Main Steam Line Break – LOCA

- **Nodalization**
  - Fine nodalization in RPV, coarse nodalization in containment
- **Key design objectives**
  - Core covered by mixture at all times
  - No core heatup




ESBWR TRACG LOCA MODEL




# Mixture Levels Inside Shroud and Downcomer


---



# MSL Break LOCA – Downcomer and GDCS Pool Levels



# RPV, DW and WW Pressures




**Note 1: Bounding estimate, DW Press = all air in WW + PCC vent submergence, before GDCS drain**

**Note 2: Bounding estimate, DW Press = all air in WW + PCC vent submergence, after GDCS drain**

**DW pressure shows > 20% Margin to the design pressure**

# Differential Pressure (DW – WW)


---



**DW/WW pressure difference drives the flow through the PCC heat exchangers**

# Reactor Decay Heat and PCCS Heat Removal


---



**PCCS removes heat during the blowdown phase, limiting suppression pool heatup**


# PCC Tube Total and Partial Air Pressures

---



# GDCS Flow


---



**GDCS - Low pressure and low flow rate makeup system**


# Main Steam Line Break – Containment

- **Nodalization**
  - Fine nodalization in containment, coarse nodalization in RPV
- **Key design objectives**
  - Long term DW pressure below design value with margin






# MSL Break Containment – RPV, DW and WW Press.




**DW pressure shows > 20% margin to the design pressure**

# WW Airspace Temperatures

---




# Reactor Decay Heat and PCCS Condensation Power




# Total PCCS Drain Flow to RPV

---




# Differential Pressure (DW – WW)

---



# Leakage Flow (DW to WW)

---



## **Summary of Main Steam Line Break (largest break) Analyses**

---

- **ESBWR has large margin ( $> 3m$ ) to core uncover and heatup**
- **Calculated DW pressure shows  $> 20\%$  Margin to the design pressure**
- **Total PCCS heat removal capacity greater than decay heat (after 2 hours)**
- **Overall pressure and level (inventory) responses are mild in nature, NO requirements for fast action**


**Other breaks expected to have similar responses**

# Design Features Affecting LOCA Response

	ESBWR	ABWR	BWR5	BWR4
Large pipes below core	No	No	Yes	Yes
Core height, m	3.05	3.66	~3.66	~3.66
TAF above RPV bottom	~ 1/4	~ 1/2	~1/2	~1/2
Separator standpipes	Long	Short	Short	Short
Vessel height, m	27.7	21.1	~21.9	~21.8
Water volume outside shroud (above TAF), m <sup>3</sup>	222	88	94	92




**ESBWR has much more water inventory!**





# Comparison of Mixture Levels Inside Shroud Following a Pipe Break




**ESBWR has large margin to core uncover and heatup  
– other breaks expected to have similar responses**

# **ESBWR Features That Improve Transient Pressure Response**

---

- **Taller reactor vessel**
- **Large steam volume in the chimney region**
- **Higher safety valve setpoint to prevent valve opening and inventory loss**

# Reactor Pressure Response to Isolation Events




**ESBWR has slower pressurization - no relief valves open**

# **ESBWR Design Features That Improve Containment Response**

---

- **Wetwell gas space volume increased**
  - GDCS pool gas space connected to wetwell
  - 10 to 25% increase in wetwell volume after GDCS pool drains
- **PCCS capacity increased**
  - Total PCCS heat removal capacity greater than decay heat (after 2 hours)
- **Containment overpressure relief system added**

# Containment Pressure Following a Pipe Break



**ESBWR has > 20% margin to design pressure**

# Summary

---

- **Natural circulation flow increased**
  - Un-restricted downcomer, tall chimney, shorter fuel & taller vessel
  - Power/flow ratio same as pump plants at rated condition
- **LOCA response improved**
  - Taller vessel and larger initial inventory in the vessel downcomer
  - No need for fast acting, high pressure and large flow rate inventory makeup
  - Large margin to core uncover and heatup
- **Containment response improved**
  - Wetwell volume increased by moving GDCS pool
  - Containment overpressure relief system added
  - ESBWR containment has  $> 20\%$  margin to design pressure even with lower containment design pressure than ABWR/SBWR

**ESBWR design features improve plant performance**