

December 14, 1988

Docket No. 50-382

Mr. Ross P. Barkhurst
Vice President Operations
Entergy Operations, Inc.
Post Office Box B
Killona, Louisiana 70066

Dear Mr. Barkhurst:

SUBJECT: CORRECTION TO AMENDMENT NO. 48 TO FACILITY OPERATING LICENSE NPF-38 - WATERFORD STEAM ELECTRIC STATION, UNIT 3 (TAC NO. M67851)

On December 14, 1988, the Commission issued Amendment No. 48 to Facility Operating License No. NPF-38 for the Waterford Steam Electric Station, Unit 3. Amendment No. 48 changed the Technical Specifications (TS) on boron dilution by adding mode 4 requirements, clarifying the surveillance to verify systems isolation only when the system is to be isolated, make surveillances consistent with the mode 4 and 5 limited conditions for operation, and revise the frequencies for backup dilution detection.

Correction is being made to TS overleaf page 3/4 1-18 to 3/4 1-17c. It failed to incorporate changes made with Amendment No. 11. A corrected TS page is enclosed. Please accept our apologies for any inconvenience this may have caused you.

Sincerely,

ORIGINAL SIGNED BY:

David L. Wigginton, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
TS pages 3/4 1-18

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File	NRC&LPDRs	PDIV-1 r/f	DWigginton(2)
OGC(MS15B18)	DHagan	CGrimes (11E22)	Wanda Jones(MS7103)
GHI11 (4)	ACRS(10)(MSP315)	OC/LFMB(MS4503)	OPA(MS2G5)
PDIV-1 p/f	WJohnson, RIV		

OFC	LA/PDIV-1	PM/PDIV-1	D/PDIV-1		
NAME	PNoonan <i>PN</i>	DWigginton /pn	JLarkins <i>JL</i>		
DATE	12/11/92	12/14/92	12/14/92		

OFFICIAL RECORD COPY

Document Name: WAT67851.1tr

9212300226 921214
PDR ADCK 05000382
P PDR

ENCLOSURE COPY

CP-1

DFOI



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

December 14, 1992

Docket No. 50-382

Mr. Ross P. Barkhurst
Vice President Operations
Entergy Operations, Inc.
Post Office Box B
Killona, Louisiana 70066

Dear Mr. Barkhurst:

SUBJECT: CORRECTION TO AMENDMENT NO. 48 TO FACILITY OPERATING LICENSE NPF-38 - WATERFORD STEAM ELECTRIC STATION, UNIT 3 (TAC NO. M67851)

On December 14, 1988, the Commission issued Amendment No. 48 to Facility Operating License No. NPF-38 for the Waterford Steam Electric Station, Unit 3. Amendment No. 48 changed the Technical Specifications (TS) on boron dilution by adding mode 4 requirements, clarifying the surveillance to verify systems isolation only when the system is to be isolated, make surveillances consistent with the mode 4 and 5 limited conditions for operation, and revise the frequencies for backup dilution detection.

Correction is being made to TS overleaf page 3/4 1-18 to 3/4 1-17c. It failed to incorporate changes made with Amendment No. 11. A corrected TS page is enclosed. Please accept our apologies for any inconvenience this may have caused you.

Sincerely,

A handwritten signature in cursive script, appearing to read "D. L. Wigginton".

David L. Wigginton, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
TS pages 3/4 1-18

cc w/enclosure:
See next page

Mr. Ross P. Barkhurst
Entergy Operations, Inc.

Waterford 3

cc:

Mr. Hall Bohlinger, Administrator
Radiation Protection Division
Office of Air Quality and Nuclear Energy
Post Office Box 82135
Baton Rouge, Louisiana 70884-2135

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. John R. McGaha
Vice President, Operations
Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286

Resident Inspector/Waterford NPS
Post Office Box 822
Killona, Louisiana 70066

Parish President Council
St. Charles Parish
P. O. Box 302
Hahnville, Louisiana 70057

William A. Cross
Bethesda Licensing Office
3 Metro Center
Suite 610
Bethesda, Maryland 20814

Mr. Donald C. Hintz, President
and Chief Executive Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286

Mr. Robert B. McGehee
Wise, Carter, Child & Caraway
P.O. Box 651
Jackson, Mississippi 39205

Chairman
Louisiana Public Service Commission
One American Place, Suite 1630
Baton Rouge, Louisiana 70825-1697

Mr. D. F. Packer
General Manager Plant Operations
Entergy Operations, Inc.
P. O. Box B
Killona, Louisiana 70066

Mr. R. F. Burski, Director
Nuclear Safety
Entergy Operations, Inc.
P. O. Box B
Killona, Louisiana 70066

Mr. L. W. Laughlin, Licensing Manager
Entergy Operations, Inc.
P. O. Box B
Killona, Louisiana 70066

Winston & Strawn
Attn: N. S. Reynolds
1400 L Street, N.W.
Washington, DC 20005-3502

REACTIVITY CONTROL SYSTEMS

3/4.1.3 MOVABLE CONTROL ASSEMBLIES

CEA POSITION

LIMITING CONDITION FOR OPERATION

3.1.3.1 All full-length (shutdown and regulating) CEAs, and all part-length CEAs which are inserted in the core, shall be OPERABLE with each CEA of a given group positioned within 7 inches (indicated position) of all other CEAs in its group.

APPLICABILITY: MODES 1* and 2*.

ACTION:

- a. With one or more full-length CEAs inoperable due to being immovable as a result of excessive friction or mechanical interference or known to be untrippable, determine that the SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is satisfied within 1 hour and be in at least HOT STANDBY within 6 hours.
- b. With more than one full-length or part-length CEA inoperable or misaligned from any other CEA in its group by more than 19 inches (indicated position), be in at least HOT STANDBY within 6 hours.
- c. With one full-length or part-length CEA misaligned from any other CEA in its group by more than 19 inches, operation in MODES 1 and 2 may continue, provided that core power is reduced in accordance with Figure 3.1-1A and that within 1 hour the misaligned CEA is either:
 1. Restored to OPERABLE status within its above specified alignment requirements, or
 2. Declared inoperable and the SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is satisfied. After declaring the CEA inoperable, operation in MODES 1 and 2 may continue pursuant to the requirements of Specification 3.1.3.6 provided:
 - a) Within 1 hour the remainder of the CEAs in the group with the inoperable CEA shall be aligned to within 7 inches of the inoperable CEA while maintaining the allowable CEA sequence and insertion limits shown on Figure 3.1-2; the THERMAL POWER level shall be restricted pursuant to Specification 3.1.3.6 during subsequent operation.
 - b) The SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is determined at least once per 12 hours.

Otherwise, be in at least HOT STANDBY within 6 hours.

*See Special Test Exceptions 3.10.2 and 3.10.4.

TABLE 3.1-5

REQUIRED MONITORING FREQUENCIES FOR BACKUP BORON
DILUTION DETECTION AS A FUNCTION OF OPERATING
CHARGING PUMPS AND PLANT OPERATIONAL MODES FOR
 K_{eff} LESS THAN OR EQUAL TO 0.95

$K_{eff} \leq 0.95$

OPERATIONAL MODE	Number of Operating Charging Pumps*			
	0	1	2	3
3	12 hours	5.0 hours	2.0 hours	1.0 hours
4	12 hours	3.0 hours	1.0 hours	0.5 hours
5 RCS filled	8 hours	3.0 hours	1.25 hours	0.5 hours
5 RCS partially drained	8 hours	2.75 hours	1.0 hours	Operation not allowed**
6	24 hours	2.25 hours	0.75 hours	Operation not allowed**

*Charging pump OPERABILITY for any period of time shall constitute OPERABILITY for the entire monitoring frequency.

**The precluded number of charging pumps shall be verified to be inoperable by racking out their motor circuit breakers.