Docket No. 50-382

August 12, 19

Mr. Ross P. Barkhurst Vice President Operations Entergy Operations. Inc. Post Office Box B Killona. Louisiana 70066

Dear Mr. Barkhurst:

SUBJECT: ISSUANCE OF AMENDMENT NO. 85 TO FACILITY OPERATING LICENSE NPF-38 - WATERFORD STEAM ELECTRIC STATION, UNIT 3 (TAC NO. M86484)

The Commission has issued the enclosed Amendment No. 85 to Facility Operating License No. NPF-38 for the Waterford Steam Electric Station, Unit 3. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated May 7, 1993.

The amendment changes the Appendix A Technical Specifications by allowing the third Type A Containment Integrated Leakage Rate Test in the first 10-year service period to be conducted at Refuel 7. This exceeds the interval by approximately 4 months.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

David L. Wigginton, Senior Project Manager Project Directorate IV-1 Division of Reactor Projects III/IV/V Office of Nuclear Reactor Regulation

Enclosures: 1. Amendment No. 85 to NPF-38 2. Safety Evaluation

NRG FILE CENTER COPY

cc w/enclosures: See next page

DISTRIBUTION

Docket File D. Wigginton (2) P. Noonan D. Hagan C. Grimes (11E22) OC/LFMB (4503)

NRC/Local PDR E. Adensam ACRS(10) (P315) G. Hill(4) J. Roe (13A2) A. Beach, RIV

PD4-1 Reading H. Rood (13A2) OGC (15B18) Wanda Jones (7103) OPA (2G5) RBarrett

						(V-	
OFC	LA/PD4-1	PM/PD4-1, 1	SCSB 122	OGC	(A)D/PD4-1)	
NAME	PNoonan My	DWigginton/vw	RBarrett	EHOLLER	HRood H		
DATE	6128/93	6 128/93	7 127/93	7/24/93	8/12/93		
COPY	YES/NO	YES/NO	YES/NO	YES/NO	YES/NO	\wedge	
OFFICIAL RECORD COPY Document Name: WAT86484.AMD							
9308200207 930812							

9308200207 930812 PDR ADOCK 05000382 PDR



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

August 12, 1993

Docket No. 50-382

Mr. Ross P. Barkhurst Vice President Operations Entergy Operations, Inc. Post Office Box B Killona, Louisiana 70066

Dear Mr. Barkhurst:

SUBJECT: ISSUANCE OF AMENDMENT NO. 85 TO FACILITY OPERATING LICENSE NPF-38 - WATERFORD STEAM ELECTRIC STATION, UNIT 3 (TAC NO. M86484)

The Commission has issued the enclosed Amendment No. 85 to Facility Operating License No. NPF-38 for the Waterford Steam Electric Station, Unit 3. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated May 7, 1993.

The amendment changes the Appendix A Technical Specifications by allowing the third Type A Containment Integrated Leakage Rate Test in the first 10-year service period to be conducted at Refuel 7. This exceeds the interval by approximately 4 months.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly <u>Federal Register</u> notice.

Sincerely,

David L. Wigginton, Senior Project Manager Project Directorate IV-1 Division of Reactor Projects III/IV/V Office of Nuclear Reactor Regulation

Enclosures: 1. Amendment No. 85 to NPF-38 2. Safety Evaluation

cc w/enclosures: See next page Mr. Ross P. Barkhurst Entergy Operations, Inc.

cc:

Mr. Hall Bohlinger, Administrator Radiation Protection Division Office of Air Quality and Nuclear Energy Post Office Box 82135 Baton Rouge, Louisiana 70884-2135

Mr. John R. McGaha Vice President, Operations Support Entergy Operations, Inc. P. O. Box 31995 Jackson, Mississippi 39286

William A. Cross Bethesda Licensing Office 3 Metro Center Suite 610 Bethesda, Maryland 20814

Mr. Robert B. McGehee Wise, Carter, Child & Caraway P.O. Box 651 Jackson, Mississippi 39205

Mr. D. F. Packer General Manager Plant Operations Entergy Operations, Inc. P. O. Box B Killona, Louisiana 70066

Mr. L. W. Laughlin, Licensing Manager Entergy Operations, Inc. P. O. Box B Killona, Louisiana 70066

Winston & Strawn Attn: N. S. Reynolds 1400 L Street, N.W. Washington, DC 20005-3502 Regional Administrator, Region IV U.S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 1000 Arlington, Texas 76011

Resident Inspector/Waterford NPS Post Office Box 822 Killona, Louisiana 70066

Parish President Council St. Charles Parish P. O. Box 302 Hahnville, Louisiana 70057

Mr. Harry W. Keiser, Executive Vice-President and Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286-1995

Chairman Louisiana Public Service Commission One American Place, Suite 1630 Baton Rouge, Louisiana 70825-1697

Mr. R. F. Burski, Director Nuclear Safety Entergy Operations, Inc. P. O. Box B Killona, Louisiana 70066

Waterford 3



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

ENTERGY OPERATIONS, INC.

DOCKET NO. 50-382

WATERFORD STEAM ELECTRIC STATION, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 85 License No. NPF-38

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Entergy Operations, Inc. (the licensee) dated May 7, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, 2. and paragraph 2.C(2) of Facility Operating License No. NPF-38 is hereby amended to read as follows:
 - (2) <u>Technical Specifications and Environmental Protection Plan</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 85, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Harry Rood, Acting Director Project Directorate IV-1 Division of Reactor Projects III/IV/V Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: August 12, 1993

ATTACHMENT TO LICENSE AMENDMENT NO. 85

TO FACILITY OPERATING LICENSE NO. NPF-38

DOCKET NO. 50-382

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE PAGES

INSERT PAGES

3/4 6-2	3/4 6-2
3/4 6-3	3/4 6-3
3/4 6-4	3/4 6-4
B ['] 3/4 6-1	B 3/4 6-1

3/4.6 CONTAINMENT SYSTEMS

3/4.6.1 PRIMARY CONTAINMENT

CONTAINMENT INTEGRITY

LIMITING CONDITION FOR OPERATION

3.6.1.1 Primary CONTAINMENT INTEGRITY shall be maintained.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

Without primary CONTAINMENT INTEGRITY, restore CONTAINMENT INTEGRITY within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

- 4.6.1.1 Primary CONTAINMENT INTEGRITY shall be demonstrated:
 - a. At least once per 31 days by verifying that all penetrations* not capable of being closed by OPERABLE containment automatic isolation valves and required to be closed during accident conditions are closed by valves, blind flanges, or deactivated automatic valves secured in their positions, except for valves that are open under administrative control as permitted by Specification 3.6.3.
 - b. By verifying that each containment air lock is in compliance with the requirements of Specification 3.6.1.3.
 - c. After each closing of each penetration subject to Type B testing, except containment air locks, if opened following a Type A or B test, by leak rate testing the seal with gas at P_a , 44 psig, and verifying that when the measured leakage rate for these seals is added to the leakage rates determined pursuant to Specification 4.6.1.2d for all other Type B and C penetrations, the combined leakage rate is less than or equal to 0.60 L.

Except valves, blind flanges, and deactivated automatic valves which are located inside the containment and are locked, sealed or otherwise secured in the closed position. These penetrations shall be verified closed during each COLD SHUTDOWN except that such verification need not be performed more often than once per 92 days.

CONTAINMENT LEAKAGE

LIMITING CONDITION FOR OPERATION

- 3.6.1.2 Containment leakage rates shall be limited to:
 - a. An overall integrated leakage rate of:
 - 1. Less than or equal to L_a , 0.50 percent by weight of the containment air per 24 hours at P_a , 44 psig, or
 - 2. Less than or equal to L, 0.25 percent by weight of the containment air per 24 hours at a reduced pressure of P_t , 22 psig.
 - b. A combined leakage rate of less than or equal to 0.60 L_g for all penetrations and valves subject to Type B and C tests when pressurized to P_g .
 - c. A combined bypass leakage rate of less than or equal to 0.06 L for all penetrations that are secondary containment bypass leakage paths when pressurized to P.

<u>APPLICABILITY</u>: MODES 1, 2, 3, and 4.

ACTION:

With either (a) the measured overall integrated containment leakage rate exceeding 0.75 L_a or 0.75 L_t , as applicable, or (b) with the measured combined leakage rate for all penetrations and valves subject to Types B and C tests exceeding 0.60 L_a , or (c) with the combined bypass leakage rate exceeding 0.06 L_a , restore the overall integrated leakage rate to less than or equal to 0.75 L_a or less than or equal to 0.75 L_t , as applicable, and the combined leakage rate for all penetrations and valves subject to Type B and C tests to less than or equal to 0.60 L_a , and the bypass leakage rate to less than or equal to 0.06 L_a prior to increasing the Reactor Coolant System temperature above 200°F.

SURVEILLANCE REQUIREMENTS

4.6.1.2 The containment leakage rates shall be demonstrated at the following test schedule and shall be determined in conformance with the criteria specified in Appendix J of 10 CFR Part 50 using the methods and provisions of ANSI N45.4-1972:

WATERFORD - UNIT 3

SURVEILLANCE REQUIREMENTS (Continued)

- a. Three Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted at 40 \pm 10 month intervals** during shutdown at either P_a, 44 psig, or at P_t, 22 psig, during each 10-year service period. The third test of each set shall be conducted during the shutdown for the 10-year plant inservice inspection.
- b. If any periodic Type A test fails to meet either 0.75 L or 0.75 L, the test schedule for subsequent Type A tests shall be reviewed and approved by the Commission. If two consecutive Type A tests fail to meet either 0.75 L or 0.75 L, a Type A test shall be performed at least every 18 months until two consecutive Type A tests meet either 0.75 L or 0.75 L, at which time the above test schedule may be resumed.
- c. The accuracy of each Type A test shall be verified by a supplemental test which:
 - 1. Confirms the accuracy of the test by verifying that the supplemental test result, L_c , minus the sum of the Type A and the superimposed leak, L_o , are equal to or less than 0.25 L_a .
 - 2. Has a duration sufficient to establish accurately the change in leakage rate between the Type A test and the supplemental test.
 - 3. Requires the quantity of gas injected into the containment or bled from the containment during the supplemental test to be between 0.75 L_a and 1.25 L_a.
- d. Type B and C tests shall be conducted with gas at P, 44 psig, at intervals no greater than 24 months* except for tests involving:
 - 1. Air locks,
 - 2. Purge supply and exhaust isolation valves with resilient material seals.

^{*}Testing for the first cycle of operation shall be done during the first refueling outage.

^{**}A one time extension of the test interval is allowed for the third Type A test of the first 10-year service period, provided that performance of the Type A test occurs prior to unit restart following Refuel 7.

SURVEILLANCE REQUIREMENTS (Continued)

- e. Purge supply and exhaust isolation valves with resilient material seals shall be tested and demonstrated OPERABLE per Surveillance Requirement 4.6.1.7.2.
- f. The combined bypass leakage rate shall be determined to be less than or equal to 0.06 L by applicable Type B and C tests at least once per 24 months* except for penetrations which are not individually testable; penetrations not individually testable shall be determined to have no detectable leakage when tested with soap bubbles while the containment is pressurized to P_a , 44 psig, during each Type A test.
- g. Air locks shall be tested and demonstrated OPERABLE per Surveillance Requirement 4.6.1.3.
- h. The provisions of Specification 4.0.2 are not applicable.

^{*}Testing for the first cycle of operation shall be done during the first refueling outage.

3/4.6 CONTAINMENT SYSTEMS

BASES

3/4.6.1 PRIMARY CONTAINMENT

3/4.6.1.1 CONTAINMENT INTEGRITY

Primary CONTAINMENT INTEGRITY ensures that the release of radioactive materials from the containment atmosphere will be restricted to those leakage paths and associated leak rates assumed in the safety analyses. This restriction, in conjunction with the leakage rate limitation, will limit the SITE BOUNDARY radiation doses to within the limits of 10 CFR Part 100 during accident conditions.

3/4.6.1.2 CONTAINMENT LEAKAGE

The limitations on containment leakage rates ensure that the total containment leakage volume will not exceed the value assumed in the safety analyses at the peak accident pressure, P_a . As an added conservatism, the measured overall integrated leakage rate is further limited to less than or equal to 0.75 L, or less than or equal to 0.75 L, as applicable during performance of the periodic tests to account for possible degradation of the containment leakage barriers between leakage tests.

The surveillance requirements for measuring leakage rates are consistent with the requirements of Appendix J of 10 CFR Part 50.*

Secondary containment bypass leakage paths previously, Table 3.6-1, have been incorporated into plant procedure UNT-005.026.

3/4.6.1.3 CONTAINMENT AIR LOCKS

The limitations on closure and leak rate for the containment air locks are required to meet the restrictions on CONTAINMENT INTEGRITY and containment leak rate. Surveillance testing of the air lock seals provides assurance that the overall air lock leakage will not become excessive due to seal damage during the intervals between air lock leakage tests.

^{*}A one time extension of the test interval is allowed for the third Type A test of the first 10-year service period, as required by Surveillance Requirement 4.6.1.2.a and by Section III.D.(a) of Appendix J to 10 CFR Part 50, provided the performance of the Type A test occurs prior to unit restart following Refuel 7.

BASES

3/4.6.1.4 INTERNAL PRESSURE

The limitations on containment internal pressure ensure that (1) the containment structure is prevented from exceeding its design negative pressure differential with respect to the annulus atmosphere of 0.65 psid, (2) the containment peak pressure does not exceed the design pressure of 44 psig during either LOCA or steam line break conditions, and (3) the minimum pressure of the ECCS performance analysis (BTP CSB 61) is satisfied.

The maximum peak pressure expected to be obtained from an MSLB event is 42.3 psig. The limit for initial positive containment pressure of +27 inches water (approximately 1.0 psig) will limit the total pressure to less than 44 psig which is less than the design pressure and is consistent with the safety analyses. The limit for initial positive containment pressure includes a correction of 1.20 inches water for possible instrument error and an additional 6.8 inches water for conservatism.

The limit of 14.375 psia for initial negative containment pressure ensures that the minimum containment pressure is consistent with the ECCS performance analysis ensuring core reflood under LOCA conditions.

3/4.6.1.5 AIR TEMPERATURE

The limitation on containment average air temperature ensures that the containment peak air temperature does not exceed the design temperature of 269.3°F during LOCA conditions and 413.5°F during MSLB conditions and is consistent with the safety analyses.

3/4.6.1.6 CONTAINMENT VESSEL STRUCTURAL INTEGRITY

This limitation ensures that the structural integrity of the containment steel vessel will be maintained comparable to the original design standards for the life of the facility. Structural integrity is required to ensure that the vessel will withstand the maximum pressure of 43.76 psig in the event of a main steam line break accident. A visual inspection in conjunction with Type A leakage test is sufficient to demonstrate this capability.

3/4.6.1.7 CONTAINMENT VENTILATION SYSTEM

The use of the containment purge valves is restricted to 90 hours per year in accordance with Standard Review Plan 6.2.4 for plants with the Safety Evaluation Report for the Construction License issued prior to July 1, 1975. The purge valves have been modified to limit the opening to approximately 52° to ensure the valves will close during a LOCA or MSLB; and therefore, the SITE BOUNDARY doses are maintained within the guidelines of 10 CFR Part 100. The purge valves, as modified, comply with all provisions of BTP CSB 6-4 except for the recommended size of the purge line for systems to be used during plant operation.

WATERFORD - UNIT 3

Amendment No. 27

UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 85 TO

FACILITY OPERATING LICENSE NO. NPF-38

ENTERGY OPERATIONS, INC.

WATERFORD STEAM ELECTRIC STATION, UNIT 3

DOCKET NO. 50-382

1.0 INTRODUCTION

TUCLEAR REGULAD

By application dated May 7, 1993, Entergy Operations, Inc. (the licensee) submitted a request for changes to the Waterford Steam Electric Station, Unit 3, Technical Specifications (TS). The requested changes would allow a one time extension of the third Type A Containment Integrated Leakage Rate Test (CILRT), by approximately 4 months in the first 10-year service period.

2.0 EVALUATION

The existing TS 4.6.1.2.a. "Containment Leakage Surveillance Requirements," states that three Type A tests (Overall Integrated Containment Leakage Rate) shall be conducted at 40 \pm 10-month intervals during shutdown at P_a (44 psig) during each 10-year service period. The 50-month maximum interval for the third Type A test within the first 10-year service period would be extended to approximately 54 months. This extension will prevent performing four CILRTs, one more than required, within the first 10-year service period. The benefit of not performing the additional CILRT is a reduction in personnel radiation exposure. A dose savings will be realized from eliminating contamination, reducing exposure for venting and draining, and from setup and restoration of instrumentation required to perform the test.

Data from the first (May 1988) and second (May 1991) CILRT at Waterford 3 indicates that most of the measured leakage is from the containment penetrations and not from the containment barrier. The "as-left" leakage rate was well below the 10 CFR Part 50 Appendix J limit. Both Appendix J and TS requires that the leakage rate be less that 75% of L to allow for deterioration in leakage paths between tests. The allowable leakage rate, L_a , is 0.5 wt.%/day. Therefore, the established acceptable limit is < 0.375 wt.%/day. The "as-left" leakage rates for the first two CILRTs were 0.116 and 0.0731 wt.%/day, which is well below the acceptance limit. The Type B and C test (Local Leakage Rate Test or LLRT) program also provides assurance that containment integrity has been maintained. LLRTs demonstrate operability of components and penetrations by measuring penetration and valve leakage. Additionally, there have been no modifications made to the plant that could adversely affect the test results.

5

Since the licensee has justified the leaktight integrity of the containment based on previous leakage test results, the staff concludes that a one-time extension of approximately 4 months beyond the maximum permitted test interval will not have a significant safety impact. The staff, therefore, concludes that the licensee's requested one-time schedular test interval extension for conducting the third CILRT of the first 10-year service period is acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Louisiana State official was notified of the proposed issuance of the amendment. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes in surveillance requirements. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration and there has been no public comment on such finding (58 FR 34079). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: D. Wigginton

Date: August 12, 1993