

Mr. Ross P. Barkhurst
Vice President Operations
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

July 6, 1995

SUBJECT: ISSUANCE OF AMENDMENT NO. 109 TO FACILITY OPERATING LICENSE
NPF-38 - WATERFORD STEAM ELECTRIC STATION, UNIT 3 (TAC NO. M90172)

Dear Mr. Barkhurst:

The Commission has issued the enclosed Amendment No. 109 to Facility Operating License No. NPF-38 for the Waterford Steam Electric Station, Unit 3. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated August 9, 1994.

The amendment changes the Appendix A TSs by revising the Administrative Controls Section of the TSs for Waterford 3 by removing the functions under review and audit from the TSs and by relocating those items in the quality assurance program manual (QAPM). In addition the amendment removes the review and audit functions for the emergency plan and implementing procedures, and security plan from the list of responsibilities of the plant operation review committee (PORC) in the TSs. These requirements will be retained in emergency plan or security plan as appropriate.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

Chandu P. Patel, Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-382

Enclosures: 1. Amendment No. 109 to NPF-38
2. Safety Evaluation

cc w/encs: See next page

DISTRIBUTION

Docket File	PUBLIC	PD4-1 r/f
C. Patel (2)	P. Noonan	ACRS (4)
OGC (15B18)	D. Hagan	G. Hill (2)
A. B. Beach, RIV	C. Grimes	E. Adensam
OPA (2G5)	OC/LFMB	LHurley, RIV

Document Name: WAT90172.AMD

OFC	LA/PD4-1	PM/PD4-1	OGC
NAME	PN Noonan	CPatel/vw	OGC
DATE	6/19/95	6/20/95 7/6/95	6/11/95
COPY	(YES) NO	(YES) NO	YES/NO

OFFICIAL RECORD COPY

NRC FILE CENTER COPY

9507180193 950706
PDR ADOCK 05000382
PDR

Subject to change: gem

DF011



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

July 6, 1995

Mr. Ross P. Barkhurst
Vice President Operations
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

SUBJECT: ISSUANCE OF AMENDMENT NO. 109 TO FACILITY OPERATING LICENSE
NPF-38 - WATERFORD STEAM ELECTRIC STATION, UNIT 3 (TAC NO. M90172)

Dear Mr. Barkhurst:

The Commission has issued the enclosed Amendment No. 109 to Facility Operating License No. NPF-38 for the Waterford Steam Electric Station, Unit 3. The amendment consists of changes to the Technical Specifications (TSs) in response to your application dated August 9, 1994.

The amendment changes the Appendix A TSs by revising the Administrative Controls Section of the TSs for Waterford 3 by removing the functions under review and audit from the TSs and by relocating those items in the quality assurance program manual (QAPM). In addition the amendment removes the review and audit functions for the emergency plan and implementing procedures, and security plan from the list of responsibilities of the plant operation review committee (PORC) in the TSs. These requirements will be retained in emergency plan or security plan as appropriate.

A copy of our related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's next biweekly Federal Register notice.

Sincerely,

Chandu P. Patel

Chandu P. Patel, Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket No. 50-382

Enclosures: 1. Amendment No. 109 to NPF-38
2. Safety Evaluation

cc w/encs: See next page

Mr. Ross P. Barkhurst
Entergy Operations, Inc.

Waterford 3

cc:

Mr. William H. Spell, Administrator
Louisiana Radiation Protection Division
Post Office Box 82135
Baton Rouge, LA 70884-2135

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Mr. Jerrold G. Dewease
Vice President, Operations
Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286

Resident Inspector/Waterford NPS
Post Office Box 822
Killona, LA 70066

Parish President Council
St. Charles Parish
P. O. Box 302
Hahnville, LA 70057

Mr. R. F. Burski, Director
Nuclear Safety
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

Mr. Harry W. Keiser, Executive Vice-
President and Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, MS 39286-1995

Mr. Robert B. McGehee
Wise, Carter, Child & Caraway
P.O. Box 651
Jackson, MS 39205

Chairman
Louisiana Public Service Commission
One American Place, Suite 1630
Baton Rouge, LA 70825-1697

Mr. Dan R. Keuter
General Manager Plant Operations
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

Mr. Donald W. Vinci, Licensing Manager
Entergy Operations, Inc.
P. O. Box B
Killona, LA 70066

Winston & Strawn
Attn: N. S. Reynolds
1400 L Street, N.W.
Washington, DC 20005-3502



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

ENTERGY OPERATIONS, INC.

DOCKET NO. 50-382

WATERFORD STEAM ELECTRIC STATION, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 109
License No. NPF-38

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Entergy Operations, Inc. (the licensee) dated August 9, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9507180211 950706
PDR ADOCK 05000382
P PDR

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-38 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 109, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance to be implemented within 60 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Chandu P. Patel

Chandu P. Patel, Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: July 6, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 109
TO FACILITY OPERATING LICENSE NO. NPF-38
DOCKET NO. 50-382

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE PAGES

3/4 3-4
3/4 3-17
6-7
6-8
6-9
6-10
6-11
6-12
6-13
6-14
6-15
6-22

INSERT PAGES

3/4 3-4
3/4 3-17
6-7
6-8
-
-
-
-
6-13
6-14
6-15
6-22

TABLE 3.3-1
REACTOR PROTECTIVE INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
1. Manual Reactor Trip	2 sets of 2 2 sets of 2	1 set of 2 1 set of 2	2 sets of 2 2 sets of 2	1, 2 3*, 4*, 5*	1 8
2. Linear Power Level - High	4	2	3	1, 2	2#, 3#
3. Logarithmic Power Level-High					
a. Startup and Operating	4 4	2(a)(d) 2	3 3	2** 3*, 4*, 5*	2#, 3# 8
b. Shutdown	4	0	2	3, 4, 5	4
4. Pressurizer Pressure - High	4	2	3	1, 2	2#, 3#
5. Pressurizer Pressure - Low	4	2(b)	3	1, 2	2#, 3#
6. Containment Pressure - High	4	2	3	1, 2	2#, 3#
7. Steam Generator Pressure - Low	4/SG	2/SG	3/SG	1, 2	2#, 3#
8. Steam Generator Level - Low	4/SG	2/SG	3/SG	1, 2	2#, 3#
9. Local Power Density - High	4	2(c)(d)	3	1, 2	2#, 3#
10. DNBR - Low	4	2(c)(d)	3	1, 2	2#, 3#
11. Steam Generator Level - High	4/SG	2/SG(g)	3/SG	1, 2	2#, 3#
12. Reactor Protection System Logic	4	2	3	1, 2 3*, 4*, 5*	5 8
13. Reactor Trip Breakers	4	2(f)	4	1, 2 3*, 4*, 5*	5 8
14. Core Protection Calculators	4	2(c)(d)	3	1, 2	2#, 3# and 7
15. CEA Calculators	2	1	2(e)	1, 2	6 and 7
16. Reactor Coolant Flow - Low	4/SG	2/SG(c)	3/SG	1, 2	2#, 3#

TABLE 3.3-1 (Continued)

TABLE NOTATION

*With the protective system trip breakers in the closed position, the CEA drive system capable of CEA withdrawal, and fuel in the reactor vessel.

#The provisions of Specification 3.0.4 are not applicable.

**Not applicable above $10^{-4}\%$ RATED THERMAL POWER.

- (a) Trip may be manually bypassed above $10^{-4}\%$ of RATED THERMAL POWER; bypass shall be automatically removed when THERMAL POWER is less than or equal to $10^{-4}\%$ of RATED THERMAL POWER.
- (b) Trip may be manually bypassed below 400 psia; bypass shall be automatically removed whenever pressurizer pressure is greater than or equal to 500 psia.
- (c) Trip may be manually bypassed below $10^{-4}\%$ of RATED THERMAL POWER; bypass shall be automatically removed when THERMAL POWER is greater than or equal to $10^{-4}\%$ of RATED THERMAL POWER. During testing pursuant to Special Test Exception 3.10.3, trip may be manually bypassed below 5% of RATED THERMAL POWER; bypass shall be automatically removed when THERMAL POWER is greater than or equal to 5% of RATED THERMAL POWER.
- (d) Trip may be bypassed during testing pursuant to Special Test Exception 3.10.3.
- (e) See Special Test Exception 3.10.2.
- (f) Each channel shall be comprised of two trip breakers; actual trip logic shall be one-out-of-two taken twice.
- (g) High steam generator level trip may be manually bypassed in Modes 1 and 2, at 20% power and below.

ACTION STATEMENTS

- ACTION 1 - With the number of channels OPERABLE one less than required by the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours and/or open the protective system trip breakers.
- ACTION 2 - With the number of channels OPERABLE one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may continue provided the inoperable channel is placed in the bypassed or tripped condition within 1 hour. If the inoperable channel is bypassed, the desirability of maintaining this channel in the bypassed condition shall be documented by the Plant Operations Review Committee in accordance with plant administrative procedures. The channel shall be returned to OPERABLE status prior to STARTUP following the next COLD SHUTDOWN.

TABLE 3.3-3 (Continued)

TABLE NOTATION

- (a) Trip function may be bypassed in this MODE when pressurizer pressure is less than 400 psia; bypass shall be automatically removed when pressurizer pressure is greater than or equal to 500 psia.
- (b) An SIAS signal is first necessary to enable CSAS logic.
- * The provisions of Specification 3.0.4 are not applicable.

ACTION STATEMENTS

- ACTION 12 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- ACTION 13 - With the number of channels OPERABLE one less than the Total Number of Channels, STARTUP and/or POWER OPERATION and/or operation in the other applicable MODE(S) may continue provided the inoperable channel is placed in the bypassed or tripped condition within 1 hour. If the inoperable channel is bypassed, the desirability of maintaining this channel in the bypassed condition shall be documented by the Plant Operations Review Committee in accordance with plant administrative procedures. The channel shall be returned to OPERABLE status no later than prior to entry into the applicable MODE(S) following the next COLD SHUTDOWN.

With a channel process measurement circuit that affects multiple functional units inoperable or in test, bypass or trip all associated functional units as listed below:

Process Measurement Circuit	Functional Unit Bypassed/Tripped
1. Containment Pressure - High	Containment Pressure - High (ESF) Containment Pressure - High (RPS)
2. Steam Generator Pressure - Low	Steam Generator Pressure - Low Steam Generator ΔP 1 and 2 (EFAS)
3. Steam Generator Level	Steam Generator Level - Low Steam Generator Level - High Steam Generator ΔP (EFAS)

TABLE 3.3-3 (Continued)

TABLE NOTATION

- ACTION 14 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE, STARTUP and/or POWER OPERATION and/or operation in the other applicable MODE(S) may continue provided the following conditions are satisfied:
- a. Verify that one of the inoperable channels has been bypassed and place the other inoperable channel in the tripped condition within 1 hour.
 - b. All functional units affected by the bypassed/tripped channel shall also be placed in the bypassed/tripped condition as listed below.
- | Process Measurement Circuit | Functional Unit Bypassed/Tripped |
|-----------------------------------|---|
| 1. Containment Pressure Circuit | Containment Pressure - High (ESF)
Containment Pressure - High (RPS) |
| 2. Steam Generator Pressure - Low | Steam Generator Pressure - Low
Steam Generator Level - High
Steam Generator ΔP (EFAS) |
| 3. Steam Generator Level | Steam Generator Level - Low
Steam Generator Level - High
Steam Generator ΔP (EFAS) |
- STARTUP and/or POWER OPERATION and/or operation in the other applicable MODE(S) may continue until the performance of the next required CHANNEL FUNCTIONAL TEST. Subsequent STARTUP and/or POWER OPERATION and/or operation in the other applicable MODE(S) may continue if one channel is restored to OPERABLE status and the provisions of ACTION 13 are satisfied.
- ACTION 15 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channels to OPERABLE status within 48 hours or be in at least HOT STANDBY within 6 hours and in HOT SHUTDOWN within the following 6 hours.
- ACTION 16 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or declare the associated valve inoperable and take the ACTION required by Specification 3.7.1.5.
- ACTION 17 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may continue provided the inoperable channel is placed in the tripped (D.C. Relay energized) condition within 1 hour, the remaining Emergency Diesel Generator is OPERABLE, and the inoperable channel is restored to OPERABLE status within the next 48 hours. Otherwise, be in at least HOT STANDBY within the next 6 hours and COLD SHUTDOWN within the next 30 hours. The surveillance requirements of Table 4.3-2 are waived for all channels while this action requirement is in effect.

ADMINISTRATIVE CONTROLS

6.3 UNIT STAFF QUALIFICATIONS

6.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI/ANS 3.1-1978 except that:

- a. The Radiation Protection Superintendent shall meet or exceed the minimum qualifications of Regulatory Guide 1.8, September 1975.
- b. Personnel in the Health Physics, Chemistry and Radwaste Departments shall meet or exceed the minimum qualifications of ANSI N18.1-1971.
- c. The licensed Operators and Senior Operators shall also meet or exceed the minimum qualifications of 10 CFR Part 55.
- d. Personnel in the Nuclear Quality Assurance Department, and other staff personnel who perform inspection, examination, and testing functions, shall meet or exceed the minimum qualifications of Regulatory Guide 1.58, Rev. 1, September 1980. (Endorses ANSI N45.2.6-1978).

6.4 TRAINING

6.4.1 A retraining and replacement training program for the unit staff shall be maintained under the direction of the Training Manager-Nuclear and shall meet or exceed the requirements and recommendations of Section 5.2 of ANSI 3.1-1978 and 10 CFR Part 55.

6.5 Not used.

Pages 6-9
through
page 6-12
not used

ADMINISTRATIVE CONTROLS

6.6 REPORTABLE EVENT ACTION

6.6.1 The following actions shall be taken for REPORTABLE EVENTS:

- a. The Commission shall be notified and a report submitted pursuant to the requirements of Section 50.73 to 10 CFR Part 50, and
- b. Each REPORTABLE EVENT shall be reviewed by the Plant Operating Review Committee (PORC) and the results of this review shall be submitted to the Safety Review Committee (SRC) and the Vice President Operations.

6.7 SAFETY LIMIT VIOLATION

6.7.1 The following actions shall be taken in the event a Safety Limit is violated:

ADMINISTRATIVE CONTROLS

SAFETY LIMIT VIOLATION (Continued)

- a. The NRC Operations Center shall be notified by telephone as soon as possible and in all cases within 1 hour. The Vice President Operations and the SRC shall be notified within 24 hours.
- b. A Safety Limit Violation Report shall be prepared. The report shall be reviewed by the PORC. This report shall describe (1) applicable circumstances preceding the violation, (2) effects of the violation upon facility components, systems, or structures, and (3) corrective action taken to prevent recurrence.
- c. The Safety Limit Violation Report shall be submitted to the Commission, the SRC and the Vice President Operations within 14 days of the violation.
- d. Critical operation of the unit shall not be resumed until authorized by the Commission.

6.8 PROCEDURES AND PROGRAMS

6.8.1 Written procedures shall be established, implemented and maintained covering the activities referenced below:

- a. The applicable procedures recommended in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978 and Emergency Operating Procedures required to implement the requirements of NUREG-0737 and NUREG-0737, Supplement 1, as stated in Generic Letter 82-33.
- b. Refueling operations.
- c. Surveillance and test activities of safety-related equipment.
- d. Not used.
- e. Not used.
- f. Fire Protection Program implementation.
- g. Modification of Core Protection Calculator (CPC) Addressable Constants, including independent verification of modified constants.

NOTES:

- (1) Modification to the CPC addressable constants based on information obtained through the Plant Computer - CPC data link shall not be made without prior approval of the PORC.
- (2) Modifications to the CPC software (including algorithm changes and changes in fuel cycle specific data) shall be performed in accordance with the most recent version of CEN-39(A)-P, "CPC Protection Algorithm Software Change Procedure," that has been determined to be applicable to the facility. Additions or deletions to CPC Addressable Constants or changes to Addressable Constant software limits values shall not be implemented without prior NRC approval.
- h. Administrative procedures implementing the overtime guidelines of Specification 6.2.2e., including provisions for documentation of deviations.
- i. PROCESS CONTROL PROGRAM implementation.

PROCEDURES AND PROGRAMS (Continued)

- j. OFFSITE DOSE CALCULATION MANUAL implementation.
- k. Quality Assurance Program for effluent and environmental monitoring, using the guidance in Regulatory Guide 1.21, Revision 1, June 1974 and Regulatory Guide 4.1, Revision 1, April 1975.

6.8.2 Each procedure of Specification 6.8.1, and changes thereto, shall be reviewed and approved prior to implementation and reviewed periodically as set forth in administrative procedures. |

6.8.3 Temporary changes to procedures of Specification 6.8.1 may be made provided:

- a. The intent of the original procedure is not altered;
- b. The change is approved by two members of the plant management staff, at least one of whom holds a Senior Operator license on the unit affected;
- c. The change is documented, reviewed and approved as required by administrative procedures within 14 days of implementation. |

6.8.4 The following programs shall be established, implemented, and maintained:

a. Primary Coolant Sources Outside Containment

A program to reduce leakage from those portions of systems outside containment that could contain highly radioactive fluids during a serious transient or accident to as low as practical levels. The systems include the containment spray, safety injection, hydrogen analyzer, and the post-accident sampling system. The program shall include the following:

- 1. Preventive maintenance and periodic visual inspection requirements, and
- 2. Integrated leak test requirements for each system at refueling cycle intervals or less.

b. In-Plant Radiation Monitoring

A program which will ensure the capability to accurately determine the airborne iodine concentration in vital areas under accident conditions. This program shall include the following:

ADMINISTRATIVE CONTROLS

PROCEDURES AND PROGRAMS (Continued)

1. Training of personnel,
2. Procedures for monitoring, and
3. Provisions for maintenance of sampling and analysis equipment.

c. Secondary Water Chemistry

A program for monitoring of secondary water chemistry to inhibit steam generator tube degradation. This program shall include:

1. Identification of a sampling schedule for the critical variables and control points for these variables,
2. Identification of the procedures used to measure the values of the critical variables,
3. Identification of process sampling points, which shall include monitoring the discharge of the condensate pumps for evidence of condenser in-leakage,
4. Procedures for the recording and management of data,
5. Procedures defining corrective actions for all off-control point chemistry conditions, and
6. A procedure identifying (a) the authority responsible for the interpretation of the data, and (b) the sequence and timing of administrative events required to initiate corrective action.

d. Post-accident Sampling

A program which will ensure the capability to obtain and analyze reactor coolant, radioactive iodines and particulates in plant gaseous effluents, and containment atmosphere samples under accident conditions. The program shall include the following:

1. Training of personnel,
2. Procedures for sampling and analysis, and
3. Provisions for maintenance of sampling and analysis equipment.

e. Basemat Monitoring

A program for monitoring of the Nuclear Plant Island Structure (NPIS) Common Foundation Basemat to ensure the continued integrity of the Basemat. The program shall include:

1. settlement of the basemat
2. changes in ground water chemistry that could effect corrosion of reinforcing steel
3. seasonal variation in ground water levels
4. monitoring of significant cracking in the basemat.

ADMINISTRATIVE CONTROLS

RECORD RETENTION (Continued)

6.10.2 The following records shall be retained for at least 5 years:

- a. Records and logs of unit operation covering time interval at each power level.
- b. Records and logs of principal maintenance activities, inspections, repair, and replacement of principal items of equipment related to nuclear safety.
- c. All REPORTABLE EVENTS.
- d. Records of surveillance activities; inspections, and calibrations required by these Technical Specifications.
- e. Records of changes made to the procedures required by Specification 6.8.1.
- f. Records of radioactive shipments.
- g. Records of sealed source and fission detector leak tests and results.
- h. Records of annual physical inventory of all sealed source material of record.

6.10.3 The following records shall be retained for the duration of the unit Operating License:

- a. Records and drawing changes reflecting unit design modifications made to systems and equipment described in the Final Safety Analysis Report.
- b. Records of new and irradiated fuel inventory, fuel transfers, and assembly burnup histories.
- c. Records of radiation exposure for all individuals entering radiation control areas.
- d. Records of gaseous and liquid radioactive material released to the environs.
- e. Records of transient or operational cycles for those unit components identified in Table 5.7-1.
- f. Records of reactor tests and experiments.
- g. Records of training and qualification for current members of the unit staff.
- h. Records of inservice inspections performed pursuant to these Technical Specifications.

ADMINISTRATIVE CONTROLS

RECORD RETENTION (Continued)

- i. Records of quality assurance activities required by the Quality Assurance Program Manual.
- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the PORC and the SRC.
- l. Records of the service lives of all hydraulic and mechanical snubbers required by Specification 3.7.8 including the date at which the service life commences and associated installation and maintenance records.
- m. Records of secondary water sampling and water quality.
- n. DELETED.
- o. Records of analyses required by the radiological environmental monitoring program that would permit evaluation of the accuracy of the analysis at a later date. This should include procedures effective at specified times and QA records showing that these procedures were followed.
- p. Records of reviews performed for changes made to the OFFSITE DOSE CALCULATION MANUAL and the PROCESS CONTROL PROGRAM.

6.11 RADIATION PROTECTION PROGRAM

6.11.1 Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.203(c)(2) of 10 CFR Part 20, each high radiation area in which the intensity of radiation is greater than 100 mrem/h but less than 1000 mrem/h shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit (RWP)*. Any individual or group of individuals permitted to enter such areas shall be provided with or accompanied by one or more of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area.

*Health physics personnel or personnel escorted by health physics personnel shall be exempt from the RWP issuance requirement during the performance of their assigned radiation protection duties, provided they are otherwise following plant radiation protection procedures for entry into high radiation areas.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 109 TO

FACILITY OPERATING LICENSE NO. NPF-38

ENTERGY OPERATIONS, INC.

WATERFORD STEAM ELECTRIC STATION, UNIT 3

DOCKET NO. 50-382

1.0 INTRODUCTION

By application dated August 9, 1994, Entergy Operations, Inc. (the licensee), submitted a request for changes to the Waterford Steam Electric Station, Unit 3 (Waterford 3), Technical Specifications (TSs). The requested changes would revise the Administrative Controls Section of the TSs for Waterford 3 by removing the functions under review and audit from the TSs and by relocating those items in the quality assurance program manual (QAPM). In addition the proposed changes will remove the review and audit functions for the emergency plan and implementing procedures, and security plan from the list of responsibilities of the plant operation review committee (PORC) in the TSs. These requirements will be retained in emergency plan or security plan as appropriate.

2.0 BACKGROUND

Section 182a of the Atomic Energy Act (the "Act") requires applicants for nuclear power plant operating licenses to state TSs to be included as part of the license. The Commission's regulatory requirements related to the content of TSs are set forth in 10 CFR 50.36. That regulation requires that the TSs include items in five specific categories, including (1) safety limits, limiting safety system settings and limiting control settings; (2) limiting conditions for operation; (3) surveillance requirements; (4) design features; and (5) administrative controls. However, the regulation does not specify the particular requirements to be included in a plant's TSs.

The Commission has provided guidance for the contents of TSs in its "Final Policy Statement on Technical Specifications Improvements for Nuclear Power Reactors" ("Final Policy Statement"), 58 FR 39132 (July 22, 1993), in which the Commission indicated that compliance with the Final Policy Statement satisfies Section 182a of the Act. In particular, the Commission indicated that certain items could be relocated from the TSs to licensee-controlled documents, consistent with the standard enunciated in *Portland General Electric Co.* (Trojan Nuclear Plant), ALAB-531, 9 NRC 263, 273 (1979). In that case, the Atomic Safety and Licensing Appeal Board indicated that "technical

specifications are to be reserved for those matters as to which the imposition of rigid conditions or limitations upon reactor operation is deemed necessary to obviate the possibility of an abnormal situation or event giving rise to an immediate threat to the public health and safety."

Consistent with this approach, the Final Policy Statement identified four criteria to be used in determining whether a particular matter is required to be included in the TSs, as follows: (1) Installed instrumentation that is used to detect, and indicate in the control room, a significant abnormal degradation of the reactor coolant pressure boundary; (2) a process variable, design feature, or operating restriction that is an initial condition of a design basis accident or transient analysis that either assumes the failure of or presents a challenge to the integrity of a fission product barrier; (3) a structure, system, or component that is part of the primary success path and which functions or actuates to mitigate a design basis accident or transient that either assumes the failure of or presents a challenge to the integrity of a fission product barrier; (4) a structure, system, or component which operating experience or probabilistic safety assessment has shown to be significant to public health and safety.¹ As a result, existing TS requirements which fall within or satisfy any of the criteria in the Final Policy Statement must be retained in the TSs, while those TS requirements which do not fall within or satisfy these criteria may be relocated to other, licensee-controlled documents.

3.0 EVALUATION

The licensee has proposed the following changes in the TSs for Waterford 3:

- a. Section 6.5.1 - PORC - Licensee proposes to delete this section from the TSs and relocate the requirement for the PORC to the QAPM.
- b. Section 6.5.2 - Safety Review Committee (SRC) - Licensee proposes to delete this section from the TSs and relocate the requirement for the SRC to the QAPM.
- c. Section 6.5.3 - Technical Review and Control Process (TRCP) - Licensee proposes to delete this section from the TSs and relocate the requirement for the TRCP to the QAPM.

1 The Commission recently promulgated a proposed change to 10 CFR 50.36, pursuant to which the rule would be amended to codify and incorporate these criteria (59 FR 48180). The Commission's Final Policy Statement specified that only limiting conditions for reactor Core Isolation Cooling, Isolation Condenser, Residual Heat Removal, Standby Liquid Control, and Recirculation Pump Trip meet the guidance for inclusion in the TS under Criterion 4 (58 FR at 39137). The Commission has solicited public comments on the scope of Criterion 4, in the pending rulemaking.

d. Section 6.8.1 - Procedures and Programs - Licensee proposes to delete subsections d. and e., security plan implementation and emergency plan implementation, respectively.

f. Licensee has revised Sections 6.8.2, 6.8.10, Table 3.3-1, and Table 3.3.3 to delete reference to the deleted Sections 6.5.1, 6.5.2, and 6.5.3. The staff finds these requested changes acceptable as they are editorial in nature.

REQUIREMENTS RELOCATED TO A QUALITY ASSURANCE PROGRAM MANUAL

The licensee proposes that the review and audit functions specified in existing TSs 6.5.1, 6.5.2, 6.5.3 be relocated from the TSs on the basis that they are adequately controlled elsewhere. These TS provisions are not necessary to assure safe operation of the facility, given the requirements in the QAPM implementing 10 CFR 50.54 and 10 CFR Part 50, Appendix B to control the requirements for all review and audit functions. Such an approach would result in an equivalent level of regulatory authority while providing for a more appropriate change control process. The level of safety of plant operation is unaffected by this change and NRC and licensee resources associated with processing license amendments to this administrative control may be used more effectively. In addition, the following considerations support relocating these items from the TSs:

1. The on-site review function, composition, alternate membership, meeting frequency, quorum, responsibilities, authority and records are all covered in equivalent detail in ANSI N18.7-1976. These requirements are in the QAPM description and change control is provided by 10 CFR 50.54(a).
2. The off-site review group is also addressed, although with less detail, in ANSI N18.7-1976. The QAPM description include the requirements for the off-site review group. Therefore, duplicating the review and audit function of the off-site review group in the TSs is unnecessary.
3. Audit requirements are specified in the QAPM description to satisfy 10 CFR Part 50, Appendix B, Criterion XVIII. Audits are also covered by ANSI N18.7, ANSI N45.2, 10 CFR 50.54(t), 10 CFR 50.54(p), and 10 CFR Part 73. Therefore, duplication of these requirements does not enhance the level of safety of the plant, nor are the provisions relating to audits necessary to assure safe operation of the facility.

On this basis, the staff concludes that the review and audit requirements do not need to be controlled by the TSs, and changes to the audit frequencies, which will be described in the QAPM, will adequately be controlled by 10 CFR 50.54(a). The staff has concluded, therefore, that relocation of the review and audit requirements described above is acceptable because (1) their inclusion in technical specifications is not specifically required by 10 CFR 50.36 or other regulations, (2) the review and audit requirements are not required to avert an immediate threat to the public health and safety, and

(3) changes to these audit requirements, as described in the applicable program description, will require prior NRC approval in accordance with Section 50.54(a).

REQUIREMENTS RELOCATED TO EMERGENCY PLAN OR SECURITY PLAN

The licensee proposes to relocate the requirements to establish, implement, and maintain procedures related to the emergency plan (existing TS 6.8.1.e) and security plan (existing TS 6.8.1.d). Since the security plan requirements are specified in 10 CFR 50.54, 73.40, 73.55, and 73.56 and the emergency plan requirements are specified in 10 CFR 50.54(q) and 10 CFR Part 50, Appendix E, Section V, in Generic Letter (GL) 93-07 the staff removed the requirements from the Standard Technical Specifications (STS) and relocated them to their respective plans.

The requirements in the existing TSs for the review of the security program and implementing procedures, and for the review of the station emergency plan and implementing procedures, will be included in the security plan and the emergency plan respectively. Further changes in these review requirements must be made in accordance with 10 CFR 50.54(p) for the security plan and 10 CFR 50.54(q) for the emergency plan.

The staff concludes that the requirements for emergency planning in 10 CFR 50.47, 50.54, 10 CFR Part 50 Appendix E and for security in 10 CFR 50.54 and 73.55, for drills, exercises, testing, and maintenance of the program, provide adequate assurance that the objective of the previous TSs for a periodic review of the program and changes to the programs will be met. Therefore, duplication of the requirements contained in the regulations would not enhance the level of safety for the facility. The staff concludes that other regulatory requirements provide sufficient control of these provisions and removing them from TSs is acceptable.

On this basis, the staff concludes that these requirements do not need to be controlled by the TSs, and changes to the audit frequencies, which will be described in the emergency plan or security plan, will adequately controlled by 10 CFR 50.54(p) or (q), as applicable. The staff has concluded, therefore, that relocation of the audit requirements described above is acceptable because (1) their inclusion in TSs is not specifically required by 10 CFR 50.36 or other regulations, (2) the audit requirements are not required to avert an immediate threat to the public health and safety, and (3) changes to these audit requirements, as described in the applicable program description, will require prior NRC approval in accordance with Appendix E to Part 50, Section 50.54(p), or Section 73.56(g).

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Louisiana State official was notified of the proposed issuance of the amendment. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendment changes recordkeeping, reporting, or administrative procedures or requirements. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(10). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: F. Allenspach
D. Barss

Date: July 6, 1995